

U. S. NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT

REGION V

Report No. 50-206/80-24

Docket No. 50-206 License No. DPR-13 Safeguards Group _____

Licensee: Southern California Edison Company

2244 Walnut Grove Avenue

Rosemead, California 91770

Facility Name: San Onofre Unit 1

Inspection at: San Onofre

Inspection conducted: August 4-8, 1980

Inspectors: A. J. Horn 9/2/80
A. J. Horn, Reactor Inspector Date Signed

Date Signed

Date Signed

Approved By: B. H. Faulkenberry 9/2/80
B. H. Faulkenberry, Chief, Reactor Projects Section 2 Date Signed
Reactor Operations and Nuclear Support Branch

Summary:

Inspection on August 4-8, 1980 (Report No. 50-206/80-24)

Areas Inspected: Routine, announced inspection of fire protection modifications, IE Bulletin/Circular followup, and independent inspection effort. This inspection involved 25 hours by one NRC inspector.

Results: No items of noncompliance or deviations were identified.

DETAILS

1. Persons Contacted

J. Curran, Plant Manager
*H. Morgan, Superintendent
*J. Haynes, Manager, Nuclear Engineering (New)
*D. Nunn, QA Manager
*G. McDonald, QA/QC Supervisor
*L. Gregory, Startup, SCE
*R. Tinsley, Startup
*L. Hebert, Startup
*D. Nicholson, Startup BPC
*D. Nanda, Project, SCE
F. Briggs, Engineer
S. Scholl, Engineer

*Denotes those persons who attended the exit interview.

2. IE Bulletin/Circular Followup

a. (Closed) Bulletin 80-08

The licensee determined that all containment liner penetration welds within the scope of this Bulletin were required to be fully radiographed during construction. No further action required.

b. (Closed) Bulletin 80-12

The inspector verified that the licensee has implemented procedure changes that meet the requirements of the Bulletin.

c. (Closed) Bulletin 80-16

The licensee determined that this Bulletin is not applicable to San Onofre Unit 1.

3. Fire Protection Modifications

Amendment No. 44 to Provisional Operating License No. DPR-13 consists of changes to the Appendix A Technical Specifications for fire protection systems. The amendment, in part, requires certain fire protection modifications be completed by the end of the Core 8 refueling (Spring 1980).

The inspector reviewed completed work packages and verified that most of the modifications have been completed, including acceptance by the SCE QA department. One of the commitments in the SER (to amendment 44) has been changed, but the inspector was unable to verify, during this inspection, NRR approval for the change.

Further reviews by NRR and consultants as to the acceptability of the modifications being made by the licensee may require additional changes.

The inspector will further review the status of the licensee's fire protection modifications at a later inspection. (80-18-02)

4. Exit Interview

The inspector met with the licensee representatives denoted in paragraph 1 on August 8, 1980 to discuss the findings of this inspection. The inspector noted that the completion of the fire protection modifications will be followed during a later inspection (see paragraph 3).