

RSB

JAN 27 1986

185-37

Docket Nos. 50-206, 50-361 and 50-362

Southern California Edison Company  
2244 Walnut Grove Avenue  
Rosemead, California 91770

Attention: Mr. Kenneth P. Baskin, Vice President  
Nuclear Engineering Safety and Licensing Department

Gentlemen:

Subject: NRC Inspection of San Onofre Units 1, 2 and 3

This refers to the inspection conducted by Mr. P. P. Narbut of this office on November 12-15 and December 9-18, 1985, of activities authorized by NRC License Nos. DPR-13, NPF-10 and NPF-15 and to the discussion of our findings with Mr. Ray and other members of your staff on November 15 and December 18, 1985. Additionally, this report describes in-office review of San Onofre event reports conducted through December 30, 1985.

Areas examined during this inspection are described in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

Based on the results of this inspection, it appears that one of your activities was not conducted in full compliance with NRC requirements, as set forth in the Notice of Violation, enclosed herewith as Appendix A.

Your response to this Notice is to be submitted in accordance with the provisions of 10 CFR 2.201 as stated in Appendix A, Notice of Violation.

Your attention is also directed to two important general areas discussed in this report: (1) the necessity to ensure procedure compliance at the implementation level as discussed in paragraph 3.a using an example of main steam safety valve test documentation and (2) the necessity to ensure maintenance personnel awareness of design issues as discussed in paragraph 5.b using the example of pipe clamp bolting torque values. No additional response to these issues are required since your expected response to the Unit 1 auxiliary feedwater pump violation of report 50-206/85-33 should address these issues.

In accordance with 10 CFR 2.790(a), a copy of this letter, the enclosure, and your response will be placed in the NRC Public Document Room.

8602130541 860127  
PDR ADDCK 05000206  
PDR

120/1/90

JAN 27 1986

Should you have any questions concerning this inspection, we will be glad to discuss them with you.

The responses directed by this letter and the accompanying Notice are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

Sincerely,

*AS*  
A. E. Chaffee, Chief  
Reactor Projects Branch

Enclosures:

1. Appendix A - Notice of Violation
2. Inspection Report  
Nos. 50-206/85-37, 50-361/85-35, 50-362/85-34.

cc w/enclosures:

D. J. Fogarty, SCE  
H. B. Ray, SCE (San Clemente)  
H. E. Morgan, Station Manager  
State of CA

bcc:

RSB/Document Control Desk (RIDS)  
Mr. J. Martin  
Mr. B. Faulkenberry  
G. Cook  
Resident Inspector  
Project Inspector

RV *PA for*  
PNarbut:dh  
1/22/86

*PA for*  
PJohnson  
1/22/86

*af*  
AJohnson  
1/24/86

*au*  
AChaffee  
1/27/86