



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

March 6, 1986

MEMORANDUM FOR: Dennis F. Kirsch, Director  
Division of Reactor Safety and Projects  
Region V

FROM: Brian K. Grimes, Director  
Division of Quality Assurance, Vendor  
and Technical Training Center Programs  
Office of Inspection and Enforcement

SUBJECT: SAN ONOFRE NUCLEAR GENERATING STATION,  
UNITS 1, 2 AND 3, INSPECTION REPORT  
NO. 50-206/85-30, 50-361/85-29; 50-362/85-28,  
NOTICE OF VIOLATION INPUT

Enclosed is the report (and attendant 766) of the special team inspection at San Onofre Nuclear Generating Station, Units 1, 2, and 3 to review the implementation of a program to meet the requirements of 10 CFR 50.49. This inspection was conducted September 23 to 27, 1985, at the plant site.

The inspection report contains seven Potential Enforcement/Unresolved Items, some of which are applicable to each Unit, relative to implementation of a 10 CFR 50.49 program. Five of these items are considered to be Severity Level IV violations, and we are enclosing input for a Notice of Violation to be prepared by the region. These items are identified in the inspection report as Potential Enforcement/Unresolved Items 50-206/85-30-1, -2, -3, -4; 50-361/85-29-1, -2; and 50-362/85-28-1, -2.

Two Potential Enforcement/Unresolved Items are still regarded as Unresolved Items. (1) Item 50-206/85-30-5, ASCO solenoid valve applies to Unit 1 only. The licensee has indicated by phone that upon evaluation valve SV 3201 required only cleaning and painting to be restored to proper condition. If you can accept this disposition after reviewing the licensee's Engineering Evaluation and corrective action, this item may be closed. (2) Item 50-206/85-30-6; 50-361/85-29-3; 50-362/85-28-3 involves replacement equipment procurement and applies to all three units. If you can verify that the licensee has corrected his procurement procedures, and that no replacement equipment has been procured contrary to paragraph (1) of 10 CFR 50.49, then this item may be closed.

The inspection report also identifies six Open Items, some of which are applicable to each Unit: 50-206/85-30-7, -8, -9; 50-361/85-29-4, -5, -6, -7; and 50-362/85-28-4, -5, -6, -7. These Open Items are being referred to you for appropriate followup and resolution.

8603100305 860306  
PDR. ADOCK 05000206  
Q PDR

Dennis F. Kirsch

- 2 -

March 6, 1986

If you have any questions concerning this inspection, please call U. Potapovs (FTS 492-8030) or G. Zech (FTS 492-9663).

151

Brian K. Grimes, Director  
Division of Quality Assurance, Vendor  
and Technical Training Center Programs  
Office of Inspection and Enforcement

Enclosures:

1. Inspection Report No. 50-266/85-013; 50-301/85-013
2. Inspectors Form (766)
3. Input for Notice of Violation

Distribution:

DCS  
VPB Reading  
DQAVT Reading  
JAxelrad  
UPotapovs  
RWilson  
GHubbard  
AJohnson  
TYoung, RV

*RAW*  
VPB:DQAVT  
RWilson:tt  
2/14/86

*UP*  
SC/VPB:DQAVT  
UPotapovs  
2/19/86

*GG*  
BC/VPB:DQAVT  
GGZech  
2/28/86

*BK*  
DIR:DQAVT  
BGrimes  
3/16/86

*X*  
DIR:ES  
JAxelrad  
1/86


IEO1  
11

Dennis F. Kirsch

- 2 -

March 6, 1986

If you have any questions concerning this inspection, please call U. Potapovs (FTS 492-8030) or G. Zech (FTS 492-9663).



Brian K. Grimes, Director  
Division of Quality Assurance, Vendor  
and Technical Training Center Programs  
Office of Inspection and Enforcement

Enclosures:

1. Inspection Report No. 50-266/85-013; 50-301/85-013
2. Inspectors Form (766)
3. Input for Notice of Violation