

APPENDIX A

NOTICE OF VIOLATION

Southern California Edison Company
2244 Walnut Grove Avenue
Rosemead, California 91770

Docket No. 50-362
License No. NPF-15

As a result of the inspection conducted July 28 through August 1, August 11 through August 15, and September 16 and 17, 1986, and in accordance with the NRC Enforcement Policy, 10 CFR 2, Appendix C, the following violation was identified:

Technical Specification 6.8.1 specifies that written procedures shall be established, implemented and maintained. Procedure SO 123-VII-9.9, Revision 3, Radiation Exposure Permit Program, specifies in Section 6.3.3 that "All personnel covered by the REP must follow the requirements specified in the REP." Radiation Exposure Permit 83001 required use of a respirator while working on valve S 31208MR135.


Contrary to the above requirement, an individual performed work on valve S 31208MR135 under REP 83001 on January 3, 1985, and did not wear a respirator as required by the Radiation Exposure Permit.

This is a Severity Level IV Violation (Supplement IV).

Pursuant to 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved.

OCT 03 1986

Date


Ross A. Scarano, Director
Division of Radiation Safety and
Safeguards

8610100755 861003
PDR ADOCK 05000206
Q PDR