



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 11, 1987

Docket Nos.: 50-206/361/362


MEMORANDUM FOR: Dennis F. Kirsch, Director
Division of Reactor Safety and Projects, RV

FROM: James G. Partlow, Director
Division of Reactor Inspection and Safeguards
Office of Nuclear Reactor Regulation

SUBJECT: SAN ONOFRE INSPECTION REPORTS 50-206/87-02,
50-361/87-03 AND 50-362/87-04

Enclosed is the report of the inspection performed at San Onofre Units 1, 2, and 3 by Messrs. E. T. Baker, J. B. Jacobson, R. P. McIntyre, P. J. Prescott, E. H. Trottier, and R. C. Wilson of the Vendor Program Branch, and Mr. L. R. Wharton of the Quality Assurance Branch on February 2-13, 1987 and March 2-6, 1987. The inspection report contains two Potential Enforcement Findings (PEF), one concerning the use of a commercial grade circuit breaker in a safety-related application without adequate dedication and the second PEF concerns the listing of unqualified butt splices on the master equipment qualification lists for Units 1, 2, and 3 without adequate documentation to substantiate the qualification.

The PEFs are being referred to you for appropriate followup and resolution. If you have any questions concerning this inspection or if additional assistance in this area is desired, please call E. Merschoff (FTS 492-9644) or J. Stone (FTS 492-9661).


James G. Partlow, Director
Division of Reactor Inspection
and Safeguards
Office of Nuclear Reactor Regulation

Enclosures:

1. Potential Enforcement Finding
2. Inspection Report
3. Inspectors Report (Form 766)

8706180008 870611
PDR ADDCK 05000206
P PDR

- 2 -

DFC	:VIB:DRIS	:SC/VIB:DRIS	:BC/VIB:DRIS	:D/DIR:DRIS	:DIR:DRIS
NAME	ETBaker:sam	JCStone	JEWerschoff	BKGrimes	JGPartlow
DATE	6/9/87	6/9/87	6/9/87	6/9/87	6/9/87

June 11, 1987

Dennis F. Kirsch

- 2 -

DISTRIBUTION: w/o Enclosure
Docket Files (50-206/361/362)

NRC PDR
Local PDR
VIB Reading
DRIS Reading
JGPartlow
BKGrimes
EWMerschhoff
ETBaker
JBJacobson
RPMcIntyre
PJPrescott
EHTrottier
RCWilson
LRWharton

need to add Project Manager of San Onofre

OFC	: VIB: DRIS	: SC/VIB: DRIS	: BC/VIB: DRIS	: D/DIR: DRIS	: DIR: DRIS	:
NAME	: ETBaker: sam	: JCStone	: EWMerschhoff	: BKGrimes	: JGPartlow	:
DATE	: 6/9/87	: 6/9/87	: 6/9/87	: 6/ /87	: 6/10/87	:

ETB
JP
mkw