

PART 21 IDENTIFICATION NO.

80-295-000

COMPANY NAME

Target Rock
Corporation

DATE OF LETTER 10/15/80

DOCKET NO. 50-361362; 50-389

DATE DISTRIBUTED 10/21/80 p.m.

ORIGINAL REPORT



SUPPLEMENTARY



DISTRIBUTION:

REACTOR (R)



FUEL CYCLE &



SAFEGUARDS (S)



MATERIALS (M)

IE FILES

AD/ROI

AD/RCI

REGIONS I,II,III,IV,V

VENDOR BR. R-IV

LOEB / MPA MNB 5715

AEOD MNB 7602

NRR/DOE

NRR/DSI

NRR/DST

NRR/DOL

ASLBP E/W 450

CENTRAL FILES 016

CENTRAL FILES (CHRON)

PDR

LPDR

TERA

IE FILES

AD/FFMSI

REGIONS I,II,III,IV,V

VENDOR BR. R-IV

NMSS / FCMS SS-396

LOEB / MPA MNB 5715

AEOD MNB 7602

ASLBP E/W 450

SAP/SP. MNB-7210A

CENTRAL FILES 016

CENTRAL FILES (CHRON)

PDR

LPDR

TERA

IE FILES

AD/SG

AD/ROI

REGIONS I,II,III,IV,V

VENDOR BR. R-IV

NRR/DOL

NMSS / SG SS-881

LOEB / MPA MNB 5715

AEOD MNB 7602

ASLBP E/W 450

CENTRAL FILES 016

CENTRAL FILES (CHRON)

CENTRAL FILES SS-396

PDR

LPDR

TERA

ACTION:

PRELIMINARY EVALUATION OF THE ATTACHED REPORT INDICATES LEAD RESPONSIBILITY FOR
FOLLOWUP AS SHOWN BELOW:

IE



NRR



NMSS



OTHER



RCI

ROI

SG

FFMSI

8010240563

S

REV. 8/1/80
9/17/80



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
655 RYAN PLAZA DRIVE SUITE 1000
ARLINGTON, TEXAS 76010

October 21, 1980

ME-100

MEMORANDUM FOR: Dudley Thompson, X005, IE
FROM: W. E. Vetter, Assistant to the Director, Region IV, IE
SUBJECT: TARGET ROCK CORPORATION - PART 21 REPORT

As discussed during our telephone conversation yesterday, the attached letter is provided.

Mr. Pattarini is now aware that the letter does not properly relate to the provisions of Part 21 and that ... if a defect in fact exists ... the reporting requirements of Part 21 have not been met. Pattarini stated on October 20, 1980, that the entire matter would be reexamined with full reference to Part 21 wording.

W. E. Vetter
Assistant to the Director

Attachment:
Ltr dtd 10/15/80

cc: w/att
Karl V. Seyfrit, RIV
U. Potapovs, RIV

60

NRC Part 21 ID #

80-295-000

Target Rock Corporation, 19551 Rockwood Road, Fort Worth, Texas 76155 Phone (817) 293-2800

Refer to: E-14815

October 15, 1980

50-361/362
50-389

United States Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76012

Attention: Karl V. Seyfrit
Director

Subject: 10 CFR Part 21

Gentlemen:

In accordance with subject regulation, we hereby notify the Commission of a failure of a motor operated valve stem during construction testing at San Onofre 2 on October 4, 1980.


The valve in question is a Target Rock Model 74R-008 motor operated globe valve equipped with a Limitorque operator. It is used in the low pressure safety injection system.

Similar valves are intended for installation at San Onofre 3 and St. Lucia 2.

Cause of failure is being investigated.

Very truly yours,

TARGET ROCK CORPORATION



D. M. Pattarini
Vice President, Engineering

DMP/jm
cc: G. Abruzzo