

Dominion Nuclear Connecticut, Inc.  
Rope Ferry Rd., Waterford, CT 06385  
Mailing Address: P.O. Box 128  
Waterford, CT 06385

dom.com

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555-0001



NOV 06 2013

Serial No.	13-215A
MPS Lic/GJC	R0
Docket Nos.	50-245 50-336 50-423
License Nos.	DPR-21 DPR-65 NPF-49

**DOMINION NUCLEAR CONNECTICUT, INC.**  
**MILLSTONE POWER STATION UNITS 1, 2, AND 3**  
**ERRATA TO THE 2012 RADIOACTIVE**  
**EFFLUENT RELEASE REPORT**

In accordance with 10 CFR 50.36a, this letter transmits the errata to the annual Radioactive Effluent Release Report (RERR) for the period January 2012 through December 2012. The report met the provisions of Section 5.7.3 of the Millstone Power Station Unit 1 Permanently Defueled Technical Specifications (PDTS), and Sections 6.9.1.6b and 6.9.1.4 of the Millstone Power Station Units 2 and 3 Technical Specifications, respectively. The RERR contains information regarding airborne, liquid, and solid radioactivity released from Millstone Power Station, including the off-site dose from airborne and liquid effluents.

Attachment 1 transmits the errata and corrigenda to the 2012 RERR. It contains six replacement pages to the 2012 RERR. These pages should be replaced with the same numbered page in the current copy of the report.

If you have any questions or require additional information, please contact Mr. William D. Bartron at (860) 444 4301.

Sincerely,

L. J. Armstrong  
Director, Nuclear Station Safety and Licensing

Attachment:

- 1 Errata to the 2012 Radioactive Effluents Release Report

IE48  
FSME20

Commitments made in this letter:

1. None.

cc: U.S. Nuclear Regulatory Commission  
Region I  
2100 Renaissance Blvd, Suite 100  
King of Prussia, PA 19406-2713

S. J. Giebel  
NRC Project Manager Millstone Unit 1  
U.S. Nuclear Regulatory Commission  
Two White Flint North, Mail Stop T-8 F5  
11545 Rockville Pike  
Rockville, MD 20852-2738

L. A. Kauffman  
NRC Inspector  
U.S. Nuclear Regulatory Commission  
Region I  
2100 Renaissance Blvd, Suite 100  
King of Prussia, PA 19406-2713

R. G. Rolph  
NRC Inspector  
U.S. Nuclear Regulatory Commission  
Region I  
2100 Renaissance Blvd, Suite 100  
King of Prussia, PA 19406-2713

J. S. Kim  
NRC Project Manager  
U.S. Nuclear Regulatory Commission  
One White Flint North, Mail Stop 08-C2A  
11555 Rockville Pike  
Rockville, MD 20852-2738

NRC Senior Resident Inspector  
Millstone Power Station

Director  
Bureau of Air Management  
Monitoring & Radiation Division  
Department of Energy and Environmental Protection  
79 Elm Street  
Hartford, CT 06106-5127

A. Honnellio  
Regional Radiation Representative  
(EPA Region 1, Boston)  
U. S. Environmental Protection Agency (Region 1)  
5 Post Office Square Suite 100  
Boston, MA 02109

G. Allen Jr.  
Department of Health and Human Services  
U. S. Food and Drug Administration  
90 Madison Street Room 402  
Worcester, MA 18608

Mr. Robert Stein  
Chairman Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051

Mr. Pat Kelley  
Waterford-East Lyme Shellfish Commission  
Waterford Town Hall  
Waterford, CT 06385

Mr. Jason A. Martinez  
American Nuclear Insurers  
95 Glastonbury Blvd.  
Glastonbury, CT 06033

D. Carey  
Connecticut Department of Agriculture  
Aquaculture Division  
P. O. Box 97  
Millford, CT 06460

Mr. Dan Steward  
First Selectman Town of Waterford  
Waterford Town Hall  
Waterford, CT 06385

Mr. Paul Formica  
First Selectman Town of East Lyme  
PO Box 519  
Niantic, CT 06357

University Of Connecticut Library  
Serials Department  
Storrs, CT 06268

Serial No. 13-215A  
Docket Nos. 50-245  
50-336  
50-423  
License Nos. DPR-21  
DPR-65  
NPF-49

**ATTACHMENT 1**

**ERRATA TO THE**  
**2012 RADIOACTIVE EFFLUENTS RELEASE REPORT**

**MILLSTONE POWER STATION UNITS 1, 2, AND 3**  
**DOMINION NUCLEAR CONNECTICUT, INC. (DNC)**

## Errata to 2012 Millstone Radioactive Effluents Release Report

### A) Instructions:

Replace each of the following pages with the same numbered page in the current copy of the report. Pages to be replaced include Pages 7, 10, 17, 20, 24 and 26.

### B) Explanation of revisions

Section 1.2.3 and Tables 1-3, 2.2-A1, 2.2-A4, 2.3-A1 and 2.3-A3 of the 2012 Radioactive Effluents Release Report are resubmitted. A new first paragraph is added to Section 1.2.3 to discuss the C-14 dose and to explain why airborne doses in 2012 were lower than prior years. Revisions to the tables were made to correct the following errors:

- 1) In Table 1-3, the Total Off-Site Dose from Millstone Station was revised for Direct Shine and totals with and without C-14. This was a transcription error on the entry for Direct Shine dose.
- 2) In Tables 2.2-A1 and 2.2-A4, the total activity of Fission & Activation Gases were revised for all four quarters because the activity for Ar-41 was not included in each quarter. The annual total activity for Fission & Activation Gases was correct and did not need revision.
- 3) In Table 2.2-A1, the total activity of Iodines/Halogens were revised for the third and fourth quarters because the activity for Br-82 was not included for those quarters.
- 4) In Table 2.3-A1, the total activity of Tritium was revised for the third and fourth quarter because of a transcription error.
- 5) In Tables 2.3-A1 and 2.3-A3, the particulates in 3<sup>rd</sup> quarter were revised because activity for Sc-46 was not included.

Beginning with this report (2012), doses are reported with and without dose from C-14.

To determine compliance with 10 CFR 50, Appendix I (Reference 7), the maximum individual whole body and organ doses include all applicable external pathways (i.e., plume and ground exposure) as well as the internal pathways (inhalation and ingestion).

### **1.2.2 Liquid Effluents**

OpenEMS performs calculations for the following pathways: fish, shellfish, shoreline activity, swimming, and boating. Doses are calculated for the whole body, skin, thyroid, and maximum organ (GI, bone, liver, kidney, and lung).

### **1.2.3 Analysis of Results**

There are two general changes in doses from airborne effluents shown in Table 1-1 compared to doses given in prior years. This year, for the first time, the increment in dose due to C-14 is shown. This was done because of the significance of the dose from C-14. The second change is a significant reduction in airborne dose compared to previous years. This reduction is due to using more accurate meteorological parameters for elevated releases from the Millstone Stack. In prior years, doses due to releases from the Millstone Stack were calculated using rooftop meteorology which gave conservatively higher doses.

Table 1-3 provides a quantitative dose comparison with the limits specified in the REMODCM. The data indicates that the total whole body and organ doses to the maximum offsite individual from Millstone Power Station including all sources of the fuel cycle are well within the limits of 40 CFR 190 (Reference 8). On-site radioactive waste and spent fuel storage during this year was within storage criteria and the maximum dose to a member of the public was approximately 0.18 mrem/yr. The doses from airborne and liquid effluents were added to the estimated dose from on-site radioactive waste storage to show compliance compared to 40 CFR 190.

The Offsite Dose Comparison, Table 1-4, provides a perspective on the maximum offsite individual dose received from Millstone Power Station with the natural background radiation dose received by the average Connecticut resident. The total dose to the maximum individual received from Millstone Power Station is small (< 0.1%) in comparison to the dose received from natural background radiation.

10/07/2013

**Table 1-3  
2012 Off-Site Dose Comparison to Limits  
Millstone Units 1, 2, 3**

**Airborne Effluents Dose (without C-14)**

	<b>Whole Body (mrem)</b>	<b>Thyroid (mrem)</b>	<b>Max Organ* (mrem)</b>	<b>Skin (mrem)</b>	<b>Beta Air (mrad)</b>	<b>Gamma Air (mrad)</b>
<b>Unit 1</b>	5.31E-05	5.31E-05	5.31E-05	4.08E-05	0.00E+00	0.00E+00
<b>Unit 2</b>	3.14E-03	1.20E-02	3.15E-03	2.09E-03	8.72E-05	4.18E-05
<b>Unit 3</b>	1.24E-02	1.24E-02	1.67E-02	7.69E-03	1.85E-05	1.92E-06
<b>Millstone Station</b>	<b>1.56E-02</b>	<b>2.44E-02</b>	<b>1.99E-02</b>	<b>9.81E-03</b>	<b>1.06E-04</b>	<b>4.38E-05</b>
<b>10CFR50 App I Limits</b>	<b>5</b>	<b>15</b>	<b>15</b>	<b>15</b>	<b>20</b>	<b>10</b>

**Airborne Effluents Dose (with C-14)**

	<b>Whole Body (mrem)</b>	<b>Thyroid (mrem)</b>	<b>Max Organ* (mrem)</b>	<b>Skin (mrem)</b>	<b>Beta Air (mrad)</b>	<b>Gamma Air (mrad)</b>
<b>Unit 1</b>	5.31E-05	5.31E-05	5.31E-05	4.08E-05	0.00E+00	0.00E+00
<b>Unit 2</b>	5.34E-02	6.24E-02	2.52E-01	2.09E-03	8.72E-05	4.18E-05
<b>Unit 3</b>	1.36E-02	1.36E-02	1.67E-02	7.69E-03	1.85E-05	1.92E-06
<b>Millstone Station</b>	<b>6.71E-02</b>	<b>7.60E-02</b>	<b>2.69E-01</b>	<b>9.81E-03</b>	<b>1.06E-04</b>	<b>4.38E-05</b>
<b>10CFR50 App I Limits</b>	<b>5</b>	<b>15</b>	<b>15</b>	<b>15</b>	<b>20</b>	<b>10</b>

**Liquid Effluents Dose**

	<b>Whole Body (mrem)</b>	<b>Thyroid (mrem)</b>	<b>Max Organ* (mrem)</b>
<b>Unit 1</b>	1.66E-05	3.69E-06	5.13E-05
<b>Unit 2</b>	1.28E-03	2.47E-04	1.72E-02
<b>Unit 3</b>	9.10E-04	5.64E-04	3.23E-03
<b>Millstone Station</b>	<b>2.21E-03</b>	<b>8.14E-04</b>	<b>2.04E-02</b>
<b>10CFR50 App I Limits</b>	<b>3</b>	<b>10</b>	<b>10</b>

**Total Off-Site Dose from Millstone Station**

	<b>Whole Body (mrem)</b>	<b>Thyroid (mrem)</b>	<b>Max Organ* (mrem)</b>
<b>Airborne without C-14</b>	1.56E-02	2.44E-02	1.99E-02
<b>Airborne with C-14</b>	6.71E-02	7.60E-02	2.69E-01
<b>Liquid</b>	2.21E-03	8.14E-04	2.04E-02
<b>Direct Shine **</b>	1.80E-01	1.80E-01	1.80E-01
<b>Total without C-14</b>	<b>1.98E-01</b>	<b>2.05E-01</b>	<b>2.20E-01</b>
<b>Total with C-14</b>	<b>2.49E-01</b>	<b>2.57E-01</b>	<b>4.70E-01</b>
<b>40CFR190 Limits</b>	<b>25</b>	<b>75</b>	<b>25</b>

10/07/2013

\* Maximum of the following organs (not including Thyroid): Bone, G-LLI, Kidney, Liver, Lung

\*\* Direct shine is radiation exposure from onsite storage of radwaste and spent fuel

**Table 2.2-A1**  
**Millstone Unit 2**  
**Airborne Effluents - Release Summary**

Units	2012				
	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Total

**A. Fission & Activation Gases**

1. Total Activity Released	Ci	4.57E-01	1.72E-01	2.03E-01	4.80E-01	1.31E+00
2. Average Period Release Rate	uCi/sec	5.81E-02	2.19E-02	2.55E-02	6.04E-02	4.15E-02

10/07/2013

**B. Iodines / Halogens**

1. Total Activity Released	Ci	6.88E-05	2.71E-04	2.32E-04	3.09E-04	8.81E-04
2. Average Period Release Rate	uCi/sec	8.75E-06	3.45E-05	2.92E-05	3.89E-05	2.79E-05

10/07/2013

**C. Particulates**

1. Total Activity Released	Ci	3.18E-07	-	-	3.04E-06	3.36E-06
2. Average Period Release Rate	uCi/sec	4.04E-08	-	-	3.83E-07	1.06E-07

**D. Gross Alpha**

1. Total Activity Released	Ci	-	-	-	-	-
----------------------------	----	---	---	---	---	---

**E. Tritium**

1. Total Activity Released	Ci	1.18E+00	7.77E+00	2.19E+00	5.59E+00	1.67E+01
2. Average Period Release Rate	uCi/sec	1.50E-01	9.88E-01	2.75E-01	7.03E-01	5.29E-01

**F. C-14**

1. Total Activity Released**	Ci	2.10E+00	2.10E+00	2.10E+00	2.10E+00	8.40E+00
2. Average Period Release Rate	uCi/sec	2.70E-01	2.67E-01	2.64E-01	2.64E-01	2.66E-01

"-" denotes less than Minimum Detectable Activity (MDA)

\*\*Calculated value per "Estimation of Carbon-14 in Nuclear Power Plant Gaseous Effluents" EPRI Final Report, 12/2010.



**Table 2.2-A4**  
**Millstone Unit 2**  
**Airborne Effluents - Elevated Batch**  
**Containment Vents and Purges, Waste Gas Decay Tanks Discharges**  
**Release Point - Millstone Site Stack**

Nuclides Released	Units	2012				
		1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Total

**A. Fission & Activation Gases**

Ar-41	Ci	4.51E-02	4.84E-02	4.29E-02	2.14E-02	1.58E-01
Kr-85	Ci	2.86E-01	6.01E-02	2.82E-02	3.47E-01	7.21E-01
Kr-85m	Ci	8.53E-06	-	-	-	8.53E-06
Xe-131m	Ci	6.20E-04	1.64E-04	-	-	7.84E-04
Xe-133	Ci	1.19E-01	6.19E-02	3.64E-02	2.92E-03	2.20E-01
Xe-133m	Ci	1.38E-03	4.49E-05	-	-	1.42E-03
Xe-135	Ci	4.82E-03	1.38E-03	1.31E-03	2.46E-04	7.76E-03
Other $\gamma$ Emitters	Ci	-	-	-	-	-
Total Activity	Ci	4.57E-01	1.72E-01	1.09E-01	3.72E-01	1.11E+00

**B. Iodines / Halogens**

I-131	Ci	-	-	-	-	-
I-133	Ci	-	-	-	-	-
Other $\gamma$ Emitters	Ci	-	-	-	-	-
Total Activity	Ci	-	-	-	-	-

**C. Particulates**

$\gamma$ Emitters	Ci	-	-	-	-	-
Total Activity	Ci	-	-	-	-	-

**D. Gross Alpha**

Gross Alpha	Ci	na	na	na	na	na
-------------	----	----	----	----	----	----

**E. Tritium**

H-3	Ci	2.46E-01	3.60E-01	1.43E-01	1.42E-02	7.63E-01
-----	----	----------	----------	----------	----------	----------

"-" denotes less than Minimum Detectable Activity (MDA)

"na" denotes not required to be analyzed

10/07/2013

**Table 2.3-A1**  
 Millstone Unit 3  
 Airborne Effluents - Release Summary

Units	2012				
	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Total

**A. Fission & Activation Gases**

1. Total Activity Released	Ci	2.44E-01	4.06E-01	2.32E-01	1.64E-01	1.05E+00
2. Average Period Release Rate	uCi/sec	3.10E-02	5.16E-02	2.92E-02	2.06E-02	3.31E-02

**B. Iodines / Halogens**

1. Total Activity Released	Ci	1.29E-06	8.35E-07	9.12E-07	7.89E-07	3.83E-06
2. Average Period Release Rate	uCi/sec	1.64E-07	1.06E-07	1.15E-07	9.93E-08	1.21E-07

**C. Particulates**

1. Total Activity Released	Ci	4.54E-11	1.56E-11	5.63E-08	1.42E-11	5.64E-08
2. Average Period Release Rate	uCi/sec	5.77E-12	1.99E-12	7.08E-09	1.79E-12	1.78E-09

**D. Gross Alpha**

1. Total Activity Released	Ci	-	-	-	-	-
----------------------------	----	---	---	---	---	---

**E. Tritium**

1. Total Activity Released	Ci	2.08E+01	1.95E+01	6.91E+00	9.87E+00	5.71E+01
2. Average Period Release Rate	uCi/sec	2.65E+00	2.48E+00	8.69E-01	1.24E+00	1.81E+00

**F. C-14**

1. Total Activity Released**	Ci	3.10E+00	3.10E+00	3.10E+00	3.10E+00	1.24E+01
2. Average Period Release Rate	uCi/sec	3.99E-01	3.94E-01	3.90E-01	3.90E-01	3.93E-01

"-" denotes less than Minimum Detectable Activity (MDA)

\*\*Calculated value per "Estimation of Carbon-14 in Nuclear Power Plant Gaseous Effluents" EPRI Final Report, 12/2010.

10/07/2013

10/07/2013

**Table 2.3-A3**  
 Millstone Unit 3  
**Airborne Effluents - Ground Continuous**  
**ESF Building Ventilation, Reactor Water Storage Tank (RWST)**  
**Release Point - ESF Building Vent, RWST Vent**

Nuclides Released	Units	2012				Total
		1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	

**A. Fission & Activation Gases**

γ Emitters	Ci	-	-	-	-	-
Total Activity	Ci	-	-	-	-	-

**B. Iodines / Halogens**

I-131	Ci	-	-	-	-	-
I-133	Ci	-	-	-	-	-
Other γ Emitters	Ci	-	-	-	-	-
Total Activity	Ci	-	-	-	-	-

**C. Particulates**

Sc-46	Ci	-	-	5.63E-08	-	5.63E-08
Cr-51	Ci	5.27E-12	1.18E-12	5.90E-13	2.56E-13	7.30E-12
Mn-54	Ci	2.45E-12	9.90E-13	1.22E-12	1.29E-12	5.95E-12
Fe-59	Ci	1.60E-12	4.60E-13	3.30E-13	2.14E-13	2.60E-12
Co-58	Ci	2.52E-11	8.50E-12	7.90E-12	6.10E-12	4.77E-11
Co-60	Ci	4.18E-12	1.77E-12	2.34E-12	2.63E-12	1.09E-11
Zr-95	Ci	6.25E-13	2.06E-13	1.82E-13	1.37E-13	1.15E-12
Nb-95	Ci	4.97E-13	1.27E-13	7.90E-14	4.28E-14	7.46E-13
Sb-125	Ci	2.40E-12	1.02E-12	1.34E-12	1.48E-12	6.24E-12
Cs-134	Ci	1.46E-12	6.10E-13	8.10E-13	8.90E-13	3.77E-12
Cs-137	Ci	1.72E-12	7.50E-13	1.00E-12	1.15E-12	4.62E-12
Other γ Emitters	Ci	-	-	-	-	-
Total Activity	Ci	4.54E-11	1.56E-11	5.63E-08	1.42E-11	5.64E-08

**D. Gross Alpha**

Gross Alpha	Ci	-	-	-	-	-
-------------	----	---	---	---	---	---

**E. Tritium**

H-3	Ci	1.24E-04	7.50E-05	1.01E-04	9.90E-05	3.99E-04
-----	----	----------	----------	----------	----------	----------

"-" denotes less than Minimum Detectable Activity (MDA)

10/07/2013

10/07/2013