

Southern California Edison Company



P. O. BOX 800
2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

M.O. MEDFORD
MANAGER, NUCLEAR LICENSING

October 2, 1984

TELEPHONE
(213) 572-1749

Director, Office of Nuclear Reactor Regulation
Attention: W. A. Paulson, Acting Chief
Operating Reactors Branch No. 5
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-206
SEP Topic III-6
Seismic Design Considerations
San Onofre Nuclear Generating Station
Unit 1

The purpose of this letter is to submit the enclosed report entitled, "Electrical Raceway Support Implementation Plan for Return to Service, San Onofre Nuclear Generating Station, Unit 1," dated September 1984. The report describes the electrical raceway support seismic reevaluation and upgrade plan which is being implemented as part of our return to service efforts at San Onofre Unit 1. The report also provides the basis for concluding that with the implementation of the identified modifications to raceway supports, the raceway system will have a seismic withstand capability of .67g without impairment of the overall integrity of the system and without impairment of the capability to achieve and maintain hot standby conditions.

If you have any questions or desire additional information regarding this subject, please contact me.

Very truly yours,

Enclosure

8410050239 841002
PDR ADDCK 05000206
P PDR

A035
1/0