

RECEIVED
11/23

Southern California Edison Company

1984 NOV 28 AM 11:18

SCE

P. O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

REGION V

M. O. MEDFORD

MANAGER, NUCLEAR LICENSING

TELEPHONE
(818) 572-1749

November 21, 1984

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. John B. Martin, Regional Administrator

IE FILE COPY

Dear Sir:

Subject: Docket No. 50-206
Upgrade of the Emergency Notification System (ENS)
San Onofre Nuclear Generating Station
Unit 1

- References: A) June 19, 1981 letter from R. H. Engelken, USNRC Region V to L. T. Papay, SCE, ENS Upgrade
- B) January 22, 1982 letter from K. P. Baskin, SCE, to R. H. Engelken, USNRC Region V, ENS Upgrade

Reference A provided the bases for the ENS upgrade and requested information relating to installing improved equipment, to the availability of power supplies, and to interconnect facilities. Reference B provided the responses to these items. In response to one of the items, a review of the conduit and related cabling for the cableway to the Control Room was performed. As indicated in Reference B, new conduit and cable, qualified per IEEE 383, will be installed. Reference B identified the schedule for installation of qualified cable to be coincident with the next scheduled outage. The purpose of this letter is to inform you that a review of this activity has identified that the replacement effort will be completed by March, 1985. Prior to installation of qualified cabling, the existing temporary cabling will ensure continued operability of the ENS. As a redundant backup system to the ENS, the SCE Private Automatic Exchange (PAX) telephone system interfacing with the PAC-TEL system will ensure the availability of communication.

If you have any questions or desire additional information, please contact me.

8412040154 841121
PDR ADOCK 05000206
F PDR

Very truly yours,

mo medford

cc: E. McKenna, NRC Project Manager
F. R. Huey, USNRC Resident Inspector, Units 1, 2 and 3

IE-28110