

*Southern California Edison Company*



P. O. BOX 800  
2244 WALNUT GROVE AVENUE  
ROSEMEAD, CALIFORNIA 91770

M. O. MEDFORD  
MANAGER, NUCLEAR LICENSING

TELEPHONE  
(818) 302-1749

July 2, 1985

Director, Office of Nuclear Reactor Regulation  
Attention: Mr. J. A. Zwolinski, Chief  
Operating Reactors Branch No. 5  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-206  
Additional Information Relating to Generic Letter 83-28  
San Onofre Nuclear Generating Station  
Unit 1

Reference: March 11, 1985 letter from J. A. Zwolinski, NRC, to  
K. P. Baskin, SCE, regarding Generic Letter 83-28

The referenced letter requested additional information relative to our response to Generic Letter 83-28 Items 2.2.2 and 4.5.3. Item 2.2.2 requires all nuclear utilities to establish, implement and maintain a continuing program to insure that vendor information is (1) complete, current and controlled throughout the life of their plants, and (2) appropriately referenced or incorporated in plant instructions and procedures. Our response to this item was provided by our letters of November 28, 1983 and May 31, 1984. Our response was based on an industry consensus developed by the Nuclear Utility Task Action Committee (NUTAC) formed through INPO. The referenced letter indicates that the NRC staff has concluded the NUTAC program fails to address the concern about establishing and maintaining an interface between all safety-related equipment vendors and the utility. (Accordingly, additional information has been requested to address this concern). The Vendor Equipment Technical Information Program (VETIP) as defined in the March 1984 NUTAC document is considered an adequate resolution to the concerns identified in Item 2.2.2. SCE has implemented the program as described therein.

In regards to Item 4.5.3, it is our understanding that the NRC staff has completed their review of the portions of WCAP-10271 and Supplement 1 relating to Reactor Protection System (RPS) analog channels, and issued their safety evaluation by letter dated in February 21, 1985. Upon completion of the staff's review of the remainder of the WCAP items relating to actuation

8507160610 850702  
PDR ADDCK 05000206  
P PDR

A055  
1/0

Mr. J. A. Zwolinski

-2-

July 2, 1985

logic and reactor trip breakers a plant specific response for San Onofre Unit 1 will be provided. We have received the Westinghouse Owners Group (WOG) guidelines for preparation of submittals requesting revisions to the RPS technical specifications which were transmitted to the NRC by letter dated May 16, 1985. The extent to which the recommendations of WCAP-10271 will be integrated into the testing, maintenance and inspection procedures at San Onofre Unit 1 is currently being evaluated. Subsequent to this evaluation, a Technical Specification change will be prepared utilizing the applicable guidelines established by WOG. It is expected that this change will be submitted to you by September of this year.

If you have any questions or desire additional information, please let me know.

Very truly yours,

A handwritten signature in dark ink, appearing to read "M. O. Medford". The signature is fluid and cursive, with the first letters of the first and last names being capitalized and prominent.

M. O. Medford  
Manager, Nuclear Licensing

MT:4345F

bcc: (see attached sheet)