

AUG 01 1985

Docket No.: 50-206

Mr. Jack Rainsberry, Supervising Engineer
San Onofre Nuclear Generating Station,
Unit 1 Licensing
Southern California Edison Company
P. O. Box 800
2244 Walnut Grove Avenue
Rosemead, California 91770

Dear Mr. Rainsberry:

SUBJECT: LONG TERM SEISMIC CRITERIA AND ANALYSIS METHODS
SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 1

As you requested during a conference call on July 31, 1985, attached is a copy of a preliminary evaluation prepared by EG&G Idaho regarding the proposed strain-elastically calculated stress relationship. We request that you review this material in preparation for the meeting scheduled on August 14-15, 1985. If you have any questions regarding this material, please contact Thomas Cheng (301-492-8393).

*Original signed by:
C. I. Grimes*

Christopher I. Grimes, Chief
Systematic Evaluation Program Branch
Division of Licensing

DISTRIBUTION
Central Files
SEPB Reading
CGrimes
TCheng
PDR
L PDR

*SEE PREVIOUS FOR CONCURRENCE.

SEPB:DL* SEPB:DL*
TCheng EMcKenna
08/01/85 08/01/85

SEPB:DL *CG*
CGrimes
08/1/85

8508090493 850801
PDR ADDCK 05000206
P PDR

Docket No.: 50-206

Mr. Jack Rainsberry, Supervising Engineer
San Onofre Nuclear Generating Station,
Unit 1 Licensing
Southern California Edison Company
P. O. Box 800
2244 Walnut Grove Avenue
Rosemead, California 91770

Dear Mr. Rainsberry:

SUBJECT: LONG TERM SEISMIC CRITERIA AND ANALYSIS METHODS
SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 1

Per your request during a July 31, 1985 Conference Call, attached is a copy of our consultant, EG&G Idaho's, informal evaluation of the proposed strain-elastically calculated stress relationship for you to prepare for the meeting scheduled on August 14-15, 1985. If you have any questions regarding this evaluation, please contact Thomas Cheng (301-492-8393).

Christopher I. Grimes, Chief
Systematic Evaluation Program Branch
Division of Licensing

DISTRIBUTION
Central Files
SEPB Reading
CGrimes
TCheng

SEPB:DL *tlc*
TCheng
08/ / 85

SEPB:DL *EMM*
EMcKenna
08/ / 85

SEPB:DL
CGrimes
08/ / 85

Evaluation of SCE Proposed Stress-Strain Relationship

SCE has proposed calculating actual strains based on elastically calculated stresses as follows:

given a linear-elastic piping stress:

$$\sigma_E = \frac{PD}{4t} + 0.75i (M/z),$$

calculate a strain by

$$\epsilon = K_s \sigma_E / E$$

where

$$K_s = 1.0 \quad \sigma_E \leq S_y$$

$$= 1.0 + \frac{(1-n)}{n(m-1)} \left\{ \frac{\sigma_E}{S_y} - 1 \right\}$$

when $S_y \leq \sigma_E < m S_y$

$$= 1/n \quad \text{when } m S_y < \sigma_E$$

and $E = \text{young's modulus}$

K_s is identical to K_e in NB-3653.6*

"Simplified elastic plastic Discontinuity Analysis"

p 131, except that $S_m / 3S_m$ is replaced by σ_E / S_y . The

K_s, K_e curves are presented on the following page.

* NB-3653.6 of the ASME B31.1 Code, W84 addenda




Figure 1. Function relationships: $K_e(S_n/35m) \leq K_s(\sigma_E/\sigma_y)$

Since the K_e expression is acceptable code methodology, and since an investigation of its basis indicates that it is appropriate for use in a seismic calculation, the suitability of the K_s methodology will be based on a comparison to K_e . Given a specific component under a specific loading, both $S_m/3S_m$ and \sqrt{E}/S_y can be calculated. Based on the Figure given earlier, $K_s \geq K_e$ only if $\sqrt{E}/S_y \geq S_m/3S_m$.

Since $\sqrt{E} \geq 0, S_y \geq 0$, $\sqrt{E}/S_y \geq 0$

and $\frac{S_m/3S_m}{(\sqrt{E}/S_y)} \leq 1$ Follows from the above

or $\frac{(S_m/\sqrt{E})}{(3S_m/S_y)} \leq 1$

it follows that

The expression has been manipulated to obtain ratios of calculated stress and ratios of allowable stress. This is necessary for the comparison. Based on Table 2, the range of piping materials used in SOWB52, and their range of operating temperatures, the term $3S_m/S_y$ varies from 1.71 to 2.72.

(Note that S_m should be based on Design Temperature according to strict definition.)

This was not done due to lack of data, but is essentially neglecting a conservatism of the Code and should be a small error)

The ratio of S_n/\sqrt{E} will require a bit more work. From NB-3653.1 of the current ASME Code (WS4),

$$S_n = C_1 \frac{P_0 D_0}{2t} + \frac{C_2 P_0 M E}{2I} + C_3 E \alpha_b (\alpha_a T_a - \alpha_b T_b)$$

This compares to SCE's \sqrt{E} (an ASME Class 2 type of stress):

$$\sqrt{E} = \frac{P_0 D}{4t} + 0.75 \alpha \left(\frac{M}{z} \right) \quad (\text{where } 0.75 \alpha \approx 2.5)$$

The assumption that the earthquake load is strongly predominate is made to make the task reasonable. This allows:

- 1) Neglecting the pressure terms
- 2) Neglecting the thermal terms
- 3) setting $M_i = 2M$ (note that Class 1 stresses are stress intensities, and Class 2 stresses are principal stresses)

Under the assumption,

$$\frac{S_n}{\sqrt{E}} = \frac{\left(\frac{C_2 P_0 (2M)}{2I} \right)}{\left(0.75 \alpha \left(\frac{M}{z} \right) \right)}$$

and since $z = \pi r_m^2 t \approx 2I/P_0$

$$\frac{S_n}{\sqrt{E}} = \frac{2C_2}{0.752}$$

Table 2 presents the range of S_n/\sqrt{E} calculated for the range of components and sizes which are likely to be found in SONGS 2. Based on table 2, a range of 2.0 to 5.8 has been chosen. Reducers have been neglected in the range because of the disparity in maximum values. The very large ratio for reducers reflects the large allowable variation in geometry, and may not represent the range of reducer geometries in the plant. Based on the chosen range of the stress ratio, the ratio of independent variables $((S_n/\sqrt{E})/(3S_m/S_y))$ is 10.74 - 3.39. This shows the proposed methodology to be non-conservative. To correct the situation, the following

recommendation is made:

Perform the calculation as proposed, except use $(3.39\sqrt{E}/S_y)$ in calculating K_s . IF the component being analyzed is a reducer, use

$S_n/3S_m$ in calculating K_s . Since the 3.39 value is conservative for most components, the option of using $S_n/3S_m$ should also be allowed in all other cases.

Footnote - Since it may be of interest;

0.74 is for straight pipe/girth weld
of B312 TP 316 @ 570°F

3.39 is for long radius elbows of carbon steel at low temperature (100°F).

Table 1 Variation in Material Properties For
SONGS₁ Piping Materials and Operating
Temperatures.

Material	T °F	S_y	S_m	$(3S_m/S_y)$
A 312 TP304L	100	25.0	16.7	2.00
	200	21.3	16.7	2.35
TP304	100	30.0	20.0	2.00
	575	18.5	16.7	2.71
TP316	100	30.0	20.0	2.00
	570	19.1	17.3	2.72
A 106 Gr B and A 53 Gr B (using SA-106)	100	35.0	20.0	1.71
	340	30.6	20.0	1.96
	545	27.2	18.2	2.01
Total	Range			(1.71 - 2.72)

Table 2 Variation in stress Parameters For Typical Piping Components

Component	Range of $2C_2 / \max(1.0, 0.75i)$
straight pipe	2.00
girth butt weld	2.00
$t \geq 0.237$ in.	1.40 to 2.00
$t < 0.237$ in.	2.96 - 4.20
girth Fillet weld (socket weld)	2.96 - 4.20
welded transition	2.96
reducers	5.13 to 14.57
LR elbows	5.80
branch connections ("stub" type)	3.04 to 5.33
Forged Tees	4.00 to 5.33
<hr/>	
Total Range	2.0 to 5.80

Attachment:

Basis For Table 2 -

$$\frac{2C_2}{0.75i} \text{ ratio}$$



From following pages

to Table 2

(4)

Component	C_2	$0.75i$	$2C_2/0.75i$
straight pipe -	1.0	1.0	2.00
girth butt weld	$t \geq 0.237$	1.0	2.00
	$t \leq 0.237$ †	1.0	1.40 - 2.00
girth Fillet weld † (socket)	2.1	1.0 - 1.92 \nearrow 1.44	2.66 - 4.20 \nearrow 2.92
welded transition	(1.7 - 2.1)	(1.15 - 1.42)	2.96
reducers	(3.23 - 10.93)	(1.26 - 1.50)	(5.13 - 14.57)
LR Elbows	—	—	5.80
Branches	} Cases complete on following pages	—	3.04 - 5.33
Forged Tees			4.0 - 5.33

† Primarily small bore

Total Range - (2.0 - 5.8)

From 1983 ed., W84 Addenda

(2)

Table NB-3681(a)-1 (p138) / Fig. NC-3673.2(b)-1, p166

Component	C ₂	i	0.75 i
straight pipe	1.0	1.0	1.0
girth butt weld in straight pipe:			
t > 0.237	{ 1.0	1.0	
t ≤ 0.237		1.0 to 1.93	1.0 to 1.44
girth fillet weld (socket)	2.1		see below

NB-3683.5 - Welded Transitions (p142) - C₂: (1.7 to 2.1)
(s=0.25?)

$$i = \frac{C_2 K_2}{2} \Rightarrow \min K_2 = 1.8, i = .7(1.7 \text{ to } 2.1) = 1.53 \text{ to } 1.49$$

NB-3683.6 - reducers (p142) 0.75 i: (1.15 to 1.42)

Population calculation req'd - all following pages (5 thru 7)

Fig NC 3673.2(b)-1 (p167) - socket weld

$$i = \max(1.3, 2.1 / C_x / t_n)$$

Fig NC-4427-1 (p251) - socket weld

$$C_{x, \min} = 1.09 t_n$$

$$i = \max(1.3, 2.1 / 1.09) = 1.93$$

range is 1.3 to 1.93

0.75 i ranges from 1.0 to 1.44

NB-3683.7 - Branch - (p143)

(3)

$$C_2 = 1.95 / h^{2/3}, \text{ but not } < 1.5$$

$$\text{since } B_2 = 1.70 h^{2/3}, \text{ but not } < 1.5,$$

$$\underline{C_2 = 1.5 B_2}$$

note B_2 limit factor will control C_2 limit factor is 1.5

from the B_2 work, the range of $B_2 / 0.75i$ is 1.93 for 3"-30", see 55 X above

therefore, $C_2 / 0.75i = 1.5 (1.93) = 2.90$

$$\frac{2C_2}{0.75i} = 5.80$$

NB 3683.8 - Branches (p143),

$$B_{2b} = 0.5 C_{2b}, \text{ but not } < 1.0$$

$$B_{2r} = 0.75 C_{2r}, \text{ but not } < 1.0$$

$$\therefore C_{2b} = 2.0 B_{2b}$$

$$C_{2r} = 1.33 B_{2r}$$

limit ratios the same

p9

from the B_{2b} work, $B_{2b}/0.75i: (1.00 - 1.33)$ (ie range from 1.0 to 1.33)
 $B_{2r}/0.75i: (1.14 - 1.41)$

therefore $(C_{2b}/0.75i): (2.0 - 2.67)$
 $(C_{2r}/0.75i): (1.52 - 1.88)$ } $\frac{C_2}{0.75i}: (1.52 - 2.67)$

$$\frac{2C_2}{0.75i} = 3.04 - 5.33$$

NB 3683.9 - B.W. Tee - (p144)

$$C_{2b} = 0.67 (R_m / T_r)^{2/3} \text{ but not } \leq 2.0$$

$$C_{2r} = C_{2b}$$

$$\begin{matrix} R_m = r \\ T_r = t \end{matrix}$$

Fig NC-3673.2 (b)-1 (p166) - for Tee.

$$i = 0.9 / h^{2/3}$$

$$h = \frac{4.4 t_m}{r}$$

r = mean radius
 t_m = nominal wall t

(4)

$$\begin{aligned}
0.75i &= 0.75 \left[\frac{0.9}{(4.4t_n/r)^{2/3}} \right] \\
&= \frac{(0.75)(0.9)}{(4.4)^{2/3}} \left(\frac{r}{t_n} \right)^{2/3} \\
&= 0.257 \left(\frac{r}{t_n} \right)^{2/3}
\end{aligned}$$

$$\begin{aligned}
\frac{1}{2} &> \frac{1}{3} \\
2 &< 3
\end{aligned}$$

← page 3

$$\frac{C_2}{.75i} = 2.665 = 2.67 = \frac{0.67}{0.251}$$

$$\frac{2C_2}{0.75i} = 5.33$$

Exp NC-3673.2(N4) - h = 0.8 @ i = 2 (h > 0.8, i = 1.0)
 (p 170)

~~$$h = 0.8 = 4.4 t_n / r$$~~

~~$$r/t_n = 4.4/8$$~~

~~$$D/t_n = 2(4.4)/8 =$$~~

$$h = 4.4 t_n / r > 0.8$$

$$r/t_n < 4.4/0.8$$

$$D/t_n < 8.8/0.8 = 11$$

There are components where $D_n, t_n < 11$:

need population calculation (which follows)

↑
pages

M/R 17/10/85

'C₂' Calculation For Reducers

(5)

P ₁ (in)	T ₁ (in)	D ₂ (in)	T ₂ (in)	Max(C ₂₅ , C ₂₄)		
				α = 30	α = 60	α = 30/60
3.500	0.216	2.375	0.154	223 2.56	5.47 3.65	1.26 / 1.50
	0.300		0.218	290 2.59	4.79 3.19	1.12 / 1.50
6.625	0.280	4.500	0.237	3.70 2.72	6.40 4.27	1.36 / 1.50
	0.432		0.337	3.17	5.35	1.20 / 1.50
	0.280	3.500	0.216	3.70	6.40	1.28 / 1.50
	0.432		0.300	3.17	5.35	1.14 / 1.50
12.750	0.375	10.750	0.365	4.24	7.47	1.50 / 1.50
	0.500		0.500	3.80	6.60	1.42 / 1.50
	0.375	8.625	0.322	4.24	7.47	1.50 / 1.50
	0.500		0.500	3.80	6.60	1.31 / 1.50
	0.375	6.625	0.280	4.24	7.47	1.47 / 1.50
	0.500		0.432	3.80	6.60	1.26 / 1.50
18.000	0.375	16.000	0.375	4.84	8.69	1.50 / 1.50
	0.500		0.500	4.33	7.66	1.50 / 1.50
	0.375	12.750	0.375	4.84	8.69	1.50 / 1.50
	0.500		0.500	4.33	7.66	1.50 / 1.50
	0.375	10.750	0.365	4.84	8.69	1.50 / 1.50
	0.500		0.500	4.33	7.66	1.42 / 1.50
24.000	0.375	20.00	0.375	5.44	9.88	1.50 / 1.50
	0.500		0.500	4.84	8.69	1.50 / 1.50
	0.375	18.000	0.375	5.44	9.88	1.50 / 1.50
	0.500		0.500	4.84	8.69	1.50 / 1.50
	0.375	16.000	0.375	5.44	9.88	1.50 / 1.50
	0.500		0.500	4.84	8.69	1.50 / 1.50
30.000	0.375	28.000	0.375	5.96	10.93	1.50 / 1.50
	0.500		0.500	5.30	9.60	1.50 / 1.50
	0.375	24.000	0.375	5.96	10.93	1.50 / 1.50
	0.500		0.500	5.30	9.60	1.50 / 1.50
	0.375	20.000	0.375	5.96	10.93	1.50 / 1.50
	0.500		0.500	5.30	9.60	1.50 / 1.50

range of $\frac{C_2}{T_2}$ is 2.56 (α=30, 3" x 4") to 7.29 (α=60, 30" x 15") $\Rightarrow \frac{2C_2}{0.75} = 5.1350$ to 14.57

Description	Flexibility Factor f	Stress Intensification Factor i	Sketch
Concentric and eccentric reducers (Note (7)) (ANSI B16.9)	1	$2.0 \text{ max. or } 0.5 + 0.01 \alpha \left(\frac{D_1}{t_r}\right)^{1/2}$	

$$.75i = \max [1.0, .75 \{ \min (2.0, 0.5 + 0.01 \alpha (D/t)^{1/2}) \}]$$

A = 2.375

A = 30.000

D = 2.375

T = 0.154

.75i = 1.259

T = 0.218

.75i = 1.110

01*LBL *RDI*

02 ADV

03 ADV

04 *****

05 PRN

06 ADV

07 * A = *

08 CF 01

09 XEQ *IO*

10 STO 01

11*LBL 01

12 * D = *

13 XEQ *IO*

14 STO 02

15 ADV

16*LBL 02

17 RCL 02

18 * T = *

19 XEQ *IO*

20 /

21 SQRT

22 RCL 01

23 *

24 .0075

25 *

26 .375

27 +

28 1.5

29 X>Y?

30 X<>Y

31 1.0

32 X<=Y?

33 X<>Y

34 *.75i = *

35 ARCL X

36 PRN

37 ADV

38 FRT 01

39 STDF

40 SF 01

41 GTO 02

42*LBL *IO*

43 PROMPT

44 ARCL X

45 PRN

46 RTN

47 END

7/10/55

ASME
13 1/2 PV
NB-3000

1983 Edition, W54, p147

7




FIG. NB-3683.6-1

(1) For reducers with r_1 and $r_2 \geq 0.1 D_1$:

$$C_1 = 1.0 + 0.0058 a \sqrt{D_n/t_n}$$

$$C_{2L} = C_2 = 1.0 + 0.36 a^{0.4} (D_n/t_n)^{0.4(D_1/D_2 - 0.5)}$$

where D_n/t_n is the larger of D_1/t_1 and D_2/t_2 .

(2) For reducers with r_1 and/or $r_2 < 0.1 D_1$:

$$C_1 = 1.0 + 0.00465 a^{1.225} (D_n/t_n)^{0.39}$$

$$C_{2S} = C_2 = 1.0 + 0.0185 a \sqrt{D_n/t_n}$$

where D_n/t_n is the larger of D_1/t_1 and D_2/t_2 .

C2: REDUCER

A = 30.000
D1 = 6.625
T1 = 0.289

D2 = 4.500
T2 = 0.237
C2L = 2.761
C2S = 3.700

D2 = 3.500
T2 = 0.216
C2L = 2.454
C2S = 3.700

C2: REDUCER

A = 60.000
D1 = 6.625
T1 = 0.289

D2 = 4.500
T2 = 0.237
C2L = 3.323
C2S = 6.395

D2 = 3.500
T2 = 0.216
C2L = 2.915
C2S = 6.395

01+LBL *RDC*	37 /
02 FIX 3	38 .5
03 ADY	39 -
04 ADY	40 .4
05 *C2: REDUCER*	41 *
06 PRA	42 RCL 06
07 ADY	43 X<>Y
08 * A = *	44 Y+X
09 XEQ *10*	45 RCL 01
10 STO 01	46 .4
11 * D1 = *	47 Y+X
12 XEQ *10*	48 *
13 STO 02	49 .36
14 * T1 = *	50 *
15 XEQ *10*	51 1
16 STO 03	52 +
17+LBL 01	53 *C2L = *
18 ADY	54 ARCL X
19 ADY	55 PRA
20 * D2 = *	56 RCL 06
21 XEQ *10*	57 SQRT
22 STO 04	58 RCL 01
23 * T2 = *	59 *
24 XEQ *10*	60 .0185
25 STO 05	61 *
26 RCL 02	62 1
27 RCL 03	63 +
28 /	64 *C2S = *
29 RCL 04	65 ARCL X
30 RCL 05	66 PRA
31 /	67 GT0 01
32 X<=Y?	68+LBL *10*
33 X<>Y	69 PROMT
34 STO 06	70 ARCL X
35 RCL 06	71 PRA
36 RCL 02	72 RTD
	73 END



	2"	3"	4"	6"	12"	18"	24"	30"
LR elbows	DB = 2.5750 R = 3.0000	DB = 3.5000 R = 4.5000	DB = 4.5000 R = 6.0000	DB = 6.6250 R = 9.0000	DB = 12.7500 R = 18.0000	DB = 18.0000 R = 27.0000	DB = 24.0000 R = 36.0000	DB = 30.0000 R = 45.0000
SL →	TN = 0.1500	TN = 0.2160	TN = 0.2370	TN = 0.2800	TN = 0.3750	TN = 0.3750	TN = 0.3750	TN = 0.3750
ELBOW	R: B1 = 0.0000 R: B2 = 1.9259	R: B1 = 0.0000 R: B2 = 1.9259	R: B1 = 0.0504 R: B2 = 1.9259	R: B1 = 0.0000 R: B2 = 1.9259	R: B1 = 0.0000 R: B2 = 1.9259	R: B1 = 0.0000 R: B2 = 1.9259	R: B1 = 0.0000 R: B2 = 1.9259	R: B1 = 0.0000 R: B2 = 1.9259
TEE	R: B2B = 1.4000 R: B2R = 1.9889	R: B2B = 1.5465 R: B2R = 1.9331	R: B2B = 1.5911 R: B2R = 1.9889	R: B2B = 1.5911 R: B2R = 1.9889	R: B2B = 1.5911 R: B2R = 1.9889	R: B2B = 1.5911 R: B2R = 1.9889	R: B2B = 1.5911 R: B2R = 1.9889	R: B2B = 1.5911 R: B2R = 1.9889
TEE	TN = 0.2160	TN = 0.3000	TN = 0.3370	TN = 0.4320	TN = 0.5000	TN = 0.5000	TN = 0.5000	TN = 0.5000
ELBOW	R: B1 = 0.0000 R: B2 = 1.9259	R: B1 = 0.2215 R: B2 = 1.9259	R: B1 = 0.1734 R: B2 = 1.9259	R: B1 = 0.1244 R: B2 = 1.9259	R: B1 = 0.0000 R: B2 = 1.9259	R: B1 = 0.0000 R: B2 = 1.9259	R: B1 = 0.0000 R: B2 = 1.9259	R: B1 = 0.0000 R: B2 = 1.9259
TEE	R: B2B = 1.4000 R: B2R = 1.9889	R: B2B = 1.2210 R: B2R = 1.5263	R: B2B = 1.3466 R: B2R = 1.6832	R: B2B = 1.4878 R: B2R = 1.8568	R: B2B = 1.5911 R: B2R = 1.9889	R: B2B = 1.5911 R: B2R = 1.9889	R: B2B = 1.5911 R: B2R = 1.9889	R: B2B = 1.5911 R: B2R = 1.9889

Elbows:
 $B_2/0.75i$
 x5

(B)

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS

Branch Dia	sch	Indices	Run Diameter (schedule same as Branch piping)										max	min
			4	6	8	10	12	14	16	18	24	30		
2"	40	Br	1.33	1.33	1.33	1.33	1.33	1.24	1.02	1.00	1.00	1.00	1.33	1.00
		Rn	1.26	1.26	1.26	1.26	1.26	1.26	1.26	1.26	1.26	1.26	1.26	1.26
4"	40	Br	X	X	1.33							1.33	1.33	1.33
		Rn			1.33							1.33	1.33	1.33
6"	40	Br	X	X	X	X	1.33					1.33	1.33	1.33
		Rn					1.41					1.41	1.41	1.41
2"	80	Br	1.33	1.33	1.24	1.00						1.00	1.33	1.00
		Rn	1.14	1.14	1.14	1.14						1.14	1.14	1.14
4"	80	Br	X	X	1.33			1.33	1.26	1.08	1.00	1.00	1.33	1.00
		Rn			1.21							1.21	1.21	1.21
6"	80	Br	X	X	X	X	1.33			1.33	1.151		1.33	1.15
		Rn					1.25				1.25		1.25	1.25

total -
 Br - 1.33 - 1.00
 Rn - 1.41 - 1.14
 For branches

B₂₆/0.75"
 B₂₈/0.75"

①

MJR 7/10/65

(10)

nominal
Ø"

TEE CIF

Sch 5

Sch X

2 1/2

D = 2.8750
T = 0.2830
C2 = 2.3530
.75I = 1.0000
RAT = 2.3530

D = 2.8750
T = 0.2760
C2 = 2.0000
.75I = 1.0000
RAT = 2.0000

3

D = 3.5000
T = 0.2160
C2 = 2.5903
.75I = 1.0000
RAT = 2.5903

D = 3.5000
T = 0.3000
C2 = 2.0452
.75I = 1.0000
RAT = 2.0452

3 1/2

D = 4.0000
T = 0.2260
C2 = 2.7575
.75I = 1.0046
RAT = 2.6653

D = 4.0000
T = 0.3100
C2 = 2.1602
.75I = 1.0000
RAT = 2.1602

4

D = 4.5000
T = 0.2370
C2 = 2.8976
.75I = 1.0072
RAT = 2.6653

D = 4.5000
T = 0.3370
C2 = 2.2555
.75I = 1.0000
RAT = 2.2555

6

0

D = 6.6250
T = 0.4320
C2 = 2.4900
.75I = 1.0000
RAT = 2.4900

0

0

8

0

D = 8.6250
T = 0.5000
C2 = 2.6653
RAT = 2.6653

0

0

0

0

0

0

0

0

D = 30.0000
T = 0.3750
C2 = 7.7709
.75I = 2.9150
RAT = 2.6653

D = 30.0000
T = 0.5000
C2 = 6.7507
.75I = 2.4000
RAT = 2.6653

C2
0.75I
ranges from 200 to 267
(2 1/2" sch X → 30" sch both)

2.C2
0.75I
ranges from 4.0 to 5.34

P146

17/12/85
W84
1983 Edition

Fig. NC-3673.2(b)-1

SECTION III, DIVISION 1 — SUBSECTION NC

W84
1983 Edition

Description	Flexibility Characteristic h	Flexibility Factor k	Stress Intensification Factor i	Sketch
Welding tee per ANSI B16.9 [Notes (1), (2)]	4.4 t_w	1	$I = \frac{0.9}{h^{1/4}}$ $.75I = \max[.75I, 1.0]$	

P144

NB-3683.8-NB-3683.9

W84
1983 Edition

Register
1
2
3

Contents
 $I_n = T_r$
 $r = R_m$

(b) Primary Plus Secondary Stress Indices. The C_{2b} and C_{2r} stress indices for moment loadings [see NB-3683.1(d)] shall be taken as:

$C_{2b} = 0.67 (R_m/T)^{1/2}$ but not < 2.0

$C_{2r} = 0.67 (R_m/T)^{1/2}$ but not < 2.0

$CZ = C_{2b} = C_{2r}$

$r = R_m = \frac{1}{2} (D_o - T)$

$RAT = C_2 / (0.75I)$

```

01*LBL *TEE*
02 * TEE SIF*
03 PRA
04*LBL 01
05 ADV
06 ADV
07 * I = *
08 XEQ *10*
09 STO 01
10 /
11 /
12 /
13 2
14 /
15 STO 02
16 RCL 01
17 /
18 2
19 ENTER
20 3
21 /
22 *
23 .67
24 *
25 /
26 X=Y?
27 X<Y
28 STO 03
29 * C2 = *
30 ARCL X
31 XEQ *PRA* -> CZ
32 .675
33 RCL 01
34 /
35 *
36 RCL 02
37 /
38 2
39 ENTER
40 3
41 /
42 YTX
43 /
44 /
45 X=Y?
46 X<Y
47 * .75I = *
48 ARCL X
49 XEQ *PRA* -> .75I
50 /
51 /
52 1/X
53 * RAT = * -> RAT
54 ARCL X
55 XEQ *PRA*
56 GTO 01
57*LBL *10*
58 PROMPT
59 /
60 XEQ *PRA*
61 FTN
62 STOP
63 END
  
```

```

TEE SIF
D_o
-> D = 18.0000
-> T = 0.3750
C2 = 5.4969 ->
.75I = 2.0624 ->
RAT = 2.6653 ->

-> D = 3.5000
-> T = 0.6000
C2 = 2.0000 ->
.75I = 1.0000 ->
RAT = 2.0000
  
```

17/11/85