

Southern California Edison Company

P. O. BOX 800 2244 WALNUT GROVE AVENUE ROSEMEAD, CALIFORNIA 91770

M. O. MEDFORD MANAGER, NUCLEAR LICENSING

May 19, 1986

TELEPHONE (818) 302-1749

Director, Office of Nuclear Reactor Regulation Attention: G. E. Lear, Director PWR Project Directorate No. 1 U. S. Nuclear Regulatory Commission Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-206 SEP Topic III-6, Seismic Design Considerations San Onofre Nuclear Generating Station Unit 1

The purpose of this letter is to respond to a number of questions regarding the seismic reevaluation of San Onofre Unit 1. Accordingly, provided as Enclosure 1 are the responses to specific questions raised by the NRC Staff or its consultants.

If you have any questions on the enclosed information, please call me.

Very truly yours,

Enclosure

cc: F. R. Huey, USNRC Senior Resident Inspector, SONGS 1, 2 and 3 M. J. Russell, EG&G

- L. Shieh, LLNL
- N. C. Tsai, NCT Engineering

8605210240 860519 700506 PDR ADOCK 05

CONCRETE EXPANSION ANCHORS AND ROCK ANCHORS

QUESTION

Explain how the group effect of bolts was considered for concrete expansion anchors and rock anchors.

RESPONSE

The group effect of bolts was considered by specifying the allowable design loads based on a minimum center to center spacing between bolts (see attached Table 3 column denoted as "Min. C/C Spacing"). A reduction in the minimum center to center spacing is permitted so long as allowable design loads are reduced according to Note A of Table 3. Similar provisions are considered in the design of concrete expansion anchors which have allowable design loads based on minimum center to center spacings of twelve bolt diameters.

	ΤA	B	LE	3
--	----	---	----	---

ALLOWABLE DESIGN LOADS FOR ROCK BOLT EXPANSION ANCHORS

Anchor Diameter (Inches)	Allo Des Load Tension (Kips)	wable ign g(l), (2) Shear (Kips)	Torque (Ft-Lbs) to Expand Shell	Pretensioning Torque at Installation (Ft-Lbs) Threads Not Lubricated	Tension Test Load (Kips)	Min. Embedment (Inches)	Min.C/C Spacing (Inches)	Min. Edge Distance (Inches)
1	$25^{(5)}$ $33^{(6)}$	$\begin{array}{r} 8^{(7)} & 12^{(8)} \\ 16^{(7)} & 24^{(8)} \\ 33^{(7)} & 48^{(8)} \end{array}$	200-250	300	30	14	10	6
1-3/8	$50^{(5)}$ $66^{(6)}$		700-750	1100 ⁽³⁾	60	18	14	8
2	$100^{(5)}$ $133^{(6)}$		950-1000 ⁽⁴⁾	3300 ⁽³⁾	120	24	20	10

(1) For 4000 psi (f'c) or higher concrete

- (2) Subject to reduction per Notes A and B and combined interaction per Note C (see next page)
- (3) Preferred method is to pretension to specified test load using calibrated hollowram hydraulic jack or calibrated stud tensioner.
- (4) May be increased to 1500 ft. lbs. if required to prevent slight pullout of bolt which may be experienced upon application of 3300 ft-lb torque for pretensioning prior to grouting.
- (5) Manufacturer's recommended design load at 2:1 safety factor.
- (6) These increased allowable loads are applicable only for "Abnormal/Extreme Environmental" (Design Basis Earthquake) or faulted loading combinations. They are based on 0.9 times Manufacturer's maximum working load to elastic limit.
- (7) Preferred design load based on AISC limits using manufacturer's ultimate strength values.

TABLE 3 (CONTINUED)

ALLOWABLE DESIGN LOADS FOR ROCK BOLT EXPANSION ANCHORS

(8) Design loads increased by 1.5 applicable only for "Abnormal/Extreme Environmental (Design Basis Earthquake) or Faulted Loading combinations.

Additional Notes:

>

- A. A reduction in the minimum center to center spacing and edge distance for anchors is acceptable provided that the allowable design loads (tension and shear) are reduced by the same proportion (i.e.: 25 percent reduction in spacing 25 percent reduction in allowable design loads). The reduction in spacing may not exceed 50 percent in any case.
- B. A reduction in the minimum embedment for anchors is acceptable provided that the allowable design load (tension only) is reduced in proportion to the square of the reduced embedment (i.e: embedment reduced to $(.80)^2 = .64$ times allowable load specified). The reduced embedment may not be less than 70 percent of the specified minimum embedment.
- C. For evaluation of simultaneous tension and shear loading, the loads shall be combined by the following interaction formulas:

 $\left(\frac{t}{T}\right)^2 + \left(\frac{s}{S}\right)^2 \le 1.0$ for rock bolt expansion anchors Where:

(t, s) = Actual design (tension, shear) loads, respectively

(T, S) = Specified allowable (tension, shear) loads, respectively

BATTERY RACKS

QUESTION

Provide information regarding the design of the new battery racks in Battery Room No. 1 of the Control-Administration Building.

RESPONSE

The new batteries and racks were designed and manufactured by Gould Industrial Battery Division. The battery rack is a two step, 19'-0" long x 3'-8" wide x 3'-2" high steel structure which supports 30 cells of batteries (Figure 1). The rack was designed for the .67g modified Housner seismic event and a 4% damping value was used. Dynamic analysis was performed with the computer code, STRUDL, and design was in accordance with Specifications IEEE 323-1983, IEEE 344-1975, AISC 8th Edition and AWS D1.1-1983. Allowable stresses were limited to 90% of minimum material yield strength.



Figure 1

ORIGINAL CONSTRUCTION WELDING PRACTICES

QUESTION

Provide additional information regarding the welding practices for original pipe support A-36 steel.

RESPONSE

Overall information regarding the original welding practices at San Onofre Unit 1 was provided in our April 16, 1986 submittal to the NRC. The additional procedure qualification record (PQR) for welding A-36 steel is attached. The PQR shows that the minimum tested tensile strength was 59.4 ksi which was greater than the minimum base metal strength of 58.0 ksi.

	ENCLOSURE (1) PAGE 10f1 Log BPC/SCE-86-4	BECHTEL (San Francis	CORPORAT	Form No. TION	WR-ZA
	PR	OCEDURE Q	UALIFICA	tion record	
_			Data	November 4, 1966	

WAINS PT							
W CLUING I I				•		•	1
Name W.B	. Keyser			\$y	mbol		
Test Condu	cted by H.J. Mantle	¢					
Parent Mat	erial Qualified On:			•			•
Chemical (C.S.		Spec.	STM A-	36		·
P-No	1		Shape 1	PLATE			
			Thickness	0.25	•		
Electrode o	r Filler Material Used	1 • ·					
AWE Class	E 6010		ASTM SD	ec. A-7	233		
				E	5010		
	•		A-No.	1			
Manufacture	er and Trade Name	Lincoln 5P					
		1m			• •		46
		15N				•	
	2 GONLY	45	. .			•	-
Joint Design	2 GONLY	45·	. -			•	-
Joint Design oot Gap: 3	2 G <u>ONLY</u> n 9/16	45·	- E		Backing	Strips Use	- d <u>YES</u>
Joint Design oot Gap: 3	2 G <u>ONLY</u> 0/16	45·	£		_Backing	Strips Use	- d <u>YES</u>
Joint Design oot Gap: 3 Heat Treatm	2 G <u>ONLY</u> n 0/16 nent	45 [•]	£		Backing	Strips Use	- YES
Joint Design oot Gap: 3 Heat Treatm Preheat	2 G <u>ONLY</u> n 9/16 nent Stress	45. Relieve Te	£	Stre	Backing a	Strips Use	e <u>Yes</u>
Joint Design oot Gap: 3 Heat Treatm Preheat	2 G <u>ONLY</u> n 0/16 nent Stress	45	emp	Stre	Backing a	Strips Use	e YES
Joint Design oot Gap: 3 Heat Treath Preheat Radiographi	2 G <u>ONLY</u> n)/16 ment Stress ic Results	45°	*mp	Stre	Backing a	Strips Use	e <u>YES</u>
Joint Design oot Gap: 3 Reat Treatm Preheat Radiographi Physical Te	2 G <u>ONLY</u> n 0/16 nent Stress ic ResultsStress isting_Tensile and ben	45 Relieve Te	emp	Stre	Backing Backing	Strips Use	e YES
Joint Design oot Gap: 3 Fiest Treatm Preheat Radiographi Physical Te	2 G <u>ONLY</u> n)/16 nent Stress ic Results Stress ic Results bends interpret	45 Relieve Te	emp	Stre	Backing Backing	Strips Use Time	e <u>YES</u>
Joint Design oot Gap: 3 Heat Treath Proheat Radiographi Physical Te	2 G <u>ONLY</u> n)/16 nent Stress ic Results Stress ic Results bends interpret	45 Relieve Te de by Anam ted by Beck HORIZC	emp	Stre Berkeley VERT	Backing in the second s	Strips Use Time	ed YES
Joint Design oot Gap: 3 Heat Treatm Preheat Radiographi Physical Te SPECIMEN	2 G <u>ONLY</u> n)/16 nent Stress ic Results Stress ic Results Stress ic Results Stress ic Results Stress is fing Tensile and ben bends interpret	45 Relieve Te de by Anam ted by Beck HOR I ZC (2G)	amp	Stre Berkeley VER7 (3G)	Backing Backing Ss relieve	Strips Use Time OVE (4G	RHEAD
Joint Design oot Gap: 3 Heat Treatm Preheat Radiographi Physical Te SPECIMEN Reduced	2 G <u>ONLY</u> n)/16 nent Stress ic Results Stress ic Results Stress isting Tensile and ben bends interpret POSITION] Yield Strength psi	45 Relieve Te ade by Anam ted by Beck HOR I ZC (2G)	emp	Stre Berkeley VERT (3G)	Backing Backing Ss relieve	Strips Use • Time OVE (4G	RHEAD
Joint Design oot Gap: 3 Heat Treatm Preheat Radiographi Physical Te SPECIMEN Reduced Section	2 G <u>ONLY</u> n 2 G <u>ONLY</u> nent Stress c Results sting Tensile and ben bends interpret POSITION <u>Yield Strength psi</u> Tensile Strength k	45° Relieve Te ade by Anam ted by Beck HOR I ZC (2G)	emp	Stre Stre Berkeley VERT (3G) 67.1	Backing Backing Ss relieve	Strips Use • Time OVE (4G 67.1	ed <u>YES</u>
Joint Design oot Gap: 3 Hest Treath Preheat Radiographi Physical Te SPECIMEN Reduced Section Tensile	2 G <u>ONLY</u> n 2 G <u>ONLY</u> nent Stress c Results sting Tensile and ben bends interpret POSITION <u>Yield Strength psi</u> <u>Tensile Strength k</u> Elongation, % in 2	45° Relieve To ade by Anam ted by Bech HOR I ZC (2G)	emp	Stre Berkeley VERT (3G) 67.1	Backing Backing Ss relieve	Strips Use Time OVE (4G 67.1	ed_YES
Joint Design oot Gap: 3 Heat Treatm Preheat Radiographi Physical Te SPECIMEN Reduced Section Tensile Bend	2 G <u>ONLY</u> n n/16 nent Stress c Results sting Tensile and ben bends interpret POSITION <u>Yield Strength psi</u> <u>Tensile Strength k</u> Elongation, % in 2 Free %	45° Relieve Te ade by Anam ted by Beck HOR I ZC (2G)	emp act Labs, atel Corp. DNTAL 59.4	Stre Berkeley VERT (3G) 67.1	Backing Backing Ss relieve	Strips Use Time OVE (4G 67.1	ed_YES
Joint Design oot Gap: 3 Heat Treatm Preheat Radiographi Physical Te SPECIMEN Reduced Section Tensile Bend Bend	2 G <u>ONLY</u> n 2 G <u>ONLY</u> nent Stress c Results sting Tensile and ben bends interpret POSITION Yield Strength bai Tensile Strength k Elongation, % in 2 Free % Root	45° Relieve Te de by Anam ted by Bech HOR I ZC (2G)	emp net Labs, ntel Corp. NTAL 59.4 180 OK	Stre Berkeley VERT (3G) 67.1	Backing Backing SS relieve TICAL 65.0 180 OK	Strips Use • Time OVE (4G 67.1 180 OK	ed YES

pared, welded, and tested in accordance with the requirements of Section IX of the ASME Code.

BECHTEL CORPORATION

002 B Encineer ì

)

)

11/4/66 Date

۰,

SEISMIC QUALIFICATION OF ELECTRICAL EQUIPMENT

QUESTION

Provide information regarding the seismic qualification of electrical equipment.

RESPONSE

The anchorage of safety related electrical equipment was evaluated and modifications were implemented, where required, as documented in SCE's letters to the NRC dated March 25, 1981, May 29, 1981 and June 28, 1982. These evaluations included the anchorage of electrical cabinets. The seismic adequacy of the electrical cabinets themselves will be demonstrated during the implementation phase of the resolution of Unresolved Safety Issue A-46, Seismic Qualification of Electrical Equipment. It is our understanding that the NRC resolution of A-46 is scheduled for issuance later this year.

SUPPORT STIFFNESS

QUESTION

Is the influence of beam flexibility considered in the piping analyses?

RESPONSE.

Beam flexibilty was considered when support structures could affect the response of piping systems. Beams were determined to be non-rigid if the beam deflection under the pipe support seismic load was greater than 1/8 inch or the beam's first modal frequency was below the zero period acceleration region of the applicable instructure response spectra (Reference SER Section 3.13). Non-rigid support beams were evaluated for their effect on piping analyses by calculating the beam stiffnesses at the pipe support locations. These beam stiffnesses were either considered in the piping analyses or compared with generic pipe support stiffnesses to confirm that the analysis results would not be significantly affected.

1854X:jk

CONDENSATE STORAGE TANK

QUESTION

Evaluate the effect of a seismic event on the condensate storage tank.

RESPONSE

The results of the evaluation of the condensate storage tank are included in the enclosed report "Seismic Evaluation of the SONGS 1 Condensate Storage Tank" dated May 1986.

.

JLR:6750F