1

PWR Examination Outline

Facility: SHE	ARON HARRIS	Date of Exam: SEPTEMBER 2013																
Tion	0			-	F	<u>10 k</u>	/A C	ateg	ory F	Point	s				SF	10-0n	ly Poin	ts
Tier	Group	К 1	К 2	к 3	К 4	К 5	К 6	A 1	A 2	A 3	A 4	G *	Total	A2		G*		Total
1.	1	3	3	3				3	3			3	18	3		3		6
Abnormal	2	1	1	2		N/A		2	2	N			9		2		2	4
Plant Evolutions	Tier Totals	4	4	5				5	5			4	27	5			5	10
	1	2	2	3	3	2	3	3	3	2	3	2	28		3		2	5
2. Plant	2	1	1	1	1	1	1	0	1	1	1	1	10	0	2		1	3
Systems	Tier Totals	3	3	4	4	3	4	3	4	3	4	3	38		5		3	8
3. Generic H	Knowledge and	Abil	ities			1		2	;	3	4		10	1	2	3	4	7
	Categories					3		2		2		3		1	2	2	2	
Note: 1.	 Ensure that at least two topics from every applicable K/A category are sampled within each tier of the RO and SRO-only outlines (i.e., except for one category in Tier 3 of the SRO-only outline, the "Tier Totals" in each K/A category shall not be less than two). 																	
2.	The point total for The final point to The final RO exa	or eac otal fo am m	h gro r eac ust to	h gro h gro tal 7	nd tie up ar 5 poir	er in th nd tie nts ar	ne pro r may id the	opose y devi e SRC	ed ou iate b D-only	tline i y ±1 / exa	nust from m mu	matc that s ist tot	h that spec specified in al 25 point	cified in the ta ts.	n the tai Ible bas	ble. ed on i	NRC re	visions.
3.	Systems/evolutio at the facility sho included on the of inappropriate	ns wi buld b butlin K/A s	thin e e del e sho taten	ach g eted ouid b nents	roup and j e ado	are io ustifie ded.	lentifi ed; oj Refe	ied or perati r to S	n the a onally lection	assoc y imp n D.1	iated ortan .b of	outlin t, site ES-4	e; systems -specific s 01 for guid	s or eve system lance i	olutions s/evolut regardir	that do tions th ng the e	not app at are r eliminati	oly iot ion
4.	Select topics from selecting a seco	m as nd to	many pic fo	/ syst r any	ems syste	and e em or	volu evol	tions lution	as po	ssibl	e; sai	mple	every syst	em or	evolutio	on in th	e group	before
5.	Absent a plant-s Use the RO and	pecifi SRO	c pric ratin	ority, o gs fo	only t r the	hose RO a	K/As Ind S	: havi RO-o	ng ar Inly p	n impo ortior	ortano Is, res	ce rat spect	ting (IR) of ivelv.	2.5 or	higher	shall b	e select	ted.
6.	Select SRO topic	s for	Tiers	1 an	d 2 fr	om th	ne sh	aded	syste	ems a	nd K	/A ca	tegories.					
7.*	The generic (G) I must be relevant	√/As i t to ti	in Tie ne ap	rs 1 a plical	and 2 ble e	shal voluti	l be s on or	elect syste	ed fro em. F	om Se Refer	ection to Se	2 of	the K/A Ca D.1.b of E	atalog, ES-401	but the	topics	able K//	As.
8. (In the relevant to the applicable evolution or system. Heter to Section D.1.b of ES-401 for the applicable K/As. I. On the following pages, enter the K/A numbers, a brief description of each topic, the topics' importance ratings (IRs) for the applicable license level, and the point totals (#) for each system and category. Enter the group and tier totals for each category in the table above; if fuel handling equipment is sampled in other than Category A2 or G* on the SRO-only exam, enter it on the left side of Column A2 for Tier 2, Group 2 (Note #1 does not apply). Use duplicate pages for RO and SRO-only exams.																	
9.	For Tier 3, select and point totals	t topi (#) or	cs fro Forr	om Se n ES-	ection -401-	2 of 3. Li	the M mit S	(/A ca RO s	atalog electi	, and ions t	ente o K/A	er the As tha	K/A numb It are linke	ers, de d to 10	escriptio	ons, IR: 5.43.	8,	

2

ES-401 Emergence	cy ar	nd A	bno	PW	'R Ex Plar	amin nt Evo	ation Outline Plutions - Tier 1/Group 1 (RO)/SRO	Form ES	-401-2
E/APE # / Name / Safety Function	к 1	к 2	К 3	A 1	A 2	G	K/A Topic(s)	IR	#
000007 (BW/E02&E10 CE/E02) Reactor Trip - Stabilization - Recovery / 1		R					R 007 EK 2.02		
000008 Pressurizer Vapor Space Accident / 3		R				100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100	R 008 AK2.02		
000009 Small Break LOCA / 3		A					R 009 K2.03		
000011 Large Break LOCA / 3						R	R 011 EG2.4.47		
000015/17 RCP Malfunctions / 4	R						R 015 K1.02		
000022 Loss of Rx Coolant Makeup / 2				R			R 022AA1.08		-
000025 Loss of RHR System / 4					5		S 025 AA2.05		
000026 Loss of Component Cooling Water / 8				R	ALL ST	No. 1	R 026 AA1.05		
000027 Pressurizer Pressure Control System Malfunction / 3									
000029 ATWS / 1	R				S	188 J	R 029 EKI.01 S029 EA2.09		
000038 Steam Gen. Tube Rupture / 3					2.55	S	S 038 EG2.4.30		
000040 (BW/E05; CE/E05; W/E12) Steam Line Rupture - Excessive Heat Transfer / 4			R				R 040 AK3.03		
000054 (CE/E06) Loss of Main Feedwater / 4					R	S	R 054 AA 2.02 5 054 AG 2.4.47		
000055 Station Blackout / 6					S	676 3	5 055 EA2.04		
000056 Loss of Off-site Power / 6						R	R 056AG2.4.45		
000057 Loss of Vital AC Inst. Bus / 6						1			
000058 Loss of DC Power / 6					R	S	R 058 AA2.01 5 058 AG2.4.3		
000062 Loss of Nuclear Svc Water / 4					R		R 062 AA2.01		
000065 Loss of Instrument Air / 8			R				R 065 AK3.08		
W/E04 LOCA Outside Containment / 3			R				R WE04 EK3.2		
W/E11 Loss of Emergency Coolant Recirc. / 4				R			R WEII EA1.3		
BW/E04,W/E05 nadequate Heat Transfer - Loss of Secondary Heat Sink / 4	R						R WE05 EK1.2		
000077 Generator Voltage and Electric Grid Disturbances / 6						R	R 077 AG 2.4.4		
K/A Category Totals:	3	3	3	3	3	3	Group Point Total:		18/6



			6				
ES-401, RE	EV 9		T1	G1 PWR EXAMINATION OUTLINE	FORM ES-401-2		
KA	NAME / SAFETY FUNCTION:		IR	K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G	TOPIC:		
007EK2.02	Reactor Trip - Stabilization - Recovery / 1	2.6	2.8		Breakers, relays and disconnects		
008AK2.02	Pressurizer Vapor Space Accident / 3	2.7	2.7		Sensors and detectors		
009EK2.03	Small Break LOCA / 3	3	3.3		S/Gs		
011EG2.4.47	Large Break LOCA / 3	4.2	4.2		Ability to diagnose and recognize trends in an accurate and timely manner utilizing the appropriate control room reference material.		
015AK1.02	RCP Malfunctions / 4	3.7	4.1		Consequences of an RCPS failure		
022AA1.08	Loss of Rx Coolant Makeup / 2	3.4	3.3		VCT level		
026AA1.05	Loss of Component Cooling Water / 8	3.1	3.1		The CCWS surge tank, including level control and level alarms and radiation alarm		
029EK1.01	ATWS / 1	2.8	3.1		Reactor nucleonics and thermo-hydraulics behavior Please make sure not solely feating GFES; when up write must fest plant		
040AK3.03	Steam Line Rupture - Excessive Heat Transfer / 4	3.2	3.5		Steam line non-return valves		
054AA2.02	Loss of Main Feedwater / 4	4.1	4.4		Differentiation between loss of all MFW and trip of one MFW pump		
056AG2.4.45	Loss of Off-site Power / 6	4.1	4.3		Ability to prioritize and interpret the significance of each annunciator or alarm.		

			P				
ES-401, RE	EV 9		T10	PWR EXAMINATION OUTLINE	FORM ES-401-2		
KA	NAME / SAFETY FUNCTION:		IR	K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G	TOPIC:		
		RO	SRO)			
058AA2.01	Loss of DC Power / 6	3.7	4.1		That a loss of dc power has occurred; verification that substitute power sources have come on line		
062AA2.01	Loss of Nuclear Svc Water / 4	2.9	3.5		Location of a leak in the SWS		
065AK3.08	Loss of Instrument Air / 8	3.7	3.9		Actions contained in EOP for loss of instrument air		
07760044	Congrator Voltage and Electric Grid	4.5	47		Ability to recognize abnormal indications for system		
077802.4.4	Disturbances / 6	4.5	ч. <i>1</i>		operating parameters which are entry-level conditions for emergency and abnormal operating procedures.		
WE04EK3.2	LOCA Outside Containment / 3	3.4	4.0		Normal, abnormal and emergency operating procedures associated with (LOCA Outside Containment).		
WE05EK1.2	Inadequate Heat Transfer - Loss of Secondary Heat Sink / 4	3.9	4.5		Normal, abnormal and emergency operating procedures associated with (Loss of Secondary Heat Sink).		
WE11EA1.3	Loss of Emergency Coolant Recirc. / 4	3.7	4.2		Desired operating results during abnormal and emergency situations.		

-	-
1	
1	
1	



ES-401, RE	EV 9	S	6 RO 1	1G1 PWR EXAMINATION OUTLINE	FORM ES-401			
KA	NAME / SAFETY FUNCTION:		IR	K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G	TOPIC:			
		RO	SRC)				
025AA2.05	Loss of RHR System / 4	3.1	3.5		Limitations on LPI flow and temperature rates of change			
029EA2.09	ATWS / 1	4.4	4.5		Occurrence of a main turbine/reactor trip			
038EG2.4.30	Steam Gen. Tube Rupture / 3	2.7	4.1		Knowledge of events related to system operations/status that must be reported to internal orginizations or outside agencies.			
054AG2.4.47	Loss of Main Feedwater / 4	4.2	4.2		Ability to diagnose and recognize trends in an accurate and timely manner utilizing the appropriate control room reference material.			
055EA2.04	Station Blackout / 6	3.7	4.1		Instruments and controls operable with only dc battery power available			
058AG2.4.3	Loss of DC Power / 6	3.7	3.9		Ability to identify post-accident instrumentation.			

3

ES-401 Emergency and Abn	P\ orma	NR al P	Exa lant	min Evc	atio olutio	n Oi ons	utline Fo - Tier 1/Group 2 (RO) (RO)	rm ES-	-401-2
E/APE # / Name / Safety Function	к 1	К 2	к 3	A 1	A 2	G	K/A Topic(s)	IR	#
000001 Continuous Rod Withdrawal / 1					R		R001 AA2.01		
000003 Dropped Control Rod / 1									
000005 Inoperable/Stuck Control Rod / 1					S		S 005 AA2,03		
000024 Emergency Boration / 1									
000028 Pressurizer Level Malfunction / 2						が			
000032 Loss of Source Range NI / 7									
000033 Loss of Intermediate Range NI / 7					alta.	1000			
000036 (BW/A08) Fuel Handling Accident / 8		R			No.	J. J. St.	R 036 AK2.01		
000037 Steam Generator Tube Leak / 3						R	R 037 AG2.4.34		
000051 Loss of Condenser Vacuum / 4				R	150		R 051 AA1.04		
000059 Accidental Liquid RadWaste Rel. / 9			R		资		R 059 A K3.04		
000060 Accidental Gaseous Radwaste Rel. / 9					19	S	5 060AG2.2.37		
000061 ARM System Alarms / 7					5	19-1 19-1	5 061 AA2.02		
000067 Plant Fire On-site / 8					1998) 1999	1.00			
000068 (BW/A06) Control Room Evac. / 8					r j	105			
000069 (W/E14) Loss of CTMT Integrity / 5				R	DWG.	S	RWE14 EAI. 5 069 AG2.2.25		
000074 (W/E06&E07) Inad. Core Cooling / 4					R	5 M	R 074 EA2.03		
000076 High Reactor Coolant Activity / 9						3			
W/EO1 & E02 Rediagnosis & SI Termination / 3					STA A	2000年			
W/E13 Steam Generator Over-pressure / 4						The second			
W/E15 Containment Flooding / 5			ď.				R WEIS EK3.1		
W/E16 High Containment Radiation / 9					10.0	5			
BW/A01 Plant Runback / 1						影ら			
BW/A02&A03 Loss of NNI-X/Y / 7						30			
BW/A04 Turbine Trip / 4									
BW/A05 Emergency Diesel Actuation / 6									
BW/A07 Flooding / 8									
BW/E03 Inadequate Subcooling Margin / 4						1			
BW/E08;W/E03LOCA Cooldown - Depress. / 4	R						R WE03 EKI.)		
BW/E09; CE/A13; W/E09&E10 Natural Circ. / 4					(c)				
BW/E13&E14 EOP Rules and Enclosures						1			
CE/A11; W/E08 RCS Overcooling - PTS / 4					100	145			
CE/A16 Excess RCS Leakage / 2					Ls.				
CE/E09 Functional Recovery						1.			
K/A Category Point Totals:	1	1	2	2	2	1	Group Point Total:		9/4

			(RD)			
ES-401, RE	EV 9		T1G2 PWR EXAMINATION OUTLINE	FORM ES-401		
КА	NAME / SAFETY FUNCTION:		IR K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G	TOPIC:		
001AA2.01	Continuous Rod Withdrawal / 1	4.2	4.2	Reactor tripped breaker indicator		
036AK2.01	Fuel Handling Accident / 8	2.9	3.5	Fuel handling equipment		
037AG2.4.34	Steam Generator Tube Leak / 3	4.2	4.1	Knowledge of RO tasks performed outside the main control room during an emergency and the resultant operational effects		
051AA1.04	Loss of Condenser Vacuum / 4	2.5	2.5	Rod position		
059AK3.04	Accidental Liquid RadWaste Rel. / 9	3.8	4.3	Actions contained in EOP for accidental liquid radioactive- waste release		
074EA2.03	Inad. Core Cooling / 4	3.8	4.1	Availability of turbine bypass valves for cooldown		
WE03EK1.1	LOCA Cooldown - Depress. / 4	3.4	4.0	Components, capacity, and function of emergency systems.		
WE14EA1.1	Loss of CTMT Integrity / 5	3.7	3.7	Components and functions of control and safety systems, including instrumentation, signals, interlocks, failure modes and automatic and manual features.		
WE15EK3.1	Containment Flooding / 5	2.7	2.9	Facility operating characteristics during transient conditions, including coolant chemistry and the effects of temperature, pressure and reactivity changes and operating limitations and reasons for these operating characteristics.		

1

ES-401, RE	EV 9	S	RO T	1G2 PWR EXAMINATION OUTLINE	FORM ES-401-2
КА	NAME / SAFETY FUNCTION:		IR	K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G	TOPIC:
		RO	SRC)	
005AA2.03	Inoperable/Stuck Control Rod / 1	3.5	4.4		Required actions if more than one rod is stuck or inoperable
060AG2.2.37	Accidental Gaseous Radwaste Rel. / 9	3.6	4.6		Ability to determine operability and/or availability of safety related equipment
061AA2.02	ARM System Alarms / 7	2.9	3.2		Normal radiation intensity for each ARM system channel
069AG2.2.25	Loss of CTMT Integrity / 5	3.2	4.2		Knowledge of the bases in Technical Specifications for limiting conditions for operations and safety limits.

1.0

4

ES-401				Plar	nt Sy	PW /ste	R E	xan Tie	nina er 2/	tion (Grou	Dutlin p 1 (F	Form E	S-401-2
System # / Name	К 1	К 2	К 3	К 4	К 5	К 6	A 1	A 2	A 3	A 4	G	K/A Topic(s)	#
003 Reactor Coolant Pump								R			「「「	R 003A2.02	
004 Chemical and Volume Control					8			100 N			海	R 004 A2.13 R 004 K5.26	
005 Residual Heat Removal							R	100				R 005 A1.05	
006 Emergency Core Cooling								19			R	R 006 G2.1.30	
007 Pressurizer Relief/Quench Tank				R				1997			8	R 007 G2.1.20 R 007 K4.01	
008 Component Cooling Water								E.	2		10	R 008 A3.08	
010 Pressurizer Pressure Control						R		1.0				R 010 K6.01, R 010 K6.03	
012 Reactor Protection	1			R				AND				R 012 K4,02	
013 Engineered Safety Features Actuation		R						AND NO		R		R 013 A4.01 R 013 K2.01	
022 Containment Cooling										R	1	R 022 A4.03	
025 Ice Condenser	-				-1	1/4					3 C -		
026 Containment Spray			R				R					B 026 A1.04 B 026 K3.02	
039 Main and Reheat Steam								K			- A	R 039 A2.01 5039 A2.03	
059 Main Feedwater				R							- 37	R 059 K4.02	1
061 Auxiliary/Emergency Feedwater					R		R	12.20			10.00	R 061 K5.05 R 061 A1.01	
062 AC Electrical Distribution		R						5			1.11	R 062 K2.01 5062 A2.11	
063 DC Electrical Distribution	\square		R					2.	R		S	A 063 A3.01 5063 G2.2.40	
064 Emergency Diesel Generator						R		3			14	R 064 K6.08	
073 Process Radiation Monitoring										R		R 073 A4.02	
076 Service Water	R							S			142	R 076 K1.01 S076 A2.01	
078 Instrument Air			R	ĺ				ielse			3.1	R 078 K3.01	
103 Containment	R										S	R 103 K1.08 5 103 G2.2.22	
								E Standard					
								14			all's		
		T	1					陵					
K/A Category Point Totals:	2	2	3	3	2	3	3	3	2	3	2	Group Point Total:	28/5

			R		
ES-401, RI	EV 9		T20	1 PWR EXAMINATION OUTLINE	FORM ES-401-2
KA	NAME / SAFETY FUNCTION:		R	K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G	TOPIC:
		RO	SRO	1	
003A2.02	Reactor Coolant Pump	3.7	3.9		Conditions which exist for an abnormal shutdown of an RCP in comparison to a normal shutdown of an RCP
004A2.13	Chemical and Volume Control	3.6	3.9		Low RWST
004K5.26	Chemical and Volume Control	3.1	3.2		Relationship between VCT pressure and NPSH for charging pumps
005A1.05	Residual Heat Removal	3.3	3.3		Detection of and response to presence of water in RHR emergency sump
006G2.1.30	Emergency Core Cooling	4.4	4.0		Ability to locate and operate components, including local controls.
007G2.1.20	Pressurizer Relief/Quench Tank	4.6	4.6		Ability to execute procedure steps.
007K4.01	Pressurizer Relief/Quench Tank	2.6	2.9		Quench tank cooling
008A3.08	Component Cooling Water	3.6	3.7		Automatic actions associated with the CCWS that occur as a result of a safety injection signal
010K6.02	Pressurizer Pressure Control	3.2	3.5		PZR
010K6.03	Pressurizer Pressure Control	3.2	3.6		PZR sprays and heaters
012K4.02	Reactor Protection	3.9	4.3		Automatic reactor trip when RPS setpoints are exceeded for each RPS function; basis for each

	~		6		
ES-401,	REV 9		T20	1 PWR EXAMINATION OUTLINE	FORM ES-401-2
KA	NAME / SAFETY FUNCTION:	IF	R	K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G	TOPIC:
		RO	SRO)	
013A4.01	Engineered Safety Features Actuation	4.5	4.8		ESFAS-initiated equipment which fails to actuate
013K2.01	Engineered Safety Features Actuation	3.6	3.8		ESFAS/safeguards equipment control
022A4.03	Containment Cooling	3.2	3.2		Dampers in the CCS
026A1.04	Containment Spray	3.1	3.3		Containment humidity
026K3.02	Containment Spray	4.2	4.3		Recirculation spray system
039A2.01	Main and Reheat Steam	3.1	3.2		Flow paths of steam during a LOCA
059K4.02	Main Feedwater	3.3	3.5		Automatic turbine/reactor trip runback
061A1.01	Auxiliary/Emergency Feedwater	3.9	4.2		S/G level
061K5.05	Auxiliary/Emergency Feedwater	2.7	3.2		Feed line voiding and water hammer
062K2.01	AC Electrical Distribution	3.3	3.4		Major system loads
063A3.01	DC Electrical Distribution	2.7	3.1		Meters, annunciators, dials, recorders and indicating lights

		G		
ES-401, R	IEV 9	T2	G1 PWR EXAMINATION OUTLINE	FORM ES-401-2
KA	NAME / SAFETY FUNCTION:	IR	K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G	TOPIC:
		RO SRO	0	
063K3.02	DC Electrical Distribution	3.5 3.7		Components using DC control power
064K6.08	Emergency Diesel Generator	3.2 3.3		Fuel oil storage tanks
073A4.02	Process Radiation Monitoring	3.7 3.7		Radiation monitoring system control panel
076K1.01	Service Water	3.4 3.3		CCW system
078K3.01	Instrument Air	3.1 3.4		Containment air system
103K1.03	Containment	3.1 3.5		Shield building vent system







ES-401, REV 9		S	RO T	2G1 PWR EXAMINATION OUTLINE	FORM ES-401-		
KA	NAME / SAFETY FUNCTION:		IR	K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G	TOPIC:		
		RO	SRC)			
039A2.03	Main and Reheat Steam	3.4	3.7		Indications and alarms for main steam and area radiation monitors (during SGTR)		
062A2.11	AC Electrical Distribution	3.7	4.1		Aligning standby equipment with correct emergency power source (D/G)		
063G2.2.40	DC Electrical Distribution	3.4	4.7		Ability to apply technical specifications for a system.		
076A2.01	Service Water	3.5	3.7		Loss of SWS		
103G2.2.22	Containment	4.0	4.7		Knowledge of limiting conditions for operations and safety limits.		

5

Form ES-401-2

ES-401				Plar	nt Sy	PW yste	R E ms -	xan Tie	nina er 2/	tion Gro	Ou up 2		Form ES	-401-2
System # / Name	К 1	к 2	к 3	К 4	K 5	К 6	A 1	A 2	A 3	A 4	G	K/A Topic(s)	IR	#
001 Control Rod Drive														
002 Reactor Coolant						i								
011 Pressurizer Level Control		R										R011 K2.02		
014 Rod Position Indication														
015 Nuclear Instrumentation			R					作品				R 015 K3.01		
016 Non-nuclear Instrumentation								R			12 1	R 016 A2.02		
017 In-core Temperature Monitor								1			5	5017 G2, 1.7		
027 Containment Iodine Removal						Q0								
028 Hydrogen Recombiner and Purge Control						R		5			いがあ	R 028 K6.01 S 028 A7.02	24	
029 Containment Purge								3-24						
033 Spent Fuel Pool Cooling											arasa Halaa			
034 Fuel Handling Equipment						N.S.			in the	1000	R	R 034G2.4.31		
035 Steam Generator											N.			
041 Steam Dump/Turbine Bypass Control														
045 Main Turbine Generator								E ST						
055 Condenser Air Removal														
056 Condensate											1			
068 Liquid Radwaste								S			調査	5 068 A2.04		
071 Waste Gas Disposal					A			記録				R 071 K5.04		
072 Area Radiation Monitoring								The second	R			R 072 A3.01		
075 Circulating Water	R										\mathcal{F}_{ij}	R 075 KI,01		
079 Station Air										R		R 079 A4.01		
086 Fire Protection				R				1544. 201			27 34	R 086 K4.02		
		1												
	1	\uparrow	İ											
			1											
	\top	1	1					1.1.1						1
K/A Category Point Totals:	1	1	1	1	1	Ĩ	0		Î	ľ	I	Group Point Total:		10/3



ES-401, REV 9

T2G2 PWR EXAMINATION OUTLINE



KA	NAME / SAFETY FUNCTION:	I	R	K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G	TOPIC:
		RO	SRO		-
011K2.02	Pressurizer Level Control	3.1	3.2		PZR heaters
015K3.01	Nuclear Instrumentation	3.9	4.3		RPS
016A2.02	Non-nuclear Instrumentation	2.9	3.2		Loss of power supply
028K6.01	Hydrogen Recombiner and Purge Control	2.6	3.1		Hydrogen recombiners
034G2.4.31	Fuel Handling Equipment	4.2	4.1		Knowledge of annunciators alarms, indications or response procedures
071K5.04	Waste Gas Disposal	2.5	3.1		Relationship of hydrogen/oxygen concentrations to flammability
072A3.01	Area Radiation Monitoring	2.9	3.1		Changes in ventilation alignment
075K1.01	Circulating Water	2.5	2.5		SWS
079A4.01	Station Air	2.7	2.7		Cross-tie valves with IAS
086K4.02	Fire Protection	3.0	3.4		Maintenance of fire header pressure

	1
/	
1	



FORM ES-401-2

ES-401, REV 9		S	RO 1	2G2 PWR EXAMINATION OUTLINE	FORM ES-40	
KA	NAME / SAFETY FUNCTION:		IR	K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G	TOPIC:	
		RO	SRC)		
017G2.1.7	In-core Temperature Monitor	4.4	4.7		Ability to evaluate plant performance and make operational judgments based on operating characteristics, reactor behavior and instrument interpretation.	
028A2.02	Hydrogen Recombiner and Purge Control	3.5	3.9		LOCA condition and related concern over hydrogen	
068A2.04	Liquid Radwaste	3.3	3.3		Failure of automatic isolation	

SRO T2G2 PWR EXAMINATION OUTLINE

Generic Knowledge and Abilities Outline (Tier 3)

Facility: Harr	is.	Date of Exam: September 2013				
Category	K/A #	Торіс	R	0	SRO-	Only
			IR	#	IR	#
	2.1. (3	Facility Regits for vital/controlled access	2.5			
1	2.1. 15	Temporary Mgmt Directives	2.7			
Conduct	2.1. l9	the planet computer	3.9			
of Operations	2.1.					
	2.1. 4	knowledge of refueling processes			3.7	
	2.1.					
	Subtotal		3		\bigcirc	
1	2.2. 20	Process for trouble shooting	2.6			
	2.2. 39	less than or equal to 1 hr TS actions	3.9			
2.	2.2.					
Equipment Control	2.2. 3	Tagging and Clearance procedures			4.3	
	2.2. 40	apply Tech Spess for a system			4.7	
	2.2.					
	Subtotal		\bigcirc		2	
	2.3. []	Control radiation releases	3.8			
	2.3.12	Radiological principles with licensed duties	3.2			
3.	2.3.	0 1 .				
Radiation Control	2.3. 4	Rad exposure limits during normal/emerg			3.7	
	2.3. 14	Radiation/Contamination paraido -N, A, or E			3.8	
	2.3.	, , , , , , , , , , , , , , , , , , , ,				
	Subtotal				Q	
	2.4. 22	Basis for prioritizing sefety functions	3.6			
4	2.4.27	Fire in the plant procedures	3.4			
Emergency	2.4.29	E-plan Knowledge	3.1			
Procedures /	2.4.					
	2.4.40	SRO responsibilities in E-plan implemendation			4.5	
	2.4.46	Verify alarms consistent of plt conditions			4.2	
	Subtotal		3		2	
Tier 3 Point Total	1		10	10	7	7

		C		
ES-401. I	REV 9	1	13 PWR EXAMINATION OUTLINE	FORM ES-401-2
KA	NAME / SAFETY FUNCTION:	IR PO SE	K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G	TOPIC:
G2.1.13	Conduct of operations	2.5 3.2		Knowledge of facility requirements for controlling vital / controlled access.
G2.1.15	Conduct of operations	2.7 3.4		Knowledge of administrative requirements for temporary management directives such as standing orders, night orders, Operations memos, etc.
G2.1.19	Conduct of operations	3.9 3.8		Ability to use plant computer to evaluate system or component status.
G2.2.20	Equipment Control	2.6 3.8		Knowledge of the process for managing troubleshooting activities.
G2.2.39	Equipment Control	3.9 4.5		Knowledge of less than one hour technical specification action statements for systems.
G2.3.11	Radiation Control	3.8 4.3	• □ □ □ □ □ □ □ □ □ □ □ □ □ □	Ability to control radiation releases.
G2.3.12	Radiation Control	3.2 3.7		Knowledge of radiological safety principles pertaining to licensed operator duties
G2.4.22	Emergency Procedures/Plans	3.6 4.4		Knowledge of the bases for prioritizing safety functions during abnormal/emergency operations.
G2.4.27	Emergency Procedures/Plans	3.4 3.9		Knowledge of "fire in the plant" procedures.
G2.4.29	Emergency Procedures/Plans	3.1 4.4		Knowledge of the emergency plan.

ES-401, I	REV 9	:	SRO	T3 PWR EXAMINATION OUTLINE	FORM ES-401-2
KA	NAME / SAFETY_FUNCTION:		IR	K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G	TOPIC:
		RO	SRC)	
G2.1.41	Conduct of operations	2.8	3.7		Knowledge of the refueling processes
G2.2.13	Equipment Control	4.1	4.3		Knowledge of tagging and clearance procedures.
G2.2.40	Equipment Control	3.4	4.7		Ability to apply technical specifications for a system.
G2.3.14	Radiation Control	3.4	3.8		Knowledge of radiation or contamination hazards that may arise during normal, abnormal, or emergency conditions or activities
G2.3.4	Radiation Control	3.2	3.7		Knowledge of radiation exposure limits under normal and emergency conditions
G2.4.40	Emergency Procedures/Plans	2.7	4.5		Knowledge of the SRO's responsibilities in emergency plan implementation.
G2.4.46	Emergency Procedures/Plans	4.2	4.2		Ability to verify that the alarms are consistent with the plant conditions.

 $(\$

Facility: Harris Nuclear Plant		Date of Examination: September 9, 2013			
Examination Level: RO	SRO	Operating Test Number: <u>05000400/2013301</u>			
Administrative Topic (see Note)	Type Code*	Describe activity to be performed			
Conduct of Operations	P, R	Determine Rod Misalignment Using Thermocouples (JPM ADM-062-c) <i>K/A G2.1.7</i> 2013 NRC RO / SRO A1-1			
Conduct of Operations	D, R	Determine Average RCS Boron Concentration per EOP-ECA-0.1 (JPM ADM-020-a) Common <i>K/A G 2.1.20</i> 2013 NRC RO / SRO A1-2			
Equipment Control	M, R	Perform a Quadrant Power Tilt Ratio (QPTR) calculation with a control rod misaligned. (JPM ADM-010-e) <i>K/A G 2.2.12</i> 2013 NRC RO A2			
Radiation Control	N, R	Using Valve Maps And HP Room Survey Maps Determine Stay Time During Refueling. (JPM ADM-065-a) Common <i>K/A G2.3.4</i> 2013 NRC RO / SRO A3			
Emergency Procedures/Plan	N/A	NOT SELECTED FOR RO 2013 NRC RO A4			
NOTE: All items (5 total) are re retaking only the admir	equired for SR histrative topic	COs. RO applicants require only 4 items unless they are s, when all 5 are required.			
* Type Codes & Criteria: (C)ontrol room, (S)imulator, or Class(R)oom (4) (D)irect from bank (\leq 3 for ROs; \leq 4 for SROs & RO retakes) (2) (N)ew or (M)odified from bank (\geq 1) (2) (P)revious 2 exams (\leq 1; randomly selected) (1)					
3/25/2013 Rev. 0					

2013 NRC RO Admin JPM Summary

<u>2013 NRC RO A1-1</u> - Determine Rod Misalignment Using Thermocouples (JPM ADM-062-c) Previous - 2011 NRC Exam JPM *randomly selected from bank

K/A G2.1.7 - Ability to evaluate plant performance and make operational judgments based on operating characteristics, reactor behavior, and instrument interpretation. (CFR: 41.5 / 43.5 / 45.12 / 45.13) RO 4.4 SRO 4.7

The plant is at 90% power with a load reduction in progress when a control rod is observed indicating 24 steps higher than group demand. The candidate must perform Attachment 2 of AOP-001, Malfunction of Rod Control and Indication System, to calculate the temperature difference between the affected thermocouple and its symmetric thermocouples. For RO's this JPM requires the candidate to identify the control rod is misaligned and notifies the CRS.

<u>2013 NRC RO A1-2</u> - (Common) - Determine Average RCS Boron Concentration per EOP-ECA-0.1 (JPM ADM-020-b)

K/A G2.1.20 - Ability to interpret and execute procedure steps. (CFR: 41.10 / 43.5 / 45.12) RO 4.6 / SRO 4.6

The candidate must perform a calculation to determine average RCS boron concentration in order to complete a Shutdown Margin calculation as required by EOP-ECA-0.1, Loss Of All AC Power Recovery Without SI Required. The candidate is provided a list of plant conditions and is required to calculate the average RCS boron concentration for these conditions IAW EOP-ECA-0.1, Attachment 1.

<u>2013 NRC RO A2</u> - Perform a Quadrant Power Tilt Ratio (QPTR) calculation with a control rod misaligned. (JPM ADM-010-e) **MODIFIED**

K/A G2.2.12 - Knowledge of surveillance procedures. (CFR: 41.10 / 45.13) RO 3.7 SRO 4.1

The candidate must perform a QPTR calculation in accordance with surveillance procedure OST-1039, Calculation of Quadrant power Tilt Ratio, Weekly Interval and as required by the AOP-001, Malfunction of Rod Control and Indication System for a misaligned rod at 95% power. For SRO's this JPM requires the candidate to identify applicable Tech Spec LCOs.

NOTE: This JPM will be modified by changing the initial reactor power, the control rod that is dropped into the reactor, and the values of the PRNI upper and lower detectors. These changes result in the QPTR value that exceeds 1.09. The Tech Spec action is now different due to the value exceeding 1.09.

2 Wed

2013 NRC RO Admin JPM Summary (continued)

<u>2013 NRC RO A3</u> - (Common) - Using Valve Maps And HP Room Survey Maps Determine Stay Time During Refueling. (JPM-ADM-065-a) **NEW**

K/A G2.3.4 - Knowledge of radiation exposure limits under normal or emergency conditions. (CFR: 41.12 / 43.4 / 45.10) RO 3.2 / SRO 3.7

The candidate will be supplied a survey map of a location in the RAB containing various radiation levels and several hot spots. In this area work must be performed by a refueling team shared resource AO. The AO will be required to have continuous HP coverage. The candidates will also have a copy of HP administrative procedures to use during this JPM. The candidate must determine the individual stay times for work in the area. The candidate should determine that the HP Technician cannot stay long enough to complete the task without either exceeding the RWP maximum radiation dose or the administrative yearly dose limit. Since the HP coverage cannot be provided for the work to be completed the job will have to be stopped before it is complete.

2013 NRC RO A4 – Not selected

(

Facility: <u>Harris Nuclear Plant</u>		Date of Examination: September 9, 2013				
Examination Level: RO	SRO	Operating Test Number: 05000400/2013301				
Administrative Topic (see Note)	Type Code*	Describe activity to be performed				
Conduct of Operations	P, R	Determine Rod Misalignment Using Thermocouples and Evaluate Tech Specs (JPM ADM-062-d) <i>K/A G2.1.7</i> 2013 NRC RO / SRO A1-1				
Conduct of Operations	D, R	Determine Average RCS Boron Concentration per EOP-ECA-0.1 (JPM ADM-020-b) Common <i>K/A G 2.1.20</i> 2013 NRC RO / SRO A1-2				
Equipment Control	M, R	Perform a Quadrant Power Tilt Ratio (QPTR) calculation with a control rod misaligned and Evaluate Tech Specs. (JPM ADM-010-f) <i>K/A G 2.2.12</i> 2013 NRC SRO A2				
Radiation Control	N, R	Using Valve Maps And HP Room Survey Maps Determine Stay Time During Refueling. (JPM ADM-065-a) Common <i>K/A G2.3.4</i> 2013 NRC RO / SRO A3				
Emergency Procedures/Plan	N, R	Given a Set of Plant Conditions, Classify an Event. (JPM ADM-064-a) <i>K/A G2.4.41</i> 2013 NRC SRO A4				
NOTE: All items (5 total) are required for SROs. RO applicants require only 4 items unless they are retaking only the administrative topics, when all 5 are required.						
* Type Codes & Criteria: (C)ontrol room, (S)imulator, or Class(R)oom (5) (D)irect from bank (\leq 3 for ROs; \leq 4 for SROs & RO retakes) (2) (N)ew or (M)odified from bank (\geq 1) (3) (P)revious 2 exams (\leq 1; randomly selected) (1)						

1 Y

2013 NRC SRO Admin JPM Summary

2013 NRC SRO A1-1 - Determine Rod Misalignment Using Thermocouples and Evaluate Tech Specs

(JPM ADM-062-d) Previous - 2011 NRC Exam JPM *randomly selected from bank

K/A G2.1.7 - Ability to evaluate plant performance and make operational judgments based on operating characteristics, reactor behavior, and instrument interpretation. (CFR: 41.5 / 43.5 / 45.12 / 45.13) RO 4.4 SRO 4.7

The plant is at 90% power with a load reduction in progress when a control rod is observed indicating 24 steps higher than group demand. The candidate must perform Attachment 2 of AOP-001, Malfunction of Rod Control and Indication System, to calculate the temperature difference between the affected thermocouple and its symmetric thermocouples. For SRO's this JPM requires the candidate to identify applicable Tech Spec LCOs.

<u>2013 NRC SRO A1-2</u> - (Common) - Determine Average RCS Boron Concentration per EOP-ECA-0.1 (JPM ADM-020-b) DIRECT

K/A G2.1.20 - Ability to interpret and execute procedure steps. (CFR: 41.10 / 43.5 / 45.12) RO 4.6 / SRO 4.6

The candidate must perform a calculation to determine average RCS boron concentration in order to complete a Shutdown Margin calculation as required by EOP-ECA-0.1, Loss Of All AC Power Recovery Without SI Required. The candidate is provided a list of plant conditions and is required to calculate the average RCS boron concentration for these conditions IAW EOP-ECA-0.1, Attachment 1.

<u>2013 NRC SRO A2</u> - Perform a Quadrant Power Tilt Ratio (QPTR) calculation with a control rod misaligned and Evaluate Tech Specs (JPM ADM-010-f) **MODIFIED**

K/A G2.2.12 - Knowledge of surveillance procedures. (CFR: 41.10 / 45.13) RO 3.7 SRO 4.1

The candidate must perform a QPTR calculation in accordance with surveillance procedure OST-1039, Calculation of Quadrant power Tilt Ratio, Weekly Interval and as required by the AOP-001, Malfunction of Rod Control and Indication System for a misaligned rod at 95% power. For SRO's this JPM requires the candidate to identify applicable Tech Spec LCOs.

NOTE: This JPM will be modified by changing the initial reactor power, the control rod that is dropped into the reactor, and the values of the PRNI upper and lower detectors. These changes result in the QPTR value that exceeds 1.09. The Tech Spec action is now different due to the value exceeding 1.09.

2013 NRC SRO Admin JPM Summary (continued)

<u>2013 NRC SRO A3</u> - (Common) - Using Valve Maps And HP Room Survey Maps Determine Stay Time During Refueling. (JPM-ADM-065-a) **NEW**

K/A G2.3.4 - Knowledge of radiation exposure limits under normal or emergency conditions. (CFR: 41.12 / 43.4 / 45.10) RO 3.2 SRO 3.7

The candidate will be supplied a survey map of a location in the RAB containing various radiation levels and several hot spots. In this area work must be performed by a refueling team shared resource AO. The AO will be required to have continuous HP coverage. The candidates will also have a copy of HP administrative procedures to use during this JPM. The candidate must determine the individual stay times for work in the area. The candidate should determine that the HP Technician cannot stay long enough to complete the task without either exceeding the RWP maximum radiation dose or the administrative yearly dose limit. Since the HP coverage cannot be provided for the work to be completed the job will have to be stopped before it is complete.

<u>2013 NRC SRO A4</u> - Given a set of conditions, Classify an Event (JPM-ADM-064-a) **NEW**

K/A G2.4.41 - Knowledge of the emergency action level thresholds and classifications (CFR: 41.10 / 43.5 / 45.11) RO 2.9 SRO 4.6

Given a set of initial conditions and the EAL Flow Path, the candidate must classify the appropriate Emergency Action Level for the event in progress.

 \bigcirc

Form ES-301-2

Control Room Systems [®] (8 for RO); (7 for SRO-I); (2 or 3 for SRO-U, including 1 ESF - bold) System / JPM Title Type Code* Safety Function a. Perform Control Rod and Rod Position Indicator Exercise per OST-1005 (JPM-CR-256-d) A, N, S 1 b. Respond to the loss of the running CSIP (JPM-CR-038-a) A, D, S 2 K/A ADE 022 AA1.01 A, D, S 2 c. Pressurizer Pressure Master Controller Failure (AOP-019) (JPM-CR-252-a) A, P, S 3 K/A APE 027 AA1.03 A, P, S 3 4 d. Loss of Power to the TDAFW Pump control system (E-0 and OP-137) (JPM-CR-281-a) A, EN, L, N, S 4S (JPM CR-281-a) K/A 022 AA.01 D, EN, L, S 5 f. Restore Off-site Power to an Emergency Bus (OP-156.02) (JPM CR-280-a) RO Only D, EN, L, S 5 K/A 062 AA.01 Sactuation. (OP-169) N, S 7 g. Restore on Excore NI Channel to service (at power, NI failed low) (OWP-RP-25) (JPM CR-28-a) N, S 7 h. Align CCW to Support RHR System (OP-145) (JPM CR-28-a) D, L, S 8	Facility Exam	r: <u>Harris Nuclear Plant</u> Date Level: RO SRO-I SRO-U (bold) Operating	of Examination: g Test No.: <u>05000</u> 4	09/09/2013 100/2013301							
System / JPM TitleType Code*Safety Functiona.Perform Control Rod and Rod Position Indicator Exercise per OST-1005 (JPM-CR-256-d) K/A 001 A2.11A, N, S1b.Respond to the loss of the running CSIP (JPM-CR-038-a) K/A APE 022 AA1.01A, D, S2c.Pressurizer Pressure Master Controller Failure (AOP-019) (JPM-CR-252-a) K/A APE 027 AA1.03A, P, S3d.Loss of Power to the TDAFW Pump control system (E-0 and OP-137) (JPM-CR-251-a) K/A 054 AA2.04A, EN, L, N, S4Se.Return the Containment Fan Coolers to normal following an SI actuation. (OP-169) (JPM CR-260-a) RO Only K/A 022 A4.01D, EN, L, S5f.Restore Off-site Power to an Emergency Bus (OP-156.02) (JPM-CR-27-b) K/A 062 A4.01A, D, EN, S69.Restore off-site Power to an Emergency Bus (OP-156.02) (JPM-CR-27-a) K/A 062 A4.01N, S7h.Align CCW to Support RHR System (OP-145) (JPM CR-085-a) K/A 008 A4.01D, L, S8	Contro	Control Room Systems [@] (8 for RO); (7 for SRO-I); (2 or 3 for SRO-U, including 1 ESF - bold)									
a. Perform Control Rod and Rod Position Indicator Exercise per OST-1005 (JPM-CR-256-d) (JPM-CR-256-d) (JPM-CR-038-a) (JPM-CR-038-a) (JPM-CR-038-a) (JPM-CR-038-a) (JPM-CR-252-a) (JPM-CR-252-a) (JPM-CR-252-a) (JPM-CR-252-a) (JPM-CR-252-a) (JPM-CR-252-a) (JPM-CR-252-a) (JPM-CR-281-a) (JPM-CR-280-a) RO Only (JPM-CR-260-a) RO Only (JPM-CR-260-a) RO Only (JPM-CR-27-b) (J		System / JPM Title	Type Code*	Safety Function							
K/A 001 A2.11A. D. Sb.Respond to the loss of the running CSIP (JPM-CR-038-a) (JPM-CR-038-a)A. D. S2c.Pressurizer Pressure Master Controller Failure (AOP-019) (JPM-CR-252-a) 	a.	Perform Control Rod and Rod Position Indicator Exercise per OST-1005 (JPM-CR-256-d)	A, N, S	1.							
b. Respond to the loss of the running CSIP (JPM-CR-038-a) A, D, S 2 K/A APE 022 AA1.01 A, D, S 2 c. Pressurizer Pressure Master Controller Failure (AOP-019) (JPM-CR-252-a) A, P, S 3 d. Loss of Power to the TDAFW Pump control system (E-0 and OP-137) (JPM-CR-281-a) A, EN, L, N, S 4S K/A 054 AA2.04 P. D, EN, L, S 5 e. Return the Containment Fan Coolers to normal following an SI actuation. (OP-169) D, EN, L, S 5 (JPM-CR-260-a) RO Only K/A 022 A4.01 D, EN, L, S 5 f. Restore Off-site Power to an Emergency Bus (OP-156.02) (JPM-CR-027-b) A, D, EN, S 6 %/A 062 A4.01 Service (at power, NI failed low) (OWP-RP-25) (JPM-CR-278-a) N, S 7 h. Align CCW to Support RHR System (OP-145) (JPM CR-085-a) D, L, S 8		K/A 001 A2.11									
K/A APE 022 AA1.01A, D, S2c.Pressurizer Pressure Master Controller Failure (AOP-019) (JPM-CR-252-a) K/A APE 027 AA1.03A, P, S3d.Loss of Power to the TDAFW Pump control system (E-0 and OP-137) (JPM-CR-281-a) K/A 054 AA2.04A, EN, L, N, S4Se.Return the Containment Fan Coolers to normal following an SI actuation. (OP-169) (JPM CR-260-a) RO Only K/A 022 A4.01D, EN, L, S5f.Restore Off-site Power to an Emergency Bus (OP-156.02) (JPM-CR-027-b) K/A 062 A4.01A, D, EN, S69.Restore an Excore NI Channel to service (at power, NI failed low) (OWP-RP-25) (JPM-CR-278-a) K/A 015 A4.03N, S7h.Align CCW to Support RHR System (OP-145) (JPM CR-085-a) K/A 008 A4.01D, L, S8	b.	Respond to the loss of the running CSIP (JPM-CR-038-a)									
c.Pressurizer Pressure Master Controller Failure (AOP-019) (JPM-CR-252-a) <i>K/A APE 027 AA1.03</i> A, P, S3d.Loss of Power to the TDAFW Pump control system (E-0 and OP-137) 		K/A APE 022 AA1.01	A, D, S	2							
K/A APE 027 AA1.03Ad.Loss of Power to the TDAFW Pump control system (E-0 and OP-137) (JPM-CR-281-a) K/A 054 AA2.04A, EN, L, N, S4Se.Return the Containment Fan Coolers to normal following an SI actuation. (OP-169) (JPM CR-260-a) RO Only K/A 022 A4.01D, EN, L, S5f.Restore Off-site Power to an Emergency Bus (OP-156.02) (JPM-CR-027-b) K/A 062 A4.01A, D, EN, S6g.Restore an Excore NI Channel to service (at power, NI failed low) (OWP-RP-25) (JPM-CR-278-a) K/A 015 A4.03N, S7h.Align CCW to Support RHR System (OP-145) (JPM CR-085-a) K/A 008 A4.01D, L, S8	c.	Pressurizer Pressure Master Controller Failure (AOP-019) (JPM-CR-252-a)	A, P, S	3							
d.Loss of Power to the TDAFW Pump control system (E-0 and OP-137) (JPM-CR-281-a) K/A 054 AA2.04A, EN, L, N, S4Se.Return the Containment Fan Coolers to normal following an 		K/A APE 027 AA1.03									
K/A 054 AA2.04Image: Constraint of the containment Fan Coolers to normal following an SI actuation. (OP-169) (JPM CR-260-a) RO Only (JPM CR-260-a) RO Only (JPM-CR-027-b) (JPM-CR-027-b)D, EN, L, S5f.Restore Off-site Power to an Emergency Bus (OP-156.02) (JPM-CR-027-b) (K/A 062 A4.01A, D, EN, S69.Restore an Excore NI Channel to service (at power, NI failed low) (OWP-RP-25) (JPM-CR-278-a) (K/A 015 A4.03N, S7h.Align CCW to Support RHR System (OP-145) (JPM CR-085-a) K/A 008 A4.01D, L, S8	d.	Loss of Power to the TDAFW Pump control system (E-0 and OP-137) (JPM-CR-281-a)	A, EN, L, N, S	4S _							
e.Return the Containment Fan Coolers to normal following an SI actuation. (OP-169) (JPM CR-260-a) RO Only <i>K/A 022 A4.01</i> D, EN, L, S5f.Restore Off-site Power to an Emergency Bus (OP-156.02) (JPM-CR-027-b) <i>K/A 062 A4.01</i> A, D, EN, S6g.Restore an Excore NI Channel to service (at power, NI failed low) (OWP-RP-25) 		K/A 054 AA2.04									
(JPM CR-260-a) RO Only K/A 022 A4.01D, EN, L, S5f.Restore Off-site Power to an Emergency Bus (OP-156.02) (JPM-CR-027-b) K/A 062 A4.01A, D, EN, S6g.Restore an Excore NI Channel to service (at power, NI failed low) (OWP-RP-25) (JPM-CR-278-a) K/A 015 A4.03N, S7h.Align CCW to Support RHR System (OP-145) (JPM CR-085-a) K/A 008 A4.01D, L, S8	e.	Return the Containment Fan Coolers to normal following an SI actuation. (OP-169)									
K/A 022 A4.01Af.Restore Off-site Power to an Emergency Bus (OP-156.02) (JPM-CR-027-b) K/A 062 A4.01A, D, EN, S6g.Restore an Excore NI Channel to service (at power, NI failed low) (OWP-RP-25) (JPM-CR-278-a) K/A 015 A4.03N, S7h.Align CCW to Support RHR System (OP-145) (JPM CR-085-a) K/A 008 A4.01D, L, S8		(JPM CR-260-a) RO Only	D, EN, L, S	5							
f.Restore Off-site Power to an Emergency Bus (OP-156.02) (JPM-CR-027-b) K/A 062 A4.01A, D, EN, S6g.Restore an Excore NI Channel to service (at power, NI failed low) (OWP-RP-25) (JPM-CR-278-a) K/A 015 A4.03N, S7h.Align CCW to Support RHR System (OP-145) (JPM CR-085-a) K/A 008 A4.01D, L, S8		K/A 022 A4.01									
K/A 062 A4.01g.Restore an Excore NI Channel to service (at power, NI failed low) (OWP-RP-25) (JPM-CR-278-a) K/A 015 A4.03N, Sh.Align CCW to Support RHR System (OP-145) (JPM CR-085-a) K/A 008 A4.01D, L, S	f.	Restore Off-site Power to an Emergency Bus (OP-156.02) (JPM-CR-027-b)	A, D, EN, S	6							
g.Restore an Excore NI Channel to service (at power, NI failed low) (OWP-RP-25) (JPM-CR-278-a)N, S7K/A 015 A4.03K/A 015 A4.03N, S7h.Align CCW to Support RHR System (OP-145) (JPM CR-085-a) 		K/A 062 A4.01									
K/A 015 A4.03 D, L, S h. Align CCW to Support RHR System (OP-145) (JPM CR-085-a) <i>K/A 008 A4.01</i> D, L, S 8	g.	Restore an Excore NI Channel to service (at power, NI failed low) (OWP-RP-25) (JPM-CR-278-a)	N, S	7							
h. Align CCW to Support RHR System (OP-145) (JPM CR-085-a) D, L, S 8 K/A 008 A4.01 D, L, S 8		K/A 015 A4.03									
K/A 008 A4.01 D, L, S 8	h.	Align CCW to Support RHR System (OP-145) (JPM CR-085-a)									
		K/A 008 A4.01	D, L, S	8							

1 Mil 13/13

03/25/2013 Rev. 0

In-Plai	nt Systems [@] (3 for RO); (3 for SRO-I); (2 or :	3 for SRO-U - BOLI	D)				
i.	Place the ASI System in Standby Alignment (OP-185) (JPM-IP-277-a) <i>K/A 004 A4.11</i>		L, N, R	2			
j.	Local Inspection of Annunciator Cabinets (/ (JPM IP-273-a) <i>K/A 016 A2.02</i>	D, E	7				
k.	Perform an Instrument Air System Leak (Turbine Bldg / Yard) (JPM-IP-161-a) <i>K/A APE 065 AA2.03</i>	D, E, L	8				
@	@ All RO and SRO-I control room (and in-plant) systems must be different and serve different safety functions; all 5 SRO-U systems must serve different safety functions; in-plant systems and functions may overlap those tested in the control room.						
	* Type Codes	or RO / SRO-I / SF	રΟ- U				
 (A)Iternate path (C)ontrol room (D)irect from bank (E)mergency or abnormal in-plant (EN)gineered safety feature (L)ow-Power / Shutdown (N)ew or (M)odified from bank including 1(A) (P)revious 2 exams (R)CA (S)imulator 		4-6 / 4-6 / 2-3 ≤ 9 / ≤ 8 / ≤ 4 ≥ 1 / ≥ 1 / ≥ 1 - / - / ≥1; ≥ 1 / ≥ 1 / ≥ 1 ≥ 2 / ≥ 2 / ≥ 1 ≤ 3 / ≤ 3 / ≤ 2 ≥ 1 / ≥ 1 / ≥ 1	(5, 5, 3) $(7, 6, 2)$ $(2, 2, 1)$ $(3, 2, 2)$ $(5, 4, 3)$ $(4, 4, 3)$ $(1, 1, 1)$ $(1, 1, 1)$				

(

در

,

<u>JPM a</u> – Perform Control Rod and Rod Position Indicator Exercise per OST-1005 (JPM-CR-256-d) SRO Upgrade NEW

K/A 001 A2.11 – Ability to (a) predict the impacts of the following malfunction or operations on the CRDSand (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those malfunctions or operations: Situations requiring a reactor trip (CFR: 41.5/43.5/45.3/45.13) RO 4.4 / SRO 4.7

The candidate will assume the watch with the unit operating at 100% power and will be directed to perform OST-1005 commencing with Control Bank D in section 7.2. The candidate will insert and withdraw Control Bank D 10 steps as required. The candidate will continue OST-1005 and select the next Control Bank and insert the Control Bank 10 steps as required. Once the candidate begins to insert the next selected Control Bank, the Alternate Path will begin and a malfunction of the rod control system will result in the Control Rods continuing to insert once the demand for rod motion has stopped. This will cause RCS Tavg, and Reactor Power will lower in response to the control rods inserting and the Control Rod step counter will continue to lower. The candidate should recognize the failure of the rod control system and perform AOP-001 immediate actions to place Rod Control in manual. The candidate may or may not select the manual position. Rod Control is considered to be in manual as long as the Auto position is not selected and being in Control Bank A satisfies this step. Rod motion will continue in either case requiring the candidate to perform the RNO action and initiate a manual reactor trip. The candidate will announce the Reactor is tripped and begin to perform the immediate actions of E-0. Once the candidate announces entry into E-0, evaluation on this JPM is complete.

<u>JPM b</u> – Respond to the loss of the running CSIP (JPM-CR-038-a)

K/A APE 022 AA1.01 - Ability to operate and / or monitor the following as they apply to the Loss of Reactor Coolant Makeup: CVCS letdown and charging (CFR: 41.7 / 45.5 / 45.6) RO 3.4 / SRO 3.3

With the plant at 100% power and the ASI system OOS for planned maintenance the candidate will assume the Operator at the Controls (OAC) responsibilities. The A CSIP will trip requiring the candidate to enter AOP-018. AOP-018 will direct the candidate to isolate letdown in response to the loss of charging flow. While the candidate is assessing letdown, RCP Thermal Barrier Flow Control valve (1CC-252) will shut. Following the isolation of letdown the candidate will evaluate the status of component cooling water to the RCP Thermal Barrier and determine that flow is isolated. The **Alternate Path** of this JPM will begin and the candidate should evaluate Attachment 1 for RCP trip limits and determine trip limit 4 Loss of all RCP seal injection (including ASI) is met due to the loss of EOP-E-0 are complete the candidate will return to AOP-018 to stop all RCPs and shut the PRZ Spray controllers for RCS loops A and B. Once the candidate has stopped all RCPs and shut the PRZ Spray controllers for RCS loops A and B, evaluation on this JPM is complete.

<u>JPM c</u> – Pressurizer Pressure Master Controller Failure (AOP-019) (JPM-CR-252-a) Previous NRC Exam – 2012* randomly selected from bank

K/A APE 027 AA1.03 – Ability to operate and / or monitor the following as they apply to the Pressurizer Pressure Control Malfunctions: Pressure control when on a steam bubble (CFR 41.7 / 45.5 / 45.6) RO 3.6 / SRO 3.5

The candidate will assume the Operator at the Controls (OAC) responsibilities and be directed to maintain current plant conditions of 100% steady state power. Soon after assuming the watch the Pressurizer Pressure Master Controller PK-444B will begin to fail in Automatic to 100%. This will cause BOTH Pressurizer Spray valves to go from full closed to the full open position. The candidate should identify the failure and enter AOP-019. While performing the immediate actions the candidate should complete the **Alternate Path** (Take manual control of the Pressurizer Master Controller and lower the output to close the Pressurizer Spray Valves.) IE the candidate takes manual of control of BOTH Pressurizer Spray valves and NOT PK-444B then the master controller will continue to fail and Pressurizer PORV 444B will go full open. When the RCS pressure is < 2000 psig an auto shut signal will be sent to PORV 444B but by this time the pressure excursion will be so great that it will most likely cause an automatic Reactor Trip on OT∆T and Safety Injection on Low Pressurizer Pressure (at 1850 psig). Once the candidate places the Pressurizer Master Controller is in manual OR both Pressurizer Spray Valves are manually shut AND PORV 444B is shut, evaluation on this JPM is complete.

<u>JPM d</u> – Loss of Power to the TDAFW Pump control system (E-0 and OP-137) (JPM-CR-281-a) SRO Upgrade NEW

K/A APE 054 AA2.04 – Ability to operate and / or monitor the following as they apply to the Loss of Main Feedwater (MFW): Proper operation of AFW pumps and regulating valves (CFR: 43.5 / 45.13) RO 4.2 / SRO 4.3

The candidate is informed that a Small Break LOCA has occurred, subsequently a leak developed in the Condensate Storage Tank (CST) and the CST level has decreased to less than 10%. The candidate is directed to supply ESW from the A Header to both the A AFW Pump and the Turbine Driven AFW pumps. This will require shutting down the 'A' Train of Containment Fan Coolers. ESW will be aligned to the 'A' AFW Pump. While aligning service water to the Turbine Drive AFW Pump the 'Aux Feedwater Pump Turbine Gov Control Power Failure' alarm (ALB-017-7/3) will annunciate. The **Alternate Path** of this JPM will begin, as the TDAFW Pump speed will begin to increase, TDAFW pump flow and pump discharge pressure will increase. These indications will require the candidate to shut the steam supply valves per the alarm response procedure. Once the A AFW Pump is supplied from the ESW system and both TDAFW pump steam supply valves are shut, evaluation on this JPM is complete.

2013 NRC Control Room/In-Plant JPM Summary

<u>JPM e</u> – Return the Containment Fan Coolers to normal following an SI actuation. (OP-169) (JPM CR-260-a) **RO Only**

K/A 026 A4.01 Ability to manually operate and/or monitor in the control room: CCS fans (CFR: 41.7 / 45.5 to 45.8) RO 3.6 / SRO 3.6

The candidate is informed an inadvertent SI initiation has occurred and the control room staff has entered EOP-E-0 and EOP-ES-1.1. Attachment 1 of EOP-ES-1.1 is being performed to realign plant systems. The candidate is directed to realign containment fan coolers IAW Attachment 1 step 6.a using OP-169, Containment Cooling And Ventilation, Section 8.4. The candidate will be directed to align the A Train of CNMT Fan Coolers for normal service. The candidate will secure both A Train CNMT Fan Coolers and verify proper damper alignment for the secured fans. The candidate will restart the A Train Fans per section 5.1 of OP-169. To minimize the starting current required for Hi-Speed operation the fans are initially started in Lo-Speed, then stopped and restarted in Hi-Speed. The candidate will return to section 8.4 to secure the B Train of CNMT Fan Coolers. Once the B Train of CNMT Fan Coolers are in standby and the determination is made that Maximum Cooling Mode is NOT required, evaluation on this JPM is complete.

<u>JPM f</u> – Restore Off-site Power to an Emergency Bus (OP-156.02) (JPM-CR-027-b) SRO Upgrade

K/A 062 A4.01 Ability to manually operate and/or monitor in the control room: All breakers (including available switchyard) (CFR: 41.7 / 45.5 / to 45.8) RO 3.3 / SRO 3.1

The candidate is informed that the plant has tripped due to a LOOP and both EDGs have energized 1A-SA and 1B-SB 6.9kV Emergency Busses. The candidate will be directed by the CRS to restore power to the 1A-SA 6.9kV Emergency Bus IAW OP-156.02, AC Electrical Distribution. The candidate will re-energize the Aux Bus D from Start Up transformer A. With Aux Bus D energized the candidate will close the first Aux Bus D supply breaker to the 1A-SA 6.9kV Emergency Bus. The **Alternate Path** of this JPM will begin after the candidate determines the status of the EDG output breaker. Because the EDG output breaker is shut the candidate must transition to OP-155 to synchronize and transfer the 1A-SA 6.9kV Emergency Bus to offsite power. The candidate will operate the voltage and governor controls to parallel the EDG and offsite power. Once parallel operations have been achieved and the candidate transitions to OP-155 section 7.1 and start to unload the EDG, evaluation on this JPM is complete.

2013 NRC Control Room/In-Plant JPM Summary

JPM g – Restore an Excore NI Channel to service (at power, NI failed) (OWP-RP-25) (JPM-CR-278-a)

NEW

K/A 015 A4.03 – Ability to manually operate and/or monitor in the control room: Trip bypasses (CFR: 41.7 / 45.5 to 45.8) RO 3.8 / SRO 3.9

New JPM to restore previously repaired failed NI-43 to service.

The candidate will assume the watch with the plant at 100% steady state power and the PRNI channel NI-43 which failed downscale earlier repaired. The candidate will be required to return NI-43 to service IAW OWP-RP-25. OWP-RP-25 ensures the components that have NI-43 as an input, Rod Control and SG Feedwater regulating bypass valves are in manual control to prevent spurious movement or uncontrolled changes in level. The candidate will verify the controllers are in manual. The OWP will require the candidate to contact maintenance (I&C personnel) to return the two previously trip bistables for the Channel III OT Δ T signals to normal in the Process Instrument Cabinet 3 (PIC-3). The candidate will return the following items to NORMAL

- At the Detector Current Comparator Drawer: Both upper and lower sections of NI-43
- At the Comparator and Rate Drawer: Comparator Channel Defeat switch

The candidate will return the following items to OPERATE

• At the Miscellaneous Control and Indication Panel: Power Mismatch Bypass switch and the Rod Stop Bypass switch.

The candidate will have to contact maintenance (I&C personnel) a second time and direct them to re-connect the NI-43 power supply leads to the NI drawer. After the I&C personnel re-connect the NI-43 power supply leads, the candidate will verify proper bi-stable and annunciator configuration for the restoration of NI-43 to service. Finally the candidate will have to restore the plant computer (ERFIS) point to processing and document the position of MCB components for the current plant conditions with NI-43. Once the candidate reports that OWP-RP-25 is complete to the CRS, evaluation on this JPM is complete.

<u>JPM h</u> – Align CCW to Support RHR System (OP-145) (JPM CR-085-a)

K/A 008 A4.10 Ability to manually operate and/or monitor in the control room: Conditions that require the operation of two CCW coolers (CFR: 41.7 / 45.5) RO 3.3 / SRO 3.1

The plant is in Mode 4 and a cool down is in progress. The CRS directs the candidate to align CCW to support RHR operation IAW OP-145 section 8.9. After reviewing section 8.9 the candidate determines a second CCW pump is required to be started and transitions to section 5.2. The candidate starts the B CCW pump IAW section 5.2 and returns to section 8.9 and isolates the A train essential header of the CCW from the non essential header. The candidate will align the B train essential header to supply RHR HX B. The candidate will verify both trains of the CCW system operating parameters are within the required band on the MCB indicators. The candidate will contact a non license operator (NLO) to locally verify the CCW flow to the Gross Failed Fuel Detector is within the required band. Once the candidate contacts the NLO to verify CCW flow locally then evaluation on this JPM is complete.

<u>JPM i</u> – Place the ASI System in Standby Alignment (OP-185) (JPM-IP-277-a) SRO Upgrade NEW

K/A 004 A4.11 Ability to manually operate and/or monitor in the control room: RCP Seal injection flow (CFR: 41.7 / 45.5 to 45.8) RO 3.4 / SRO 3.3

NOTE: This JPM is inside the RCA.

The plant is in Mode 4 and a heat up is in progress. The CRS directs the candidate to place the ASI system in automatic standby alignment IAW OP-185 section 5.1. The candidate will verify the ASI supply header isolation valves are open and the status of the ASI system control panel. The candidate will realign the ASI pump to automatic and return the Squib valve bypass control switches to normal alignment on the ASI control panel. The candidate will recheck the indications on the ASI system control panel for the proper standby alignment of the system. Once the candidate proceeds to section 5.1.3, Automatic Standby alignment configuration control closeout then evaluation on this JPM is complete.

<u>JPM j</u> – Local Inspection of Annunciator Cabinets (AOP-037) (JPM IP-273-a)

K/A 016 A2.02 Ability to (a) predict the impacts of the following malfunctions or operations on the NNIS; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those malfunctions or operations: Loss of power supply (CFR: 41.5 / 43.5 / 45.3 / 45.5) RO 2.9 / SRO 3.2

The candidate is informed that the control room annunciator System 2 power failure alarm has been received and the CRS has entered AOP-037. The CRS will direct the candidate to check the status of System 2 annunciator power supplies per AOP-037 Attachment 2. The candidate will perform Attachment 2 and obtain the annunciator cabinet key. The JPM cues include information of the proper status of the power supply light indications. The candidate will initial for the indications that remain lit. The candidate will determine based on the cues that one of the System 2, Bay 1, 12 VDC power supplies, one of the System 2, Bay 3, 12 VDC power supplies and the System 2, Bay 5, 24 VDC power supplies are de-energized. Once the CRS is notified that AOP-037, Attachment 2 is complete and the correct de-energized power supplies have been identified then evaluation on this JPM is complete.

<u>JPM k</u> – Perform an Instrument Air System Leak Isolation Locally (Turbine Bldg / Yard) (AOP-017) (JPM-IP-161-a) SRO Upgrade

K/A APE 065 AA2.03 Ability to determine and interpret the following as they apply to the Loss of Instrument Air: Location and isolation of leaks (CFR: 43.5 / 45.13) RO 2.6 / SRO 2.9

The candidate is informed that the plant was operating at 100% when the plant was tripped due to lowering instrument air pressure. AOP-017 is being performed. The CRS directs the operator to perform Attachment 3 of AOP-017 to reduce instrument air header loads. They will be required to isolate individual sections of the instrument air system within the Turbine Building and contact the Main Control room staff following the completion of each action to determine if the prior actions have successfully isolated the instrument air leak. The JPM cues include information of the proper sequence of actions that must be taken in order reposition the valves and due to the valve locations a description of the nearest ladder location is given to simulate climbing to the valve location. Once notified by the Main Control room that the instrument air header pressure has stabilized then evaluation on this JPM is complete.



Appendix D

 \bigcirc

Scenario Outline

Form ES-D-1

HARRIS 2013 NRC I	Exam SCENARIO 1
-------------------	-----------------

Facility:	SHEARON-H	ARRIS	Scenario No.:	1	Ор Те	est No.:	05000400/2013301	
Examiners:				Operator	s: S	RO:		
					R	:0:		
					В	OP:		
Initial Cond	litions: •	C-5, BOL, 5	55% power					
• F	RHR pump A-SA	is under cle	earance for pur	np seal repl	aceme	nt		
• 1	SI-4, Boron Inje	ction Tank (Outlet valve is u	nder cleara	ance fo	r breaker	repairs	
· 'I	B' Condenser V		n is under eleer	once for m			where the second second	
• (акеир	water sup	ply valve problems	
• E	onc Acia Trans	ier Pump A-	SA IS UNDER Cle	arance for I	motor r	eplacem	ent	
				· · · · · · · · · · · · · · · · · · ·				
Turnover:	• [Plant is at ap GP-005 step	oproximately 55 135.e. After ta	% power. F king shift co	Plant st ontinue	artup is ir plant sta	n progress IAW irtup at 4 DEH Units/mir	
Critical Tas	ks: • I	solate AFW	flow to 'C' Stea	m Generat	or prior	to exiting	g EOP E-2	
	• {	Shut BIT Ou	tlet valve 1SI-3	prior to rea	ching \	water reli	ef from PZR SRV's	
Event No.	Malf. No.	Event Ty	ype*	Event Description				
1	N/A	R – RO/3	SRO Contine	Continue plant startup to 100% power		er		
		N – BOP/	/SRO		`			
2	pt:495	I - BOP/S	SRO Failure	Failure of the 'C' SG Pressure Transmitter PT-495 to 0%		mitter PT-495 to 0%		
3	lt:112	I RO/S	RO VCTI	VCT T-112 fails bigh letdown full divert to PHT (AOP 002)				
4	rms007	1 - BOP/S	SRO Radiati	Padiation Monitor 25024 fails high and als		nd alarma Containment		
	zcr744	TS - SF	RO Purge	Purge fails to isolate automatically (AOP-005)				
5	prs14b	I - RO/S	RO Pressu Contro	Pressurizer Spray Valve, PCV-444D, fails Open (with Manual Control available) (AOP-019)				
6	mss01c	M - A	II Steam	Steam line Break on 'C' SG inside Containment				
7	zrpk617a zrpk617b	I – BOP/	SRO Failure	Failure of Auto AFW Isolation on 'C' SG				
8	nis06b	I – RO/S	SRO SR Nu	SR Nuclear Instruments fail to energize post trip due to IR NI-36 undercompensated				
* (N)c	ormal. (R)eactiv	ity. (I)nstrum	ment (C)ompor	ent (M)ai	nr			
		, (.)						

perid 3 Page 1 of 9

HARRIS 2013 NRC Exam SCENARIO 1

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 1

Turnover provided to the crew is - The plant is operating at ~55% power in BOL. Criticality was achieved 8 hours ago, 74 hours after a trip from 100% power. A plant startup IAW GP-005 is in progress. After initial turbine loading, the load increase has been performed at 4 Units/min. The unit is currently at ~55% power 82 hours post-trip.

A startup has commenced and the crew has been directed to continue the power increase using GP-005, Power Operation Mode 2 to Mode 1, to 100% power at a ramp rate of 4 DEH Units/Minute.

The following equipment is under clearance:

RHR Pump A-SA is under clearance for pump packing repairs. The pump has been inoperable for 12 hours and is expected to be repaired in the next 24 hours. The pump must be restored to operable status within the next 60 hours. Tech Spec 3.5.2 LCO Action a. and Tech Spec 3.3.3.5.b Action c. applies. OWP-RH-01 has been completed.

EMERGENCY CORE COOLING SYSTEMS

3/4.5.2 ECCS SUBSYSTEMS - Terr GREATER THAN OR EQUAL TO 350 °F

LIMITING CONDITION FOR OPERATION

3.5.2 Two independent Emergency Core Cooling System (ECCS) subsystems shall be OPERABLE with each subsystem comprised of:

- a. One OPERABLE Charging/safety injection pump.
- b. One OPERABLE RHR heat exchanger.
- c. One OPERABLE RHR pump, and
- d. An OPERABLE flow path capable of taking suction from the refueling water storage tank on a Safety Injection signal and, upon being manually-aligned, transferring suction to the containment sump during the recirculation phase of operation.

APPLICABILITY: MODES 1, 2, and 3,

ACTION:

a. With one ECCS subsystem inoperable, restore the inoperable subsystem to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.

Ę

HARRIS 2013 NRC Exam SCENARIO 1

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 1 (continued)

Tech Specs associated with inoperable RHR Pump A-SA continued

INSTRUMENTATION

REMOTE SHUTDOWN SYSTEM

LIMITING CONDITION FOR OPERATION

3.3.3.5.a The Remote Shutdown System monitoring instrumentation channels shown in Table 3.3-9 shall be OPERABLE.

3.3.3.5.b All transfer switches, Auxiliary Control Panel Controls and Auxiliary Transfer Panel Controls for the OPERABILITY of those components required by the SHNPP Safe Shutdown Analysis to (1) remove decay heat via auxiliary feedwater flow and steam generator power-operated relief valve flow from steam generators A and 8, (2) control RCS inventory through the normal charging flow path, (3) control RCS pressure, (4) control reactivity, and (5) remove decay heat via the RHR system shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- c. With one or more inoperable Remote Shutdown System transfer switches, power, or control circuits required by 3.3.3.5.b, restore the inoperable switch(s)/circuit(s) to OPERABLE status within 7 days, or be in HOT STANDBY within the next 12 hours.
- 'B' Condenser Vacuum Pump is under clearance for makeup water supply valve problems
- 1SI-4, Boron Injection Tank Outlet valve is under clearance for breaker repairs. Tech Spec 3.5.2 Action **a** applies. OWP-SI-01 has been completed.

EMERGENCY CORE COOLING SYSTEMS

3/4.5.2 ECCS SUBSYSTEMS - Tang GREATER THAN OR EQUAL TO 350°F

LIMITING CONDITION FOR OPERATION

3.5.2 Two independent Emergency Core Cooling System (ECCS) subsystems shall be OPERABLE with each subsystem comprised of:

- a. One OPERABLE Charging/safety injection pump.
- b. One OPERABLE RHR heat exchanger,
- c. One OPERABLE RHR pump, and
- d. An OPERABLE flow path capable of taking suction from the refueling water storage tank on a Safety Injection signal and, upon being manually aligned, transferring suction to the containment sump during the recirculation phase of operation.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

a. With one ECCS subsystem inoperable, restore the inoperable subsystem to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.

• Boron Injection Pump A-SA is under clearance for motor replacement. Tech Spec 3.1.2.2 applies (tracking only). OWP-CS-04 has been completed.



HARRIS 2013 NRC Exam SCENARIO 1

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 1 (continued)

Event 1: Continue plant startup to 100% power - Crew performs a power increase of approximately 5%-10% power (Lead Examiners discretion). For this reactivity manipulation it is expected that the SRO will conduct a reactivity brief, the RO will dilute and monitor auto rod withdrawal per the reactivity plan and the BOP will operate the DEH Controls as necessary to raise Main Turbine power.

Event 2: Failure of the 'C' SG Pressure Transmitter PT-495 to 0%. This event will require the BOP to place the 'C' SG level control to manual and control SG level within Reactor trip limits. The SRO should provide level band and trip guidance IAW OMM-001. The crew will take the channel out of service using OWP-ESF-04, Protection channel III Steam flow. The SRO should evaluate Tech Spec 3.3.1 action 6, Tech Spec 3.3.6 Accident Monitoring Instrumentation Action **a**, and Tech Spec 3.3.2 1.e Steam Line Press Low Action 19 applies.

T.S. 3.3.1: As a minimum, the Reactor Trip System instrumentation channels and interlocks of Table 3.3-1 shall be OPERABLE

REACTOR TRIP SYSTEM INSTRUMENTATION

FUNC	FIONAL UNIT	TOTAL NO. <u>OF_CHANNELS</u>	CHANNELS TO_TRIP	MINIMUM CHANNELS <u>OPERABLE</u>	APPLICABLE MODES	ACTION		
14.	Steam Generator Water LevelLow Coincident With Steam/ Feedwater Flow Mismatch	2 stm. gen, level and 2 stm./feed- water flow mismatch in each stm. gen.	l stm. gen. level coincident with 1 stm./feedwater flow mismatch in same stm. gen.	l stm. gen. level and 2 stm./feed- water flow mismatch in same stm. gen. or 2 stm. gen. level and 1 stm./feedwater flow mismatch in same stm. gen.	1, 2	6		
	ACTION 6 - With the Number of provided	number of OPE f Channels, ST the following	RABLE channels ARTUP and/or P(conditions ar	one less than DWER OPERATION e satisfied:	the Total may proceed			
	a. The with	a. The inoperable channel is placed in the tripped condition within 6 hours, and						
	b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.3.1.1.							
TS 3. OPEI	3.3.6 The Accident Monitor RABLE	ing instrumenta	ation channels	shown in Table	3.3-10 shall	be		

 ACTION a. - With the number of OPERABLE accident monitoring instrumentation channels except In Core Thermocouples and Reactor Vessel Level less than the Total Required Number of Channels requirements shown in Table 3.3-10 restore the inoperable channel(s) to OPERABLE status within 7 days. or be in at least HOT STANDBY within the next 6 hours and in at least HOT SHUTDOWN within the following 6 hours.

Page 4 of 9
SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 1 (continued)

Tech Spec 3.3.2

INSTRUMENTATION

3/4.3.2 ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.2 The Engineered Safety Features Actuation System.(ESFAS) instrumentation channels and interlocks shown in Table 3.3-3 shall be OPERABLE with their Trip Setpoints set consistent with the values shown in the Trip Setpoint column of Table 3.3-4.

APPLICABILITY: As shown in Table 3.3-3.

TABLE 3.3-3

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT 1. Safety Injection (Rea Feedwater Isolation, - Isolation, Start Dres Generators, Containme Ventilation Isolation Containment Isolation Auxiliary Feedwater S, Motor-Oriven Pumps, S Containment Fan Coole Emergency Service Wat Start Emergency Service Booster Pumps)	TOTAL NO <u>OF CHARNELS</u> ctor Trip. Control Room el nt , Phase A , Start ystem tart rs. Start er Pumps. ce Water	CHANNELS TO_TRIP_	MINIMUM CHANNELS <u>OPERABLE</u>	APPLICABLE MODES	<u>ACTION</u>
e. Steam Line Pressure	-Low 3/steam Tine	2/steam line in any steam line	2/steam line	1. 2. 3≇	19
ACTION 19 - With the n Number of conditions	umber of OPERABLE channels Channels, operation may pro- are satisfied:	one less tha oceed provide	n the Total d the followi	ng	
a. The ir withir	noperable channel is placed 1 6 hours, and	l in the tripp	ed condition		
b. The Mi the ir for su Specif	Inimum Channels OPERABLE re operable channel may be by irveillance testing of othe fication 4.3.2.1.	quirement is passed for up r channels pe	met: however, to 4 hours er		

The SRO should also prepare OMM-001, Attachment 5 Equipment Problem Checklist for the failure.

Page 5 of 9

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 1 (continued)

Event 3: LT-112 fails HIGH – full divert to RHT. Enter AOP-003. This will require entry into AOP-003, Malfunction of Reactor Makeup Control (no immediate actions). A failure of LT-112 high will cause 1CS-120, Letdown VCT/Hold Up Tank valve to shift to the Hold Up Tank. The RO will have to return the MCB switch to the VCT position. Since VCT level has failed HIGH auto CSIP suction switch over on 5% VCT level to the RWST will not occur until Maintenance has lifted the leads associated with LT-112. The operator will have to monitor VCT level and communicate with Maintenance to resolve this failure.

The SRO should also prepare OMM-001, Attachment 5 Equipment Problem Checklist for the failure.

Event 4: Radiation Monitor 3502A high alarm, Containment Purge fails to isolate automatically. This failure will cause the radiation monitor output to immediately fail high and RM-11 to go into High Alarm. The automatic response to isolate Normal Containment Purge fails to occur due to a failed relay. The crew should respond to the alarms and enter AOP-005, Radiation Monitoring (no immediate actions). AOP-005 Attachment 1 will direct verifying that the automatic response for this alarm has occurred (other procedure options are available and detailed in exercise guide). This will also require the SRO to evaluate Tech Spec 3.3.2 for the failed Containment Isolation and Tech Spec 3.4.6.1, Leakage Detection Systems.

Tech Spec 3.4.6.1, Leakage Detection Systems, Action a

REACTOR COOLANT SYSTEM

3/4.4.6 REACTOR COOLANT SYSTEM LEAKAGE

LEAKAGE DETECTION SYSTEMS

LIMITING CONDITION FOR OPERATION

 $3.4.6.1\,$ The following Reactor Coolant System Leakage Detection Systems shall be <code>OPERABLE</code>:

- a. The Containment Airborne Gaseous Radioactivity Monitoring System,
- b. The Reactor Cavity Sump Level and Flow Monitoring System, and
 c. The Containment Airborne Particulate Radinactivity Monitoring
 - The Containment Airborne Particulate Radioactivity Monitoring System.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

a. With a. or c. of the above required Leakage Detection Systems INOPERABLE. operation may continue for up to 30 days provided grab samples of the containment atmosphere are obtained and analyzed for airborne gaseous and particulate radioactivity at least once per 24 hours when the required Airborne Gaseous or Particulate Radioactivity Monitoring System is inoperable: otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

Page 6 of 9

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 1 (continued)

Tech Spec 3.3.3.1 - Table 3.3-6 item 1.b.1) Airborne Gaseous Radioactivity – RCS leakage Detection Actions 26 and 27

RADIATION MONITORING INSTRUMENTATION FOR PLANT OPERATIONS

	ACTION 27 - With less operation and exhau	s than t n may co 1st isol	he Minimu ntinue pr ation val	um Channels OPE covided the con	RABLE requirement tainment purge	nt, makeup
	ACTION 26 - Must sati	Lsfy the	ACTION 1	equirement for	Specification	3.4.6.1.
	1) RCS Leakage Detection 2) Pre-entry Purge	1 1	1 1	1, 2, 3, 4 ##	$\leq 1.0 \times 10^{-3} \mu \text{Ci/m}$ $\leq 2.0 \times 10^{-3} \mu \text{Ci/m}$	26. 27 30
	b. Airborne Gaseous Radioactivi	tv				
<u>INS</u> 1.	<u>TRUMENT</u> Containment Radioactivity	CHANNELS TO_TRIP	MINIMUM CHANNELS <u>OPERABLE</u>	APPLICABLE MODES	ALARM/TRIP SETPOINT	ACTION

The SRO should also prepare OMM-001, Attachment 5 Equipment Problem Checklist for the failure.

Event 5: Pressurizer Spray Valve, PCV-444D, fails to maximum output in Auto (with manual control available). This failure will cause one of the Pressurizer spray valve to fail to 100% open while the other valve closes to 0% open. The crew should respond to multiple alarms and enter AOP-019, Malfunction of RCS Pressure Control. The RO should complete the immediate actions by gaining control of the Pressurizer Spray Valves. If RCS pressure decreases to < 2202 psig during the event the SRO will have to evaluate Tech Spec 3.2.5

POWER DISTRIBUTION LIMITS

3/4.2.5 DNB PARAMETERS

LIMITING CONDITION FOR OPERATION

3.2.5 The following DNB-related parameters shall be maintained within the following limits:

- a. Reactor Coolant System $T_{avg} \le 594.8^\circ F$ after addition for instrument uncertainty, and
- b. Pressurizer Pressure $\gtrsim 2185~{\rm psig}^*$ after subtraction for instrument uncertainty, and
- c. RCS total flow rate $\geq 293.540~\text{gpm}$ after subtraction for instrument uncertainty.

APPLICABILITY: MODE 1.

<u>ACTION</u>:

With any of the above parameters not within its specified limit, restore the parameter to within its limit within 2 hours or reduce THERMAL POWER to less than 5% of RATED THERMAL POWER within the next 6 hours.

The SRO should also prepare OMM-001, Attachment 5 Equipment Problem Checklist for the failure.

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 1 (continued)

Event 6: MAJOR – Steam line Break on 'C' SG inside Containment. Once RCS pressure control has been established to the satisfaction of the Lead Examiner a Steam Line Break inside Containment on the 'C' SG will occur. The crew should enter and carry out the immediate actions of EOP E-0.

The crew should diagnose that a LOCA is NOT in progress and transition from EOP E-0 to EOP E-2, Faulted Steam Generator Isolation.

While the crew is performing actions of E-2 the Containment pressure will continue to rise beyond 10 psig which will actuate a Containment isolation Phase B signal and require ALL RCPs to be secured.

Event 7: Failure of Auto AFW Isolation on 'C' SG. The crew should identify that an actuation signal for AFW Auto Isolation has failed on the 'C' SG and manually isolate AFW flow to the 'C' SG.

Event 8: Source Range channels will fail to energize post trip due to IR NI-36 under compensation. The crew will need to identify the failure of the SR instrumentation MCB indication and audible counts. They will then manually energize the SR channels to establish an audio count rate.

The scenario is ended when Safety Injection has been terminated and the crew transitions to EOP-ES-1.1, SI Termination.

Page 8 of 9

CRITICAL TASK JUSTIFICATION:

1. Isolate AFW flow to 'C' Steam Generator prior to exiting EOP E-2.

Failure to isolate a faulted Steam Generator that can be isolated causes challenges to the Critical Safety Functions beyond those irreparably introduced by the postulated conditions. Also, depending upon the plant conditions, it could constitute a demonstrated inability by the crew to recognize a failure of the automatic actuation of an ESF system or component. This critical task requires the crew to recognize an automatic actuation should have occurred of an ESF system or component but has not and then take manual operator actions to perform the isolation.

2. Shutting BIT outlet valves 1SI-3 prior to water relief through the PZR Safety Relief Valves (SRV's).

FSAR Section 15.1.5.2 (page 15.1.5-7) states the operator will secure one of the two CSIPs to facilitate PZR level indication remaining on scale and controllable. Additionally, shutting the BIT outlet valves is the first steps in realigning normal charging to the RCS. Continued flow through the BIT will cause the PZR level to reach solid conditions potentially causing the SRV's to lift. At low fluid temperature (like those present in the PZR at this time) the SRV's may not reset after fluid operation. This operator action is critical to prevent a challenge to plant safety



Appendix D

Scenario Outline

Form ES-D-1

HARRIS 2013 NRC SCENARIO 2

Facility:	SHEARON-I	HARRIS	Scen	ario No.:	2	Op	o Test No.:	05000400/2013301
Examiners					Operato	ors:	SRO:	
							RO:	
							BOP:	
Initial Cond	litions: • IC	-26, MOL,	~88% p	ower				
٠	RHR pump A-S	A is under	clearan	ce for pu	mp seal	repla	acement	
•	1SI-4, Boron Inj	ection Tan	k Outlet	valve is	under cl	eara	nce for brea	ker repairs
•	'B' Condenser V	/acuum Pu	mp is u	nder clea	rance fo	or ma	keup water	supply valve problems
•	Boric Acid Trans	sfer Pump	A-SA is	under cle	earance	for n	notor replace	ement
	the ex col Mo col pla ha	e A RHR p piring. Th mplete con ode 3 within mpleted. 3 an. Contro ve been m	oump. F e plant i itinue the n the ne. 300 gallo I Bank D ade to ir	s operating operating operating (xt 6 hours) (xt 6 hours)	nil not be reductio s. GP-0 ric acid l ave just s concer	e abl 8% µ n at 4 006 is have stepp rning	e to be comp power in MO 4 DEH units/ s currently in been injecte ped IN. All r the reason f	Deted prior to the LCO L. When turnover is min to support being in progress with step 8 ed IAW the reactivity equired notifications for the shutdown.
Critical Tas	ks: • Ins be • Tri	sert negativ fore compl p RCPs or	ve reacti eting the ice RCP	vity into t e immedia ? Trip Fole	he core ate actic dout Cri	by ir on ste teria	nserting cont eps of FR-S. is met and p	rol rods during an ATWS 1 prior to exiting E-1
Event No.	Malf. No.	Event 1	ype*		E	Event	Description	
1	N/A	R – RO N – BOF	/SRO P/SRO	Continue	e plant sl	nutdo	wn at 4 DEH	Units/min
2	crf14b	C – RO.	/SRO	Rods fai up for A	l to opera TWS) En	ate ir iter A	n AUTO (man OP-001	ual control works- setting
3	ft:497	I – BOP TS- S	/SRO RO	Feed flo for 1C S	w transm G) fails l	nitter (ow –	on 'C' SG FT- OMM-001	497 Channel IV (selected
4	idi xd1i142 ilo xd1o142w ian xn27e05	C - BOP	/SRO	Reactor	Primary	Shiel	d Fan S2-A-S	A Failure
5	cvc05a	C - RO/ TS-SI	SRO RO	CSIP Tri ASI Pum	ip - 1 ava np start /	ailable Resp	e, requiring AC	DP-018 entry addition to RCS from ASI
6	N/A	N - RO/	SRO	Restore	letdown	IAW	OP-107	
7	rcs18b	R – RO N – BOF	/SRO P/SRO	~30 gpm ramp rat	n RCS le le IAW A	ak to OP-0	Containment. 38	Enter AOP-016 increase
8	rcs18b rps01b	M – A ATV	ILL /S	RCS lea Trip with manual	kage exc ATWS I	ceeds React	VCT makeup or Trip Break	o capability E-0 manual Rx ers fail to open in auto or

nee-sli Page 1 of 9

SCENARIO 2 continued

Event No.	Malf. No.	Event Type*	Event Description
9	rcs18b	M – ALL	RCS leakage increases to SBLOCA ~650 gpm
10	zdsq2:6b jpb9101b	C – RO/SRO	'B' ESW pump fails to auto start from the Sequencer or from low pressure
* (N)c	ormal, (R)eactivity,	(l)nstrument, ((C)omponent, (M)ajor

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 2

Turnover provided to the crew is – A shutdown is in progress due to problems encountered during the repairs on the 'A' RHR pump. Repairs will not be able to be completed prior to the LCO expiring. The plant is operating at ~88% power in MOL. Control Bank D is at 200 steps. The latest RCS Boron sample was 1067 ppm. GP-006 step 9 is in progress. When turnover is complete continue the power reduction at 4 DEH units/min to support being in Mode 3 within the next 6 hours. All required notifications have been made to individuals concerning the reason for the shutdown.

The following equipment is under clearance:

• RHR Pump A-SA is under clearance for pump packing repairs. The pump has been inoperable for 12 hours and must be restored to operable status within the next 60 hours. Tech Spec 3.5.2 LCO Action **a** and Tech Spec 3.3.3.5.b Action **c** applies. OWP-RH-01 has been completed.

EMERGENCY CORE COOLING SYSTEMS 3/4.5.2 ECCS SUBSYSTEMS - T_{erp} GREATER THAN OR EQUAL TO 350°F

LIMITING CONDITION FOR OPERATION

 $3.5.2\,$ Two independent Emergency Core Cooling System (ECCS) subsystems shall be OPERABLE with each subsystem comprised of:

- a. One OPERABLE Charging/safety injection pump.
- b. One OPERABLE RHR heat exchanger.
- c. One OPERABLE RHR pump, and
- d. An CPERABLE flow path capable of taking suction from the refueling water storage tank on a Safety Injection signal and, upon being manually aligned, transferring suction to the containment sump during the recirculation phase of operation.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

a. With one ECCS subsystem inoperable, restore the inoperable subsystem to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.



Page 3 of 9

HARRIS 2013 NRC SCENARIO 2

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 2 (continued)

Tech Specs associated with inoperable RHR Pump A-SA continued

INSTRUMENTATION

RENOTE SHUTDOWN SYSTEM

LINITING CONDITION FOR OPERATION

3.3.3.5.b All transfer switches, Auxiliary Control Panel Controls and Auxiliary Transfer Panel Controls for the OPERABILITY of those components required by the SHNPP Safe Shutdown Analysis to (1) remove decay heat via auxiliary feedwater flow and steam generator power-operated relief valve flow from steam generators A and 8, (2) control RCS inventory through the normal charging flow path, (3) control RCS pressure, (4) control reactivity, and (5) remove decay heat via the RHR system shall be OPERABLE.

ŧ

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- C. With one or more inoperable Remate Shutdown System transfer switches, power, or control circuits required by 3.3.3.5.b, restore the inoperable switch(s)/circuit(s) to OPERABLE status within 7 days, or be in HOT STANDBY within the next 12 hours.
- 'B' Condenser Vacuum Pump is under clearance for makeup water supply valve problems
- 1SI-4, Boron Injection Tank Outlet valve is under clearance for breaker repairs. Tech Spec 3.5.2 Action **a** applies. OWP-SI-01 has been completed.

EHERGENCY CORE COOLING SYSTEMS

3/4.5.2 ECCS SUBSYSTERS - T GREATER THAN OR EQUAL TO 350 F

LIMITING CONDITION FOR OPERATION

3.5.2 . Two independent Emergency Core Cocling System (ECCS) subsystems shall be OPERABLE with each subsystem comprised of:

- a. Cne OPERABLE Charging/safety injection pump.
- b. Cne OPERABLE RHR heat exchanger,
- c. Cne OPERABLE RHR pump, and
- d. An DPERABLE flow path capable of taking suction from the refueling water storage tank on a Safety Injection signal and, upon being manually aligned, transferring suction to the containment sump during the recirculation phase of operation.

APPLICABILITY: MODES 1, 2, and 3.

<u>ACTION:</u>

- a. With one EUCS subsystem inoperable, restore the inoperable subsystem to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 5 hours.
- Boron Injection Pump A-SA is under clearance for motor replacement. Tech Spec 3.1.2.2 applies (tracking only). OWP-CS-04 has been completed.

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 2 continued

Event 1: Continue plant shutdown at 4 DEH Units/min - Crew performs a power decrease of approximately 5%-10% power (Lead Examiners discretion). For this reactivity manipulation it is expected that the SRO will conduct a reactivity brief, the RO will borate and monitor auto rod insertion per the reactivity plan and the BOP will operate the DEH Controls as necessary to reduce Main Turbine load.

Event 2: Rods do not move in AUTO (manual control works- setting up for ATWS) Enter AOP-001. During the downpower the rod control system will fail to operate in AUTO and the crew will be required to enter AOP-001, Malfunction of Rod Control and Indication System. The crew must take immediate actions and place rods in MANUAL. The SRO will have a TS check of 3.1.3.1, 3.1.3.5 and determine that all rods are trippable per Attachment 5 of AOP-001. System Engineering will be contacted. The crew will be expected to continue with the power reduction. If necessary, to get the crew moving, prompting by the Manager of Operations can be used.

TS 3.1.3.1 All shutdown and control rods shall be OPERABLE and positioned within + 12 steps (indicated position) of their group step counter demand position.

Applicability: Modes 1 and 2

TS 3.1.3.4 All shutdown rods shall be fully withdrawn as specified in the CORE OPERATING LIMITS REPORT (COLR), plant procedure PLP-106.

Applicability: Modes 1 and 2

AOP-001 Attachment 5

 MALFUNCTION OF ROD CONTROL AND INDICATION SYSTEM

 Attachment 5 - Determination of Control Rod Trippability Sheet 1 of 1

 The following guidance is provided for making the determination of control rod trippability: A control rod may be considered trippable under any of the following circumstances:

 • Rod Control System URGENT FAILURE alarm exists

 • Inspection of the affected system cabinets reveals obvious electrical problems (for example, blown fuses)

 • All rods of a particular group or bank are simultaneously affected

 • NO control rod motion is possible

 If none of the four conditions exist the rod must be considered untrippable until proven otherwise.

Page 4 of 9

HARRIS 2013 NRC SCENARIO 2

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 2 continued

Event 3: Feed flow transmitter on 'C' SG FT-497 Channel IV (selected for 1C SG) fails low – OMM-001. When the plant is in a stable condition, the Lead Evaluator can cue the SG 'C' Feed Flow channel failure. The crew should respond in accordance with the alarm response procedure and OMM-001. The BOP will be controlling SG 'C' level with the FRV in MANUAL and may switch controlling FF channels to restore control to AUTO. The crew will take the channel out of service using OWP-RP-10, SF/FF Loop 3. The SRO should evaluate the following Tech Specs for failure of FT-497:

T.S. 3.3.1: As a minimum, the Reactor Trip System instrumentation channels and interlocks of Table 3.3-1 shall be OPERABLE

REACTOR TRIP SYSTEM INSTRUMENTATION

FUNCT	IONAL UNIT	TOTAL NO. <u>OF CHANNELS</u>	CHANNELS TO TRIP	MINIMUM CHANNELS <u>OPERABLE</u>	APPLICABLE MODES	ACTION
14.	Steam Generator Water LevelLow Coincident With Steam/ Feedwater Flow Mismatch	2 stm. gen. level and 2 stm./feed- water flow mismatch in each stm. gen.	l stm. gen. level coincident with l stm./feedwater flow mismatch in same stm. gen.	l stm. gen. level and 2 stm./feed- water flow mismatch in same stm. gen. or 2 stm. gen. level and 1 stm./feedwater flow mismatch in same stm. gen.	1, 2	б
	ACTION 6 - With the Number of provided	number of OPE Channels, ST. the following	RABLE channels ARTUP and/or P(conditions are	one less than DWER OPERATION a satisfied:	the Total may proceed	
	a. The with	inoperable ch nin 6 hours, a	annel is place nd	in the trippe	ed condition	
	b. The	Minimum Chann	els OPERABLE r	equirement is a	er: however	

the inoperable channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.3.1.1.

The crew should implement OWP-RP-10 for this failure.

Event 4: Reactor Primary Shield Fan S2-A-SA Failure. When event 3 concludes to the satisfaction of the Lead Examiner then event 4 "Reactor Primary Shield Cooling Fan S2-A-SA failure" can be inserted. The crew will respond to ALB 027-05-5, Reactor Primary Shield Clg Fans S2 Low Flow - O/L and evaluate the condition. The crew should identify that the running fan has tripped, start the standby fan IAW OP-169, Containment Cooling and Ventilation, and dispatch an operator to check the status of the breaker. If flow cannot be established by starting the standby fan then APP-ALB-027-05-5 will direct a Reactor Shutdown to be initiated within 1 hour and cooldown to <350°F within 6 hours would be required. OP-169 P&L 4.0.3 states One Reactor Primary Shield Fan is required to be in operation anytime RCS temperature is greater than 140°F.

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 2 continued

Event 5: Trip of the running 'A' Charging Pump breaker. The crew will enter AOP-018 and carry out the immediate actions. The crew should isolate letdown and then implement actions to place the 'B' Charging Pump in service. The crew will have to secure the ASI pump after the CSIP is started and evaluate the boration caused by the ASI pump running. The efficiency that the crew has in progressing through AOP-018 to the point of securing the ASI pump will determine the amount of boric acid added to the RCS through the RCP seals. This could require the SRO to direct the RO and BOP to coordinate Reactor and Turbine controls (dilute, rod movement and / or Turbine reduction) to accommodate the boron addition for Tavg/Tref stabilization.

The SRO should evaluate the loss of the CSIP in accordance with Tech Specs 3.1.2.2, 3.1.2.4 and 3.5.2

TS 3.1.2.2 - At least two of the following three boron injection flow paths shall be OPERABLE:

b. Two flow paths from the refueling water storage tank via charging/safety injection pumps to the RCS.

ACTION: With only one of the above required boron injection flow paths to the RCS OPERABLE, restore at least two boron injection flow paths to the RCS to OPERABLE status within 72 hours or be in at least HOT STANDBY and borated to a SHUTDOWN MARGIN as specified in the CORE OPERATING LIMITS REPORT (COLR), plant procedure PLP-I06 at 200°F within the next 6 hours; restore at least two flow paths to OPERABLE status within the next 7 days or be in HOT SHUTDOWN within the next 6 hours.

TS 3.1.2 4 - With only one Charging/safety injection pump OPERABLE restore at least two charging/safety injection pumps to OPERABLE status within 72 hours or be in at least HOT STANDBY and borated to a SHUTDOWN MARGIN as specified in the CORE OPERATING LIMITS REPORT (COLR) plant procedure PLP-106 at 200°F within t he next 6 hours: restore at least two charging/safety injection pumps to OPERABLE status within the next 7 days or be in HOT SHUTDOWN within the next 6 hours.

TS 3.5.2 - Two independent Emergency Core Cooling System (ECCS) subsystems shall be OPERABLE with each subsystem comprised of:

One OPERABLE Charging/safety injection pump One OPERABLE RHR heat exchanger One OPERABLE RHR pump and

An OPERABLE flow path capable of taking suction from the refueling water storage tank on a Safety Injection signal and. upon being manually aligned transferring suction to the containment sump during the recirculation phase of operation.

ACTION: a. With one ECCS subsystem inoperable restore the inoperable subsystem to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.

The SRO should also prepare OMM-001, Attachment 5 Equipment Problem Checklist for the failure

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 2 (continued)

Event 6: Restore letdown IAW OP-107 - once the 'B' Charging Pump is in service, the crew will restore letdown IAW OP-107 Section 5.4 to establish inventory control. Once letdown has been restored, Tech Specs have been evaluated for the loss of the 'A' CSIP, and the crew response to the boron addition from the ASI system have been addressed to the satisfaction of the Lead Examiner the next event can be initiated.

Event 7: ~30 gpm RCS leak to Containment. Enter AOP-016 increase ramp rate IAW AOP-038. This will be the initiating event for the Major event. The crew will identify that leakage is present by radiation monitor alarms associated with increasing Containment sump leakage. Pressurizer level will decrease and Charging flow will increase. The crew should enter AOP-016, Excessive Primary Plant Leakage (no immediate actions) based on the indications of unidentified RCS leakage. The crew should determine that RCS leakage is now exceeding TS 3.4.6.2 leakage of 1 gpm Unidentified Leakage but RCS leakage is within VCT makeup capability \leq 120 gpm). They should determine that Attachment 7 for leakage inside Containment is the applicable attachment and stop Containment Purge. Since a shutdown is already in progress IAW GP-006, the crew should evaluate that a more rapid means of plant shutdown is required and enter AOP-038 The SRO should implement AOP-038, Rapid Downpower and direct an increase of the ramp rate to some value \geq 5 DEH Units/min in an attempt to rapidly remove the unit from service.

Event 8: RCS leakage exceeds VCT makeup capability E-0 manual Rx Trip with ATWS Reactor Trip Breakers fail to open in auto or manual. The crew will continue actions of AOP-038 and attempt a manual Reactor trip when leakage exceeds VCT makeup capability IAW AOP-016 continuous action step 4. When the RO attempts to perform a Manual Reactor trip he/she will find that the Reactor will not trip from either of the MCB trip switches. The crew will enter FR-S.1, Response to Nuclear Power Generation/ATWS and perform the immediate actions of manually inserting control rods (auto rod insertion is not available due to event 2 malfunction), tripping the main Turbine, starting AFW and directing an AO to locally trip the Reactor trip breakers when the crew initiates emergency boration of the RCS. The crew will then continue with FR-S.1 until completing step 10 or when the foldout for Reactor Subcriticality Criteria is met. At that time they will transition from FR-S.1 to E-0.

Event 9: RCS leakage increases to SBLOCA ~650 gpm. After the crew transitions from FR-S.1 to E-0 they will verify the E-0 immediate actions and actuate SI if automatic SI initiation (PRZ Pressure less than 1850 psig) did not occur after the Reactor trip breakers were opened. The RCS leakage will increase in magnitude. RCS pressure will decrease to less than 1400 psig which will require the crew to trip the RCP's based on E-0 foldout criteria of RCS pressure less than 1400 psig and SI flow greater than 200 gpm.



SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 2 (continued)

Event 10: 'B' ESW pump fails to start from the sequencer or from low pressure. This failure requires the crew to manually start the 'B' ESW pump. The crew should identify that the 'B' ESW pump did not start from the B sequencer. Either the RO should identify that the 'B' ESW pump is not running by observation of the MCB OR the BOP should identify that the B sequencer has skipped the 'B' ESW pump start. IF neither operator identifies that the 'B' ESW pump did not start then the BOP should identify that it is NOT running when performing EOP E-0 Attachment 3. Step 4 of the attachment has the operator "verify" that ALL ESW AND ESW Booster Pumps are running. By the time the operator performs this step in attachment 4 the actions of AOP-022 to secure both the 'B' CSIP and the 'B' EDG will have been met. The reason for securing the CSIP and EDG can be found in AOP-022 Basis Document. It states that both the CSIPs and EDGs are considered an essential load and requires the component to be stopped to protect against equipment damage due to overheating.

Securing the 1B SB EDG will remove the emergency power supply to the 'B' RHR pump. The 'B' RHR pump will continue to run since it was started by the 'B' sequencer but will only have the normal power source available to it.

The scenario can be terminated when directed to initiate RCS cooldown in ES-1.2.

Page 8 of 9

CRITICAL TASK JUSTIFICATION:

1. Insert negative reactivity into the core by inserting control rods during an ATWS before completing the immediate action steps of FR-S.1.

There are four (4) immediate actions steps of FR-S.1 at HNP with step 4 directing an operator to contact OR report to the MCR to receive instructions to locally trip the reactor. Control rod insertion to add negative reactivity to the core attempting to bring the reactor core subcritical is crucial to prevent the possibility of core damage. Not performing rod insertion prior to completing the immediate actions of FR-S.1 is demonstrating the lack of ability to complete a required operator action during a function restoration procedure.

2. Trip RCPs once RCP Trip Foldout Criteria is met and prior to exiting E-1.

Securing RCPs during a SB LOCA event will prevent depleting the RCS to a critical inventory by pumping more mass through the break than would occur if the RCP operation were ceased. (Critical inventory is defined as the amount of inventory remaining in the RCS when the break completely uncovers and the break flow changes from a mixture of liquid and steam to all steam.) Both E-0 and E-1 foldout criteria requires RCP's to be secured when SI flow of > 200 gpm is established and when RCS pressure is < 1400 psig. IF the crew continues to allow the RCPs to operate then RCS inventory will continue to deplete. Manually tripping the RCPs before depletion below the critical inventory conservatively ensures that Peak Clad Temperature remains below 2200°F. If the crew does NOT secure the RCP's could continue to run.

Appendix D

(

Scenario Outline

Form ES-D-1

HARRIS 2013 NRC SCENARIO 3

Facility:	SHEARC	N-HARRIS	Scenario No.:	3	Op Test No.:	05000400/2013301
Examiners:			Opera	tors:		
					<u> </u>	
					•	
Initial Cond	itions: IC-1	9, MOL, 100% p	ower			
•	'B' MD AFW I 24 hours, TS	Pump under clea 3.7.1.2 – 72 hou	rance 12 hours ago r LCO	for pu	mp packing repla	acement, due back in
•	1SI-3, Boron	Injection Tank O	utlet valve is under c	learar	nce for breaker r	epairs
•	'B' Condense	r Vacuum Pump	is under clearance fo	or mal	keup water supp	ly valve problems
•	Boric Acid Tra	ansfer Pump B-S	B is under clearance	e for m	otor replacemer	nt
Turnover:	Plar	nt is operating at	100% steady state p	ower.	Maintain preser	t conditions.
	•	Isolate AFW flo Loss of Reacto	w to the ruptured 'C r Coolant: Subcoole	' SG p d Rec	rior to entering I overy	ECA-3.1, SGTR with
Critical Tas	ks: •	Isolate 1MS-72 Coolant: Subco	Prior to entering EC	CA-3.1	, SGTR with Los	s of Reactor
	•	Shut 'A' and 'B'	MSIV's prior to exit	ing E-	2, Faulted SG Is	solation
Event No.	Malf. No.	Event Type*		Event	Description	
1	prs06a	C – RO/SRO TS – SRO	Pressurizer PORV	445A L	eakage	
2	nis03a	I – BOP/SRO	NI-31 high voltage t (OP-105)	olock fa	ailure and energiza	ation at power
3	eps05a zdsq94:6a	C – BOP/SRO TS – SRO	Loss of 1A-SA Eme HVAC to restart (AC	rgency DP-025	v Bus with failure c	of 'A' CSIP Room
4	ccw01a ccw047	C – RO/SRO TS – SRO	Trip of 'A' CCW Pur standby CCW pump	np on b failur	O/C during 'A' ED e to auto start (AO	G sequencer start with P-014)
5	pt:308c	R – RO/SRO N – BOP/SRO	SG 'C' PORV Press open requiring the c	sure In: crew to	strument fails high reduce power bel	and the PORV stays ow 100%. (AOP-042)
6	sgn05c	M – ALL	'C' Steam Generato	r tube	rupture ~ 420 gpm	n (AOP-016)
7	mss11	M – ALL	Main Steam Header MSIVs)	r break	outside Containm	nent (downstream of
8	zrpk504a zrpk504a	C – BOP/SRO	Main Steam Line Is	olation	Signal Fails, 'C' I	MSIV fails to shut

Z

HARRIS 2013 NRC SCENARIO 3

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 3

The plant is operating at ~100% power in MOL. When turnover is complete the crew will be directed to maintain the current plant conditions.

The following equipment is under clearance:

• 'B' MDAFW Pump is under clearance for pump packing repairs. The pump has been inoperable for 12 hours and will be restored to operable status within the next 24 hours. Tech Spec 3.7.1.2 LCO Action **a** and Tech Spec 3.3.3.5.b Action **c** applies.

PLANT SYSTEMS

AUXILIARY FEEDWATER SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.1.2 At least three independent steam generator auxiliary feedwater pumps and associated flow baths shall be OPERABLE with:

- Two motor-driven auxiliary feedwater pumps, each capable of teing powered from separate energency buses, and
- b. One steam turbine-driven auxiliary feedwater pump capable of being powered from an OPERABLE steam supply system.

APPLICAEILITY: MODES 1. 2. and 3.

ACTION:

a. With one auxiltary feedwater pump inoperable. restore the required auxiliary feedwater pumps to OPERABLE status within 72 hours or be in at least HOT STANEBY within the next 6 hours and in HOT SHUTDOWN within the following 8 hours.

ŧ,

INSTRUMENTATION

RENOTE SHUTDOWN SYSTEM

LINITING CONDITION FOR OPERATION

3.3.3.5.b All transfer switches, Auxiliary Control Panel Controls and Auxiliary Transfer Panel Controls for the GPERABILITY of those components required by the SHRPP Safe Shutdown Analysis to (1) remove decay heat via auxiliary feedwater flow and staam generator power-operated relief valve flow from staam generators A and B, (2) control RCS inventory through the normal charging flow path, (3) control RCS pressure, (4) control reactivity, and (5) remove decay heat via the RHR system shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

C. With one or more inoperable Remote Shutdown System transfer switches, power, or control circuits required by 3.3.3.5.b, restore the inoperable switch(s)/circuit(s) to OPERABLE status within 7 days, or be in HOT STANDBY within the next 12 hours.

Page 2 of 10

HARRIS 2013 NRC SCENARIO 3

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 3 continued

- 'B' Condenser Vacuum Pump is under clearance for makeup water supply valve problems
- 1SI-3, Boron Injection Tank Outlet valve is under clearance for breaker repairs. Tech Spec 3.5.2 Action **a** applies. OWP-SI-01 has been completed.

EMERGENCY CORE CODLING SYSTEMS

3/4.5.2 ECCS SUBSYSTEMS T. GREATER THAN OR EQUAL TO 350°F

LIMITING CONDITION FOR OPERATION

3.5.2 Two independent Emergency Core Cooling System (ECCS) subsystems shall be OPERABLE with each subsystem comprised of:

- a. One OPERABLE Charging/safety injection pump.
- b. One OPERABLE RHR neat exchanger,
- c. One OPERABLE RHR pump, and
- d. An OPERABLE flow path capable of taking suction from the refueling water storage tank on a Safety Injection signal and, upon being manually-aligned, transferring suction to the containment sump during the recirculation phase of operation.

APPLICABILITY: MODES 1, 2, and 3.

<u>ACTION</u>:

- a. With one ECCS subsystem inoperable, restore the inoperable subsystem to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- Boron Injection Pump B-SB is under clearance for motor replacement. Tech Spec 3.1.2.2 applies (tracking only). OWP-CS-05 has been completed.

Page 3 of 10

HARRIS 2013 NRC SCENARIO 3

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 3 continued

Event 1: Pressurizer PORV 445A Leakage: Pressurizer PORV 445A leakage. This failure will cause PRZ PORV 445A to leak, resulting in rising PRT pressure and level. PORV Line Temp indicator TI-463 will increase as observed on the MCB and the crew will respond IAW ALB 009-8-2, PRESSURIZER RELIEF DISCHARGE HIGH TEMP. The crew may utilize AOP-016 Attachment 5 to determine which PORV is leaking. The SRO will evaluate Tech Spec 3.4.4, Reactor Coolant System – Relief Valves.

TS 3.4.4 applicable LCO is Action **a**, 1 hour to restore

REACTOR COOLANT SYSTEM

3/4.4.4 RELIEF VALVES

LIMITING CONDITION FOR OPERATION

3.4.4 All power-operated relief valves (PORVs) and their associated block valves shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3

ACTION:

a. With one or more PORV(s) inoperable, because of excessive seat leakage, within 1 hour either restore the PORV(s) to OPERABLE status or close the associated block valve(s) with power maintained to the block valve(s); otherwise, be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.

Page 4 of 10

HARRIS 2013 NRC SCENARIO 3

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 3 continued

Event 2: NI-31 high voltage block failure and energization at power (OP-105). The high voltage block on NI-31 will fail and cause the Source Range to suddenly energize and the audio count rate to become audible. The crew should respond to the failure by implementing OP-105, Excore Nuclear Instrumentation, Section 8.2 – Inadvertent Source Range Detector Energization at Power. They will promptly de-energize NI-31 by removing the 118V 5A instrument power fuse. The SRO should refer to TS 3.3.1 (no action required above P-6) and direct the implementation of OWP-RP-19.

3/4.3 INSTRUMENTATION

3/4.3.1 REACTOR TRIP SYSTEM INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.1 As a minimum, the Reactor Trip System instrumentation channels and interlocks of Table 3.3-1 shall be OPERABLE.

APPLICABILITY: As shown in Table 3.3-1.

ACTION: As shown in Table 3.3-1.

FUNCTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
6. Source Range, Newtron Flux a. Startup b. Shutdown	2 2	1	2 2	2## 3,4,5	4 5

##Below the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint.

Page 5 of 10

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 3 continued

Event 3: Loss of 1A-SA Emergency Bus with failure of CSIP 'A' Room HVAC to restart (AOP-025). Emergency Bus A SA to Aux Bus D Tie Breaker 105 SA trips open causing a loss of power to the Emergency Bus A. The Emergency Diesel Generator 'A' starts and loads the bus. The crew will enter AOP-025 and perform the immediate action of checking any CSIP running. The crew should NOT perform the RNO action to isolate letdown since guidance is provided in AOP-025 Basis Document stating that this should only be done if the sequencer does not start the CSIP. IF the letdown flow is secured then the crew will have to restore letdown IAW OP-107. During the recovery steps of AOP-025 the BOP should identify that the CSIP 'A' room HVAC is NOT running. Since this is a "Verify" step the BOP should start the fan. The SRO will be directed by AOP-025 to review multiple Tech Specs due to the loss of power to Tech Spec related systems. Tech Spec 3.0.3 is the most limiting action due to the isolation of the CNMT vacuum relief valves caused by 2/4 Radiation monitors failing high after losing power.

٠

- **4. REFER TO** the following Tech Specs:
- 3.0.3 (Due to loss of 2/4 containment rad monitors and CVIS affect on CNMT vacuum reliefs)
- 3.3.3.1 Radiation Monitoring for Plant Operations (Due to inoperable Control Room Outside Air Intake Monitors)
- 3.4.6.1 RCS Leak Detection (Due to RM-3502A inop)
- 3.6.5 Vacuum Relief System
- 3.8.1.1 AC Sources Operating
 - 3.8.1.2 AC Sources Shutdown
- 3.8.2.1 DC Sources Operating
- 3.8.3.1 Onsite Power
 - Distribution Operating 3.8.3.2 Onsite Power
 - Distribution Shutdown

Rev. 0

6 of 10

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 3 continued

Event 4: Trip of "A" CCW Pump on O/C during EDG 'A' sequencer start with standby CCW pump failure to auto start (AOP-014). During the loss of power to 1A-SA Emergency Bus the 'A' CCW Pump will be started by the sequencer and after 20 seconds it will trip on overcurrent. The standby 'B' CCW Pump fails to Auto Start due to a pressure transmitter failure (instrument is isolated therefore pressure decrease is not sensed). The crew should recognize the loss and enter AOP-014, Loss of Component Cooling Water in conjunction with AOP-025. AOP-025 additionally, has direction to recover the CCW pump IAW AOP-014. AOP-014 will direct the restoration of the CCW system. The RO will be directed by the SRO to manually start the 'B' CCW (or will have started it IAW OPS-NGGC-1000 when it did not auto start). The SRO should also evaluate Tech Spec 3.7.3, Component Cooling Water System.

PLANT SYSTEMS

3/4.7.3 COMPONENT COOLING WATER SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.3 At least two component cooling water (CCW) pumps^{*}, heat exchangers and essential flow paths shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With only one component cooling water flow path OPERABLE. restore at least two flow paths to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

*The breaker for CCW pump 1C-SAB shall not be racked into either power source (SA or SB) unless the breaker from the applicable CCW pump (IA-SA or IB-SB) is racked out.



SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 3 continued

Event 5: SG 'C' PORV Pressure Instrument fails high and the PORV stays open requiring the crew to reduce power below 100% (AOP-042). A transmitter failure will cause the 'C' SG PORV to fail 100% open. Steam Generator 'C' PORV Pressure transmitter PT-308c fails high causing the 'C' SG PORV to open in automatic. The crew should identify this failure by annunciator ALB-014-8-5, Computer Alarm-Steam Generators alarming and status light indications for the 'C' SG PORV. Note: The PT-308c does not have MCB indications. The BOP will be directed by the SRO to take manual control of the PORV and shut it. The valve control will NOT respond and an Aux Operator will be dispatched to locally shut the isolation valve to the PORV. During this time Reactor Power will exceed 100%. The combination of the steam leak and Reactor power will cause the crew to enter AOP-042, Secondary Steam Leak/Efficiency Loss. AOP-042 is used to rapidly reduce Reactor power to < 100% at a ramp rate of up to 45 MW/min. When Reactor power has been stabilized below 100% the AO that was dispatched to locally isolate the PORV will report back that the valve has been shut. When power is stabilized to the satisfaction of the Lead Examiner event (2) can be introduced.

The SRO should evaluate Tech Specs 3.6.3, Containment Isolation Valves and PLP-106 Technical Specification Equipment List Program and Core Operating Limits Report. If the Tech Specs are not referred to during the scenario then if required ask a follow up question at the end of the scenario dealing with the LCO.

TS 3.6.3 – Action **c**, isolate the affected penetration within 4 hours. The redundant manual isolation valve per PLP-106 is Containment Isolation valve 1MS-63.

CONTAINMENT SYSTEMS

3/4.6.3 CONTAINMENT ISOLATION VALVES

LIMITING CONDITION FOR OPERATION

3.6.3 Each containment isolation value specified in the Technical Specification Equipment List Program, plant procedure PLP-106, shall be OPERABLE with isolation times less than or equal to required isolation times.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With one or more of the containment isolation valve(s) inoperable, maintain at least one isolation valve OPERABLE in each affected penetration that is open and:

- a. Restore the inoperable valve(s) to OPERABLE status within 4 hours, or
- b. Isolate each affected penetration within 4 hours by use of at least one deactivated automatic valve secured in the isolation position, or
- c. Isolate each affected penetration within 4 hours by use of at least one closed manual valve or blind flange, or
- d. Be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

Page 8 of 10

HARRIS 2013 NRC SCENARIO 3

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 3 continued

Event 6: 'C' Steam Generator tube rupture ~ 420 gpm (AOP-016). 'C' Steam Generator (SGTR) one tube sheared. Break flow of 420 gpm. The crew should recognize the presence of a large leak in the primary and announce entry into AOP-016. Due to the leak size the crew will promptly recognize that the leak is beyond CVCS makeup capability and the RCS pressure is being rapidly reduced. Prior to reaching the Reactor trip setpoint on Pressurizer Low Pressure (1960 psig) they should manually trip the Reactor, carry out the immediate actions of E-0 and time permitting manually initiate Safety Injection (an automatic Safety Injection may occur if actions are not promptly taken).

Event 7: Main Steam Line Header break outside Containment. Five minutes after the Reactor is tripped a Main Steam line break on the main steam header outside Containment will occur. It is expected that the crew transition from E-0 to E-3 to address the ruptured Steam Generator. While in E-3 the faulted Steam Generator will become apparent by the rapid reduction in Steam Generator pressure.

Event 8: Main Steam Line Isolation Signal Fails, 'C' MSIV fails to shut. The crew should attempt to manually actuate the Main Steam Line Isolation due to approaching the criteria 'Any SG Pressure - Less Than or Equal to 601 psig'. With this failure the crew will attempt to shut the MSIV's manually on the MCB, but only 'A' and 'B' MSIV can be manually shut. 'C' MSIV will not shut from the MCB or locally. The crew should use the Secondary Integrity Foldout Criteria to address the faulted 'C' Steam Generator and transition to E-2, Faulted Steam Generator Isolation, (if isolation attempts were not performed during the implementation of E-3). After entry into E-2 for "C" Steam Generator isolation the crew will return to E-3.

The scenario will end after the crew transitions to ECA-3.1, SGTR with Loss of Reactor Coolant: Subcooled Recovery and initiates an RCS Cooldown.



Page 9 of 10

CRITICAL TASK JUSTIFICATION:

1. Isolate AFW flow to the ruptured 'C' Steam Generator prior to entering ECA-3.1, SGTR with Loss of Reactor Coolant: Subcooled Recovery.

Failure to isolate the ruptured SG causes a loss of differential pressure between the ruptured SG and the intact SGs. Upon a loss of differential pressure, the crew must transition to a contingency procedure that constitutes an incorrect performance that necessitates the crew taking compensating action which complicates the event mitigation strategy. This critical task requires the crew to isolate the feedwater flow to the ruptured SG. Any delay in the isolation of feedwater adds additional inventory along with the primary to secondary leakage. If the primary to secondary leakage is not stopped, SG inventory increase leads to water release through the PORV or safety valve which has the potential for an unmonitored radiation release. Continued filling of the SG could lead to SG overfill which could fill the SG steam lines with water and potentially cause a steam line pipe failure due to the additional weight of the water in the steam lines.

2. Isolate 1MS-72 prior to entering ECA-3.1, SGTR with Loss of Reactor Coolant: Subcooled Recovery.

Failure to isolate the ruptured SG causes a loss of differential pressure between the ruptured SG and the intact SGs. Upon a loss of differential pressure, the crew must transition to a contingency procedure that constitutes an incorrect performance that necessitates the crew taking compensating action which complicates the event mitigation strategy. This critical task requires the crew to isolate the steam flow from the ruptured SG. Isolation of the ruptured SG is necessary because the crew cannot start RCS cooldown to establish RCS subcooling margin. Delaying isolation of the ruptured SG steam flow further depressurizes the ruptured SG increasing the differential pressure between the RCS and ruptured SG requiring the RCS to be depressurized to a lower value. This delay increases the duration of the primary to secondary leakage.

3. Shut 'A' and 'B' MSIV's prior to exiting E-2, Faulted SG Isolation.

Failure to isolate a faulted Steam Generator that can be isolated causes challenges to the Critical Safety Functions beyond those irreparably introduced by the postulated conditions. Also, depending upon the plant conditions, it could constitute a demonstrated inability by the crew to recognize a failure of the automatic actuation of an ESF system or component. This critical task requires the crew to recognize an automatic actuation should have occurred of an ESF system or component but has not and then take manual operator actions to perform the isolation.



Page 10 of 10

Appendix D

 \bigcap

Scenario Outline

HARRIS 2013 NRC SCENARIO 4

Facility:	SHEARON-H	IARRIS	Scenario No.: 4	Op Test No.: <u>05000400/2013301</u>				
Examiners	:		Operators:	SRO:				
				RO:				
			_	BOP:				
Initial Cond	litions: • IC	C-19, MOL, 100% p	ower					
•	B' MD AFW Pu	mp is under cleara	nce for pump packing rep	placement				
•	1SI-3, Boron In	ection Tank Outlet	valve is under clearance	o for breaker repairs				
•	'B' Condenser	/acuum Pump is ur	der clearance for makeu	up water supply valve problems				
•	Boric Acid Tran	sfer Pump B-SB is	under clearance for moto	or replacement				
Turnover:	 A plant shutdown is required due to problems encountered during the repairs on the 'B' MDAFW pump. Repairs will not be able to be completed prior to the LCO expiring. The plant is operating at ~100% power in MOL. When turnover is complete a power reduction at 4 DEH units/min must be started to support being in Mode 3 within the next 6 hours. All required notifications have been made to individuals concerning the reason for the shutdown 							
Critical Tas	 Critical Task: Open 1MS-70 or 1MS-72 to establish a minimum of 210 KPPH AFW flow to the Steam Generators prior to exiting ECA-0.0 Energize "B" AC emergency bus when offsite power becomes available prior to aligning equipment for extended power loss (step 11 of ECA-0.0) 							
Event No.	Malf. No.	Event Type*	Ever	nt Description				
1	N/A	R – RO/SRO N – BOP/SRO	Plant Shutdown (GP-0	06)				
2	nis08b	I – RO/SRO TS – SRO	PR NIS Channel N-42	fails HIGH (AOP-001)				
3	gen01	C – BOP/SRO	Generator Voltage Reg	gulator Failure (APP-ALB-022)				
4	lt:459	l – RO/SRO TS – SRO	Controlling Pressurizer (APP-ALB-009)	⁻ Level Channel, LT-459, fails HIGH				
5	hva04	C – BOP/SRO TS – SRO	"A" Emergency Service	es Chilled Water Pump Trip (AOP-026)				
6	cfw17b	C – RO/SRO	Main Feedwater Pump OPEN	1B Recirculation Valve (1FW-39) fails				
7	eps01a	M – ALL	Loss of Offsite Power,	Reactor Trip				
8	dsg38, dsg05b	C – BOP/SRO	EDG 'A' output breaker EDG 'B' fails to start Loss of ALL power / res	r trips prior to Load Block 9 storation possible with offsite power				
9	z1974tdi z1975tdi	C – BOP/SRO	1MS-70 and 1MS-72 fa (Loss of all AFW until c	ail to auto open operator opens 1MS-70 or 72)				
* (N)ormal, (R)eactivity	/, (I)nstrument,	(C)omponent, (M)ajor					

Harris 2013 NRC Exam Scenario 4

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 4

A plant shutdown is required due to problems encountered during the repairs on the 'B' MDAFW Pump. Repairs will not be able to be completed prior to the LCO expiring. The plant is operating at ~100% power in MOL. When turnover is complete a power reduction at 4 DEH units/min must be started to support being in Mode 3 within the next 6 hours. All required notifications have been made to individuals concerning the reason for the shutdown.

The following equipment is under clearance:

• 'B' MDAFW Pump is under clearance for pump packing repairs. The pump has been inoperable for 12 hours and will be restored to operable status within the next 24 hours. Tech Spec 3.7.1.2 LCO Action **a** and Tech Spec 3.3.3.5.b Action **c** applies.

PLANT SYSTEMS

AUXILIARY FEEDWATER SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.1.2 At least three independent steam generator auxiliary feedwater pumps and associated flow paths shall be OPERABLE with:

- a. Two motor-driven auxiliary feedwater pumps. each capable of being powered from separate emergency buses. and
- b. One steam turbine-driven auxiliary feedwater pump capable of being powered from an OPERABLE steam supply system.

APPLICABILITY: MODES 1. 2. and 3.

ACTION:

a. With one auxiliary feedwater pump inoperable, restore the required auxiliary feedwater pumps to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.

INSTRUMENTATION

REMOTE SHUTDOWN SYSTEM

LIMITING CONDITION FOR OPERATION

3.3.3.5.b All transfer switches, Auxiliary Control Pasel Controls and Auxiliary Transfer Panel Controls for the OPERABILITY of those components required by the SHNPP Safe Shutdown Analysis to (1) remove decay heat via auxiliary feedwater flow and steam generator power-operated relief valve flow from steam generators A and B, (2) control RCS inventory through the normal charging flow path, (3) control RCS gressure, (4) control reactivity, and (5) remove decay heat via the RHR system shall be OPERABLE.

¥.,

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

c. With one or more inoperable Remote Shutdown System transfer switches, power, or control circuits required by 3.3.3.5.b, restore the inoperable switch(s)/circuit(s) to OPERABLE status within 7 days, or be in HOT STANDBY within the next 12 hours.

HARRIS 2013 NRC SCENARIO 4

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 4 continued

The following equipment is under clearance (continued):

- 'B' Condenser Vacuum Pump is under clearance for makeup water supply valve problems
- 1SI-3, Boron Injection Tank Outlet valve is under clearance for breaker repairs. Tech Spec 3.5.2 Action **a** applies. OWP-SI-01 has been completed.

EMERGENCY CORF COOLING SYSTEMS

3/4.5.2 ECCS SUBSYSTEMS - Terr GREATER THAN OR EQUAL TO 350°F

LIMITING CONDITION FOR OPERATION

 $3.5.2\,$ Two independent Emergency Core Cooling System (ECCS) subsystems shall be OPERABLE with each subsystem comprised of:

- a. One OPERABLE Charging/safety injection pump.
- b. One OPERABLE RHR heat exchanger,
- c. One OPERABLE RHR pump, and
- d. An OPERABLE flow path capable of taking suction from the refueling water storage tank on a Safety Injection signal and, upon being nanually aligned, transferring suction to the containment sump during the recirculation phase of operation.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- a. With one ECCS subsystem inoperable, restore the inoperable subsystem to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- Boron Injection Pump B-SB is under clearance for motor replacement. Tech Spec 3.1.2.2 applies (tracking only). OWP-CS-05 has been completed.

Page 3 of 9

HARRIS 2013 NRC SCENARIO 4

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 4 continued

Event 1: Plant Shutdown (GP-006). Crew performs a power reduction IAW GP-006. For this reactivity manipulation it is expected that the SRO will conduct a reactivity brief, the RO will borate per the reactivity plan and the BOP will operate the DEH Controls as necessary to lower power.

Event 2: PRNIS Channel N-42 fails HIGH (AOP-001). This malfunction will cause rods to start stepping in at maximum speed (72 steps per minute). The crew should respond by entering AOP-001, Malfunction of Rod Control and Indication System and perform the immediate actions which will be placing the Rod Control selector switch to MANUAL. The crew will then perform the follow up actions of AOP-001, implement OWP-RP-24 and OP-104 Section 5.5 in order to restore Rod Control to automatic. The SRO will evaluate Tech. Spec 3.3.1 for any impact due to the failed instrument.

FUNCT	FIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
1.	Manual Reactor Trip	2 2	1	2 2	1, 2 3', 4', 5'	· 1 9
2.	Power Range, Neutron Flux a. High Setpoint b. Low Setpoint	4 4	2	3 3	1, 2 1###, 2	2
3.	Power Range, Neutron Flux High Positive Rate	4	2	3	1, 2	2
4.	Power Range, Neutron Flux, High Negative Řate	4	2	3	1, 2	2

- ACTION 2 With the number of OPERABLE channels one less than the Total Number of Channels. STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:
 - a. The inoperable channel is placed in the tripped condition within 6 hours,
 - b. The Minimum Channels OPERABLE requirement is met: however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.3.1.1, and
 - c. Either. THERMAL POWER is restricted to less than or equal to 75% of RATED THERMAL POWER and the Power Range Neutron Flux Trip Setpoint is reduced to less than or equal to 85% of RATED THERMAL POWER within 4 hours; or. the QUADRANT POWER TILT RATIO is monitored at least once per 12 hours per Specification 4.2.4.2.

Event 3: Generator Voltage Regulator Failure (APP-ALB-022). The voltage regulator failure will cause generator MVARS to rise above the normal control band. ALB-22-9-4 Computer Alarm Gen/Exciter Systems, ALB-22-4-5 Generator Exciter Field Forcing and ERFIS indications will alert the operators to this condition if not detected earlier by changes in generator MVARS. Annunciator guidance will have the BOP operator attempting to control voltage with the voltage regulator in MANUAL, but attempts for this type of control will fail requiring the base adjuster to be used to reduce MVARs to a value within normal operational limits (75 to 175 MVARs). This failure will also require the crew to notify the Load Dispatcher that the voltage regulator is in Manual control within 30 minutes.

Harris 2013 NRC Exam Scenario 4



HARRIS 2013 NRC SCENARIO 4

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 4 continued

Event 4: Controlling Pressurizer Level Channel, LT-459, fails HIGH (APP-ALB-009). The crew should respond in accordance with alarm response procedure APP-ALB-09-4-2 and window 2-2. The crew should take Charging FCV-122 to Manual and maintain pressurizer level within the control bands and trip limits of OMM-001 Attachment 13. They will shift level control to an alternate channel. The SRO will evaluate Tech. Spec 3.3.1 for any impact due to the failed instrument.

TS 3.3.1 As a minimum the Reactor Trip System instrumentation channels and interlocks of Table 3.3-1 shall be OPERABLE

Table 3.3-1

TABLE 3.3-1

REACTOR TRIP SYSTEM INSTRUMENTATION

FUNCT	ICNAL UNIT	TOTAL ND. <u>Of Channels</u>	CHANNELS TO TRIP	MINIMUN CHANNELS <u>OPERABLE</u>	APPLICABLE MOCES	ACTION
11.	Pressurizer Water LevelHigh (Above P-7)	3	2	2	1	6

ACTION 6 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:

> The inoperable channel is placed in the tripped condition within 6 hours, and

b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.3.1.1.

Page 5 of 9

HARRIS 2013 NRC SCENARIO 4

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 4 continued

Event 5: "A" Emergency Services Chilled Water Pump Trip (AOP-026). The crew will respond to various alarms on ALB-023, diagnose the event, and enter AOP-026, Loss of Essential Chill Water System (no immediate actions). The SRO will direct the BOP to start the 'B' Train ESCWS Chiller IAW OP-148, Essential Service Chilled Water System. The crew should implement OWP-ECW-01 for the ESCW Chiller 1A-SA failure. The SRO should evaluate Tech Spec 3.7.13, Essential Services Chilled Water System and PLP-114; Relocated Technical Specifications and Design Basis Requirements – Attachment 4 for Area Temperature Monitoring. Note that the 'A' Chiller will be inoperable for the remainder of the scenario and this will impact plant response during the Major Event in that this failure will prevent Load Block 9 on sequencer Train 'A" from energizing.

TS 3.7.13

PLANT SYSTEMS

3/4.7 13 ESSENTIAL SERVICES CHILLED WATER SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.13. At least two independent Essential Services Chilled Water System Toops shall be OPERABLE.

APPLICABILITY: MODES 1. 2. 3. and 4.

ACTION:

With only one Essential Services Chilled Water System loop OPERABLE, restore at least two loops to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

PLP-114 Attachment 4

Attachment 4 Sheet 1 of 3

Area Temperature Monitoring

1.0 OPERATIONAL REQUIREMENTS

 The temperature of each area shown in Table & shall not be exceeded for more than 8 hours or by more than 30°F.

<u>APPLICABILITY</u>: Whenever the equipment in an affected area is required to be OPERABLE.

ACTION:

- 2. With one or more areas exceeding the temperature limit(s) shown in Table A for more than 8 hours, prepare within 30 days an evaluation to demonstrate the continued OPERABILITY of the affected equipment.
- b. With one or more areas exceeding the temperature limit(s) shown in Table A by more than 30°F, prepare an evaluation as required by Action a, above and within 4 hours either restore the area(s) to within the temperature limit(s) or declare the equipment in the affected area(s) inoperable.

HARRIS 2013 NRC SCENARIO 4

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 4 continued

Event 6: Main Feedwater Pump 1B Recirculation Valve (1FW-39) fails OPEN - The crew should identify that the 1B FW pump recirc valve has failed open by MCB light changes from green to red, FW discharge pressure changes, SG Feedflow/Steam flow changes, SG level trends on the ERFIS computer screen displays and by level trends on the WR and NR level recorders. The BOP may attempt to close the valve when the incorrect position is observed but the valve will not close from the MCB. The crew may dispatch the Turbine Building AO immediately or when directed by AOP-010, Feedwater Malfunctions. When the crew enters AOP-010 they will initially perform the immediate action to verify that a FW pump has not tripped. The SRO work through procedure steps to have the recirc valve manually closed. The AO will not be successful with shutting the recirc valve and all SG levels will reach OMM-001 trip limits of 30% within approximately 5 minutes. When the Reactor trip is activated event 7 will be automatically inserted.

Event 7 (**Major**): Loss of Offsite Power, Reactor Trip – Once the crew has activated the Reactor trip switch and the Reactor trip breakers open a loss of Offsite Power will occur. The crew will identify that Offsite power has occurred which leads to a loss of all AC when Event 8 occurs.

Event 8: EDG 'A' output breaker trips prior to Load Block 9, EDG 'B' fails to start, Loss of ALL power / restoration possible with offsite power. 'A' EDG will start but the output breaker will trip 30 seconds after energizing the bus. Additionally, Load Block 9 would not have been reached due to Event 5 when the "A" Chiller tripped.

The crew should enter ECA-0.0, Loss of All AC Power and perform the immediate actions of verifying a Reactor and Turbine trip. The crew will continue efforts to restore power to the station. The Load Dispatcher will inform the crew the fault that has caused the Offsite power failure has been isolated and power has been restored to the switch yard. The Load Dispatcher call is critical and should be performed while the crew is evaluating the status of the diesel generators so they may make a decision to restore offsite power in step 9. If the call for offsite power restoration is delayed the crew could continue with ECA-0.0 extended power loss recovery. They should be allowed to make a decision to either restore offsite power or line up systems for extended power loss (the second decision would not be appropriate).) The crew should determine that the 'B' Emergency Bus is the best choice to restore power to since the 'A' diesel generator output breaker has tripped and an evaluation of the cause has not been completed. The crew should restore offsite power to the 'B' Emergency Bus is the 'B' Emergency Bus IAW EOP-ECA-0.0 Attachment 1.

Milli 3/25/1 Appendix D

Scenario Outline

HARRIS 2013 NRC SCENARIO 4

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 4 continued

Event 9: 1MS-70 and 1MS-72 fail to auto open (Loss of all AFW until operator opens 1MS-70 or 72). 'B' MD AFW Pump is under clearance and 'A' MD AFW Pump will not have power. The Turbine Driven AFW pump will not start due to failures on both 1MS-70 and 1MS-72 to automatically open. The loss of all FW to the Steam Generators will create a RED path on Heat Sink (FR-H.1). With a loss of AC Power ECA-0.0 is in effect. A caution prior to step 1 of ECA-0.0 states: Critical Safety Function Status Trees should be monitored for information only. Function Restoration Procedures should <u>NOT</u> be implemented unless directed by this procedure. The crew should remain in ECA-0.0 and NOT transition to FR-H.1 when a RED path exists. The crew should identify that there is no Feedwater flow to the SG's and open either 1MS-70 or 1MS-72 to establish a motive force to run the Turbine Driven AFW pump. Once flow has been established the TDAFW pump speed controller should be manually adjusted to obtain a minimum of 210 KPPH AFW flow to the Steam Generators.

The scenario is terminated when the crew transitions from ECA-0.0 to E-0, Reactor Trip or Safety Injection then transition from E-0 to ES-0.1, Reactor Trip Response.

CRITICAL TASK JUSTIFICATION:

1. Open 1MS-70 or 1MS-72 to establish a minimum of 210 KPPH AFW flow to the Steam Generators prior to exiting ECA-0.0

Failure to establish the minimum required AFW flow results in adverse consequences or significant degradation in the mitigative capability of the plant. This critical task requires the crew to recognize an automatic actuation of an ESF system or component should have occurred but has not and then take manual operator actions to restore the required flow.

2. Energize "B" AC emergency bus when offsite power becomes available prior to aligning equipment for extended power loss (step 11 of ECA-0.0).

Failure to energize an AC emergency bus constitutes mis-operation or incorrect crew performance which leads to degraded emergency power capacity. Failure to perform this task also results in the needless degradation of a barrier to fission product release via the RCP seals. Energize at least one AC emergency bus before transition out of E-0, unless the transition is to ECA-0.0, in which case the critical task must be performed before placing safeguards equipment hand switches in the pull-to-lock position. For Harris station safeguards equipment cannot be placed in pull-to-lock so the task would be to energize the emergency bus prior to aligning equipment for extended power loss and locally de-energizing control power to the ESF pumps.



Appendix D

Scenario Outline

Form ES-D-1

HARRIS 2013 NRC SCENARIO 5

Facility:	SHEARON	I-HARRIS	Scenario No.: 5 Op Test No.: 05000400/2013301
Examiners			Operators: SRO
			BO
			*
Initial Conc	litions: IC	-27, MOL, ~4%	Dower
• Pla	int startup to	full power on HC	DLD until 'B' Condensate Booster Pump is in service
• 'B'	Condenser V	/acuum Pump is	under clearance for makeup water supply valve problems
• 1S	I-3, Boron Inj	ection Tank Outl	et valve is under clearance for breaker repairs
• Bo	ric Acid Trans	sfer Pump B-SB	is under clearance for motor replacement
• GF	-005, Power	Operation, step	95.c
	• F	Power ascension	is on hold for 'B' Condensate Booster pump oil system repairs.
Turnover:	F	Repairs are now	completed and the pump is ready for service.
	• €	Start the Second	'B' Condensate Booster Pump IAW OP-134 Section 5.6.
	• \	With RCS pressu	ire < 1400 psig, establish SI flow of >200 gpm using alternate
Critical Las	KS: I	Manually actuate	Main Steam Line Isolation prior to Containment procesure
	• •	exceeding 10 psi	q
		<u> </u>	<u> </u>
Event No.	Malf. No.	Event Type*	Event Description
1	N/A	N – BOP/SRO	Start the 'B' Condensate Booster Pump
2	tt:144 jtb143b	I – RO/SRO	Letdown Temperature Controller fails LD/Diversion Valve fails to bypass demineralizers
3	lt:496	C – BOP/SRO TS - SRO	Controlling 'C' Steam Generator Level Transmitter, LT-496, fails low
4	jfb7579	C-BOP/SRO	AH-39 Containment Fan Coil Unit fan trip with back up auto start
	z2715tic	TS - SRO	failure ('C' RCP cooling fan)
5	ccw08a	C – RO/SRO	Component Cooling Water system leak requiring AOP-014 entry and manual makeup to maintain level
6	rcs09a	C – RO/SRO	RCP "A" rising vibration requires manual Reactor trip and securing "A" RCP and associated PRZ spray valve after E-0 immediate actions are completed
7	rcs18a	M- ALL	SBLOCA inside containment (100% severity)
8	sis017 sis018	C – RO/SRO	Failure of BIT outlet valve 1SI-4 to open requiring alternate high head injection flow path use
9	N/A	C – RO/SRO	Manually trip "B" and "C" RCP when RCP trip criteria are met IAW E-0 foldout
10	zrpk504a zrpk504b	C – BOP/SRO	Failure of automatic Main Steam Line Isolation to occur when Containment pressure exceeds 3 psig
* (N)	ormal, (R)e	activity, (I)nstr	ument, (C)omponent, (M)ajor

Page 1 of 8

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 5

Low power scenario – Turnover to crew is the unit startup on hold. The plant is in Mode 2 with Reactor power less than 5%. Power ascension was on hold while 'B' Condensate Booster pump oil system leak repairs are completed. The repairs have just been completed and the pump checkout is completed and ready to be started. When the crew takes the shift the expectation is to start the 'B' Condensate Booster pump IAW OP-134, Condensate System, Section 5.6. After the pump is running they will continue with GP-005, Power Operation, to obtain rated power conditions.

The following equipment is under clearance:

- 'B' Condenser Vacuum Pump is under clearance for makeup water supply valve problems.
- 1SI-3, Boron Injection Tank Outlet valve is under clearance for breaker repairs. Tech Spec 3.5.2 Action **a** applies. OWP-SI-01 has been completed.

EMERGENCY CORE COULING SYSTEMS

3/4.5.2 ECCS SUBSYSTEMS - T ,, GREATER THAN OR EQUAL TO 350°F

LIMITING CONDITION FOR OPERATION

3.5.2 Two independent Emergency Core Cooling System (ECCS) subsystems shall be OPERABLE with each subsystem comprised of:

- a. One OPERABLE Charging/safety injection pump.
- b. One OPERABLE RHR heat exchanger,
- c. One OPERABLE RHR pump, and
- d An OPFRABLE flow path capable of taking suction from the refueling water storage tank on a Safety Injection signal and, upon being nanually aligned, transferring suction to the containment sump during the recirculation phase of operation.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- a. With one ECCS subsystem inoperable, restore the inoperable subsystem to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next G hours and in HOT SHUTDOWN within the following 6 hours.
- Boron Injection Pump B-SB is under clearance for motor replacement. Tech Spec 3.1.2.2 applies (tracking only). OWP-CS-05 has been completed.

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 5 continued

Event 1: Start the 'B' Condensate Booster Pump. Upon turnover and assuming the shift the crew will start the 'B' Condensate Booster pump IAW OP-134, Condensate System, Section 5.6 "Second Condensate Booster Pump Start up". After the pump is in operation the crew will discuss raising power IAW GP-005 to prepare to place the Main Feedwater Regulating valves in service. Prior to the power increase event 2 will occur.

Event 2: Letdown Temperature Controller fails LD/Diversion Valve fails to bypass demineralizers. This failure will cause temperature controller TK-144 output to decrease to zero. Without cooling to the letdown heat exchanger, temperatures observed on TI-143 will increase. At 135°F annunciator ALB-07-3-2, Demin Flow Diversion High Temp will alarm. The crew should respond IAW the alarm procedure. The RO should identify that the divert valve to the VCT has failed to respond. The RO should report the failure to the SRO. The SRO should direct manually bypassing the CVCS Demineralizers, and should also provide directions to the RO to restore letdown temperature to normal utilizing MANUAL control of TK-144. The SRO should provide a temperature band to the RO IAW OMM-001, Conduct of Operations, for operation of components in manual. The SRO can find this temperature band guidance in OP-107. With TK-144 controller not in auto the temperature band should be from 110 – 120°F. The CVCS Demineralizers should remain bypassed pending an evaluation for continued resin use. Soon after stabilizing from this temperature controller failure event 3 will occur.

Event 3: Controlling 'C' Steam Generator Level Transmitter, LT-496, fails low. The BOP should respond to multiple 'C' Steam Generator alarms on ALB-014 and take manual control of the 'C' FRV Bypass valve in accordance with the alarm response procedures and OMM-001, Conduct of Operations. The SRO should evaluate the following Tech Specs for failure of LT-496:

T.S. 3.3.1: As a minimum, the Reactor Trip System instrumentation channels and interlocks of Table 3.3-1 shall be OPERABLE

REACTOR TRIP SYSTEM INSTRUMENTATION

FUNCT	IONAL UNIT	TOTAL NO. <u>OF CHANNELS</u>	CHANNELS TO TRIP	MINIMUM CHANNELS <u>OPERABLE</u>	APPLICABLE MODES	ACTION
13.	Steam Generator Water LevelLow-Low	3/stm. gen.	2/stm. gen. in any operating stm. gen.	2/stm. gen. each operating stm. gen.	1, 2	6(1)
14.	Steam Generator Water LevelLow Coincident With Steam/ Feedwater Flow Mismatch	2 stm. gen. level and 2 stm./feed- water flow mismatch in each stm. gen.	l stm. gen. level coincident with I stm./feedwater flow mismatch in same stm. gen.	l stm. gen. level and 2 stm./feed- water flow mismatch in same stm. gen. or 2 stm. gen. level and 1 stm./feedwater flow mismatch in same stm. gen.	1, 2	6
(1)Th	e applicable MODES for these	channels noted	d in Table 3.3-3	3 are more		

restrictive and, therefore, applicable.



SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 5 continued

ACTION 6 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:

- a. The inoperable channel is placed in the tripped condition within 6 hours, and
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.3.1.1.
- T.S. 3.3.2: The Engineered Safety Features Actuation System (ESFAS) instrumentation channels and interlocks shown in Table 3.3-3 shall be OPERABLE with their Trip Setpoints set consistent with the values shown in the Trip Setpoint column of Table 3.3-4.

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT			<u>1T</u>	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS <u>OPERABLE</u>	APPLICABLE MODES	ACTION	
5.	Turbine Trip and Feedwater Isolation b. Steam Generator Water LevelHigh-High (P-14)		Trip and r Isolation n Generator Water High-High (P-14)	4/stm, gen.	2/stm. gen. in any stm.	3/stm. gen. in each	1,2.	19	
6.	Auxiliary Feedwater c. Steam Generator Water LevelLow-Low		ry Feedwater am Generator Water elLow-Low		uen.	sun, den,			
	1	1)	Start Motor- Driven Pumps	3/stm. gen.	2/stm. gen in any stm. gen.	2/stm. gen. in each stm. gen.	1, 2, 3	19	I
	2	2)	Start Turbine- Driven Pump	3/stm. gen.	2/stm. gen. in any 2 stm. gen.	2/stm. gen. in each stm. gen.	1. 2. 3	19	1

ACTION STATEMENTS (Continued)

- ACTION 19 With the number of OPERABLE channels one less than the Total Number of Channels, operation may proceed provided the following a conditions are satisfied:
 - a. The inoperable channel is placed in the tripped condition within 6 hours, and
 - b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.3.2.1.

The OWP is not required to be implemented in order to continue with the scenario. If the crew allows SG levels to decrease to < 30% they will be required to perform a manual Reactor Trip.

1
HARRIS 2013 NRC SCENARIO 5

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 5 (continued)

Event 4: AH-39 Containment Fan Coil Unit fan trip with back up auto start failure ('C' RCP cooling fan). The fan failure will cause annunciator ALB-029 4-5 "Containment Fan Coolers AH-39 Low Flow-O/L to alarm. The crew should identify that the standby fan did not auto start and start the standby fan. There are no Tech Spec actions are required for SRO evaluation for this failure.

Event 5: Component Cooling Water system leak requiring AOP-014 entry and manual makeup to maintain level. A CCW leak in the running pump suction header will develop. The leak will be within CCW Surge Tank makeup capability. The crew should identify the leak by observation of MCB indications for CCW Surge Tank level or MCB annunciators based on CCW Surge Tank low level. The crew should respond to the CCW Surge Tank level change and/or alarm and enter AOP-014, LOSS OF COMPONENT COOLING WATER. The RAB RO will be dispatched to investigate the leak. The crew will maintain CCW Surge Tank level in the normal operating range by opening the demin water make up valve 1DW-15, on the MCB. Shortly after being dispatched the leak will be identified as a leak in the suction header near the pump. The leak can be manually isolated by closing local isolation valves. The crew will then be required to start the standby 'B' CCW pump and secure the running 'A' CCW pump IAW OP-145. The SRO should evaluate TS 3.7.3.

PLANT SYSTEMS

3/4.7.3 COMPONENT COOLING WATER SYSTEM

LIMITING CONDITION FOR OPERATION

 $3.7.3~{\rm At}$ least two component cooling water (CCW) ${\rm pumps}^*,$ heat exchangers and essential flow paths shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With only one component cooling water flow path OPERABLE, restore at least two flow paths to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

*The breaker for CCW pump 1C-SAB shall not be racked into either power source (SA or SB) unless the breaker from the applicable CCW pump (1A-SA or 1B-SB) is racked out.

HARRIS 2013 NRC SCENARIO 5

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 5 (continued)

Event 6: RCP "A" rising vibration requires manual Reactor trip and securing "A" RCP and associated PRZ spray valve after E-0 immediate actions are completed. During this event the 'A' RCP vibrations will begin to increase and over 3 minutes peak at 28 mils shaft. Note: the shaft vibration instrumentation reads up to 30 mils. The crew will respond to the 'A' RCP malfunction by either identifying rising vibrations or when ALB-010-3-1, RCP-A Trouble alarms. The crew should see the 'A' RCP vibration probe readings are increasing. The crew should enter AOP-018, Reactor Coolant Pump Abnormal Conditions and perform the immediate actions of checking any CSIP running (YES). Vibrations will continue to increase and exceed AOP-018 Attachment 1 RCP trip criteria of 20 mils shaft. Since the RCP is NOT operating within the trip limits and the Reactor is NOT tripped, the crew will have to Trip the Reactor, GO TO EOP-E-0, perform the immediate actions of E-0 and return to AOP-018 follow up actions of steps 5-8 when time permits. The SRO should address steps 5-8, stopping the affected RCP and shutting the associated PZR spray valve prior to the manual Reactor trip.

Note: AOP-018 recent revisions now direct Tripping the Reactor prior to tripping a running RCP. ALL RCP's must be operating whenever the Reactor trip breakers are closed. Previously two loop power operation was allowed after securing one RCP if the initial power level was <49%.

The crew will then transition from EOP E-0 to ES-0.1, Reactor Trip Response. The Lead Examiner can allow the crew to stabilize the plant then insert the major event.

Event 7: **Major** – SBLOCA inside containment (100% severity). The major event is a SBLOCA (100% severity) on 'A' Loop. The crew should recognize a rapid decrease in Pressurizer level and RCS pressure. If the crew responds quickly to the event they may manually actuate a Safety Injection based on ES-0.1 foldout criteria of not being able to maintain Pressurizer level > 5% or RCS subcooling < 10°F. If they do not respond quickly an Automatic Safety Injection will occur. The crew will then transition from ES-0.1 back to E-0, Reactor Trip or Safety Injection. They will again carry out immediate actions of E-0.

Event 8: Failure of BIT outlet valve 1SI-4 to open requiring alternate high head injection flow path use. 1SI-4 will fail to automatically open with the Safety Injection signal and cannot be manually opened from the MCB switch. Additionally, 1SI-3 was under clearance and cannot be opened from the MCB due to control power being removed from the breaker. In order to obtain Safety Injection flow the crew will have to use the alternate high head injection flow path as directed by E-0 RNO actions. They should OPEN alternate high head Safety Injection to cold legs valve 1SI-52 SA and then identify Safety Injection flow exceeding 200 gpm.

Event 9: Manually trip 'B' and 'C' RCP when RCP trip criteria are met IAW E-0 foldout. Shortly after entering E-0, the crew should recognize that the RCS pressure is low enough to meet Foldout Criteria for securing all RCPs but there is no flow indicated on FI-943 (normal SI flow indication). The crew will have to establish SI flow by opening the alternate high head Safety Injection to cold legs valve 1SI-52 SA. After opening 1SI-52A adequate flow (> 200 gpm) will be indicated on FI-940 (alternate SI flow indication) to STOP the 'B' and 'C' RCP's.

Scenario Outline

HARRIS 2013 NRC SCENARIO 5

SCENARIO SUMMARY: 2013 NRC EXAM SCENARIO 5 (continued)

Event 10: Failure of automatic Main Steam Line Isolation to occur when Containment pressure exceeds 3 psig. As the Small Break LOCA continues to flow RCS to the Containment the pressure in the Containment will continue to rise. An automatic Main Steam Isolation signal is generated when Containment pressure is \geq 3.0 psig. The failure of this signal will require the crew to manually actuate Main Steam Line Isolation. The MCB switch will NOT function requiring the crew to shut ALL MSIVs.

The crew will transition from E-0, Reactor Trip or Safety Injection at step 30 when Containment pressure is checked and found to be NOT normal to E-1, Loss of Reactor or Secondary Coolant step 1. The crew will progress through E-1 based on crew performance they will reach a decision point at step 13.

They will transition from in E-1 to ES-1.2, Post LOCA Cooldown and Depressurization, based on RCS pressure > 230 psig and RHR HX header flow < 1000 gpm.

While in ES-1.2 based on RCS cooldown rate exceeding 100°F/HR they will have to wait prior to reducing RCS temperature further.

The scenario ends when the crew has determined that the 100°F/HR cooldown rate has been exceed.



Scenario Outline

HARRIS 2013 NRC SCENARIO 5

CRITICAL TASK JUSTIFICATION:

1. With RCS pressure < 1400 psig, establish SI flow of > 200 gpm using alternate high head safety injection to cold legs prior to securing RCPs

Securing RCPs during a SB LOCA event will prevent depleting the RCS to a critical inventory by pumping more mass through the break than would occur if the RCP operation were ceased. (Critical inventory is defined as the amount of inventory remaining in the RCS when the break completely uncovers and the break flow changes from a mixture of liquid and steam to all steam.) The PRZ Steam Space LOCA event in this scenario is a SB LOCA that requires the RCPs to be secured when E-0 foldout conditions are met. IF the crew continues to allow the RCPs to operate due to lack of establishment of SI flow of > 200 gpm then RCS inventory will continue to deplete. Manually tripping the RCPs before depletion below the critical inventory conservatively ensures that Peak Clad Temperature remains below 2200°F. NOT establishing SI flow prior to RCS reaching 230 psig (RHR injection pressure) was chosen as an applicable plant parameter to use for grading criteria for the task of securing RCPs.

2. Manually actuate Main Steam Line Isolation prior to Containment pressure exceeding 10 psig

Containment pressure increasing to \geq 3 psig should have caused an automatic Main Steam Line Isolation to occur. Since it has not the crew should manually actuate this isolation to prevent the potential release of contamination outside of Containment from the event. At 10 psig a Containment Phase B signal is actuated which will cause the remaining Containment Isolation valves to automatically close thus preventing a release of potential contamination. Since the 10 psig Containment Phase B isolation signal is the last signal to automatically isolate potential Containment release pathways this pressure was chosen as an applicable plant parameter to use for grading criteria for the task of Manual Steam Line Isolation.

