



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
REGION III
2443 WARRENVILLE ROAD, SUITE 210
LISLE, IL 60532-4352

November 21, 2013

EA-13-182

LICENSEE: NextEra Energy Duane Arnold, LLC

FACILITY: Duane Arnold Energy Center

SUBJECT: SUMMARY OF PUBLIC MEETING WITH NEXTERA ENERGY
DUANE ARNOLD, LLC, HELD ON NOVEMBER 5, 2013

On November 5, 2013, representatives of NextEra Energy Duane Arnold, LLC, met with NRC personnel in the Region III office located in Lisle, Illinois, at a Regulatory Conference to discuss the safety significance of the finding and apparent violation identified in NRC Inspection Report Number 05000331/2013010. The finding involves failure of a lubricating oil gasket on one of the standby diesel generators. The conference was held at the request of NextEra Energy Duane Arnold, LLC.

The licensee presented a summary of their risk evaluation, the causes for the apparent violation, and their corrective actions.

A list of the meeting attendees is provided in the Enclosure to this summary, and the licensee's presentation can be found in the Agencywide Documents Access and Management System under ML13308A905.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this summary and its enclosure will be available for public inspection in the NRC Public Document Room or from the Publicly Available Records System (PARS) component of NRC's Agencywide Documents Access and Management Systems (ADAMS), accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA/

Christine Lipa, Chief
Branch 1
Division of Reactor Projects

Docket No. 50-331
License No. DPR-49

Enclosure: List of Attendees

cc w/encl: Distribution via ListServ™

Regulatory Conference List of Attendees

NextEra Energy

Richard Anderson, Site Vice President
Ken Kleinheinz, Site Engineering Director
Mark Gilbert, Operations Shift Manager
Anil Julka, Fleet Risk and Reliability Manager
Mike Davis, Site Licensing/EP Manager
James Petro, Fleet Licensing Director
Larry Lee, ERIN Engineering

U.S. Nuclear Regulatory Commission

Anne Boland, Acting Deputy Regional Administrator, Region III
Julio Lara, Acting Deputy Division Director, Division of Reactor Projects (DRP)
Christine Lipa, Chief, Branch 1, DRP
Steven Orth, Enforcement Officer
Robert Murray, Resident Inspector, Duane Arnold site, DRP
Laura Kozak, Senior Risk Analyst, DRP
Antonios Zoulis, Reliability and Risk Analyst, Office of Nuclear Reactor Regulation (NRR)
David Passehl, Acting Branch Chief, Technical Support Staff, DRP
Nick Valos, Senior Risk Analyst, DRP
Charles Phillips, Project Engineer, DRP
Jakob Steffes, Reactor Engineer, DRP
Roy Elliott, Reactor Engineer, DRP
Benny Jose, Acting Branch Chief, Division of Reactor Safety (DRS)
Randal Baker, Operations Engineer, DRS
Viktoria Mitlyng, Public Affairs Officer
Prema Chandrathil, Public Affairs Officer
Patricia Loughheed, Senior Enforcement Coordinator
Alexander Schwab, Reactor Engineer, DRP
Navid Tehrani, Materials Inspector, Division of Nuclear Materials Safety
Lucas Haeg, Senior Resident Inspector, Duane Arnold site, DRP (via phone)
Michael Jones, Reactor Inspector, DRS (via phone)
Joe Giitter, Director, Division of Risk Management, NRR (via phone)
Sunil Weerakkody, Chief, PRA Operational Support Branch, NRR (via phone)
Jeff Circle, Senior Reliability and Risk Analyst, NRR (via phone)
Carolyn Faria-Ocasio, Project Manager, NRR (via phone)
Michelle Kichline, Reliability and Risk Analyst, NRR (via phone)
Mandy Halter, Enforcement Coordinator, NRR (via phone)
Lauren Casey, Enforcement Specialist, Office of Enforcement (via phone)

Public

Ron Gaston, Exelon Corporation

EA-13-182

LICENSEE: NextEra Energy Duane Arnold, LLC

FACILITY: Duane Arnold Energy Center

SUBJECT: SUMMARY OF PUBLIC MEETING WITH NEXTERA ENERGY
DUANE ARNOLD, LLC, HELD ON NOVEMBER 5, 2013

On November 5, 2013, representatives of NextEra Energy Duane Arnold, LLC, met with NRC personnel in the Region III office located in Lisle, Illinois, at a Regulatory Conference to discuss the safety significance of the finding and apparent violation identified in NRC Inspection Report Number 05000331/2013010. The finding involves failure of a lubricating oil gasket on one of the standby diesel generators. The conference was held at the request of NextEra Energy Duane Arnold, LLC.

The licensee presented a summary of their risk evaluation, the causes for the apparent violation, and their corrective actions.

A list of the meeting attendees is provided in the Enclosure to this summary, and the licensee's presentation can be found in the Agencywide Documents Access and Management System under ML13308A905.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this summary and its enclosure will be available for public inspection in the NRC Public Document Room or from the Publicly Available Records System (PARS) component of NRC's Agencywide Documents Access and Management Systems (ADAMS), accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,
/RA/

Christine Lipa, Chief
Branch 1
Division of Reactor Projects

Docket No. 50-331
License No. DPR-49

Enclosure: List of Attendees

cc w/encl: Distribution via ListServ™

DISTRIBUTION:
See next page

DOCUMENT NAME: November 5, 2013 - Meeting Summary

Publicly Available Non-Publicly Available Sensitive Non-Sensitive

To receive a copy of this document, indicate in the concurrence box "C" = Copy without attach/encl "E" = Copy with attach/encl "N" = No copy

OFFICE	RIII	N	RIII	E	RIII	RIII
NAME	JDraper:rj		SOrth		CLipa	
DATE	11/21/13		11/21/13		11/21/13	

OFFICIAL RECORD COPY

Enclosure

Memorandum to file from Christine Lipa dated November 21, 2013

SUBJECT: SUMMARY OF PUBLIC MEETING WITH NEXTERA ENERGY
DUANE ARNOLD, LLC, HELD ON NOVEMBER 5, 2013

DISTRIBUTION:

Brett Rini
Nick Hilton
Lauren Casey
Carleen Sanders
RidsNrrDorLp3-1 Resource
RidsNrrPMDuaneArnold Resource
RidsNrrDirslrib Resource
RidsOemailCenter Resource
Cynthia Pederson
Anne Boland
Steven Orth
Allan Barker
Harral Logaras
Viktoria Mitlyng
Prema Chandrathil
Patricia Lougheed
DRPIII
DRSIII