

NOV 17 1978

Docket No. 50-206

Southern California Edison Company
ATTN: Mr. James H. Drake
Vice President
2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770

DISTRIBUTION:

Docket (50-206)

NRC PDR
Local PDR
ORB#2 RDG
VStello
BGrimes
HSmith
ABurger
OELD
OI&E(5)
BJones(4)
BScharf(15)

STS Group
BHarless
DEisenhut
ACRS(16)
CMiles
RDiggs
DDavis
TERA
JRBuchanan

Gentlemen:

The Commission has issued the enclosed Amendment No. 38 to Provisional Operating License No. DPR-13 for the San Onofre Nuclear Generating Station, Unit 1. The amendment consists of changes to the Technical Specifications in partial response to your request (Proposed Change No. 68) dated December 30, 1977. The pending portion of your request (Proposed Change No. 67) will be handled separately.

The amendment revises the Technical Specifications to: (1) reduce the maximum allowable rate for pressurizer heatup from 195°F/hour to 100°F/hour, (2) increase the maximum allowable rate for pressurizer cooldown from 195°F/hour to 200°F/hour, and (3) delete the provisions of the Respiratory Protection Program (Section 6.12).

A copy of our related Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

*original signed by
D.V. Wambach for*

Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

7812040007

Enclosures:

- 1. Amendment No. 38 to DPR-13
- 2. Safety Evaluation
- 3. Notice

cc w/encl:
See next page

*See previous yellow for concurrence

CP-1 *p*

OFFICE	*DOR:ORB#2	*DOR:ORB#2	*OELD	DOR:ORB#2	
SURNAME	HSmith: sah	ABurger	LChandler	DLZiemann	
DATE	11/17/78	/ /78	/ /78	11/17/78	

SAVE

DISTRIBUTION:

Docket	OELD
NRC PDR	OI&E (5)
Local PDR	BJones (4)
ORB#2 RDG	BScharf (15)
VStello	JMMcGough
BGrimes	BHarless
HSmith	DEisenhut
ABurger	ACRS (16)
	CMiles
	RDiggs
	TBAbernathy
	JRBuchanan

Docket No. 50-206

Southern California Edison Company
 ATTN: Mr. James H. Drake
 Vice President
 2244 Walnut Grove Avenue
 Post Office Box 800
 Rosemead, California 91770

Gentlemen:

The Commission has issued the enclosed Amendment No. to Provisional Operating License No. DPR-13 for the San Onofre Nuclear Generating Station, Unit 1. The amendment consists of changes to the Technical Specifications in partial response to your request (Proposed Change No. 68) dated December 30, 1977.

The amendment revises the Technical Specifications to: (1) reduce the maximum allowable rate for pressurized heatup from 195°F/hour to 100°F/hour, and (2) delete the provisions of the Respiratory Protection Program (Section 6.12).

Your request (Proposed Change No. 67) for a Technical Specification change to Section 4.10, "Augmented Inservice Inspection of High Energy Lines Outside Containment" will be handled by a separate license amendment.

A copy of the related Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

Dennis L. Ziemann, Chief
 Operating Reactors Branch #2
 Division of Operating Reactors

Enclosures:

1. Amendment No. to DPR-13
2. Safety Evaluation
3. Notice

cc w/encl:

See next page

actually returned from ELD on 10/24/78
ASmith

OFFICE >	DOR:ORB#2	DOR:ORB#2	OELD <i>UC</i>	DOR:ORB#2		
SURNAME >	<i>LP</i> HSmith:sah	ABurger <i>AB</i>	<i>BScharf</i>	DLZiemann		
DATE >	6/7/78	6/7/78	6/1/78	6/1/78		