

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-206SOUTHERN CALIFORNIA EDISON COMPANYANDSAN DIEGO GAS AND ELECTRIC COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO PROVISIONAL
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. **45** to Provisional Operating License No. DPR-13, issued to Southern California Edison Company and San Diego Gas and Electric Company (the licensees), which revised the Technical Specifications for operation of the San Onofre Nuclear Generating Station, Unit No. 1 (SONGS, Unit 1) (the facility) located in San Diego County, California. The amendment is effective as of its date of issuance.

The amendment allows temporary, simultaneous chlorination of both condenser halves and an increase of the chlorination time during the approximately three-day special fish impingement studies required under Section 316(b) of the Federal Water Pollution Control Act.

The application for amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

7909180 570

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated July 31, 1979, and (2) Amendment No. 45 to License No. DPR-13, including the Commission's related transmittal letter. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C., and at the Mission Viejo Branch Library, 24851 Chrisanta Drive, Mission Viejo, California. A single copy of item (2) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this **AUG 16 1979**

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by
Dennis L. Ziemann

Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-206SOUTHERN CALIFORNIA EDISON COMPANYANDSAN DIEGO GAS AND ELECTRIC COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO PROVISIONAL
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. to Provisional Operating License No. DPR-13, issued to Southern California Edison Company and San Diego Gas and Electric Company (the licensees), which revised the Technical Specifications for operation of the San Onofre Nuclear Generating Station, Unit No. 1 (SONGS, Unit 1) (the facility) located in San Diego County, California. The amendment is effective as of its date of issuance.

The amendment allows ^{temporary,} simultaneous chlorination of both condenser halves and an increase of the chlorination time during ^{the three-day} special fish impingement studies required under Section 316(b) of the Federal Water Pollution Control Act.

The application for amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

William O. Miller, Chief
License Fee Management Branch, ADM

Date: 8/14/79
Amended Form Date: _____

FACILITY AMENDMENT CLASSIFICATION - DOCKET NO(S). 50-206

Licensee: Southern California Edison Company

Plant Name and Unit(s): San Onofre, Unit 1

License No(s): DPR-13 Mail Control No: 7908030182

Request Dated: 7/31/79 Fee Remitted: Yes No

Assigned TAC No: 11985

Licensee's Fee Classification: Class I , II , III , IV , V , VI ,
None

Subject: Simultaneous elimination of both values of condensers ... fuel engagement
Amendment No. 45 Date of Issuance 8/16/79

1. This request has been reviewed by DOR/DPM in accordance with Section 170.22 of Part 170 and is properly categorized.

2. This request is incorrectly classified and should be properly categorized as Class _____. Justification for classification or reclassification: _____

~~3.~~ 3. Additional information is required to properly categorize the request:
This constitutes our preliminary and final fee position

4. This request is a Class _____ type of action and is exempt from fees because it:

- (a) _____ was filed by a nonprofit educational institution,
- (b) _____ was filed by a Government agency and is not for a power reactor,
- (c) _____ is for a Class _____ (can only be a I, II, or III) amendment which results from a written Commission request dated _____ for the application and the amendment is to simplify or clarify license or technical specifications, has only minor safety significance, and is being issued for the convenience of the Commission, or
- (d) _____ other (state reason therefor): _____

L.P. 8/15/79
A. Burger

Dennis L. Reiman

Division of Operating Reactors/Project Management

THE INITIAL FEE DETERMINATION HAS BEEN REASSESSED AND IS HEREBY AFFIRMED _____

The above request has been reviewed and is exempt from fees.