



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SOUTHERN CALIFORNIA EDISON COMPANY AND

SAN DIEGO GAS AND ELECTRIC COMPANY

DOCKET NO. 50-206

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 1

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 69
License No. DPR-13

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Southern California Edison Company and San Diego Gas and Electric Company (the licensees) dated March 4, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8305060381 830503
PDR ADOCK 05000206
P PDR

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 3.B of Provisional Operating License No. DPR-13 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendices A and B as revised through Amendment No. 69, are hereby incorporated in the license. Southern California Edison Company shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 3, 1983

ATTACHMENT TO LICENSE AMENDMENT NO. 69
PROVISIONAL OPERATING LICENSE NO. DPR-13
DOCKET NO. 50-206

Replace the following pages with the enclosed pages, which contain marginal lines reflecting the area of change.

PAGES

75a

77

6.5.1.14 Recommended changes to the station security program and implementing procedures shall be approved by the Station Manager and transmitted to the Manager of Nuclear Operations and to the Chairman of the NARC.

6.5.1.15 Recommended changes to the station emergency plan, and implementing procedures shall be approved by the Station Manager and transmitted to the Manager of Nuclear Operations and to the Chairman of the NARC.

6.5.1.16 The Station Manager shall assure the performance of a review by a qualified individual/organization of changes to the radwaste treatment systems.

6.5.1.17 Reports documenting each of the activities performed under Specifications 6.5.1.9 through 6.5.1.16 shall be maintained. Copies shall be provided to the Manager of Nuclear Operations and the Chairman of the NARC.

AUDITS

6.5.2.8

Audits of facility activities shall be performed under the cognizance of the NARC. These audits shall encompass:

- a. The conformance of facility operation to all provisions contained within the Technical Specifications and applicable license conditions at least once per year.
- b. The performance, training and qualifications of the entire facility staff at least once per year.
- c. The results of all actions taken to correct deficiencies occurring in facility equipment, structures, systems or method of operation that affect nuclear safety at least once per six months.
- d. The performance of all activities required by the Quality Assurance Program to meet the criteria of Appendix "B", 10 CFR 50, at least once per two years.
- e. (Deleted)
- f. (Deleted)
- g. The Facility Fire Protection Program and implementing procedures at least once per 24 months.
- h. An independent fire protection and loss prevention inspection and audit shall be performed annually utilizing either qualified offsite licensee personnel or an outside fire protection firm.
- i. An inspection and audit of the fire protection and loss prevention program shall be performed by qualified outside fire consultant at least once per 36 months.
- j. Any other area of facility operation considered appropriate by the NARC or the Nuclear Control Board.

AUTHORITY

6.5.2.9

The NARC shall report to and advise the Nuclear Control Board on those areas of responsibility specified in Sections 6.5.2.7 and 6.5.2.8.