



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION V

1450 MARIA LANE, SUITE 210  
WALNUT CREEK, CALIFORNIA 94596-5368

OCT 28 1991

Docket Nos. 50-206 and 50-362

Southern California Edison Company  
P. O. Box 128  
San Clemente, California 92672

Attention: Mr. R. W. Krieger, Station Manager

Gentlemen:

Subject: Temporary Waiver of Compliance from San Onofre Unit 1 Technical Specification 4.7 and San Onofre Unit 3 Technical Specification 4.4.9, Inservice Inspection of Reactor Coolant Pump Flywheels

This letter documents the granting of a temporary waiver of compliance to the Southern California Edison (SCE) Company for San Onofre Nuclear Generating Station Unit 1, Operating License DPR-13; and Unit 3, Operating License NPF-15. The waiver of compliance was granted verbally at 3:50 p.m. (PDT) on October 25, 1991 based upon SCE's oral request for the waiver during a telephone conference call. A followup written waiver request was submitted by SCE on October 26, 1991.

The waiver involves Technical Specification (TS) surveillance requirements to perform inservice inspections of the reactor coolant pump (RCP) flywheels at intervals of approximately three years. This requirement is contained in Unit 1 TS 4.7, "Inservice Inspection Requirements," and in Unit 3 TS 4.4.9, "Reactor Coolant System - Structural Integrity." These inspections were last performed on Unit 1 RCPs B and C in December 1985, on Unit 1 RCP A in 1988, and on all Unit 3 RCPs in February 1987.

Since these TSs do not specifically address the operability requirements for RCP flywheels, your staff considered TS 3.0.3 to be applicable for both Units 1 and 3. TS 3.0.3 for both units requires the units to be placed in Mode 3 within six hours. In addition, Unit 1 TS 3.1.2, "Reactor Coolant System - Operational Components," and Unit 3 TS 3.4.1.1, "Reactor Coolant Loops and Coolant Circulation," which require all RCPs to be operable, were considered applicable. Your letter noted that, although all RCPs remained in operation, each RCP must fully satisfy all surveillance requirements to be considered operable. With an inoperable RCP, Unit 1 TS 3.1.2 and Unit 3 TS 3.4.1.1 require that the units be placed in Mode 3 within one hour.

Shutdown of both Units in accordance with the Action requirements of Unit 1 TS 3.0.3 and TS 3.1.2, and Unit 3 TS 3.0.3 and TS 3.4.1.1, was delayed for a period not to exceed 24 hours in accordance with TS 4.0.3 for both units. This TS permits such a delay to allow the completion of surveillances.


AA3

1/0  
JEO1

Region V, with NRR concurrence, concluded after reviewing your request that a temporary waiver of compliance from the Unit 1 TS 4.7 and Unit 3 TS 4.4.9 requirements for inspections of the RCP flywheels will not negatively impact public health and safety. Accordingly, a temporary waiver was verbally granted, to remain in effect until 3:50 p.m. (PST) on October 30, 1991. During that period, the NRC will consider whether to extend this waiver until December 1, 1991, as requested in your letter.

This approval of your requested temporary waiver of compliance is conditioned upon the implementation of the compensatory measures described in your letter dated October 26, 1991.

Sincerely,

 FOR

R. P. Zimmerman, Director  
Division of Reactor Safety  
and Projects

cc:

H. B. Ray, Senior Vice President, Nuclear  
H. E. Morgan, Vice President and Site Manager  
State of California

bcc:

- J. Martin, RV
- B. Faulkenberry, RV
- R. Zimmerman, RV
- K. Perkins, RV
- S. Richards, RV
- P. Johnson, RV
- K. Johnston, RV
- C. Caldwell, SONGS
- T. Murley, NRR
- J. Partlow, NRR
- M. Virgilio, NRR
- T. Quay, NRR
- G. Kalman, NRR
- L. Kokajko, NRR
- A. Mendiola, NRR
- M. Blume, RV
- A. Johnson, RV

REGION V

*4*  
KJohnston  
10/28/91

*PK*  
PJohnson  
10/28/91

*SAR*  
SRichards  
10/28/91

*PK per telcom. SAR*  
MVirgilio, NRR RZimmerman  
10/28/91 10/28/91

REQUEST COPY YES / NO	REQUEST COPY YES / NO	REQUEST COPY YES / NO	REQUEST COPY YES / NO	REQUEST COPY YES / NO
				SEND TO PDR YES / NO