



*Southern California Edison Company*

23 PARKER STREET  
IRVINE, CALIFORNIA 92718

August 24, 1992

R. M. ROSENBLUM  
MANAGER OF  
NUCLEAR REGULATORY AFFAIRS

TELEPHONE  
(714) 454-4505

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Subject: **Docket No. 50-206**  
**Supplement 1 to Amendment Application No. 202**  
**Extension to Steam Generator Inspection Interval**  
**San Onofre Nuclear Generating Station, Unit 1**

Reference: Letter, Harold B. Ray, SCE, to U. S. Nuclear Regulatory  
Commission, "Amendment Application No. 202, Extension to Steam  
Generator Inspection Interval," April 6, 1992

This letter forwards Supplement 1 to Amendment Application No. 202 to Facility Operating License No. DPR-13 for San Onofre Nuclear Generating Station, Unit 1 (SONGS 1). Amendment Application No. 202 (see reference) requested a 4-month extension to the maximum steam generator inspection interval from 24 calendar months as required by Technical Specification 4.16.C.1 to 28 calendar months. The enclosed supplement provides the Technical Specification page (page no. 4.16-2) reflecting the extended interval. This page had not been included in our April 6, 1992 amendment application.

The enclosed Technical Specification page incorporates a footnote stating that the 28-month interval between steam generator inspections is authorized for the inspection interval ending in 1992. This change is editorial in nature, and has no impact on the safety evaluation performed as a part of the referenced amendment application. The safety and significant hazards determination and other conclusions reached in the referenced amendment application remain valid.

We look forward to the NRC's expedited approval of our referenced amendment application so that SONGS 1 will not have to be shutdown in September 1992 to perform the steam generator inspection (as required currently), and that the


9208260206 920824  
PDR ADDOCK 05000206  
P PDR

A001  
110

Unit can continue to operate until its planned permanent shutdown in November 1992.

If you have any questions regarding this matter, or desire additional information, please contact me.

Very truly yours,



Enclosure

cc: J. B. Martin, Regional Administrator, NRC Region V  
George Kalman, NRC Senior Project Manager, San Onofre Unit 1  
J. O. Bradfute, NRC Project Manager, San Onofre Unit 1  
C. W. Caldwell, NRC Senior Resident Inspector, San Onofre Units 1, 2&3