

#### UNITED STATES NUCLEAR REGULATORY COMMISSION REGION V 1450 MARIA LANE, SUITE 210 WALNUT CREEK, CALIFORNIA 94596

DEC 2 8 1989

Docket Nos. 50-206, 50-361, 50-362

Southern California Edison Company Irvine Operations Center 23 Parker Street Irvine, California 92718

Attention: Mr. Harold B. Ray, Vice President Nuclear Engineering, Safety, and Licensing

Gentlemen:

This refers to the Management Meeting on November 29, 1989 during which we discussed issues related to the failure of an Automatic Switch Company (ASCO) solenoid on August 23, 1989 and recent operator performance problems. In addition, you provided a status on enhancements to the Emergency Preparedness and Root Cause Assessment Programs, engineering program improvements, the Design Basis Documentation (DBD) review, and the activities of Nuclear Oversight Organizations. The subjects discussed during the meeting are described in the enclosed Meeting Report for activities authorized by NRC License Nos. DPR-13, NPF-10 and NPF-15. A copy of the agenda for this meeting (transmitted to you by our letter dated November 22, 1989) is enclosed.

With regard to the failure of the ASCO solenoid valve for CV-304, as previously discussed in NRC Inspection Report No. 50-206/89-31, we are concerned that sufficient information was available to have prevented the failure of CV-304 and that appropriate information inputs were not made to the Control of Problem Equipment (COPE) list. The COPE program appears to have been the feature of your administrative controls which could most likely have prevented the use of this problem equipment. Weaknesses in your corrective action program also appear to have contributed to the failure of CV-304.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosure will be placed in the NRC Public Document Room.

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

Regional Administrator


Enclosures: Management Meeting Report Nos. 50-206/89-34, 50-361/89-34, and 50-362/89-34

001180153

FUR

cc w/Enclosure: D. J. Fogarty, Executive Vice President H. B. Bridenbecker, Vice President and Site Manager (San Clemente) H. E. Morgan, Station Manager (San Clemente) State of California

9



- 2 -

## Enclosure 1

### MANAGEMENT MEETING

# SOUTHERN CALIFORNIA EDISON COMPANY

# Region V Office, Walnut Creek, California

November 29, 1989

#### AGENDA

- 1. Opening Remarks, Purpose of Meeting -- J. B. Martin, Regional Administrator, and H. B. Ray, Vice President
- 2. NRC Discussion items
  - a. Failure of ASCO Solenoid Valve CV-304
    - Inadequate Corrective Actions (In Response to Previous Failures and NRC Information Notice No. 88-43)
    - Technical Specifications Requirements
  - b. Recent Operational Performance
    - Review of Recent Events and Experiences
    - SCE Discussion of Causal Factors and Corrective Actions
- 3. Presentations by Southern California Edison
  - a. Emergency Preparedness Program
    - Classification of Events
    - Interface between Emergency Operations Facility (EOF) and Technical Support Center (TSC)
  - b. Status of Root Cause Assessment Program
  - c. Update on Engineering Improvements and SONGS Design Basis Documentation (DBD) Review
  - d. Update on Activities of Nuclear Oversight Organizations
- 4. Closing remarks