



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION V

1450 MARIA LANE
WALNUT CREEK, CALIFORNIA 94596-5368

JUN 11 1993

Docket Nos. 50-206, 50-361, 50-362

Southern California Edison Company
Irvine Operations Center
23 Parker Street
Irvine, California 92718

Attention: Mr. Harold B. Ray, Senior Vice President, Nuclear

SUBJECT: NRC INSPECTION REPORT NOS. 50-206, 361, 362/93-09

This refers to the routine inspection conducted by Messrs. C. W. Caldwell, J. J. Russell, D. L. Solorio and T. B. Sundsmo from this office and Messrs. C. M. Regan, S. P. Sanchez, C. C. Harbuck and J. R. Ball from the office of Nuclear Reactor Regulation on April 1 through May 12, 1993, of activities authorized by NRC License Nos. DPR-13, NPF-10 and NPF-15 and to the discussion of our findings held by the inspectors with Mr. R. W. Krieger and other members of the Southern California Edison staff on May 21, 1993.

Areas examined during this inspection are described in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspectors.

No violations of NRC requirements were identified within the scope of this inspection. However, weaknesses were noted with Unit 1 procedures used for sluicing spent resin from the demineralizer to the spent resin storage tank. While we recognize that your staff is still evaluating the cause of the apparent resin backup in the piping, these weaknesses contributed to a lack of understanding of why high radiation levels developed in the piping.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosure will be placed in the NRC Public Document Room.

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.


Sincerely,


C. A. VanDenburgh, Chief
Reactor Projects Branch

Enclosure:

1. Inspection Report Nos. 50-206/93-09,
50-361/93-09, and 50-362/93-09

9306240024 930611
PDR ADOCK 05000206
Q PDR



cc w/Enclosure:

D. Womeldorf, California Department of Health Services
R. Lacy, Manager, San Diego Gas and Electric
Mayor, City of San Clemente
Chairman, Board of Supervisors, County of San Diego
H. Kocol, State Department of Health Services
C. Brinkman, ABB Combustion Engineering Nuclear Power
A. Watts, Esq., Rouke & Woodruff
S. Harris, City of Riverside
R. Kosiba, Bechtel Power Corporation
J. Beoletto, Esq., Southern California Edison Company
R. Krieger, Station Manager (San Clemente)
State of California

JUN 11 1993

bcc w/enclosure:
Project Inspector
Resident Inspector
Docket File
Greg Cook
S. Richards
B. Faulkenberry

bcc w/o enclosures:
M. Smith
J. Zollicoffer
J. Bianchi

RV <i>Hunter</i> CCaldwell 6/10/93	<i>Hunter</i> DSolorio 6/10/93	<i>Hunter</i> JRussell 6/10/93	<i>Hunter</i> HWong 6/10/93	<i>CV</i> CVandenberg 6/10/93
--	--------------------------------------	--------------------------------------	-----------------------------------	-------------------------------------

[REQUEST COPY]	[REQUEST COPY]	[REQUEST COPY]	[REQUEST COPY]	[REQUEST COPY]
[YES / NO]	[YES / NO]	[YES / NO]	[YES / NO]	[YES / NO]

TSundsmo 6/11/93	<i>Hunter</i> CRegan 6/10/93	SSanchez / /93	<i>Hunter</i> CHarback 6/10/93	<i>Hunter</i> JBall 6/10/93
---------------------	------------------------------------	-------------------	--------------------------------------	-----------------------------------

[REQUEST COPY]	[REQUEST COPY]	[REQUEST COPY]	[REQUEST COPY]	[REQUEST COPY]
[YES / NO]	[YES / NO]	[YES / NO]	[YES / NO]	[YES / NO]

SRichards
/ 93
[REQUEST COPY]
[YES / NO]

[SEND TO DCS]	[YES / NO]
[SEND TO PDR]	[YES / NO]

g:\ps2\songs\insprpts\so93-09.hjw

230032