

U. S. NUCLEAR REGULATORY COMMISSION

REGION V

Report Nos. 50-206/93-20, 50-361/93-20, and 50-362/93-20

Docket Nos. 50-206, 50-361, 50-362

License Nos. DPR-13, NPF-10, NPF-15


Licensee: Southern California Edison Company
Irvine Operations Center
23 Parker Street Drive
Irvine, California 92718

Facility Name: San Onofre Units 1, 2, and 3

Meeting at: Region V Office
Walnut Creek, California

Prepared by: B. J. Olson, Project Inspector

Approved by:


H. Wong, Chief
Reactor Projects Section II

7/14/93
Date Signed

Summary:

A meeting was held on July 1, 1993, to discuss the ongoing Unit 3 steam generator primary to secondary leak and plans for Unit 2 steam generator eddy current inspections. A copy of the slides used in the licensee's presentation is enclosed.

DETAILS

1. Meeting Attendees

Southern California Edison Company (SCE)

D. Rosenblum, Vice President, Engineering & Technical Services
R. Waldo, Manager, Operations
M. Short, Manager, Site Technical Services
J. Clark, Manager, Chemistry
G. Gibson, Supervisor, Generic Licensing
J. Mundas, Senior Engineer, Nuclear Engineering

Nuclear Regulatory Commission

K. Perkins, Director, Division of Reactor Safety and Projects
C. Serpan, Acting Deputy Director, Division of Reactor Safety and Projects
C. VanDenburgh, Chief, Reactor Projects Branch
H. Wong, Chief, Reactor Projects Section II
W. Ang, Chief, Engineering Section
J. Reese, Chief, Facilities Radiological Protection Branch
M. Fields, Project Manager, NRR
E. Murphy, Materials & Chemical Engineering Branch, NRR
J. Winton, Materials & Chemical Engineering Branch, NRR
C. Myers, Reactor Inspector
B. Olson, Project Inspector

2. Details

Mr. Perkins provided opening remarks and indicated that the NRC was interested in SCE's assessment of the ongoing primary to secondary leak in San Onofre Unit 3 and the eddy current inspection program that would be conducted during the current Unit 2 refueling outage. Mr. Rosenblum provided opening remarks for SCE and indicated that, in general, SCE considered the steam generators at San Onofre to be less vulnerable to the tube flaws that have been recently observed at Palo Verde. He also listed the topics that would be presented: (1) Unit 3 steam generator primary to secondary leakage, (2) Unit 2 steam generator eddy current inspection plans, and (3) a comparison of San Onofre and Palo Verde secondary characteristics.

a. Unit 3 Steam Generator Primary to Secondary Leakage

Mr. Waldo reviewed the history of an ongoing Unit 3 steam generator primary to secondary leak. The leak was first observed on May 11, 1993, and initially stabilized at approximately five gallons per day (gpd). The leak had slowly increased to approximately 15 gpd in the month and one-half period since developing. San Onofre's Technical Specifications require that primary to secondary leakage from one steam generator be limited to less than 720 gpd.

Mr. Waldo explained that the most likely source of the leak was through a Westinghouse steam generator tube plug known as a plug-in-plug. This

design, of which there are 178 installed in the Unit 3 steam generators, incorporates a separate, internal plug and has developed leaks at other facilities. Westinghouse analysis indicated that the potential leakage past this type of plug is limited to approximately 15 gpd.

Mr. Waldo provided an overview of the methods used to monitor the leakrate and the actions that would be taken if the leakrate increased. He indicated that San Onofre uses activity measurements of the main condenser air ejector exhaust as the primary method for determining the leakrate. He also indicated that operating crews would perform a rapid plant shutdown if the leakrate increased by more than 60 gpd in one hour.

b. Unit 2 Steam Generator Eddy Current Inspection Plans

Mr. Mundas described the steam generator eddy current inspection plan which will be implemented during the current Unit 2 refueling outage. He indicated that 20% of the steam generator tubes will be inspected using an eddy current bobbin coil. This sampling percentage follows recommendations from the Electric Power Research Institute and exceeds the Technical Specification minimum inspection requirements. In addition, about 500 tubes per steam generator will be inspected just above the hot leg side of the tubesheet using an eddy current motorized rotating pancake coil (MRPC). Mr. Mundas stated that San Onofre had previously only used the more sensitive MRPC to perform inspections of areas where anomalies had been observed in bobbin coil signals.

Mr. Mundas described the actions being taken as a result of axial indications that have been recently observed in Palo Verde Unit 2 steam generators. He indicated that Combustion Engineering developed a thermal-hydraulic model of the San Onofre steam generators, and the model was used to determine areas where deposits may form on steam generator tubes. The model was developed after Palo Verde observed axial indications associated with tube deposits. Based on an evaluation of the deposit parameters from the San Onofre model, additional tubes would be inspected using the MRPC. Mr. Mundas said that approximately 400 additional tubes in each steam generator would be partially inspected using the MRPC, although the final evaluation was not complete. In addition to changes in the scope of inspection activities as a result of the Palo Verde findings, Mr. Mundas stated that the training program for the eddy current analysts had been modified to use actual data from indications observed at Palo Verde.

Mr. Murphy stated that the bobbin coil could inspect long tube sections faster than the MRPC and commented that SCE might want to consider using the bobbin coil to inspect more full length tube sections and use the MRPC to inspect more tubes at the top of the tubesheet. Mr. Mundas indicated that SCE was confident that any existing flaws would be found by inspecting 20% of the tubes with the bobbin coil and that the MRPC would be capable of finding flaws in the early stages of development. He added that the inspection plan would be evaluated if any flaws were found. Mr. Rosenblum said that SCE wanted a balanced perspective in

developing the inspection plan; to have reasonable assurance of finding an existing flaw using the bobbin coil and to find early indications of flaw development using the MRPC.

c. Comparison of San Onofre and Palo Verde

Mr. Clark provided a comparison of San Onofre and Palo Verde secondary operating characteristics. He described differences in steam generator and balance of plant designs. He also described San Onofre design features which contribute to maintaining low concentrations of impurities in the steam generators.

d. Closing Remarks

Mr. Perkins thanked the SCE personnel and indicated that the presentations were very informative. He reiterated Mr. Murphy's comment that SCE might want to consider additional eddy current MRPC inspections in the steam generator tubesheet area. Mr. Rosenblum said that SCE was very sensitive to steam generator tube issues and would want to deal with any potential problems early. He added that Mr. Murphy's comment would be considered.

EFFLUENT WARRANTY VALUES
(Continued)

1.3 Moderate Condenser Leakage (200 ppb Cl Influent)

| | |
|------------------------------|-----------------|
| Sodium | 0.1 ppb (max) |
| Chloride | 0.2 ppb (max) |
| Sulfate | 0.5 ppb (max) |
| Copper | 2.0 ppb (max) |
| Silica | 5.0 ppb (max) |
| Cation conductivity @ 25°C | 0.10 μ S/cm |
| Straight conductivity @ 25°C | 0.10 μ S/cm |
| Total Suspended Solids | 10.00 ppb (max) |
| Total Iron | 10.00 ppb (max) |
| pH @ 25°C. | 6.5 to 7.5 |
| Run length | 60 hrs. (min) |

1.4 Severe Condenser Inleakage (500 ppb Cl Influent)

| | |
|------------------------------|-----------------|
| Sodium | 0.2 ppb (max) |
| Chloride | 0.5 ppb (max) |
| Sulfate | 1.0 ppb (max) |
| Copper | 2.0 ppb (max) |
| Silica | 5.0 ppb (max) |
| Cation conductivity @ 25°C | 0.10 μ S/cm |
| Straight conductivity @ 25°C | 0.10 μ S/cm |
| Total Suspended Solids | 10.0 ppb (max) |
| Total Iron | 10.0 ppb (max) |
| pH @ 25°C. | 6.5 to 7.5 |
| Run length | 12 hours (min) |

Steam Generator Inspection

San Onofre Units 2 and 3

Southern California Edison

SIGNIFICANT SONGS DESIGN FEATURES

Steam Generator

Blowdown/Feedwater

Feedwater fed at the top of the shroud.

150 gpm/SG continuous and optimally located

Seawater Typical Chemistry

| | |
|------------------------------------|--------|
| Chloride (ppm) | 19,000 |
| Calcium (ppm as calcium carbonate) | 400 |
| Sulfate (ppm) | 2,650 |
| Silica (ppm) | 4 |

[illegible]

SIGNIFICANT SONGS DESIGN FEATURES

Full Flow Condensate Polishing Demineralizer (FFCPD)

- * Resin Fines Filters
5 u fines filters down stream of resin beds. No resin leakage.

- * Lead Cation Polisher (CPs)
Six lead CPs, removes all ammonia and sodium in condensate.
High sodium removal.

SECONDARY CHEMISTRY HISTORY

* Steam Generator Hideout Data

| | Unit 2 | | Unit 3 | |
|---------------|---------|---------|---------|---------|
| | Cycle 4 | Cycle 5 | Cycle 4 | Cycle 5 |
| Sodium (gm) | 64 | 66 | 60 | 80 |
| Sulfate (gm) | 96 | 210 | 50 | 106 |
| Chloride (gm) | 54 | 52 | 16 | 12 |

These values are within Industry average.

* Steam Generator Molar Ratios

| | Unit 2 | | | Unit 3 | | |
|--|---------|---------|---------|---------|---------|---------|
| | Cycle 4 | Cycle 5 | Present | Cycle 4 | Cycle 5 | Present |
| | 1.8 | 1.9 | 0.74 | 5.8 | 10.3 | 1.23 |

* Steam Generator Resin Intrusions

None.

SECONDARY CHEMISTRY HISTORY

Typical Steady State Secondary Chemistry

* Steam Generator

| | SONGS 1992/1989-1991 | EPRI GUIDELINES | RATIOS GL/SONGS |
|----------------|-------------------------|--------------------|--------------------|
| Cation (uS/cm) | 0.08/0.08 | < 0.8 | 10/10 |
| Chloride (ppb) | 0.3/0.3 | < 20 | 66.7/66.7 |
| Sulfate (ppb) | 0.1/0.3 | < 20 | 200/66.7 |
| Sodium (ppb) | 0.1/0.3 | < 20 | 200/66.7 |

* Condensate Demineralizer Effluent

| | | | |
|----------------|-------|-------|------|
| Chloride (ppb) | 0.002 | NA | |
| Sulfate (ppb) | 0.010 | NA | |
| Sodium (ppb) | 0.003 | < 3 | 1000 |
| Cation (uS/cm) | 0.057 | < 0.2 | 3.5 |

* Condenser Leaks

Leak detection @ 0.2 uS cat.cond.

No significant leaks, corrective action taken immediately

FFCPD in service to eliminate contaminants ingress to SG.

SONGS SECONDARY SYSTEM CHEMISTRY

HISTORY AND DESIGN FEATURES

**SAN ONOFRE/PALO VERDE COMPARISON
FACTORS AFFECTING SECONDARY IGA/IGSCC**

- **Operating Temperature (~ 532 deg F)**
- **Secondary Chemistry (Na ~0.1, Cl ~0.3, SO₄ ~0.1)**
- **Thermal Hydraulic Conditions (Maximum Quality 53%)**
- **Tube Proximity to Other Tubes (Three partial supports)**
- **Fabrication Defects/Scars (None identified)**
- **Tube Vibration (Effect not known)**

BALANCE OF PLANT DESIGN DIFFERENCES

| | Palo Verde ----- | San Onofre ----- |
|-------------------------------------|---|--|
| Condensate Polishing Demineralizers | Mixed bed only | Lead cation bed + mixed bed + resin fines filt. |
| Continuous Blowdown Capacity (gpm) | 36 - 50 | 100 - 150 |
| Cooling Water | Processed "gray" water + cooling tower treatment | Seawater |
| Feedwater Heater Tubing Material | Stainless steel | Copper- Nickel |

STEAM GENERATOR DESIGN DIFFERENCES

| | Palo Verde ----- | San Onofre ----- |
|---|--------------------------|---------------------|
| Type: | U-tube Recirc | U-tube Recirc |
| C-E Model: | System 80 | 3410 MWt |
| Number of Tubes: | 11,012 | 9,350 |
| Tube Diameter (in.) | 0.750 | 0.750 |
| Tube Wall Thickness (in.) | 0.043 | 0.048 |
| Tube Manufacturer: | Noranda (Units 1 & 2) | Sawhill |
| | Sandvick (Unit 3) | |
| Tubing Material: | Alloy 600 | Alloy 600 |
| Annealing Temperature (degF): | 1810-1850 | 1875 |
| Tube Support Type: | Lattice Bar | Lattice Bar |
| Tube Support Material: | Stainless Steel * | Carbon Steel |
| Number of Partial Tube Supports | 2 | 3 |
| Special Features (Palo Verde): | | |
| o Drilled stainless steel flow distribution plate | | |
| o Feedwater preheater (economizer) on cold-leg side | | |
| - Affects blowdown flow/concentrations | | |
| o No handhole access to tubesheet | | |
| o High capacity blowdown (short term) | | |
| Special Features (San Onofre): | | |
| o Handhole access to tubesheet | | |

* Except for "scallop bars"

SAN ONOFRE UNIT 2 STEAM GENERATOR INSPECTION
SAN ONOFRE/PALO VERDE COMPARISON

- **Steam Generator Design Differences**
- **Balance of Plant Design Differences**
- **Factors Affecting Secondary IGA/IGSCC**
- **Water Chemistry**

EDDY CURRENT TESTING IMPROVEMENTS

- Improved MRPC Probe Signal Amplitude
- Optimized Combinations of Probes/Frequencies
- All MRPC Data to be Plotted on C-Scan
- C-Scan Plots Use Doubled Amplitude




FIGURE 1. SCHEMATIC OF SONGS 2/3 STEAM GENERATORS

FIGURE 13 SONGS 2/3 SG DEPOSIT PARAMETER AT IZ = 23
(323 TO 338 IN. ABOVE TUBESHEET - HOT SIDE)

MAX. VALUE: 1.000






FIGURE 12 SONGS 2/3 SG DEPOSIT PARAMETER AT IZ = 22
(308 TO 323 IN. ABOVE TUBESHEET - HOT SIDE)

MAX. VALUE: 0.888






FIGURE 11 SONGS 2/3 SG DEPOSIT PARAMETER AT IZ = 21
(297 TO 308 IN. ABOVE TUBESHEET - HOT SIDE)

MAX. VALUE: 0.878






FIGURE 10 SONGS 2/3 SG DEPOSIT PARAMETER AT IZ = 20
(287 TO 297 IN. ABOVE TUBESHEET - HOT SIDE)

MAX. VALUE: 0.887






FIGURE 9 SONGS 2/3 SG DEPOSIT PARAMETER AT IZ = 19
(277 TO 287 IN. ABOVE TUBESHEET - HOT SIDE)

MAX. VALUE: 0.991









FIGURE 8 SONGS 2/3 SG DEPOSIT PARAMETER AT IZ = 6
(63 TO 81 IN. ABOVE TUBESHEET - HOT SIDE)

MAX. VALUE: 0.883








FIGURE 7

SONGS 2/3 SG - DEPOSIT PARAM. AT IX = 5 AND 10






FIGURE 6

SONGS 2/3 SG - DEPOSIT PARAM. AT IX = 4 AND 11




FIGURE 5






FIGURE 4






FIGURE 3




FIGURE 2. ATHOS II MODEL OF THE SAN ONOFRE STEAM GENERATOR

SAN ONOFRE UNIT 2 EDDY CURRENT TESTING PLAN
EDDY CURRENT TESTING IGA/IGSCC PROGRAM GOALS

- Use Best Available Eddy Current Test Techniques
- Identify Mid-Span /Tube Support IGA/IGSCC
- Quantify/Maximize Signal/Noise Ratio
- Identify Detectable Deposits
- Establish Baseline for Future Inspections

FACTORS AFFECTING SECONDARY IGA/IGSCC

- Operating Temperature
- Secondary Chemistry
- Thermal-Hydraulic Conditions
- Tube Proximity to Other Tubes
- Fabrication Defects/Scars
- Tube Vibration

06/93, SOUTHERN CALIFORNIA EDISON, SAN ONOFRE, UNIT 2

STEAM GENERATOR: 88

PROC: S023-XXVII-23.1

MRPC EXPANSION NUMBER 1


CRITERIA: TUBES TO BE EXAMINED IN GROUP (S) 13, 14, 15, 16, 17, 18, 19, 20

DATE: 06/29/93

TIME: 18:24:18

STAYS

PLUGGED 266 DBH-VSH 41 10H-VH1 21 69H-DBH 272 02H-03H 74



06/93, SOUTHERN CALIFORNIA EDISON, SAN ONOFRE, UNIT 2


STEAM GENERATOR: 88
PROC: S023-XXVII-23.1

DATE: 06/29/93
TIME: 11:56:51

CRITERIA: TUBES TO BE EXAMINED IN GROUP (S) 1, 2, 3, 4, 5, 6

STAYS

| | | | | | | | | | | | |
|----------|-------|--------|-----|--------|--------|--------|--------|--------|-------|--------|-------|
| PLUGGED | 200 ♦ | Group1 | 734 | Group3 | 1742 * | Group4 | 1480 O | Group5 | 262 * | Group6 | 108 7 |
| MULTIPLE | 319 X | | | | | | | | | | |



06/93, SOUTHERN CALIFORNIA EDISON, SAN ONOFRE, UNIT 2


STEAM GENERATOR: 88
PROC: S023-XXVII-23.1

DATE: 06/30/93
TIME: 13:18:06

CRITERIA: TUBES TO BE EXAMINED IN GROUP(S) 11, 12

STAYS

PLUGGED 266 ♦ Group11 260 ♦ Group12 210 ♦
MULTIPLE 0 *



06/93, SOUTHERN CALIFORNIA EDISON, SAN ONOFRE, UNIT 2


STEAM GENERATOR: 88
PROC: S023-XXVII-23.1

DATE: 06/30/93
TIME: 13:14:37

CRITERIA: TUBES TO BE EXAMINED IN GROUP(S) 1, 2, 3, 4, 5, 6

STAYS

PLUGGED 266 ♦ Group1 424 ♦ Group2 269 ♦ Group3 705 ♦ Group4 337 ♦ Group5 20 ♦ Group6 21 ♦
MULTIPLE 0 x



BASES FOR EDDY CURRENT TESTING PROGRAM

- Technical Specifications
 - 3%
 - + prior > 20% indications
- EPRI Recommendation
 - 20%
- Top of Hot Leg Tubesheet (MRPC)
 - o PWSCC
 - o Secondary IGA/IGSCC
 - 500 tubes/SG
- Profilometry
 - 100 tubes/SG
- Mid-Span/Tube Support IGA/IGSCC
 - under development


Steam Generator Status (con't)

| | SO2 | SO3 |
|----------------------------|------------|------------|
| Tubes Plugged | 614 | 555 |
| Improper Annealing | 62 | 24 |
| Batwing Wear | 460 | 459 |
| Vertical Strap Wear | 9 | 9 |
| Loose Part Wear | 3 | 15 |
| Tie-Rod Denting | 33 | 6 |
| Pre-Service | 21 | 35 |
| Other Causes | 26 | 7 |

Steam Generator Status

| | S02 | S03 |
|-------------------------|---------------|---------------|
| Tubes Installed | 18,700 | 18,700 |
| Tubes Plugged | 614 | 555 |
| Tubes In Service | 18,086 | 18,145 |

FIGURE 1: SIDE VIEW OF SONGS, UNITS 2 AND 3
STEAM GENERATORS



SAN ONOFRE UNIT 2 STEAM GENERATOR INSPECTION

EDDY CURRENT TESTING PLAN

- Steam Generator Characteristics/History
- Bases for Eddy Current Testing Program
- Factors Affecting Secondary IGA/IGSCC
- Preliminary Detailed Inspection Plan
- Eddy Current Testing Improvements

SONGS 2E088. TUBE LEAK


3/1/88

250 gpd


30 Mi nutes

FIGURE 2
1 Month by Days 100 Divisions 5th, 10th Accent

R 7870, AIR EJECTOR BASED PEAKRATE (GPD)



STEAM GENERATOR TUBE LEAKS




—●— Maine Yankee -+- Mihama #2 -x- Indian Point 3

RESPONSE TO INDICATION OF TUBE LEAKAGE

(SO123 - III - 2.22.23 & SO23 - 13 - 14)

- BLOWDOWN is sampled every 72 hours Air Ejector is sampled once per week.
- Upon indication of tube leakage Chemistry leak rate determinations increase to every 72 hours.
- Upon exceeding 10gpd leakage, Chemistry leak rate determinations increase to daily.
- Upon reaching the Air Ejector Alarm Setpoint (30 gpd) Operations begins logging RE-7870 readings.
- If RE-7870 indicates leakage has increased by more than 60gpd in any 1 hour period, verify the monitor response is real and sustained (by checking blowdown). If valid, then commence a rapid shutdown at 1% to 5% power per minute.
- For large leaks we would utilize our EOIs. A Mihama type of tube rupture event was run last year in simulator training. All 15 crews isolated the affected generator within 32 minutes.

AIR EJECTOR MONITOR 3-7870 ACTIVITY



DAILY AVE. (read early morning, past 1hr)

STEAM GENERATOR TUBE LEAKAGE MONITORING

| LOCATION | TYPE | FREQUENCY | LLD (AT Current RCS Activity) |
|-------------|---------|-----------------|----------------------------------|
| Air Ejector | Monitor | Continuous | < 1 gpd |
| Air Ejector | Alarm | Continuous | 30 gpd |
| Air Ejector | Grab | Weekly | ~ 0.1 gpd |
| Blowdown | Monitor | Continuous | ~ 5 gpd |
| Blowdown | Alarm | Continuous | ~1000 gpd |
| Blowdown | Grab | Every 72 Hours | < 1 gpd |
| Steamline | N-16 | As needed (new) | ~ 1 gpd |
| Steamline | Monitor | Continuous | ~3000 gpd |
| Feedwater | Tritium | As needed | ~ 0.3 gpd |

Unit 3 Tube Leakage - Likely Causes


W tube plug - 178 PIP's installed in Unit 3

CE tube plug

Tie-rod denting

Vertical strap or batwing wear

PRIMARY TO SECONDARY LEAK RATE MAY / JUNE 1993



*-- CALC FROM (Xe133) +-- CALC FROM (Xe135) — DAILY SAMPLE REQ
 — HOTWELL REQ x-- AE 3-7870 (uCi/sec)

UNIT 3

Vulnerability Assessment

| | |
|-------------------------------|------------------------|
| Secondary Chemistry | less vulnerable |
| Thermo-Hydraulics | less vulnerable |
| Tube Support Structure | less vulnerable |
| Operating Temperature | less vulnerable |

Agenda

Introduction

Unit 3 Steam Generator Tube Leakage

Leakage Progression

Suspected Cause

Operational Capabilities

Unit 2 Steam Generator Inspection

Background

Inspection Program

Comparison of PVNGS and SONGS

Mechanical and Plant Design

Chemistry Program

Summary