

ENCLOSURE 1 TO NL-13-147

IP-CALC-13-00062, R1

EVALUATION OF LEAK AT LINE 1093 IN UNIT 3 MOAT

ENTERGY NUCLEAR OPERATIONS, INC  
INDIAN POINT NUCLEAR GENERATING UNIT NO. 3  
DOCKET NO. 50-286

<input type="checkbox"/> ANO-1	<input type="checkbox"/> ANO-2	<input type="checkbox"/> GGNS	<input type="checkbox"/> IP-2	<input checked="" type="checkbox"/> IP-3	<input type="checkbox"/> PLP
<input type="checkbox"/> JAF	<input type="checkbox"/> PNPS	<input type="checkbox"/> RBS	<input type="checkbox"/> VY	<input type="checkbox"/> W3	
<input type="checkbox"/> NP-GGNS-3	<input type="checkbox"/> NP-RBS-3				
<b>CALCULATION COVER PAGE</b>		<sup>(1)</sup> EC # <b>47540</b>		<sup>(2)</sup> Page 1 of <u>7</u>	
<sup>(3)</sup> Design Basis Calc. <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO			<sup>(4)</sup> <input checked="" type="checkbox"/> CALCULATION <input type="checkbox"/> EC Markup		
<sup>(5)</sup> Calculation No: <b>IP-CALC-13-00062</b>				<sup>(6)</sup> Revision: <b>1</b>	
<sup>(7)</sup> Title: <b>Evaluation of Leak at Line 1093 in Unit 3 Moat</b>				<sup>(8)</sup> Editorial <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
<sup>(9)</sup> System(s): <b>SW</b>			<sup>(10)</sup> Review Org (Department): <b>Civil/Structural</b>		
<sup>(11)</sup> Safety Class: <input checked="" type="checkbox"/> Safety / Quality Related <input type="checkbox"/> Augmented Quality Program <input type="checkbox"/> Non-Safety Related			<sup>(12)</sup> Component/Equipment/Structure Type/Number: <b>Line 1093</b>		
<sup>(13)</sup> Document Type: <b>CALC</b>					
<sup>(14)</sup> Keywords (Description/Topical Codes):  <b>SW</b>					
<b>REVIEWS</b>					
<sup>(15)</sup> Name/Signature/Date <b>Kai Lo 10-30-2013</b> <i>[Signature]</i> <b>Responsible Engineer</b>		<sup>(16)</sup> Name/Signature/Date <b>G. Bhalla 10-30-2013</b> <i>[Signature]</i> <input checked="" type="checkbox"/> Design Verifier <input checked="" type="checkbox"/> Reviewer <input type="checkbox"/> Comments Attached		<sup>(17)</sup> Name/Signature/Date <b>R. Drake</b> <i>[Signature]</i> <b>Supervisor/Approval</b> 10/31/13 <input type="checkbox"/> Comments Attached	

<b>CALCULATION REFERENCE SHEET</b>	<b>CALCULATION NO:</b> <u>IP-CALC-13-00062</u> <b>REVISION:</b> <u>1</u>																																				
<b>I. EC Markups Incorporated</b> (N/A to NP calculations) 1. 2. 3. 4. 5.																																					
<b>II. Relationships:</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;">Sht</th> <th style="width: 10%;">Rev</th> <th style="width: 15%;">Input Doc</th> <th style="width: 15%;">Output Doc</th> <th style="width: 10%;">Impact Y/N</th> <th style="width: 15%;">Tracking No.</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td></td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> <td></td> <td></td> </tr> <tr> <td>2.</td> <td></td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> <td></td> <td></td> </tr> <tr> <td>3.</td> <td></td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> <td></td> <td></td> </tr> <tr> <td>4.</td> <td></td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> <td></td> <td></td> </tr> <tr> <td>5.</td> <td></td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table>	Sht	Rev	Input Doc	Output Doc	Impact Y/N	Tracking No.	1.		<input type="checkbox"/>	<input type="checkbox"/>			2.		<input type="checkbox"/>	<input type="checkbox"/>			3.		<input type="checkbox"/>	<input type="checkbox"/>			4.		<input type="checkbox"/>	<input type="checkbox"/>			5.		<input type="checkbox"/>	<input type="checkbox"/>		
Sht	Rev	Input Doc	Output Doc	Impact Y/N	Tracking No.																																
1.		<input type="checkbox"/>	<input type="checkbox"/>																																		
2.		<input type="checkbox"/>	<input type="checkbox"/>																																		
3.		<input type="checkbox"/>	<input type="checkbox"/>																																		
4.		<input type="checkbox"/>	<input type="checkbox"/>																																		
5.		<input type="checkbox"/>	<input type="checkbox"/>																																		
<b>III. CROSS REFERENCES:</b> 1. ENN-DC-185, "Through-Wall Leaks in ASME Section XI Class 3 Moderate Energy Piping Systems" 2. EN-CS-S-008-MULTI Rev. 0, "Pipe Wall Thinning Structural Evaluation" 3. ASME Code Case N513-3 4. USAS B31.1, Power Piping Code, 1967 & 1973 5. ASME B & PV Code, Section XI, 2001 edition 6. CR-IP3-2013-04174 7. CR-IP3-2013-04416 8. UT report <b>IP3-UT-13-058</b> 9. VT report IP3-VT-13-021																																					
<b>IV. SOFTWARE USED:</b> Title: _____ Version/Release: _____ Disk/CD No. _____																																					
<b>V. DISK/CDS INCLUDED:</b> Title: _____ Version/Release _____ Disk/CD No. _____																																					
<b>VI. OTHER CHANGES:</b>   																																					

Revision	Record of Revision
0	Initial issue.
1	Revised cover page 1, through 5 based on VT report IP3-VT-13-021. Revised Attachment A, page 4 and 5.

## LIST OF EFFECTIVE PAGES

Page 4 of 7

Calculation Number: IP-CALC-13-00062 Revision Number: 1

PAGE	REV.	PAGE	REV.	PAGE	REV.
All	0				
1 to 5	1				
6, 7	1				
Att. A p.1 to 3	0				
Att. A p.4, 5	1				
Att B p. 1 to 7	0				
Att B p. 8, 9	1				

<u>Topic</u>	<u>Page No.</u>
1 Calculation Cover Page .....	1
2 Calculation Reference Sheet .....	2
3 Record of Revisions .....	3
4 List of Effective Pages .....	4
5 Table of Contents .....	5
6 Calculation Section .....	6
6.1 Background .....	6
6.2 Purpose .....	6
6.3 Method of Analysis .....	6
6.4 Assumptions .....	6
6.5 Design Input .....	6
6.6 References .....	6
6.7 Calculation .....	6
6.8 Results/Conclusions .....	7

Attachment A: Calculation (5 pages)

Attachment B: Miscellaneous (9 pages)

Total number of pages: 23 pages

**6.1 Background**

On October 3, a through wall weeping leak was identified and later determined not to be an active leak on the 10"-1093 pipe in the Unit 3 moat in the transformer yard. An area was identified of missing metal of the pipe wall thickness approximately equals to  $\frac{3}{4}$ " x 3". The degraded pipe location is in the ISI code boundary. (See CR-IP3-2013-04174). There are two other areas approximately 20 feet away that show evidence of external corrosion. Structural operability evaluation is needed.

On October 29, after the removal of the support and coating on the pipe to facilitate the installation of a temporary repair clamp (EC-47124), the portion of the defect that is close to the bottom of pipe became more accessible. The length of the defect along the circumferential direction was found to be 8.25" (IP3-VT-13-021) instead of 4.75" (IP3-UT-13-058).

**6.2 Purpose**

The purpose of this calculation is twofold:

1. To determine the allowable through wall flaw length per ASME CC N-513-3. If the actual flaw including the leak is less than the allowable flaw length, then the pipe will be structurally adequate and operable.
2. To determine the minimum required pipe wall thickness per EN-CS-S-008-MULTI for the two areas that show external corrosion.

**6.3 Method of analysis**

1. The pipe is typically buried but is temporary supported every 8 feet. The pipe's bending stress is based on the 8 feet pipe span. The equivalent static method using the peak seismic acceleration from the ground response spectra is used in the determination of the pipe stress.
2. The pipe wall thickness around the 2" by 8.5" defect is based on 0.319", 87.5% of the nominal pipe wall thickness basing on the UT and VT report. The lowest of the five UT readings is 0.378" and visually the pipe surface around the defective area is in good, un-corroded condition.
3. For the through wall indication location, the allowable flaw length in the circumferential and axial direction are determined per CC-N513-3.
4. The minimum pipe wall thickness is determined based on EN-CS-S-008-MULTI. The lowest UT thickness from the two externally corroded locations is compared to the minimum required pipe wall thickness and the remaining service life is determined.

**6.4 Assumption**

1. For the through wall indication location (area#3), the adjusted wall thickness is the average value of the five UT readings around the defective area (2.5" by 4.75"), namely 0.382". The calculation conservatively uses 0.319". This value is judged to be conservative for the good, non-corroded metal surface around the newly found, lengthened defect area identified in the IP3-VT-13-00021.
2. For the average circumferential pipe wall thickness at the leak location area #3, 80% of the pipe's nominal wall thickness is used. This is conservative because the wall thinning is externally induced by failed coating and is usually localized around the damaged coating location.

**6.5 Design Input**

1. Pipe Specification TS-MS-027
2. USAS B31.1, Power Piping Code, 1967 & 1973
3. Drawing 9321-F-22363

4. UT report IP3-UT-13-058
5. VT report IP3-VT-13-021

#### 6.6 Reference

1. EN-CS-S-008-MULTI Rev. 0, "Pipe Wall Thinning Structural Evaluation"
2. ASME Code Case N513-3
3. USAS B31.1, Power Piping Code, 1967 & 1973
4. ASME B & PV Code, Section XI, 2001 edition
5. CR-IP3-2013-04174
6. CR-IP3-2013-04416
7. UT report IP3-UT-13-058
8. VT report IP3-VT-13-021
9. EC 47127

#### 6.7 Calculation

See Attachment A.

#### 6.8 Conclusion

1. Based on CC-N513-3, with an adjusted pipe wall thickness of 0.319", the allowable thorough wall flaw length in the circumferential direction is 9", greater than the measured 8.25"; the allowable thorough wall flaw length in the axial direction is 4.7", greater than the measured 2.5". The pipe is structurally adequate and operable. For 1.5 year of service until the outage, with an estimated average corrosion rate of 12 mils per year, the estimate flaw will be 2.54" axially and 8.29" circumferentially.
2. The minimum pipe wall thickness per EN-CS-S-008-MULTI is 0.073", less than the UT measured lowest reading of 0.109" at area #2 & 3. The remaining service life is 4.6 years unless if damaged coating is not repaired.
3. The original CR has identified occasional intermittent weepage at location area 1 at node point 4 on the weld. This has been identified as a pin hole leak with the entire area above the minimum wall thickness. This area is enveloped by the previous CCN513-3 evaluation for area 3.



# Attachment A

$P = \text{design pressure} = 150 \text{ psi}$   
 $D = \text{outside diameter} = 10.75 \text{ in}$   
 $t = \text{nominal wall thickness} = 0.365 \text{ in}$   
 $S = \text{section modulus} = 29.9 \text{ in}^3$   
 $L = \text{pipe span} = 8 \text{ ft} = 96 \text{ in}$   
 $w = \text{uniform weight of pipe, water \& cement lining} = 84.2 \text{ plf} = 7.017 \text{ \#/inch}$

Conservatively consider the pipe as simple support

$Ma = \text{moment due to DW} = wL^2/8 = 8083 \text{ in-lb}$   
 $Ma/S = 270 \text{ psi}$

For P + DW:

the leak section is at a straight pipe

$0.75i = 1.0$   
 $PD/4t = 1104 \text{ psi}$   
 $PD/(4t) + 0.75i(Ma/S) = 1375 \text{ psi} < Sh = 15000 \text{ psi}$

Using the peak G from DBE ground response spectra for 0.5% damping

MRM = multi modal response multiplier = 1.5

Gh = horizontal seismic acceleration = 0.64

Gv = vertical seismic acceleration = 0.427

$Gr = [Gh^2 + Gv^2]^{0.5} = 0.769$

MRM(Gr) = 1.154

Mb = seismic moment = MRM(Gr)(Ma) = 9326 in-lb

Ma + Mb = 17409 in-lb

$PD/(4t) + 0.75i(Ma + Mb)/S = 1687 \text{ psi} < 1.8Sh = 27000 \text{ psi}$

For OBE

MRM = multi modal response multiplier = 1.5

Gh = horizontal seismic acceleration = 0.427

Gv = vertical seismic acceleration = 0.284

$Gr = [Gh^2 + Gv^2]^{0.5} = 0.513$

MRM(Gr) = 0.769

Mb = seismic moment = MRM(Gr)(Ma) = 6217 in-lb

Ma + Mb = 14301 in-lb

$PD/(4t) + 0.75i(Ma + Mb)/S = 1583 \text{ psi} < 1.2Sh = 18000 \text{ psi}$

**1. Design Parameters**

- D<sub>o</sub>: Outside Diameter, (in)
- t<sub>nom</sub>: Nominal Thickness, (in)
- Material
- P: Design Pressure, (psi)
- T: Design Temperature, (°F)
- S<sub>h</sub>: Allowable Stress at Design Temperature, (psi) (See App. A of B31.1)
- S<sub>A</sub>: Thermal Expansion Allowable Stress, (psi)
- A: An additional thickness per Section 104.1 of B31.1, (in)

10.75
0.365
A53 Gr B
150
160
15000
22500
0

**2. Prediction of Min. Thickness at Next Inspection, t<sub>p</sub>**

- t<sub>meas</sub>: Measured thickness of latest inspection, (in)
- W<sub>r</sub>: Wear Rate (in/yr)
- Y: Service years between the latest and next inspections, (yr)
- SF: Safety factor
- Projected thermal cycles between the latest and next inspections
- t<sub>p</sub> = t<sub>meas</sub> - SF\*W<sub>r</sub>\*Y, (in)
- R<sub>o</sub>/t<sub>p</sub> ≤ 50, "OK"; or > 50, "Buckling Evaluation Required"

lowest UT	0.109
	0.00711
	1.5
(1)	1.1
	80
	0.0973
R <sub>o</sub> /t <sub>p</sub> =	55
	Buckling Eval Req
	12.30

b = estimate width of thinned section =

Based on clamp support at 4 edges, allowable buckling stress = 8.46E(t<sub>p</sub>/b)<sup>2</sup> =

- Actual compressive stress = [S<sub>nor</sub> - PD/(4t<sub>nom</sub>)](t<sub>nom</sub>/t<sub>p</sub>)(l'/l)
- Actual compressive stress = [S<sub>ups</sub> - PD/(4t<sub>nom</sub>)](t<sub>nom</sub>/t<sub>p</sub>)(l'/l)
- Actual compressive stress = [S<sub>emg</sub> - PD/(4t<sub>nom</sub>)](t<sub>nom</sub>/t<sub>p</sub>)(l'/l)

14760 psi < S <sub>h</sub>
1014 psi, o.k.
1795 psi, o.k. < 1.2S <sub>h</sub>
2185 psi, o.k. < 1.8S <sub>h</sub>
15000
18000
27000

**3. Screening Rules for Pipe Wall Thinning**

- Rule 1: Acceptance Standard = 0.875\*t<sub>nom</sub>
- Rule 2: Minimum Required Thickness
  - 0.3\*t<sub>nom</sub> for Class 1
  - 0.2\*t<sub>nom</sub> for Class 2 or 3
- Rule 3: Between the above two limits, wall thinning can be accepted by a structural evaluation

	0.319
(2), (3)	0.110
	0.073

Action required based on the above screening rules for the inspected thinned pipe

- Class 1 piping
- Class 2 or 3 piping

Replace or repair  
Structural Evaluation Req'd

**4. Structural Evaluation**

a. Minimum Thickness for Hoop Stress :

t<sub>min</sub> = P\*D<sub>o</sub>/[2(S<sub>h</sub>+4\*P)] + A, (in)

0.054

b. Minimum Thickness for Axial Stress :

(4)

Is the thermal expansion stress required to be evaluated?  
( No for t<sub>p</sub> ≥ 0.75\*t<sub>nom</sub> and cycles ≤ 150; Yes for otherwise)

Yes

- K<sub>Nor</sub>: Allowable stress increase factor for Normal Condition
- K<sub>Ups</sub>: Allowable stress increase factor for Upset Condition
- K<sub>Emg</sub>: Allowable stress increase factor for Emergency Condition
- γ: Allowable stress increase factor for CC-N-597

1.0
1.2
1.8
1.143

Original Piping Stresses

S<sub>Nor</sub> : Normal Condition Stress, (psi)  
 S<sub>Ups</sub> : Upset Condition Stress, (psi)  
 S<sub>Emg</sub> : Emergency Condition Stress, (psi)  
 S<sub>The</sub> : Thermal Expansion Stress, (psi)

1375
1583
1687
0

Let  $t_{min}^a =$

$i =$

$i' =$

$i' / i =$

$Z/Z' = [D_o^4 - (D_o - 2t_{nom})^4] / [D_o^4 - (D_o - 2t_{min}^a)^4]$

(5)

(6)

0.029
1.0
1.0
1.000
11.45

Allowable Stress - Axial Stress  $\geq 0$

Normal conditions:  $\gamma * K_{Nor} * S_h - [ P * D_o / 4 t_{min}^a + (i'/i) * (S_{Nor} - P * D_o / 4 t_{nom}) * (Z/Z') ] \geq 0$  148  
 Upset conditions:  $\gamma * K_{Ups} * S_h - [ P * D_o / 4 t_{min}^a + (i'/i) * (S_{Ups} - P * D_o / 4 t_{nom}) * (Z/Z') ] \geq 0$  1195  
 Emergency conditions:  $\gamma * K_{Emg} * S_h - [ P * D_o / 4 t_{min}^a + (i'/i) * (S_{Emg} - P * D_o / 4 t_{nom}) * (Z/Z') ] \geq 0$  10291  
 Normal and Ther. Expansion conditions:  $\gamma * (S_h + S_A) - [ P * D_o / 4 t_{min}^a + (i'/i) * (S_{Nor} - P * D_o / 4 t_{nom} + S_{The}) * (Z/Z') ] \geq 0$  25865

c. Minimum Required Thickness

Class 1:  $t_{min} = \text{Max. } [ t_{min}, t_{min}^a, 0.3 * t_{nom} ]$ , (in); Acceptable if  $t_p \geq t_{min}$  0.110 No  
 Class 2 & 3:  $t_{min} = \text{Max. } [ t_{min}, t_{min}^a, 0.2 * t_{nom} ]$ , (in); Acceptable if  $t_p \geq t_{min}$  0.073 Yes

5. Remaining Service Life (RSL)

Class 1:  $RSL = [ t_{meas} - t_{min} ] / (SF * W_r)$ , (yr) -0.1  
 Class 2 & 3:  $RSL = [ t_{meas} - t_{min}^a ] / (SF * W_r)$ , (yr) 4.6

Notes:

- (1) The wear rate will be obtained from Responsible FAC Engineer or based on the Attachment 7.7.
- (2) The acceptance standard ( $0.875 t_{nom}$ ) can not be applied to:
  1. Class 1 short radius elbows,
  2. Reinforcement area of a tee or branch connection, and
  3. For regions of piping designed to specific wall thickness requirements, such as counterbores or weld attachments.
- (3) For the small end of reducers, the standard shall be based on the  $t_{nom}$  of the pipe size at the small end. For the large end, the large end transition and the conical portion, it shall be based on the  $t_{nom}$  of the pipe size at the larger end.
- (4) The formula is applicable for straight pipes, bends, and elbows.
 

For reducers,  $t_{min}$  at each end shall be equal to  $t_{min}$  of straight pipe of the same nominal size as the reducer end.

For the conical portion and transition at larger end of reducers,  $t_{min}$  shall be that of the large diameter pipe end.

For branch connections and tees, the reinforcement area of the opening shall be based on the B31.1 code.
- (5)  $t_{min}^a$  can be obtained by the "Trial and Error" method until the "Allowable Stress - Axial Stress" due to Normal, Upset, Emergency, and combined Normal and Thermal Expansion conditions are all positive and one of them shall be close to zero.
- (6) (i) can be calculated from Appendix D of ANSI B31.1. (i') needs to be adjusted for the pipe wall thinning. It is suggested that the average thickness or 2 times of the original value be used for the i' calculation.

**A. Pipe Parameters**

- D<sub>o</sub> = Pipe OD (in)
- t<sub>adj</sub> = Pipe wall thickness at flaw location (in)
- t<sub>ave</sub> = average wall thickness of pipe circumference based on UT report (in)
- t<sub>nom</sub> = nominal pipe wall thickness (in)
- p<sub>d</sub> = Design Pressure (psi)
- p<sub>o</sub> = Operational Pressure (psi) (< 275 psig)
- T = Metal Temperature at evaluation (°F) (< 200°F)
- E = elastic modulus at T (ksi)
- v = poisson ratio
- J<sub>1c</sub> = material toughness (lb/in) 7161.6
- S = allowable stress for pipe (ksi) 1104
- i = SIF = stress intensification factor used in the stress analysis
- Service Level
- p<sub>d</sub>D<sub>o</sub>/(4t<sub>nom</sub>) or from stress summary: Axial stress due to design pressure (ksi)
- s = p<sub>d</sub>D<sub>o</sub>/(4t<sub>nom</sub>) + (0.75i)σ<sub>b</sub>: Piping Axial Stress (ksi, from stress output)
- SF<sub>m</sub>: Level A = 2.7; Level B = 2.4; Level c = 1.8; Level D = 1.3 [C-2621& 2622]
- SF<sub>b</sub>: Level A = 2.3; Level B = 2.0; Level c = 1.6; Level D = 1.4 [C-2621]
- R<sub>m</sub> = pipe mean radius (in) = (D<sub>o</sub> - t)/2
- E' = E/(1 - v<sup>2</sup>)
- K<sub>1c</sub> = material critical stress intensity factor = J<sub>1c</sub>\*E'/1000<sup>0.5</sup> (ksi(in)<sup>0.5</sup>)

10.75
0.319
0.290
0.365
150
90
70
27800
0.3
45
15
1.00

	A	B	C	D
	1.10	1.10	1.10	1.10
	1.37	1.58	1.69	1.69
	2.7	2.4	1.8	1.3
	2.3	2.0	1.6	1.4
				5.216
				30549
				37.08

**B. Evaluate as a planar flaw in axial direction**

(Based on LFM C-7400 & N513-2, I-3.0)

- Service Level
- c = l/2 = Half axial flaw length (in), try "c" to make K<sub>1c</sub> - K<sub>1</sub> >= 0.0
- p = pressure for the service level condition
- σ<sub>h</sub> = p\*D<sub>o</sub>/(2t)/1000 (ksi)
- For through wall flaw, a = c:
- λ = c/(tR<sub>m</sub>)<sup>0.5</sup>
- F = 1 + Aλ + Bλ<sup>2</sup> + Cλ<sup>3</sup> + Dλ<sup>4</sup> + Eλ<sup>5</sup>
- Where A= 0.0724 B= 0.6486 C= -0.2327 D= 0.0382 E= -0.0023
- K<sub>1c</sub> - K<sub>1</sub> = K<sub>1c</sub> - K<sub>1m</sub> = (SF<sub>m</sub>)Fσ<sub>h</sub>(πc)<sup>0.5</sup> (ksi(in)<sup>0.5</sup>)
- flaw length "2c"

	A	B	C	D
	3.21	2.35	2.96	3.82
	90	150	150	150
	1.52	2.53	2.53	2.53
	2.49	1.82	2.29	2.96
	2.85	2.25	2.67	3.26
	0.00	0.00	0.00	0.00
	6.42	4.70	5.91	7.64

Allowable Axial Flaw Length = Smaller "2c" of four service levels (in.) =

**4.70**

**C. Evaluate as a planar flaw in circumferential direction**

- Service Level
- (0.75i) >= 1.0
- σ<sub>b</sub> = (s - p<sub>d</sub>D<sub>o</sub>/(4t<sub>nom</sub>))/(0.75i) (ksi)
- σ<sub>b</sub> = σ<sub>b</sub>[D<sub>o</sub><sup>4</sup> - (D<sub>o</sub> - 2t<sub>nom</sub>)<sup>4</sup>]/[D<sub>o</sub><sup>4</sup> - (D<sub>o</sub> - 2t<sub>ave</sub>)<sup>4</sup>] (ksi)
- p = pressure at the service level
- σ<sub>m</sub> = pD<sub>o</sub>/(4t<sub>ave</sub>): Axial stress due to service pressure (ksi)
- K<sub>1c</sub> =
- For through wall flaw, based on a = c
- c: Half circumferential flaw length, try "c" to make K<sub>1c</sub> - K<sub>1</sub> > 0.0
- α = c/(πR<sub>m</sub>)
- r = R<sub>m</sub>/t
- i = 0 1 2 3
- A<sub>m</sub> = A<sub>m0</sub> + A<sub>m1</sub>\*r + A<sub>m2</sub>\*r<sup>2</sup> + A<sub>m3</sub>\*r<sup>3</sup> A<sub>mi</sub> -2.0292 1.6776 -0.0799 0.0018
- B<sub>m</sub> = B<sub>m0</sub> + B<sub>m1</sub>\*r + B<sub>m2</sub>\*r<sup>2</sup> + B<sub>m3</sub>\*r<sup>3</sup> B<sub>mi</sub> 7.0999 -4.4239 0.2104 -0.0046
- C<sub>m</sub> = C<sub>m0</sub> + C<sub>m1</sub>\*r + C<sub>m2</sub>\*r<sup>2</sup> + C<sub>m3</sub>\*r<sup>3</sup> C<sub>mi</sub> 7.7966 5.1668 -0.2458 0.0054
- A<sub>b</sub> = A<sub>b0</sub> + A<sub>b1</sub>\*r + A<sub>b2</sub>\*r<sup>2</sup> + A<sub>b3</sub>\*r<sup>3</sup> A<sub>bi</sub> -3.2654 1.5278 -0.0727 0.0016
- B<sub>b</sub> = B<sub>b0</sub> + B<sub>b1</sub>\*r + B<sub>b2</sub>\*r<sup>2</sup> + B<sub>b3</sub>\*r<sup>3</sup> B<sub>bi</sub> 11.363 -3.9141 0.1862 -0.0041
- C<sub>b</sub> = C<sub>b0</sub> + C<sub>b1</sub>\*r + C<sub>b2</sub>\*r<sup>2</sup> + C<sub>b3</sub>\*r<sup>3</sup> C<sub>bi</sub> -3.1861 3.8476 -0.1830 0.0040
- F<sub>m</sub> = 1 + A<sub>m</sub>\*α<sup>1.5</sup> + B<sub>m</sub>\*α<sup>2.5</sup> + C<sub>m</sub>\*α<sup>3.5</sup>
- F<sub>b</sub> = 1 + A<sub>b</sub>\*α<sup>1.5</sup> + B<sub>b</sub>\*α<sup>2.5</sup> + C<sub>b</sub>\*α<sup>3.5</sup>
- K<sub>1c</sub> - K<sub>1</sub> = K<sub>1c</sub> - [(SF<sub>m</sub>)(πc)<sup>0.5</sup>(σ<sub>m</sub>F<sub>m</sub>) + SF<sub>b</sub>(πc)<sup>0.5</sup>(σ<sub>b</sub>F<sub>b</sub>)] >= 0.0
- Flaw length (2c) =

	A	B	C	D
	1.00	1.00	1.00	1.00
	0.27	0.48	0.58	0.58
	0.334	0.590	0.718	0.718
	90	150	150	150
	0.83	1.39	1.39	1.39
	37.1	37.1	37.1	37.1
	6.32	4.81	5.65	6.68
	0.386	0.293	0.345	0.407
	16.3	16.3	16.3	16.3
	11.7	11.7	11.7	11.7
	-29	-29	-29	-29
	50.2	50.2	50.2	50.2
	9.3	9.3	9.3	9.3
	-21	-21	-21	-21
	28.4	28.4	28.4	28.4
	2.90	2.19	2.55	3.12
	2.32	1.89	2.11	2.44
	0.0	0.0	0.0	0.0
	12.65	9.61	11.30	13.35

Allowable Circumferential Crack Length = Smaller "2c" of 4 service levels (in.) =

**9.61**

**D. Determine the flaw length from the UT report using the adjusted wall thickness,  $t_{adj}$**

$L_{axial}$  = length of through wall flaw in the axial direction of the pipe (inch)

$2.5" + 1.5(2)(.012) =$  2.54 < allow flaw, O.K

$L_{circ}$  = length of through wall flaw in the circumferential direction of the pipe (inch)

$8.25" + 1.5(2)(.012) =$  8.29 < allow flaw, O.K

**E. Minimum remaining ligament thickness requirement**

[N-513-3, 3.2(d)]

$t_{min} = P_d \cdot D_o / [2(S + .4 \cdot P_d)] + A$ , (in),  $A = 0$

$d_{adj} = 1.5 [R_m t_{adj}]^{0.5} (t_{adj} - t_{min}) / t_{min}$  (in)

9.59	use	9.00
		0.054 0.318

Minimum remaining ligament thickness requirement =  $0.353 d_{adj} (P/S)^{0.5}$  (in)

Minimum remaining ligament thickness is less than adjusted thickness used in Section A, O.K.

Originator: Allen II, Robert E

Originator Phone: 6774

Originator Site Group: IP3 P&amp;C Eng Codes Staff IP3

Operability Required: Y

Supervisor Name: Azevedo, Nelson F

Reportability Required: Y

Discovered Date: 10/30/2013 09:39

Initiated Date: 10/30/2013 09:48

**Condition Description:**

Further visual examination of Line No. 1093 in the 32 MT moat excavation revealed that the corroded area originally found (ref. CR-IP3-2013-04174) extended underneath the pipe to the area that was resting on the wood support. The area now measures 8-1/4" circumferentially and 2" wide in the axial direction. The remainder of the exposed pipe in that area was in good condition with no corrosion.

**Immediate Action Description:**

The pipe surface was cleaned up and pipe clamp installed over the corroded area.

**Suggested Action Description:**

Engineering to evaluate this information.

**EQUIPMENT:**Tag Name

10 LINE 1093

Tag Suffix Name Component Code Process System Code

PIPE

SW

**REFERENCE ITEMS:**Type Code

DOC

DWG

WON

Item Desc

VT report IP3-VT-13-021

9321-F-22363

00350692-31

# Attachment B





Entergy

# UT Erosion/Corrosion Examination

Site/Unit: IP3 / 3  
 Summary No.: 10" Line # 1093  
 Workscope: BOP

Procedure: CEP-NDE-0505  
 Procedure Rev.: 4  
 Work Order No.: 00350692-17

Outage No.: N/A  
 Report No.: IP3-UT-13-058  
 Page: 1 of 7

Code: ANSI B31.1, '67 Ed. - '69 Ad. Cat./Item: / Location: YD - 5'

Drawing No.: 9321-F-22363 Description: Characterize (3) areas of corrosion found in the MT Moat excavation

System ID: Service Water

Component ID: 10" Line # 1093 Size/Length: 10" Sch 40 Thickness/Diameter: 0.365"

Limitations: None Component File No.: N/A Start Time: 1418 Finish Time: 1455

Calibration Information			
Calibration Thickness (In)		Calibration Times / Initials	
Actual	Measured		
0.040"	0.500"	Start: 1418	REA
0.100"	N/A	Verify: 1425	REA
0.200"	N/A	Verify: N/A	
0.300"	N/A	Verify: 1440	REA
0.400"	N/A	Final: 1455	REA

Partitioning Information		
Component	Begin/Col/Row	Ending/Col/Row
M. UPST Ext.	N/A	
Main UPST.	N/A	
Main	N/A	
Main DNST.	N/A	
M. DNST Ext.	N/A	
Branch	N/A	
Branch Ext.	N/A	

Component Information	
Component Geometry:	<u>Pipe</u>
Outside Diameter:	<u>10"</u> Grid Size: <u>N/A</u>
Max. Thickness:	<u>0.394"</u> Min. Thickness: <u>0.109"</u>
Nominal Thickness:	<u>0.365"</u> Tmin.: <u>0.319"</u>
Min. Thickness Location:	<u>Area 1</u>
Max. Thickness Location:	<u>Area 1 &amp; 2</u>
Surface Condition:	<u>As preped</u>

Instrument:  
 Manufacturer: Panametrics  
 Model: 37-DL Plus  
 Serial No.: 031110106  
 Gain: 50 dB  
 Range: 1.00"

Transducer:  
 Manufacturer: Panametrics  
 Serial No.: 536066  
 Size: 0.283" Freq.: 7.5 MHz  
 Model: D798  
 # of Elements: Dual

Reference/Simulator Block:  
 Serial No.: 99-7437  
 Type: C/S 0.04"-0.5"  
 Ref./Simulator Block Temp.: 76.1 °F  
 Material/Component Temp.: 74.2 °F

Temp. Tool:  
 Manufacturer: Control Co., Inc  
 Serial No.: QS-97  
 Couplant:  
 Type: Ultragel II  
 Batch No.: 12125

Comments/Obstructions: The coating was removed and the pipe preped prior to this exam.

Results: Accept  Reject  Info  Tmin = 87.5% Nominal Thickness. Reference CR-IP3-2013-04174


Examiner	Level	III EOI	Signature	Date	Reviewer	Signature	Date
Allen, Robert E.				10/3/2013	N/A		
Examiner	Level	N/A	Signature	Date	Site Review	Signature	Date
N/A					J. PERSON		10/7/2013
Other	Level	N/A	Signature	Date	ANII Review	Signature	Date
N/A					N/A		




# Supplemental Report

Report No.: IP3-UT-13-058

Page: 2 of 7

Summary No.: 10" Line # 1093  
Examiner: Allen, Robert E.   
Examiner: N/A  
Other: N/A


Level: III EOI  
Level: N/A  
Level: N/A

Reviewer: N/A  
Site Review:   
ANII Review: N/A


Date: \_\_\_\_\_  
Date: 10/7/2013  
Date: \_\_\_\_\_

Comments: Photo left below of Area 1, North end of the pipe in the moat. Photo right below showing the UTT locations.

Sketch or Photo: \\Client\Y\$\Ideal Ver 8\Ideal\_Server\IDDEAL\_IP3\Graphics-Pictures\Service Water\10 Line 1093 area 1a.jpg



\\Client\Y\$\Ideal Ver 8\Ideal\_Server\IDDEAL\_IP3\Graphics-Pictures\Service Water\10 Line 1093 area 1b.jpg





Entergy

# Supplemental Report

Report No.: IP3-UT-13-058

Page: 3 of 7

Summary No.: 10" Line # 1093

Examiner: Allen, Robert E.

Level: III EOI

Reviewer: [Signature]

Date: \_\_\_\_\_

Examiner: N/A

Level: N/A

Site Review: [Signature]

Date: 10/7/2013

Other: N/A


Level: N/A

ANII Review: N/A

Date: \_\_\_\_\_

Comments: Area 1 UTT readings.

Sketch or Photo: \\Client\YS\Ideal Ver 8\Ideal\_Server\IDEAL\_IP3\Graphics-Pictures\Service Water\10 in Line 1093 Area 1.TIF







# Supplemental Report

Report No.: IP3-UT-13-058

Page: 4 of 7

Summary No.: 10" Line # 1093

Examiner: Allen, Robert E.

Examiner: N/A

Other: N/A

Level: III EOI

Level: N/A

Level: N/A

Reviewer: N/A

Site Review: [Signature]

ANII Review: N/A


Date: \_\_\_\_\_

Date: 10/7/2013


Date: \_\_\_\_\_

Comments: Photo left below of Area 2, North end of the pipe in the moat just South of Area 1. Photo right below showing the UTT locations.

Sketch or Photo: \\Client\Y\$\Ideal Ver 8\Ideal\_Server\IDDEAL\_IP3\Graphics-Pictures\Service Water\10 Line 1093 area 2a.jpg



Sketch or Photo: \\Client\Y\$\Ideal Ver 8\Ideal\_Server\IDDEAL\_IP3\Graphics-Pictures\Service Water\10 Line 1093 area 2b.jpg






# Supplemental Report

Report No.: IP3-UT-13-058

Page: 5 of 7

Summary No.: 10" Line # 1093

Examiner: Allen, Robert E. 

Level: III EOI

Reviewer: N/A

Date: \_\_\_\_\_

Examiner: N/A

Level: N/A

Site Review: 

Date: 10/7/2013

Other: N/A


Level: N/A

ANII Review: N/A

Date: \_\_\_\_\_

Comments: **Area 2 UTT readings.**

Sketch or Photo: \\Client\Y\$\Ideal Ver 8\ideal\_Server\IDDEAL\_IP3\Graphics-Pictures\Service Water\10 in Line 1093 Area 2.TIF



- |           |           |            |            |
|-----------|-----------|------------|------------|
| 1 - .394" | 5 - .265" | 9 - .326"  | 13 - .389" |
| 2 - .280" | 6 - .391" | 10 - .341" |            |
| 3 - .320" | 7 - .339" | 11 - .350" |            |
| 4 - .320" | 8 - .387" | 12 - .354" |            |





# Supplemental Report

Report No.: IP3-UT-13-058

Page: 6 of 7

Summary No.: 10" Line # 1093

Examiner: Allen, Robert E.

Examiner: N/A

Other: N/A

Level: III EOI

Level: N/A

Level: N/A

Reviewer: N/A

Site Review: [Signature]

ANII Review: N/A


Date: \_\_\_\_\_

Date: 10/7/2013


Date: \_\_\_\_\_

Comments: Photo left below of area 3, mid span of the pipe in the moat South of areas 1 & 2. Line 1 and line 2 are the locations where pit gage readings were taken 1/4" apart across the area of thinning. Photo right below showing the pit gage at maximum depth of 3/8".

Sketch or Photo: \\Client\Y\$\Ideal Ver 8\Ideal\_Server\IDDEAL\_IP3\Graphics-Pictures\Service Water\10 Line 1093 area 3a.jpg



\\Client\Y\$\Ideal Ver 8\Ideal\_Server\IDDEAL\_IP3\Graphics-Pictures\Service Water\10 Line 1093 area 3b.jpg






Entergy

# Supplemental Report

Report No.: IP3-UT-13-058

Page: 7 of 7

Summary No.: 10" Line # 1093

Examiner: Allen, Robert E. 

Examiner: N/A


Other: N/A

Level: III EOI

Level: N/A

Level: N/A

Reviewer: N/A

Site Review: 

ANII Review: N/A

Date: \_\_\_\_\_


Date: 10/27/13

Date: \_\_\_\_\_

Comments: Area 3 UTT and pit gage readings.

Sketch or Photo: \\Client\YS\Ideal Ver 8\Ideal\_Server\IDDEAL\_IP3\Graphics-Pictures\Service Water\10 in Line 1093 Area 3.TIF

## AREA 3



PIT GAGE READING @ 1/4" SPACING:

Row	1/4"	1/2"	3/4"	1"	1 1/4"	1 1/2"	1 3/4"	2"	2 1/4"
1	1/32"	1/16"	3/16"	1/4"	3/8"	3/8"	5/16"	3/16"	1/32"
2	1/64"	1/16"	7/32"	5/16"	3/8"	5/16"	3/16"	1/32"	-

UTT READINGS:

A - .387"

B - .387"

C - .380"

D - .378"

E - .378"