

SUMMARY OF RESULTS FOR RTS ACTIVE VALVE
AND EQUIPMENT EVALUATIONS

Prepared For:
Southern California Edison Company

Prepared By:
Impell Corporation
350 Lennon Lane
Walnut Creek, CA 94598

REPORT NUMBER 01-0310-1315

November 8, 1984

8411260421 841120
PDR ADOCK 05000206
P PDR

TABLE OF CONTENTS

	<u>Page</u>
Coversheet	i
Contents	ii
List of Tables	iii
1.0 Introduction	1
2.0 Scope	1
3.0 Evaluation Criteria	1
3.1 Equipment Supports	1
3.2 Active Valves	1
3.3 Passive Values	2
3.4 Load Combinations	2
3.4.1 Equipment Supports	2
3.4.2 Active Valves	2
4.0 Evaluation Methodology	2
4.1 Equipment Supports	2
4.2 Active Valves	3
5.0 Results	3
6.0 References	4
Appendix A - Equipment Support Evaluation Summaries	9
Appendix B - Valve Qualification Levels	21
Appendix C - Valve Body Stresses for RTS Valves (Impell letter No. 0310-036-015, dated 09/25/84)	25

LIST OF TABLES

	<u>Page</u>
Table 2.1 Equipment Items	7
Table 2.2 Active Valves	8
Table A-01 Summary of Results for Auxiliary Feedwater Turbine Driven Pump	10
Table A-02 Summary of Results for CVCS Test Pump	11
Table A-03 Summary of Results for Seal Water Injection Filters, C-42, C-42S	12
Table A-04 Summary of Results for Seal Water Supply Filters, C-952A, C-952C	13
Table A-05 Summary of Results for Seal Water Supply Filter, C-952B	14
Table A-06 Summary of Results for Seal Water Heat Exchanger, E-34	15
Table A-07 Summary of Results for the Water Cooled Charging Pump Oil Coolers	16
Table A-08 Summary of Results for the Air Cooled Charging Pump Oil Coolers	17
Table A-09 Summary of Results for the Charging Pumps, G8A,B	18
Table A-10 Summary of Results for the Auxiliary Feedwater Motor Driven Pump	19
Table A-11 Summary of Results for the Seal Water Return Filter, C-40	20
Table B-1 Valve Qualification Levels	22

1.0 INTRODUCTION

As part of the Return To Service (RTS) efforts for the San Onofre Nuclear Generating Station Unit 1 (SONGS-1), seismic evaluations were performed for mechanical equipment supports and valves. The methods used and the results of these evaluations are described in the following sections.

2.0 SCOPE

The components evaluated include 11 equipment types (14 equipment items) and 88 valves. The equipment items are listed in Table 2.1 and the valves are listed in Table 2.2.

3.0 EVALUATION CRITERIA

3.1 Equipment Supports

The evaluation criteria for the equipment supports are based on the requirement that the supports maintain their structural integrity during and after a design basis earthquake.

The criteria for all structural elements, with the exception of concrete expansion bolts, were based on Section III, Appendix F of the ASME Code for Level D service limits. These stress limits allow local yielding but ensure the overall stability of the structure. The more stringent criteria of Service Level A were applied to some components. Qualification to Level A limits demonstrates a large safety factor and envelopes all possible loading conditions. Criteria were established for bending, axial, and shear loads as well as checks on welds, bolting, and member stability.

The RTS expansion bolt allowables were established by applying a factor of safety to the ultimate bolt pullout capacity. For normal conditions the allowable load is taken as 1/4 of the ultimate capacity. This provides a safety factor of 4.0. The RTS evaluations are based on the Design Basis Earthquake (DBE), a one time event with an extremely low probability of occurrence. Based on this low probability, interim criteria for the RTS have been established using 1/2 of the ultimate capacity. This provides a safety factor of 2 and meets the criteria established in [2].

A more detailed description of the equipment criteria is contained in [3].

3.2 Active Valves

Eighty-eight (88) valves have been designated as "active" by SCE and were evaluated. The evaluation criteria for the active valves was established to ensure the functionality and structural integrity of the valves during and after a design basis earthquake.

The seismic capacities of the valves were determined based on the bending, axial, and shear stresses in the critical section of the valve and the requirements of Section III, Appendix XVII of the ASME Code [1]. Qualification was demonstrated by comparing the seismic capacity of the valve to the seismic acceleration resulting from the actual pipe/pipe support configuration.

Functionality of the valves is ensured by limiting all stresses to the elastic range. The Level C allowable stresses of Appendix XVII maintain all stresses below the yield point.

In addition to demonstrating pressure integrity, the BOPMEP criteria for SONGS 1 [38] require that stresses in the valve bodies are limited to yield.

A more detailed description of the valve criteria is contained in [4].

3.3 Passive Valves

Passive Valves are not required to operate during or after the postulated seismic event. Therefore gross deformations in the extended structures (non-pressure retaining components) are acceptable and these parts were not included in Impell's RTS work scope.

The BOPMEP criteria [38] limit stresses in the valve bodies to the level D limit of [1]. The evaluation of valve body stresses is described in Appendix C.

3.4 Load Combinations

3.4.1 Equipment Supports

Evaluations of equipment supports included SSE inertia loads, load applied by attached piping (nozzle loads), and gravity loads.

3.4.2 Active Valves

Evaluations of the active valves included gravity, SSE inertia, and operational loads.

4.0 EVALUATION METHODOLOGY

4.1 Equipment Supports

Equipment supports were evaluated using equivalent static analyses. These analyses were performed in 3 steps as described below:

1. Component Frequency. The fundamental frequency of vibration was determined using hand calculations or simplified computer models. The natural frequencies were used with the floor response spectra to provide the seismic load factor.

2. Seismic Loads. Seismic load factors were determined in accordance with Section II.2.a.(2) of [5]. The SSE inertial loads were calculated by applying the seismic load factors to the component CG. The seismic loads were combined with nozzle and deadweight loads.
3. Qualification Determination. Stresses resulting from the combined loads were calculated and compared to the allowables described in Section 3.1. The results of these comparisons are summarized in Appendix A.

4.2 Active Valves

In most cases, valves were evaluated by applying a 1.0g seismic load in the weakest direction of the valve. The seismic loads were combined with loads due to gravity and operation (such as stem thrust) to determine a "Total" load. Stresses in critical sections of the valve were calculated based on this "Total" load. By comparing the stresses due to the 1.0g seismic load to the allowable stresses described in Section 3.2, the seismic capacity of the valve in the weakest direction could be found.

The anticipated seismic acceleration of the valve was determined by calculating the resultant (i.e., SRSS of the vertical and two horizontal) acceleration at the CG of the valve from the data provided by the appropriate piping analysis. Qualification was determined by comparing the seismic capacity to the applied acceleration.

If the method described above did not show the valve to be qualified, a more detailed analysis was performed. The three components of acceleration, as determined by the piping analysis, were applied to the valves. Conservatively, the accelerations were assumed to be oriented such that the maximum orthogonal component was oriented in the weakest direction of the valve. The stresses were then calculated and compared to the allowables.

5.0 RESULTS

The Impell evaluations have shown that all items included in Tables 2.1 and 2.2 are qualified. No modifications to the equipment or valves are required to meet the RTS criteria. Also as discussed in Appendix C, the stresses in all valve bodies satisfy the requirements of the BOPMEP criteria for the RTS scope.

The results of the equipment evaluations are summarized in Appendix A. Valve qualification levels are listed in Appendix B.

6.0 REFERENCES

1. ASME Boiler and Pressure Vessel Code, Section III, Rules for Construction of Nuclear Power Plant Components, 1983 Edition.
2. IE Bulletin 79-02, Revision No. 1, (Supplement 1), August 20, 1979, "Pipe Support Base Plate Designs Using Concrete Expansion Anchor Bolts".
3. "Design Criteria for Return To Service, San Onofre Nuclear Generating Station, Unit 1, Equipment Supports", Revision 1, July 12, 1984, Impell Job No. 0310-036-1356.
4. "Design Criteria for Return To Service, San Onofre Nuclear Generating Station, Unit 1, Active Valves", Revision 1, August 9, 1984, Impell Job No. 0310-036-1356.
5. "Dynamic Testing and Analysis of Systems, Components, and Equipment", USNRC Standard Review Plan 3.9.2, NUREG-0800, Rev. 2, July 1981.
6. "AFW Turbine Driven Pump, G-10", Impell Calculation No. EQ-01, Job No. 0310-036-1356, Rev. 0, July 23, 1984.
7. "CVCS Test Pump, G-42", Impell Calculation No. EQ-02, Job No. 0310-036-1356, Rev. 0, 7/23/84.
8. "Seal Water Injection Filter C42, C42S", Impell Calculation No. EQ-03, Job No. 0310-036-1356, Rev. 0, July 18, 1984.
9. "Seal Water Supply Filter G2A, G2C (C-952A, C-952C)", Impell Calculation No. EQ-04, Job No. 0310-036-1356, Rev. 0, July 18, 1984.
10. "Seal Water Supply Filter G2B (C-952B)", Impell Calculation No. EQ-05, Job No. 0310-036-1356, Rev. 0, July 18, 1984.
11. "Seal Water Heat Exchanger, E-34", Impell Calculation No. EQ-06, Job No. 0310-036-1356, Rev. 0, July 30, 1984.
12. "Charging Pump Oil Cooler (Water Cooled)", Impell Calculation No. EQ-07, Job No. 0310-036-1356, Rev. 0, July 23, 1984.
13. "Air-Cooled Oil Cooler", Impell Calculation No. EQ-08, Job No. 0310-036-1356, Rev. 0, July 23, 1984.
14. "Qualification of Charging Pumps G-8A,B", Impell Calculation No. EQ-09, Job No. 0310-036-1356, Rev. 0, July 18, 1984.
15. "Auxiliary Feedwater Motor Driven Pump", Impell Calculation No. EQ-10, Job No. 0310-036-1356, Rev. 0, July 23, 1984.
16. "Seal Water Return Filter, C-40", Impell Calculation No. EQ-11, Job No. 0310-036-1356, Rev. 0, June 8, 1984.

17. "Valve Seismic Qualification", Impell Calculation No. CV 76-79, Rev. 0, June 6, 1984, Job No. 0310-036-1356.
18. "Valve Seismic Qualification", Impell Calculation No. CV 113, Rev. 0, June 6, 1984, Job No. 0310-036-1356.
19. "Valve Seismic Qualification", Impell Calculation No. CV 203, 304, 545, 546, Rev. 0, June 6, 1984, Job No. 0310-036-1356.
20. "Valve Seismic Qualification", Impell Calculation No. CV 410, 406B, Rev. 0, June 6, 1984, Job No. 0310-036-1356.
21. "Valve Seismic Qualification", Impell Calculation No. CV 528, Rev. 0, June 6, 1984, Job No. 0310-036-1356.
22. "Valve Seismic Qualification", Impell Calculation No. CV 530, 531, Rev. 0, June 12, 1984, Job No. 0310-036-1356.
23. "Valve Seismic Qualification", Impell Calculation No. CV 532, Rev. 0, June 25, 1984, Job No. 0310-036-1356.
24. "Valve Seismic Qualification", Impell Calculation No. CV 3201, Rev. 0, June 12, 1984, Job No. 0310-036-1356.
25. "Valve Seismic Qualification", Impell Calculation No. CV 3203, FCV 2300, 2301, 3300, 3301, Rev. 0, June 12, 1984, Job No. 0310-036-1356.
26. "Valve Seismic Qualification", Impell Calculation No. FCV 1115D, E, F, Rev. 0, June 6, 1984, Job No. 0310-036-1356.
27. "Valve Seismic Qualification", Impell Calculation No. LCV 1112, Rev. 0, June 12, 1984, Job No. 0310-036-1356.
28. "Valve Seismic Qualification", Impell Calculation No. MOV 356, 357, 358, Rev. 0, June 6, 1984, Job No. 0310-036-1356.
29. "Valve Seismic Qualification", Impell Calculation No. MOV 1100B, C, D, Rev. 0, May 21, 1984, Job No. 0310-036-1356.
30. "Valve Seismic Qualification", Impell Calculation No. MOV 18, 19, Rev. 0, May 21, 1984, Job No. 0310-036-1356.
31. "Valve Seismic Qualification", Impell Calculation No. MOV 14-17, Rev. 0, May 21, 1984, Job No. 0310-036-1356.
32. "Valve Seismic Qualification", Impell Calculation No. MOV 1202, Rev. 0, May 21, 1984, Job No. 0310-036-1356.
33. "Valve Seismic Qualification", Impell Calculation No. PCV, Rev. 0, May 25, 1984, Job No. 0310-036-1356.
34. "Valve Seismic Qualification", Impell Calculation No. RV 1-10, Rev. 0, June 6, 1984, Job No. 0310-036-1356.

35. "Valve Seismic Qualification", Impell Calculation No. RV 532, 533, Rev. 0, June 6, 1984, Job No. 0310-036-1356.
36. "Valve Seismic Qualification", Impell Calculation No. Solenoid Valves, Rev. 0, June 6, 1984, Job No. 0310-036-1356.
37. "Dynamic Qualification for Main Stop and Trip Valves", Rev. 0, August 8, 1984.
38. "Balance of Plant Mechanical Equipment and Piping Seismic Reevaluation Criteria (BOPMEP Criteria)", San Onofre Nuclear Generating Station Unit 1, dated May 20, 1983, Bechtel Power Corporation Job No. 14000-300/339.
39. Impell Letter No. 0310-036-015 to SCE, dated September 25, 1984, Subject: Valve Body Stresses for RTS Valves (included in Appendix C).

TABLE 2.1
EQUIPMENT ITEMS

Auxiliary Feedwater Turbine Driven Pump G-10
CVCS Test Pump G-42
Seal Water Injection Filter C-42 (C-42N), C-42S Note 1
Seal Water Supply Filter C-952A, C-952C (G2A, G2C) Note 1
Seal Water Supply Filter C-952B (G2B) Note 1
Seal Water Heat Exchanger E-34
Charging Pump Oil Coolers (water-cooled) E-906, E-907
Charging Pump Oil Coolers (air-cooled) E-908, E-909
Charging Pumps G-8A, G-8B
Auxiliary Feedwater Motor-Driven Pump G-10S
Seal Water Return Filter C-40

NOTE 1: Tag numbers in parenthesis also used for this equipment item.

TABLE 2.2
ACTIVE VALVES

MOV - 14	PCV - 3000	SV - 2401
MOV - 15	PCV - 3001	SV - 2402
MOV - 16	PCV - 3002	SV - 2403
MOV - 17	PCV - 3003	SV - 2404
MOV - 18	PCV - 3004	SV - 3401
MOV - 19	PCV - 3005	SV - 3402
MOV - 1100B	PCV - 3006	SV - 3403
MOV - 1100C	PCV - 3007	SV - 3404
MOV - 1100D	PCV - 3021	SV - 3200
MOV - 1202	PCV - 3022	SV - 3205
MOV - 356	PCV - 3023	SV - 3211
MOV - 357	PCV - 4051	SV - 135
MOV - 358	PCV - 4052	
	PCV - 4054	
	PCV - 4055	CV - 2145
	PCV - 4056	CV - 3203
	PCV - 4057	CV - 532
	PCV - 4058	CV - 3201
	PCV - 4059	
	PCV - 4060	
	PCV - 4061	FCV - 2300
	PCV - 4063	FCV - 2301
	PCV - 4064	FCV - 3300
		FCV - 3301
	CV - 76	
	CV - 77	
	CV - 78	
	CV - 79	
	CV - 406B	
	CV - 410	
		LCV - 1112
		CV - 113
		CV - 528
		CV - 203
		CV - 304
		CV - 545
		CV - 546
		CV - 530
		CV - 531
RV - 1		
RV - 2		
RV - 3		
RV - 4		
RV - 5		
RV - 6		
RV - 7		
RV - 8		
RV - 9		
RV - 10		
RV - 532		
RV - 533		
FCV - 1115D		
FCV - 1115E		
FCV - 1115F		
Main Stop Valves (2)		

APPENDIX A - EQUIPMENT SUPPORT EVALUATION SUMMARIES

TABLE A-01

SUMMARY OF RESULTS FOR AUX. FEEDWATER
TURBINE DRIVEN PUMP, G-10

<u>Component</u>	<u>Calculated Stress</u>	<u>Allowable Stress</u>	<u>Remarks</u>
Turbine Holddown Bolts	0.03 (Interaction)	1.0	OK, Level A Limits
Pump Holddown Bolts	0.05 (Interaction)	1.0	OK, Level A Limits
Base Holddown Bolts	0.60 (Interaction)	1.0	OK, FS = 4.0
Base Channel Flange	2.25 ksi	23.67 ksi	OK, Level A Limits

TABLE A-02

SUMMARY OF RESULTS FOR CVCS TEST
PUMP, G-42

<u>Component</u>	<u>Calculated Stress</u>	<u>Allowable Stress</u>	<u>Remarks</u>
Motor Hold Down Bolts	.013 (Interaction)	1.0	OK, Level A Limits
Motor Base	3.45 ksi	21.6 ksi	OK, Level A Limits
Pump Hold Down Bolts	.08 (Interaction)	1.0	OK, Level A Limits
Foundation Bolts	.26 (Interaction)	1.0	OK, FS = 4.0

TABLE A-03

SUMMARY OF RESULTS FOR SEAL WATER INJECTION
 FILTERS, C-42, C-42S

<u>Component</u>	<u>Calculated Stress</u>	<u>Allowable Stress</u>	<u>Remarks</u>
Support Legs 2-1/2x2-1/2x1/4 Angles	.88 (Interaction)	1.0	OK, Level D Limits
Leg to Shell Weld	15.6 ksi	23.9 ksi	OK, Level D Limits

Note: The support legs are embedded in concrete, therefore no anchor bolts or base plates are evaluated.

TABLE A-04

SUMMARY OF RESULTS FOR SEAL WATER
SUPPLY FILTERS, C-952A, C-952C

<u>Component</u>	<u>Calculated Stress</u>	<u>Allowable Stress</u>	<u>Remarks</u>
Upper Supports 2x2x1/4 Angles	.59 (Interaction)	1.0	OK, Level D Limits
Upper Supports Anchor Bolts	.57 (Interaction)	1.0	OK, RTS Limits (FS = 2.0)
Upper Supports Base Plates	16.2 ksi	40.6 ksi	OK, Level D Limits
Upper Supports Base Plate Weld	19.0 ksi	23.9 ksi	OK, Level D Limits
Upper Supports Pipe Clamp	.18 (Interaction)	1.0	OK, Level D Limits
Support Legs 2-1/2x2-1/2x1/4 Angles	.92 (Interaction)	1.0	OK, Level D Limits
Anchor Bolts (Structural Bolting)	.63 (Interaction)	1.0	OK, Level D Limits
Leg to Shell Weld	21.2 ksi	23.9 ksi	OK, Level D Limits
Leg to Base Plate Weld	5.8 ksi	23.9 ksi	OK, Level D Limits

TABLE A-05

SUMMARY OF RESULTS FOR SEAL WATER
SUPPLY FILTER, C-952B

<u>Component</u>	<u>Calculated Stress</u>	<u>Allowable Stress</u>	<u>Remarks</u>
Support Legs: 2-1/2x2-1/2x1/4 Angle	.45 (Interaction)	1.0	OK, Level D Limits
Anchor Bolts	.77 (Interaction)	1.0	OK, FS = 4.0
Leg-Base Plate Weld	2.4 ksi	23.9 ksi	OK, Level D Limits
Leg-Shell Weld	10.4 ksi	23.9 ksi	OK, Level D Limits
Brace: 2x2x1/4 Angle	1.6 ksi	40.6 ksi	OK, Level D Limits
12" Pipe Clamp	.1 (Interaction)	1.0	OK, Level D Limits
Weld at Angle Brace	4.3 ksi	23.9 ksi	OK, Level D Limits

TABLE A-06

SUMMARY OF RESULTS FOR SEAL WATER
HEAT EXCHANGER (E-34)

<u>Component</u>	<u>Calculated Stress</u>	<u>Allowable Stress</u>	<u>Remarks</u>
C6x10.5	.41 (Interaction)	1.0	OK, Level A Limits
W6x20	.05 (Interaction)	1.0	OK, Level A Limits
W4x13	.30 (Interaction)	1.0	OK, Level A Limits
C4x5.4	.07 (Interaction)	1.0	OK, Level A Limits
Group 1 Base Plates	.49" Required thickness	.75" Actual thickness	OK, Level A Limits
Group 1 Anchor Bolts	.61 (Interaction)	1.0	OK, Level A Limits
Group 2 Anchor Bolts	1.0 (Interaction)	1.0	OK, RTS Limits (FS = 2.0) (Note 1)
Group 2 Base Plates	15.6 ksi	21.6 ksi	OK, Level A Limits
Group 3 Base Plates	Extremely low loads, Qualified by Inspection		
Group 3 Anchor Bolts			
Group 4 Base Plates	.10 ksi	21.6 ksi	OK, Level A Limits
Group 4 Anchor Bolts	.27 (Interaction)	1.0	OK, Level A Limits
Support Saddles	.31 (Interaction)	1.0	OK, Level A Limits
Saddle Bolts	.82 (Interaction)	1.0	OK, Level A Limits

NOTE 1: Anchors were assumed to be expansion bolts with embedded length of 3-1/4" (minimum for 3/4" dia. bolts). Actual embedded length is expected to be much greater, therefore results are conservative.

TABLE A-07

SUMMARY OF RESULTS FOR THE WATER COOLED CHARGING
PUMP OIL COOLERS

<u>Component</u>	<u>Calculated Stress</u>	<u>Allowable Stress</u>	<u>Remarks</u>
Cooler/Saddle Plate Bolts	.25" required Diameter	N/A	Actual bolt size not available, judged acceptable, See Note.
Saddle Plate to Support Plate Bolts	.206 (Interaction)	1.0	OK, Level A Limits
Support Plate/Channel Weld	14.0 ksi	18.0 ksi	OK, Level A Limits
Support Plate	.96 (Interaction)	1.0	OK, Level D Limits

NOTE: All loads were combined by absolute sum, maximum nozzle loads were assumed to act simultaneously in the most severe direction. Therefore, results are conservative.

TABLE A-08

SUMMARY OF RESULTS FOR THE AIR COOLED
CHARGING PUMP OIL COOLERS

<u>Component</u>	<u>Calculated Stress</u>	<u>Allowable Stress</u>	<u>Remarks</u>
Angle/Cooler Bolts	.60 (Interaction)	1.0	OK, Level A Limits
Support Legs	.19 (Interaction)	1.0	OK, Level A Limits
Anchor Bolts	.64 (Interaction)	1.0	OK, FS = 4.0
Leg/Base Plate Weld	.08 inch required size	.25 inch actual size	OK, Level A Limits
Base Plate	.185 inch required thickness	.25 inch actual thickness	OK, Level D Limits

TABLE A-09

SUMMARY OF RESULTS FOR THE CHARGING PUMPS,
G-8A, G-8B

<u>Component</u>	<u>Calculated Stress</u>	<u>Allowable Stress</u>	<u>Remarks</u>
Motor Hold Down Bolts	.02 (Interaction)	1.0	OK, Level A Limits
Pump Hold Down Bolts	.79 (Interaction)	1.0	OK, Level A Limits
Foundation Anchor Bolts	3644 lb.	4250 lb.	OK, FS = 4.0 Note 1
Base Channel	20.6 ksi	23.76 ksi	OK, using Level A Allowables

Note 1: Foundation Bolts are J-Bolts with an embedment exceeding 12". Allowable is based on expansion bolt with 7-1/2" embedment in 4000 psi concrete. Results are conservative.

TABLE A-10

SUMMARY OF RESULTS FOR AUXILIARY
FEEDWATER MOTOR DRIVEN PUMP, G-10S

<u>Component</u>	<u>Calculated Stress</u>	<u>Allowable Stress</u>	<u>Remarks</u>
1" Pump Hold Down Bolts	.36 (Interaction)	1.0	OK, Level D Limits
5/8" Motor Hold Down Bolts	.06 (Interaction)	1.0	OK, Level D Limits
Pump Pedestal	.44 (Interaction)	1.0	OK, Level D Limits
5/8" Anchor Bolts	.65 (Interaction)	1.0	OK, FS = 4.0
Base Skid	14.9 ksi (bending)	40.6 ksi	OK, Level D Limits

TABLE A-11

SUMMARY OF RESULTS FOR THE SEAL WATER
RETURN FILTER, C-40

<u>Component</u>	<u>Calculated Stress</u>	<u>Allowable Stress</u>	<u>Remarks</u>
Support legs	.84 (Interaction)	1.0	OK, Level D Limits
Leg, Anchor Bolts	.70 (Interaction)	1.0	OK, RTS Allowables (FS = 2.0)
Base Plate	27.7 ksi	40.6 ksi	OK, Level D Limits
Top Support Member A	.24 (Interaction)	1.0	OK, Level D Limits
Top Support Member B	.10 (Interaction)	1.0	OK, Level D Limits
Top Support Bolts	.43 (Interaction)	1.0	OK, Level D Limits
Top Support Member C	.69 (Interaction)	1.0	OK, Level D Limits
Top Support Anchor Bolts	.55 (Interaction)	1.0	OK, Level D Limits
Top Support Weld	.91 kip/inch	4.2 kip/inch	OK, Level D Limits

APPENDIX B - VALVE QUALIFICATION LEVELS

TABLE B-1 VALVE QUALIFICATION LEVELS

VALVE	QUALIFICATION LEVEL			
	a_x	a_y	a_z	$a_{\text{resultant}}$
MOV-18 MOV-19	2.65	1.77	2.65	--
MOV-1100B MOV-1100C MOV-1100D	2.29	1.53	2.29	--
MOV-356 MOV-357 MOV-358	8.20	5.47	8.20	--
FCV-2300 FCV-2301 FCV-3300 FCV-3301	--	--	--	22.3
CV-3203	--	--	--	22.3
CV-3201	--	--	--	21.8
CV-532	--	--	--	19.6
CV-113	1.28	1.98	1.06	--
CV-410 CV-406B	--	--	--	11.07
CV-528	.73	.47	1.15	--
CV-76 CV-77 CV-78 CV-79	4.14	4.19	7.24	--
LCV-1112	2.74	3.15	2.90	--
CV-530 CV-531	4.53	2.81	3.02	--
FCV-1115D FCV-1115E FCV-1115F	1.36	5.14	1.31	--
MOV-14 MOV-15 MOV-16 MOV-17	.64	5.01	2.06	--
MOV-1202	4.71	3.14	4.71	--

TABLE B-1 VALVE QUALIFICATION LEVELS

VALVE	QUALIFICATION LEVEL			$a_{\text{resultant}}$
	a_x	a_y	a_z	
RV-532 RV-533	--	--	--	14.2
CV-203 CV-304 CV-545 CV-546	4.11	4.73	4.35	--
RV-1 RV-2 RV-3 RV-4 RV-5 RV-6 RV-7 RV-8 RV-9 RV-10	--	--	--	10.41
SV-2401 SV-2402 SV-3401 SV-3402 SV-2403 SV-2404 SV-3403 SV-3404 SV-3200 SV-3205 SV-3211 SV-135 CV-2145	--	--	--	7.75
PCV-3000 PCV-3001 PCV-3002 PCV-3003 PCV-3004 PCV-3005 PCV-3006 PCV-3007 PCV-3021 PCV-3022 PCV-3023 PCV-4051 PCV-4052 PCV-4054 PCV-4055	1/2 inch diameter pressure control valves (regulators) qualified by inspection.			

TABLE B-1 VALVE QUALIFICATION LEVELS

VALVE	QUALIFICATION LEVEL			
	<u>a_x</u>	<u>a_y</u>	<u>a_z</u>	<u>a_{resultant}</u>
PCV-4056 PCV-4057 PCV-4058 PCV-4059 PCV-4060 PCV-4061 PCV-4063 PCV-4064				1/2 inch diameter pressure control valves (regulators) qualified by inspection.
Main Steam Stop Valves				Stop valves are considered piping anchors. Valves were qualified for applied piping loads.

APPENDIX C - VALVE BODY STRESSES FOR RTS VALVES [39]

September 25, 1984
0310-036-015

Southern California Edison Company
Post Office Box 800
2244 Walnut Grove Avenue
Rosemead, California 91770

ATTENTION: Mr. Duane Martin

SUBJECT: Valve Body Stresses for RTS Valves

REFERENCE: 1. Impell Report 01-0310-1305, Rev. 0,
"Summary of Results for RTS Active Valve
and Equipment Evaluations," transmitted to
SCE with Impell Letter 0310-036-014, dated
August 10, 1984.

Gentlemen:

Enclosed for your use is the justification of the valve body stress qualification to the BOPMEP criteria for RTS valves. We will also incorporate this discussion in the RTS valve and equipment report (Reference 1) and transmit the revised report to you later this week.

If you have any questions please call Mr. Ward Ingles or me.

Very truly yours,

W. D. Gallo for

W. D. Gallo
Project Manager

WDG/WI/jb
Enclosure

cc: Mr. George Stawmiczy, SCE (w/enc.)
Mr. Ed Kimoto, SCE (w/enc.)
Mr. Jack Rainsberry, SCE (w/enc.)

VALVE BODY STRESSES

The piping in the Return to Service (RTS) Scope at SONGS-1 was evaluated using equation (9) of NC-3652 [1]. The piping evaluations considered pressure, deadweight, and seismic inertia loads. The effects of valves on the piping system was addressed by including the valve body in the piping model. A lumped mass is included at the CG of the valve extended structure. The primary stresses in the piping, including the effects of the stress intensification factors of Figure NC-3673.2 (b)-1 [1], were limited to $2.0S_y$.

Seismic qualification of valves is performed in two parts; evaluation of pressure retaining components and evaluation of non-pressure retaining parts.

Non-pressure retaining components, such as yoke legs and yoke to bonnet bolting are evaluated as linear type supports using Subsection NF or Appendix XVII of [1]. Passive valves are not required to operate during (or after) the DBE, therefore, gross structural deformations in the extended structure are acceptable.

The pressure retaining parts of the valve, including the body and bonnet, are evaluated according to the rules of NC/ND-3500 of [1]. These rules require that the valve body be stronger than the attached piping (NC-3521(a) of [1]). The weakest section of the valve body is at the welded joint to the pipe. At this section the valve body thickness is reduced to match the thickness of the attached piping. In the RTS piping evaluations the valve to pipe welded joints were qualified to the functionality limits. This demonstrates the pressure integrity of all the valve bodies in the RTS Scope.

In addition to demonstrating pressure integrity, the BOPMEP criteria for SONGS-1 require that stresses in the bodies be limited to yield for active valves and to Level D limits for passive (inactives) valves ([3], Table 3).

The following paragraphs discuss the evaluation of stresses in the bodies of the valves in the RTS Scope at SONGS-1. In each case the primary stress at the pipe/valve interface is conservatively assumed to be $2.0S_y$. Valves are connected to the piping systems using butt welds, flanges, or socket welds. These three connections are described below:

1. Socket Welds - For the small valves, including solenoid valves, a stress intensification factor of 2.1 is applied to socket welded joints. In addition, a comparison of the section modulus of standard 3000# socket weld fittings [2] with the section modulus of standard weight piping shows that the couplings have a moment capacity from 4.8 (for 1/2") to 3.1 (for 2") greater than the piping. Consideration of these two factors gives the maximum primary stress in the valve body:

$$S_{\text{Valve}} = \frac{2.0S_y}{(.75 \times 2.1)(3.1)} = .41S_y$$

Review of the stress qualification concluded that with this magnitude it reserves sufficient margins for the secondary stresses (thermal and SAM) and the total stress in the valve body is less than yield.

2. Flanged Ends - Relief valves are commonly constructed such that the limiting section is the flanged ends. The valves in the RTS scope with flanged ends were qualified by evaluating the loads in the flanged connections using the rules of NC-3658. All connections were qualified to Level A or B service limits for all loading. This demonstrates that the stresses in the valve body are below yield, since the level A and B stress limits are approximately equal to the yield stress.
3. Butt Welded Ends - Control and motor operated valves greater than 2" NPS generally used butt welding ends. Butt welds are generally included in the piping model as as-welded butt welds using stress intensification factor of 1.8 or as tapered transitions using stress intensification factors of 1.5 to 1.9.

A detailed review of 7 valve/pipe interfaces in 3 plants was performed in [4]. The sizes range from 2" NPS to 6" NPS. The data from [4] is summarized in Table 1. This data shows that the ratio of pipe section modulus to valve section modulus ranges from 4.18 to 7.36. Consideration of the stress intensification factors and the difference in section moduli reduces the stress of $2.0S_y$ to:

$$S_v = \frac{2.0S_y}{(.75 \times 1.5)(4.18)} = .43S_y$$

Again, this reserves enough margins for the secondary stresses. Hence the total stress in the valve body is less than yield.

Conclusion:

Stress in valve bodies have been calculated based on pipe end loads (for flanged valves) or by assuming a primary stress of $2.0S_y$ in the attached piping. In all cases the basic stress in the valve body was found to be less than S_y . Therefore, the stresses in all valve bodies satisfy the requirements of the BOPMEP criteria for the RTS scope.

REFERENCES

1. ASME Boiler and Pressure Vessel Code, Section III, Subsection WC, 1983 Edition.
2. "Forged Steel Fittings, Socket-Welding and Threaded," AWSI Standard B16.11-1973, ASME, New York.
3. "Balance of Plant Mechanical Equipment and Piping Seismic Reevaluation Criteria (BOPMEP Criteria)," San Onofre Nuclear Generating Station Unit 1, dated May 20, 1983, Bechtel Power Corp. Job No. 14000-300/339.
4. "A Review of the 1-D and 2-D Thermal Transient Analysis of Piping Components," EDS Nuclear Report No. 01-9602-1113, July 2, 1981.

TABLE 1


Case	MPS	t_{pipe}	t_{valve}	Z_v/Z_p (Note 1)
1	2"	.343	.922	4.18
2	2"	.343	.922	4.18
3	3"	.438	1.390	5.08
4	3"	.438	1.688	7.10
5	3"	.438	1.688	7.10
6	4"	.531	2.00	6.53
7	6"	.718	3.00	7.36

Note 1:
$$\frac{Z_v}{Z_p} = \frac{(D_o^4 - D_i^4) d_o}{(d_o^4 - d_i^4) D_o}$$

Where: D_o and D_i are OD and ID for valve.
 d_o and d_i are OD and ID for pipe.

ENCLOSURE 2

CALCULATION/PROBLEM COVER SHEET



Calculation/Problem No: EQ - 01
 Title: AEW TURBINE DRIVEN PUMP - 410
 Client: ECE Project: SONGS - 1
 Job No: 0310 - 036 - 1356

Design Input/References:

STATED WITHIN

Assumptions:

STATED WITHIN

Method:


STATED WITHIN

Remarks:

REV. NO.	REVISION	APPROVED	DATE
0	ORIGINAL ISSUE	M/R Burk Jr	7/23/84

TABLE OF CONTENTS


	PAGE
i. PROBLEM COVER SHEET	1
ii. TABLE OF CONTENTS	2
1. CALCULATION SUMMARY	3
2. ASSUMPTIONS	4
3. REFERENCES	5
4. GEOMETRY	6
5. FREQUENCY/SEISMIC LOADS	8
6. TURBINE HOLDDOWN BOLTS	10
7. PUMP HOLDDOWN BOLTS	13
7.1 SEISMIC LOADS	13
7.2 NOZZLE LOADS	14
8. BASE HOLDDOWN BOLTS	20
9. LOCAL STRESSES ON BASE CHANNEL	27
10. APPENDIX A	} REFERENCE INFORMATION PROVIDED FOR INFORMATION, NOT INCLUDED IN TOTAL PAGES
11. APPENDIX B	
12. APPENDIX C	

APW TURBINE DRIVEN PUMP - 610									
0	CAG	6/25/84	_____	_____			JOB NO 0310-036-1356 CALC NO Eq 01	PAGE 2 OF 27	
REV	BY	DATE	CHECKED	DATE					

1. CALCULATION SUMMARY

COMPONENTS ANALYZED AND FINDINGS & CRITERIA FOR EACH, ARE LISTED BELOW:

<u>COMPONENT</u>	<u>STATUS</u>	<u>CONDITION</u>
TURBINE HOLDDOWN BOLTS -- 8- $\frac{3}{4}$ " ϕ A307	QUALIFY	LEVEL A/B
PUMP HOLDDOWN BOLTS -- 4- $\frac{1}{4}$ " ϕ A307	QUALIFY	LEVEL A/B
BASE HOLDDOWN BOLTS -- 10- $\frac{1}{8}$ " ϕ A307	QUALIFY	LEVEL A/B
BASE CHANNEL FLANGE -- 2" x $3\frac{1}{2}$ " x $\frac{1}{4}$ " A106, GRB	QUALIFIES	LEVEL A/B

				AFN TURBINE DRIVEN PUMP- 910			
				JOB NO 0310-036-1356			
				CALC NO EQ-01			
				PAGE 3 OF 27			
				 IMPELLOR CORPORATION			
REV	BY	DATE	CHECKED	DATE			
0	calc CJY	6/25/84	WTE	7/10/84			

2. ASSUMPTIONS

1. SINCE DEADWEIGHT LOADS DUE TO GRAVITY ACT TO DECREASE UPWARD LOADS, DEADWEIGHT LOADS ARE NOT CONSIDERED IN THE EVALUATION OF THE TURBINE & PUMP HOLDDOWN BOLTS
2. THERE ARE NO NOZZLE LOADS ON THE TURBINE SINCE THE "TURBINE MUST BE RELIEVED OF ALL PIPING STRAINS" [1]
3. THE NOZZLE LOADS ON THE PUMP ARE AS WERE FOUND IN THE BECHTEL CALC [2] (SEE APPENDIX A)
4. WT OF PUMP LEG SUPPORT IS INCLUDED IN WT OF PUMP AND ACTS @ ITS CENTROID
5. SUPPORTING CHANNEL IS MC 6x18 AND IS MADE OF A36 (SEE p. 27)

(OTHERS AS NOTED WITHIN)

					AFW TURBINE DRIVEN PUMP - 610		
					JOB NO 0310-036-1356		PAGE 4
					CALC NO		OF 27
0	Cal	6/25/84	WI	7/10/84	EQ-01		
REV	BY	DATE	CHECKED	DATE			





3. REFERENCES


1. BECHTEL LETTER #BPC/V-84-161 DATED 3/30/84 FROM J.D. DUFFIN (BECHTEL) TO W.D. GALLO (IMPELL) WITH INFORMATION PERTAINING TO AUXILIARY FEEDWATER TURBINE DRIVEN PUMP 9-10
2. BECHTEL CALCULATION FILE # MC-284-21 -- FOR INFORMATION ONLY
3. AISC CODE 8th EDITION, C. 1980
4. ASME CODE, SECTION III, 1980 EDITION
5. WORTHINGTON CORP. DWG., "3-WTL-86 DIFFUSER PUMP ELEVATION," DWG. NO RY 146501, DATED 6-9-66. REV A. INCLUDED WITHIN [1]
6. "DESIGN CRITERIA FOR RETURN TO SERVICE SONGS-1, EQUIPMENT SUPPORTS" JN #0310-036-1356 DATED 6/13/84
7. HILTI KWIK-BOLT CATALOG -- SEE APPENDIX B
8. WORTHINGTON CORP. DWG #LC-85816 DATED 3-14-60, OUTLINE DWG FOR FORM SCR STEAM TURBINE, INCLUDED IN [1]
9. "FORMULAS FOR STRESS & STRAIN" BY ROARK & YOUNG 5th ED. MCGRAW-HILL BOOK CO., 1975.

					AFW TURBINE DRIVEN PUMP -910		
					JOB NO 0310-036		PAGE 5 OF 21
					CALC NO		
0	COX	6/25/84	WI	7/1/84	EQ-01		
REV	BY	DATE	CHECKED	DATE			




GEOMETRY -- FROM REF. 5



					APW TURBINE DRIVEN PUMP - 610			
							JOB NO 0310-036-1356 CALC NO EQ-01	
0	cgc	6/14/84	WI	7/10/84			PAGE 6	
REV	BY	DATE	CHECKED	DATE			OF 21	

BOLT CONFIGURATION -- FROM REF 1




VIEW "A-A"

					AFW TURBINE DRIVEN PUMP - 610			
							JOB NO 0310-036-1356 CALC NO EQ-01	PAGE 7 OF 27
0	<i>Cge</i>	6/14/84	WI	7/1/84				
REV	BY	DATE	CHECKED	DATE				

FREQUENCY

THE DATA AVAILABLE TO DETERMINE THE FREQUENCY OF THE SYSTEM IS INSUFFICIENT.

HOWEVER, THE SYSTEM MAY BE MODELED AS TWO MASSES INDEPENDENTLY CONNECTED TO A BASE WHICH VIBRATES WITH THE SAME FREQUENCY AS THE FLOOR, OR --



REGARDLESS OF THEIR NATURAL FREQUENCIES THEREFORE, THE TWO MASSES SEE NO AMPLIFICATION BEYOND THE PEAK ACCELERATION OF THE FLOOR RESPONSE SPECTRA SHOWN ON THE FOLLOWING PAGE.

					APW TURBINE DRIVEN PUMP - G10		
					JOB NO 0310-036-1356		PAGE
					CALC NO		8
0	COX	6/14/84	WJ	7/10/84	EQ - 01		OF
REV	BY	DATE	CHECKED	DATE			27




SEISMIC LOADS

FROM THE SPECTRUM SHOWN BELOW [2], SEISMIC ACCELERATIONS ARE ASSUMED. FOR CONSERVATISM, SPECTRAL PEAKS @ 4% DAMPING ARE APPLIED TO THE PUMP & TURBINE.

$$z_x = 1.05 g$$

$$z_z = 1.05 g$$

$$z_y = \frac{2}{3}(1.05 g) = 0.70 g$$




					APW TURBINE DRIVEN PUMP - 410		
0	cgc	6/14/04	WI	7/16/04	JOB NO 0310-036-1356		PAGE 9
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-01		OF 27



TURBINE HOLDDOWN BOLTS

ASSUMPTIONS: (1) NO NOZZLE LOADS SINCE "TURBINE MUST BE RELIEVED OF ALL PIPING STRAINS" [1]

(2) WT OF TURBINE IS CONCENTRATED @ THE CENTROID



FROM [1]:

TURBINE: WT = 2200#

BOLTS: 8-3/4" φ A307
 P.4-141 { ROOT AREA: 0.302 IN²
 [3] TENSILE AREA: 0.334 IN²

ASSUME: ΔZ BETWEEN THE 2 SETS OF 4-BOLTS IS:

$$\Delta Z = \frac{18\frac{1}{2} - 13}{2} + 13 = 15.75"$$

TENSILE LOAD

DUE TO z_z : $\frac{(2200 \text{ lb})(1.05 g)(15.5")}{(4 \text{ BOLTS})(15.75")} = 568.33 \text{ lb}$

DUE TO z_x : $\frac{(2200 \text{ lb})(1.05 g)(15.5")}{(4 \text{ BOLTS})(17")} = 526.54 \text{ lb}$

DUE TO z_y : $\frac{(2200 \text{ lb})(0.7 g)}{8 \text{ BOLTS}} = 192.5 \text{ lb}$

TOTAL TENSILE LOAD = 568.33 + 526.54 + 192.5
 = 1287.4 lb

					APW TURBINE DRIVEN PUMP - 610		
0	CE	6/4/84	WI	7/10/84	JOB NO 0310-036-1356		PAGE 10
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-01		OF 21

SHEAR LOAD

$$\text{DUE TO } Z_x : \frac{(2200 \text{ lb} \times 1.05 g)}{8 \text{ bolts}} = 288.75 \text{ lb}$$

$$\text{DUE TO } Z_z : \frac{(2200 \text{ lb} \times 1.05 g)}{8 \text{ bolts}} = 288.75 \text{ lb}$$

$$\text{RESULTANT SHEAR LOAD} = \sqrt{(288.75)^2 + (288.75)^2} = 408.35 \text{ lb}$$

STRESSES

$$f_t = \frac{P}{A_t} = \frac{1287.4 \text{ lb}}{0.334 \text{ in}^2} = 3.85 \text{ KSI}$$

$$f_v = \frac{V}{A_v} = \frac{408.35 \text{ lb}}{0.302 \text{ in}^2} = 1.35 \text{ KSI}$$

MAXIMUM ALLOWABLES

$S_u = 60 \text{ KSI}$ FOR A307 BOLTS
(ASME SECTION II, TABLE I-7.3)

$$F_t = \frac{S_u}{2} = \frac{60}{2} = 30 \text{ KSI}$$


$$F_v = \frac{0.62 S_u}{3} = \frac{(0.62 \times 60)}{3} = 12.4 \text{ KSI}$$

ASME CODE
NF-3324.6
-- LEVEL A
CONDITIONS

INTERACTION (PER NF-3324.6 (a) [3])

$$\left(\frac{f_t}{F_t}\right)^2 + \left(\frac{f_v}{F_v}\right)^2 < 1 ?$$

$$\left(\frac{3.85}{30}\right)^2 + \left(\frac{1.35}{12.4}\right)^2 = 0.03 < 1 \quad \text{OK} \quad \text{BOLTS QUALIFY}$$

					APW TURBINE DRIVEN PUMP - 410		
0	cgc	6/14/84	WI	7/16/84	JOB NO 0310-036-1356		PAGE 11
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-01		OF 21
							


BOLTS ARE GREATLY OVERSIZED. IF ANY NOZZLE
 EXIST, THEY WOULD HAVE TO BE VERY LARGE
 IN ORDER TO OVERSTRESS THE BOLTS.

					APW TURBINE DRIVEN PUMP - 410		
0	cgc	7/10/84	WT	7/10/84	JOB NO 0310-036-1356		PAGE 12
REV	BY	DATE	CHECKED	DATE	CALC NO		OF 21
					Eq-01		



PUMP HOLDDOWN BOLTS

ASSUMPTION: (1) WT OF PUMP IS CONCENTRATED @ CENTROID
 (2) NOZZLE LOADS ARE AS FOUND IN
 BECHTEL CALC [2]



FROM [1]:

PUMP: WT = 2590 #
 FLUID: WT = 260 #

BOLTS: 4 - 1/4" φ A307
 P. 4-141 { ROOT AREA: 0.890 IN²
 [3] { TENSILE AREA: 0.969 IN²

DIMENSIONS FROM [1]

SEISMIC ACCELERATIONS

TENSILE LOAD

DUE TO a_z : $\frac{(2850 \text{ lb}) \times (1.05g) \times (15.5")}{(2 \text{ bolts}) \times (43")}$ = 539.35 lb

DUE TO a_x : $\frac{(2850 \text{ lb}) \times (1.05g) \times (15.5")}{(2 \text{ bolts}) \times (15")}$ = 1546.13 lb

DUE TO a_y : $\frac{(2850 \text{ lb}) \times (0.7g)}{4 \text{ bolts}}$ = 498.75 lb

TOTAL TENSILE (SEISMIC) = 539.35 + 1546.13 + 498.75
 = 2584.23 lb

					APW TURBINE DRIVEN PUMP - 610		
0	cgc	6/15/84	WE	7/1/84	JOB NO 0310-036-1356	CALC NO	PAGE 13 OF 21
REV	BY	DATE	CHECKED	DATE			


SHEAR LOAD

DUE TO a_x : $\frac{(2850 \text{ lb} \times 1.05 g)}{4 \text{ bolts}} = 748.13 \text{ lbs}$

DUE TO a_z : $\frac{(2850 \text{ lb} \times 1.05 g)}{4 \text{ bolts}} = 748.13 \text{ lbs}$

TOTAL SHEAR LOAD = $\sqrt{(748.13)^2 + (748.13)^2}$
 = 1058 lb

NOZZLE LOADS



SUCTION: 4" NOZZLE
 --LINE # 8110-4"-JN

DISCHARGE: 3" NOZZLE
 --LINE # 381A-3"-EQ-3ACB

ASSUME ALL FORCES
 AND MOMENTS ACT
 @ CENTER OF BOLT
 PATTERN

* DIMENSION FROM EQUIP. DWG. [1]

WHERE,

SUCTION: $15\frac{1}{2} - 4\frac{3}{4} = 10\frac{3}{4}$ "

DISCHARGE: $15\frac{1}{2} - 4 = 11\frac{1}{2}$ "

					APW TURBINE DRIVEN PUMP - 910		
0	CGC	6/20/84	WT	7/10/84	JOB NO 0310-036-1356		PAGE 14
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-01		OF 27

ASSUME ALL COORDINATES ARE GLOBAL:

FROM [2], SELECT MAXIMUM FORCES & MOMENTS
 -- SEE APPENDIX B

		FORCES	MOMENTS
SUCTION	X	356 lb	860 ft-lbs
	Y	932 lb	1179 ft-lbs
	Z	1463 lb	1009 ft-lbs
DISCHARGE	X	218 lb	259 ft-lbs
	Y	134 lb	620 ft-lbs
	Z	800 lb	424 ft-lbs

TENSILE LOAD

-- @ SUCTION NOZZLE

$$\text{DUE TO } F_z : \frac{(1463 \text{ lb}) \times (10.75")}{(2 \text{ bolts}) \times (43")} = 182.9 \text{ lbs}$$

$$\text{DUE TO } F_x : \frac{(356 \text{ lb}) \times (10.75")}{(2 \text{ bolts}) \times (15")} = 127.6 \text{ lbs}$$

$$\text{DUE TO } F_y : \frac{932 \text{ lbs}}{4 \text{ bolts}} = 233 \text{ lbs}$$

$$\text{DUE TO } M_x : \frac{(860 \text{ ft-lbs}) \times (12)}{(2 \text{ bolts}) \times (43")} = 120 \text{ lbs}$$

$$\text{DUE TO } M_z : \frac{(1009 \text{ ft-lbs}) \times (12)}{(2 \text{ bolts}) \times (15")} = 403.6 \text{ lbs}$$

					APW TURBINE DRIVEN PUMP - 910		
0	CJC	6/20/84	WT	7/10/84	JOB NO 0310-036-1356		PAGE 15
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-01		OF 21



-- @ DISCHARGE NOZZLE

$$\text{DUE TO } F_z : \frac{(800 \text{ lb})(11.50")}{(2 \text{ bolts})(43")} = 107 \text{ lbs}$$

$$\text{DUE TO } F_x : \frac{(218 \text{ lb})(11.50")}{(2 \text{ bolts})(15")} = 83.6 \text{ lbs}$$

$$\text{DUE TO } F_y : \frac{134 \text{ lb}}{4 \text{ bolts}} = 33.5 \text{ lbs}$$

$$\text{DUE TO } M_x : \frac{(359 \text{ ft-lb})(12")}{(2 \text{ bolts})(43")} = 50.1 \text{ lbs}$$

$$\text{DUE TO } M_z : \frac{(424 \text{ ft-lb})(12")}{(2 \text{ bolts})(15")} = 169.6 \text{ lbs}$$

SHEAR LOAD

-- @ SUCTION NOZZLE

$$\text{DUE TO } F_x : \frac{356 \text{ lb}}{4 \text{ bolts}} = 89 \text{ lbs}$$

$$\text{DUE TO } F_z : \frac{1463 \text{ lb}}{4 \text{ bolts}} = 365.75 \text{ lbs}$$

$$\text{DUE TO } M_y^* : \frac{(1179 \text{ ft-lb})(12")}{(4 \text{ bolts})(22.77")} = 155.33 \text{ lbs}$$

* SINCE M_y IS AT CENTER OF BOLT PATTERN
THEN,

$$d = \sqrt{\left(\frac{48}{2}\right)^2 + \left(\frac{15}{2}\right)^2} = 22.77"$$

					AFW TURBINE DRIVEN PUMP - 410		
					JOB NO 0310-036-1356		
					CALC NO		
0	gpc	6/21/84	WE	7/10/84	EQ-01		
REV	BY	DATE	CHECKED	DATE	PAGE 16 OF 27		



-- @ DISCHARGE NOZZLE

DUE TO F_x : $\frac{218 \text{ lb}}{4 \text{ bolts}} = 54.5 \text{ lb}$

DUE TO F_z : $\frac{800 \text{ lb}}{4 \text{ bolts}} = 200 \text{ lb}$

DUE TO M_y : $\frac{(620 \text{ ft} - 16)(12)}{(4 \text{ bolts})(22.77'')} = 81.69 \text{ lb}$

SUMMARIZING LOADS


TOTAL TENSILE LOAD


NOZZLE: @ SUCTION SEISMIC
 $(182.9 + 127.6 + 233 + 120 + 403.6) + (258 + .23)$
 $+ (107 + 83.6 + 33.5 + 50.1 + 169.6) = 4095.23 \text{ lbs}$
 NOZZLE: @ DISCHARGE

TOTAL SHEAR LOAD:

IN ORDER TO COMBINE LOADS, RESOLVE LOAD F_M
 DUE TO M_y INTO LOADS IN THE X & Z DIRECTIONS

I.E. GIVEN THE BOLT PATTERN --



					AFW TURBINE DRIVEN PUMP - 610		
0	<i>cgl</i>	6/21/84	WI	7/10/84		JOB NO 0310-036-1356	PAGE 17
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-01	OF 21

-- @ SUCTION NOZZLE

$$\frac{F_x}{155.3 \text{ lb}} = \frac{21.50}{22.77} \quad \therefore F_x = 146.64 \text{ lb}$$

$$\frac{F_z}{155.3 \text{ lb}} = \frac{7.5}{22.77} \quad \therefore F_z = 51.15 \text{ lb}$$

-- @ DISCHARGE NOZZLE

$$\frac{F_x}{81.69 \text{ lb}} = \frac{21.50}{22.77} \quad \therefore F_x = 77.13 \text{ lb}$$

$$\frac{F_z}{81.69 \text{ lb}} = \frac{7.5}{22.77} \quad \therefore F_z = 26.91 \text{ lb}$$

RESULTANT SHEAR LOAD --

$$\begin{aligned} & \left[\begin{array}{l} \text{X-DIRECTION} \qquad \qquad \qquad \text{SEISMIC} \\ (89 + 54.5 + 146.64 + 77.13 + 748.13)^2 \\ + (365.75 + 200 + 51.15 + 26.91 + 748.13)^2 \end{array} \right]^{1/2} \\ & \qquad \qquad \qquad \text{Y-DIRECTION} \qquad \qquad \qquad \text{SEISMIC} \\ & = 1783.71 \text{ lb} \end{aligned}$$

					AFW TURBINE DRIVEN PUMP - S10			
0	cgc	6/21/84	WT	7/10/84	JOB NO 0310-036-1356		PAGE 18	
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-01		OF 21	



STRESSES

$$f_t = \frac{P}{A_t} = \frac{4095.23 \text{ lbs}}{0.969 \text{ in}^2} = 4.23 \text{ KSI}$$

$$f_v = \frac{V}{A_r} = \frac{1783.71 \text{ lbs}}{0.890 \text{ in}^2} = 2.00 \text{ KSI}$$

MAXIMUM ALLOWABLES

$S_u = 60 \text{ KSI}$ FOR A307 BOLTS
(ASME SECTION III, TABLE I-7.3)

$$F_t = \frac{S_u}{2} = \frac{60}{2} = 30 \text{ KSI}$$

$$F_v = \frac{0.62 S_u}{3} = \frac{0.62(60)}{3} = 12.4 \text{ KSI}$$

ASME CODE
--NF-3324.6
LEVEL A
CONDITIONS

INTERACTION (PER NF-3324.6(a) (3))

$$\left(\frac{f_t}{F_t}\right)^2 + \left(\frac{f_v}{F_v}\right)^2 < 1$$

$$\left(\frac{4.23}{30}\right)^2 + \left(\frac{2.00}{12.40}\right)^2 = 0.05 < 1 \quad \text{OK}$$

∴ BOLTS QUALIFY


					APW TURBINE DRIVEN PUMP - 410			
0	CJC	6/21/84	WI	7/10/84	JOB NO 0210-036-1356		PAGE 19	
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-01		OF 21	



BASE HOLDOWN BOLTS

ASSUMPTIONS:

- (1) WT OF PUMP ACTS ABOUT \bar{E} OF PUMP BOLTING
WT OF TURBINE ACTS ABOUT \bar{E} OF TURBINE BOLTING
- (2) WT OF PUMP LEG SUPPORTS IS INCLUDED IN
WT OF PUMP & ALSO ACTS ABOUT \bar{E} OF PUMP BOLTING
- (3) NOZZLE LOADS ARE AS FOUND IN BECHTEL CALC [2]
- (4) ALL BASEPLATE BOLTS REACT TO ALL LOADS
- (5) ALL FORCES & MOMENTS ACT @ CENTER OF BOLT PATTERN



FROM [1]:

BASEPLATE: 400 #

BOLTS: 10- $\frac{7}{8}$ " ϕ HOOKS
 P.4-441 { ROOT AREA: 0.419 IN²
 [3] { TENSILE AREA: 0.462 IN²
 -- EMBEDMENT = 1"

					APW TURBINE DRIVEN PUMP - 610		
0	CGL	6/22/84	WE	7/10/84	JOB NO 0310-036-1356	PAGE 20	
REV	BY	DATE	CHECKED	DATE	CALC NO	OF 21	
					EQ-01		



SUMMARIZING FORCES ACTING ON BASEPLATE BOLTS :

		X	Y	Z
TURBINE	F	2310 lb	1540 lb	2310 lb *
	M	—	—	—
PUMP	F	2993 lb	1995 lb	2993 lb **
	M	—	—	—
PUMP SECTION NOZZLE	F	356 lb	932 lb	1463 lb
	M	860 ft-lb	1179 ft-lb	1009 ft-lb
PUMP DISCHARGE NOZZLE	F	218 lb	134 lb	800 lb
	M	359 ft-lb	620 ft-lb	424 ft-lb

FROM BASEPLATE: (BASEPLATE WT: 400 #)

$$F_x = F_z = (400 \text{ lb})(1.05 g) = 420 \text{ lb}$$

$$F_y = (400 \text{ lb})(0.7 g) = 280 \text{ lb (UPWARD)}$$

-- MOMENT DUE TO SKID OVERTURNING IS NEGLIGIBLE

* TURBINE WT: 2200 #


$$F_x = F_z = (2200 \text{ lb})(1.05 g) = 2310 \text{ lb}$$

$$F_y = (2200 \text{ lb})(0.70 g) = 1540 \text{ lb}$$

** PUMP WT: 2850 #

$$F_x = F_z = (2850 \text{ lb})(1.05 g) = 2993 \text{ lb}$$


$$F_y = (2850 \text{ lb})(0.70 g) = 1995 \text{ lb}$$

					AFW TURBINE DRIVEN PUMP - 610		
0	Cgc	6/23/84	WI	7/10/84	JOB NO 0310-036-1356		PAGE 21
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-01		OF 27
							

TENSILE LOAD

DUE TO F_2 & M_x --

LOADS ON BOLTS MAY BE MODELED AS:



WHERE,
$$\begin{cases} M_x = F_1(22+21) + F_2(21) + F_3(21) + F_4(22+21) \\ F_1 = F_4 \neq F_2 = F_3 \end{cases}$$

AND,

$$\frac{F_1}{22+21} = \frac{F_2}{21} \rightarrow F_2 = \frac{21}{43} F_1 = 0.50 F_1$$

THUS, $M_x = 2F_1(43) + 2(0.5F_1)(21) = 107F_1$

FOR 2 BOLTS ACTING @ EACH DISTANCE -- $M_x = 214 F_1$

$$F_1 = \frac{\text{TURBINE} \quad \text{PUMP}}{(2310 \text{ lb} \times 21.5") + (2993 \text{ lb} \times 21.5")}{214"} = 533 \text{ lb}$$

$$F_1 = \frac{\text{EJECTION NOZZLE}}{(1463 \text{ lb} \times 16.75") + (860 \text{ ft-lb} \times 12")}{214"}$$

$$+ \frac{\text{DISCHARGE NOZZLE}}{(800 \text{ lb} \times 17.5") + (359 \text{ ft-lb} \times 12")}{214"}$$

= 248 lbs

					AFW TURBINE DRIVEN PUMP - 610		
0	cgc	6/22/04	WE	7/12/04	JOB NO 0310-036-1356		PAGE 22
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-01		OF 27

DUE TO $F_x \neq M_z$ --

$$F_x = \frac{\text{TURBINE } (2310 \text{ lb} \times 21.5") + \text{PUMP } (2093)(21.5")}{(5 \text{ boHs} \times 20")} = 1140 \text{ lbs}$$

$$F_x = \frac{\text{SUCTION NOZZLE } (356 \text{ lb} \times 16.75") + (1009 \text{ ft-lb} \times 12)}{(5 \text{ boHs} \times 20")}$$

$$+ \frac{\text{DISCHARGE NOZZLE } (218 \text{ lb} \times 17.5") + (424 \text{ ft-lb} \times 12)}{(5 \text{ boHs} \times 20")}$$

$$= 270 \text{ lbs}$$

DUE TO F_y --

$$F_x = \frac{\text{TURBINE } 1540 \text{ lb} + \text{PUMP } 1995 \text{ lb} + \text{BASEPLATE } 280 \text{ lb}}{10 \text{ boHs}} = 381.5 \text{ lbs}$$

$$F_x = \frac{\text{SUCTION } 932 \text{ lb} + \text{DISCHARGE } 134 \text{ lb}}{10 \text{ boHs}} = 106.6 \text{ lbs}$$

TOTAL TENSILE LOAD = ASUM (F_x) - DEADWEIGHT

$$\text{TOTAL TENSILE} = (533 + 248 + 1140 + 270 + 381.5 + 106.6)$$

$$- \frac{\text{TURBINE } 2200 \text{ lb} + \text{PUMP } 2850 \text{ lb} + 400 \text{ lb}}{10 \text{ boHs}}$$

$$= 2134.1 \text{ lbs/boH}$$

					AFW TURBINE DRIVEN PUMP - G10		
0	cgc	6/22/84	WI	7/10/84	JOB NO 0310-036-1356		PAGE 23
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-01		OF 21



SHEAR LOAD

DUE TO F_z --

$$F_{Vz} = \frac{\text{TURBINE} \quad \text{PUMP} \quad \text{SUCTION} \quad \text{DISCHARGE BASEPLATE}}{10 \text{ BOLTS}}$$

$$= \frac{2310 \text{ lb} + 2993 \text{ lb} + 1463 \text{ lb} + 800 \text{ lb} + 420}{10}$$

$$= 798.6 \text{ lb}$$

DUE TO F_x --

$$F_{Vx} = \frac{\text{TURBINE} \quad \text{PUMP} \quad \text{SUCTION} \quad \text{DISCHARGE BASEPLATE}}{10 \text{ BOLTS}}$$

$$= \frac{2310 \text{ lb} + 2993 \text{ lb} + 356 \text{ lb} + 218 \text{ lb} + 420}{10}$$

$$= 629.7 \text{ lb}$$

DUE TO M_y^* --

$$M_y = 4(44.15)F_{V_a} + 4(23.26)F_{V_c} + 2(10)F_{V_o}$$

$$F_{V_o} = \frac{10}{44.15} F_{V_z} = 0.23 F_{V_z}, \quad F_{V_c} = \frac{23.26}{44.15} F_{V_z} = 0.53 F_{V_z}$$

$$(1179 \text{ ft-lb} + 620 \text{ ft-lb})(12)$$

$$= 4(44.15)F_{V_z} + 4(23.26)(0.53 F_{V_z}) + 2(10)(0.23 F_{V_z})$$

$$21,588 \text{ in-lbs} = 230.5 F_{V_z} \quad \therefore F_{V_z} = 93.65 \text{ lbs}$$

$$F_{V_c} = 49.63 \text{ lbs}$$

$$F_{V_o} = 21.54 \text{ lbs}$$

* SINCE M_y IS AT CENTER OF BOLT PATTERN
THEN,

$$d_e = 10"$$

$$d_a = \sqrt{(10)^2 + (43)^2} = 44.15"$$

$$d_c = \sqrt{(10)^2 + (21)^2} = 23.26"$$

					AFW TURBINE DRIVEN PUMP - #10		
0	CJC	6/22/84	WJ	7/10/84	JOB NO 0310-036-1356		PAGE 24
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-01		OF 27




SUMMARIZING LOADS

TOTAL TENSILE : 2134.1 lb

TOTAL SHEAR:

IN ORDER TO COMBINE LOADS, RESOLVE LOADS F_{Vz}, F_{Vc}, F_{Vo} DUE TO M_y INTO LOADS IN THE X & Z DIRECTIONS

I.E. GIVEN THE BOLT PATTERN --



$$\frac{F_x}{F_v} = \frac{z}{d} \quad \frac{F_z}{F_v} = \frac{x}{d}$$

EVALUATE FOR LARGEST FORCES -- @ BOLT J

$$\frac{F_{xj}}{93.65} = \frac{43}{44.15} \quad F_{xj} = 91.21 \text{ lb}, \quad \frac{F_{zj}}{93.65} = \frac{10}{44.15} \quad F_{zj} = 21.21 \text{ lb}$$

RESULTANT SHEAR LOAD --

$$F_v = \sqrt{(629.7 + 91.21)^2 + (798.6 + 21.21)^2} = 1092 \text{ lb}$$

					APW TURBINE DRIVEN PUMP - 610		
0	CGC	6/22/84	WI	7/10/84	JOB NO 0310-026-1356		PAGE 25
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-01		OF 27

MAXIMUM ALLOWABLES

ASSUME: CONCRETE J-BOLTS HAVE THE SAME ALLOWABLES AS EXPANSION BOLTS OF THE SAME SIZE AND SAME DEPTH OF EMBEDMENT

PER [1], J-BOLTS ARE 3/8" ϕ , 1' LONG (W/ 4" HOOK)

ASSUME ALLOWABLES FOR 3/4" ϕ BOLTS
-- PER [7] IN 4000 PSI CONCRETE
WITH 9" EMBEDMENT

PER [6], USE FACTOR OF SAFETY = 4 --

$$F_t = \frac{23500}{4} = 5875 \text{ lbs}$$

$$F_v = \frac{18466}{4} = 4616.5 \text{ lbs}$$

INTERACTION

$$\frac{f_t}{F_t} + \frac{f_v}{F_v} < 1$$

$$\frac{234}{5875} + \frac{1092}{4616.5} = 0.60 < 1 \quad \text{(OK)}$$


∴ BOLTS QUALIFY

					AFW TURBINE DRIVEN PUMP - G10		
0	CGC	6/22/84	WI	7/10/84	JOB NO 0310-036-1356		PAGE 26
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-01		OF 27



LOCAL STRESSES ON THE FLANGE OF THE BASE

ASSUMPTIONS: (1) THE FLANGE IS RIGID
(2) CHANNELS ARE A36



FROM DIMENSIONS SHOWN IN [1], AND LIST OF MISC. CHANNELS IN [3], CHANNEL IS ASSUMED TO BE: MC 6x18

USING TABLE ON P. 190 [9] --

$$\sigma = K_m \left(\frac{6P}{t^2} \right)$$

$$\left\{ \begin{array}{l} P = 2134.1 \text{ lb} \\ t = 0.25" \end{array} \right.$$

$$\textcircled{a} \frac{c}{d} = \frac{2}{3.5} = 0.57$$

$$\frac{z}{d} = \frac{21}{3.5} = 6$$

$$K_m = 0.011$$


$$\sigma = 0.011 \left[\frac{6(2134.1 \text{ lb})}{(0.25)^2} \right] = 2.25 \text{ ksi}$$

MAXIMUM ALLOWABLE --


BENDING: $F_b = 0.66 F_y = 0.66 (36 \text{ ksi}) = 23.67 \text{ ksi}$

$$2.25 < 23.67 \text{ ksi} \quad \textcircled{\text{OK}}$$

∴ FLANGE IS QUALIFIED

					APW TURBINE DRIVEN PUMP - 610		
0	gcu	6/25/84	WI	7/10/84	JOB NO 0310-036-1356		PAGE 27
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-01		OF 27
							

APPENDIX A


					AFW TURBINE DRIVEN PUMP - 610		
						JOB NO 0310-036-135	PAGE
						CALC NO EQ-01	OF
REV	BY	DATE	CHECKED	DATE			

AUX. FWD PUMP G-10^N (DISCHARGE)

NOZZLE SIZE 3"
 LINE NUMBER 3B1A-3"-EG-3ACB
 DATA POINT 1

STRESS PROBLEM: So. Cal. Ed.
EALC NO DC-859-1

PSID S159570
CC#2 SHT 20F2
 (BY EDISON LETTER, 11-22-82,
 NO 708)



LOADS	WT+TH+DEE+SAMS NOTE 2		WT+DBE		TH+SAMS		COMMENTS
	F	M	F	M	F	M	
WHALE	390	1370	N.A.	N.A.	N.A.	N.A.	1. Calculation by So. Cal. Ed. 2. SAMS is negligible, not included. 3. North Direction is (FT).
+ Fx = FT	218		0		226		
- Fx = FT	8		8		0		
+ Fy = Fc	120		40		80		
- Fy = Fc	134		134		0		
+ Fz = FL	31		31		0		
- Fz = FL	799		17		782		
+ Mx = MT		151		151		0	
- Mx = MT		359		129		230	
+ Mz = ML		424		197		227	
- Mz = ML		211		211		0	
+ My = ML		11		11		0	
- My = ML		620		19		601	

Prepared By: W. VAN METER Date: 11-17-82

Checked By: _____ Date: _____


SONGS # 1, Job No 14000-300

AF

P. F. 2-11 2151
10/10

MECH. CALC # MC-384-21
 EQUIPMENT PUMP 6-10 (SUCTION)
 NOZZLE SIZE 4"
 LINE NUMBER 8110-4"-JN
 DATA PT. 650
 STRESS PROBLEM PI-AF-02

SHT. 17 OF 64
 REV. 0




PE ID NO. 5159570
 LOADS/ACCELERATIONS HEREIN HAVE
 BEEN REVIEWED AND APPROVED BY
 THE MECHANICAL DISCIPLINE

SHOW ORIENTAT
 IF DIFFERENT T
 ABOVE.


EGS CR Myr
 DATE 3/23/83 CALC # MC-384-21

LOADS	WT + TH + DBE + SLL		WT + DBE		TH + SAM		COMMENTS
	F	M	F	M	F	M	
<u>ALLOWABLE</u>	2150 40	7155 2185	N/A	N/A	N/A	N/A	
F _x = F _T	356 / -354						
-F _y = F _C	932 / -263						
F _z = F _L	1033 / -1463						
M _{1x} = M _T	10320	860 / -322					
M ₂ = M _C	12180	51 / -1009					
-M ₃ = M _L	14148	745 / -1179					



UNITS - F (LBS)
 M (FT-LBS)

APPENDIX B

					AFW TURBINE DRIVEN PUMP - G10		
						JOB NO 0310-036-1356	PAGE
						CALC NO	EQ-01
REV	BY	DATE	CHECKED	DATE			

KWIK-BOLT

AVERAGE ULTIMATE TENSILE & SHEAR LOADS*

CONCRETE STRENGTH		2000 PSI		4000 PSI		6000 PSI	
Diameter	Embedment	Tension	Shear	Tension	Shear	Tension	Shear
5/8"	2 3/4"	5410	11198	6600	11562	7700	13500
	3 1/2"	6250	11198	9100	11562	9560	13500
	4 1/2"	7000	11198	12000	11562	14500	13500
	5 1/2"	7550	13378	14300	15437	20300	15437
	6 1/2"	8025	13378	16000	15437	21000	15437
	7 1/2"	9000	13378	17000	15437	21000	15437
3/4"	3 1/4"	8155	13257	10150	17133	10860	18102
	4"	9700	13257	13400	17133	13700	18102
	5"	11700	13257	16500	17133	17600	18102
	6"	13800	15195	18000	18466	22500	21009
	7"	15800	15195	21000	18466	23600	21009
	8"	16000	15195	23000	18466	23600	21009
	9"	16000	15195	23500	18466	23600	21009
1"	4 1/2"						
	5"						
	6"						
	7"						
	8"						
	9"						

Actual Concrete Strengths

2178 psi 4027 psi 6119 psi

*See sheet A-3 for notes

A-2

ABBOT A. HANKS, TESTING LABORATORIES, SAN FRANCISCO, CA. 94107

APPENDIX C

					AFW TURBINE DRIVEN PUMP - 610		
						JOB NO 0310-036-1356	PAGE
						CALC NO	OF
REV	BY	DATE	CHECKED	DATE	EQ-01		



Bechtel Power Corporation

Engineers - Constructors

12400 East Imperial Highway

Norwalk, California 90650

MAIL ADDRESS

P.O. BOX 60860 - TERMINAL ANNEX, LOS ANGELES, CALIFORNIA 90060

TELEPHONE: (213) 807-2000



March 30, 1984

BPC/V-84-161

ROUTE :

WD GALLO

RLGRUBB

A SEIKEN

WR BIK

DGOMEZ

Mr. W. D. Gallo
Project Manager
Advanced Engineering
Impell Corporation
350 Lennon Lane
Walnut Creek, CA 94598

Subject: San Onofre Nuclear Generating Station, Unit 1
Bechtel Job No. 15691-384
Safe Shutdown Equipment Data For:
~~_____~~
b) CVCS Test Pump G-42
c) Seal Water Injection Filter C-42 N/S

Dear Mr. Gallo:

The enclosed information is forwarded for your use in performing calculations to determine seismic capability of the subject equipment. Should you require further information, please contact Rick Gold at (213) 807-2466.

Very truly yours,

BECHTEL POWER CORPORATION

A handwritten signature in dark ink, appearing to read "John Duffin", is written over the typed name and title.
J. D. Duffin
Project Engineering Manager

RKG:jem/1925L

Enclosure: 1. Summary of Equipment Data
Transmittal to Impell
2. Equipment Data

cc: A. R. Guerrero
W. L. Nelson
G. W. Gartland
All with Enclosure 1 only

ENCLOSURE 1


SUMMARY OF EQUIPMENT
DATA TRANSMITTAL TO IMPELL

Equipment No.	Description	Type of Data Provided
G-10	Auxiliary Feedwater Turbine Driven Pump	<ol style="list-style-type: none">✓ 1. Component material, weight, nozzle and vessel thickness and pump foundation details.✓ 2. Pump, motor and base plate bolt patterns.✓ 3. Pump pedestal and base (channel) dimensions.✓ 4. Pump and turbine outline dwgs. (2 dwgs.)✓ 5. Pump and turbine data (2 sheets).
G-42	CVCS Test Pump	<ol style="list-style-type: none">1. Component material, weight, nozzle and vessel thickness and motor base detail.2. Foundation detail.3. Pump outline dwg.
C-42 N/S	Seal Water Injection Filter	<ol style="list-style-type: none">1. Component weight, material, nozzle and vessel thickness and horizontal support information.2. Filter installation information.3. Filter shell and base assembly dwg.4. Filter outline dwg.5. Seal Water Filters concrete enclosure plan and detail dwg.

A1

DATE APPROVALS SUPV MATL CHK OR ENG REV. DESCRIPTION	LIQUID PUMPED <u>Condensate</u> FLOW: MINIMUM /DESIGN _____ (GPM)(LBS/HR) <u>300</u> FLOW TEMP/SPECIFIC GRAVITY <u>40-90F/1.0</u> VISCOSITY (CST)/VAPOR PRESS.(PSIA) <u>1.0/0.3</u> PRESSURE: SUCTION/DISCHARGE Ft. Abs. (XXXX) <u>30-60</u> DIFFERENTIAL: FEET/INCH <u>2510</u> NPSH: AVAILABLE/REQUIRED By Bidder (FT) <u>30/18.5</u>
	GMP/DRIVER HP/EFFICIENCY (AT RATING) <u>292/292/65%</u> IMPELLER DIAMETER: SIG/MAX <u>8-3/8"/8-3/8"</u> IMPELLER EYE: AREA/ENTRANCE VEL: <u>8.83 in</u> RPM/ROTATION (FACING COUPLING) <u>4400/CW</u> MAX. ALLOW WORK PRESS./NO. STAGES <u>1600 psig/6</u> BEAR RING (OR IMPELLER) CLEARANCE _____
	Material <u>Suggested Bidders</u> <u>Trim</u> <u>11-13% Chrome</u>
	CASE MATERIAL: INNER/OUTER <u>Cast Iron</u> IMPELLER MATERIAL <u>Chrome Steel 11-13%</u>
	WEAR RING MTL: CASE/IMPELLER <u>Chrome Steel 11-13%</u> SHAFT: MATERIAL/DIAMETER <u>Chrome Steel 11-13% / 1.25" @ impeller</u> SHAFT SLEEVE MTL/EXTEND THRU GLAND? <u>Harden Chrome Steel/Yes 11-13%</u> COUPLING: TYPE/MANUFACTURER <u>Thomas Flexible</u> COUPLING GUARD REQUIRED? <u>Yes</u> BASEPLATE: TYPE/MATERIAL <u>Lip or Rim/Fabricated Steel</u> SHAFT SEAL: TYPE/SEALING COM? <u>Packing/No</u> BEARINGS: TYPE: THRUST/RADIAL <u>Ball/Ball</u> LUBRICATION: THRUST/RADIAL <u>Oil/Oil</u>
	SUCTION CONNECTION: SIZE/RATING/FACING <u>600#/ASA FF 3" Right Side</u> (DOUBLE)(SINGLE)/POSITION _____ DISCHARGE CONNECTION: SIZE/RATING/FACING <u>600# ASA FF 4" Left Side</u> POSITION _____
	PUMP MANUFACTURER <u>Worthington Corp.</u> TYPE & SIZE <u>3WTF - 86</u> NET WEIGHT (PUMP ONLY)/SERIAL NUMBER <u>2590#</u> DRIVER MFG./FURN BY Bidder <u>Worthington/Worthington</u> (MOTOR)(TURB.)/(PROPELLER) (CPLD.) <u>S2R/Coupled</u> SERIAL NUMBER/DRAWING REFERENCE _____ INSPECTION/HYDROSTATIC TEST? <u>Yes/Yes</u> PERFORMANCE TEST?/WITNESSED? <u>Yes/No</u> COST CODE _____ PO NO) (XXXX) (SPEC NO) <u>BSO-421</u>

VPS-832-12/56

BECHTEL CORPORATION

 POWER DIVISION
 ENGINEERING

HORIZONTAL CENTRIFUGAL PUMP DATA SHEET
 AUXILIARY FEEDWATER PUMP,
 TURBINE DRIVEN, G-10

JOB No - 3246
 San Onofre Nuclear
 Generating Station,
 Unit 1
 REV.

A2

DATE APPROVALS SUPV ENGR OR ENG DESCRIPTION

(HORIZONTAL) (VERTICAL)	horizontal
HP: GEG/BID/WITH MAX. MANU VALVES	292/292/none
PPM OF TURBINE WHEEL: BID/MAX	4400/4500
NUMBER OF HAND VALVES: BID/MAX	none/Three
STEAM: PRESSURE/TEMPERATURE	600 psig/486 °
MAX. STEAM: PRESSURE/TEMPERATURE	600 psig/600 °
BACK PRESSURE (PSIG) (INCHES)	5
MAX. BACK PRESSURE ALLOWABLE ON CASE	75 psig
WATER RATE: FULL LOAD $\frac{3}{4}$ LOAD (LBS/HP-HR)	27.7 #/hp-hr
$\frac{1}{2}$ LOAD $\frac{1}{4}$ LOAD	34.2 #/hp-hr
NO. OF STAGES/EFFICIENCY	Single
ROTATION: TURBINE/GENERATOR	CW
GOVERNOR: TYPE/NEMA CLASS	Mechanical Shaft/Nema Class A
SPEED CHANGER: TYPE	Manual
CONTROLLED BY/LOADING PRESS.	
CASING RELIEF VALVE: SIZE/SETTING	Sentinel Warning Set @ 90 psig
ROTOR MATERIAL	Open hearth carbon steel plate
BLADE MATERIAL	Stainless Steel
CASING MATERIAL	Cast Steel
SHAFT: MATERIAL/NOM. DIAMETER	hot rolled steel alloy
STEAM STRAINER FURN?/BASEPLATE FURN	Yes - Integral & removable/W/pump
BEARINGS: TYPE: THRUST/RADIAL	Bronze & habbitt
LUBRICATION: THRUST/RADIAL	Ring oiled sleeve bearings
LUBE OIL COOLER: TYPE/MFR.	None
SHAFT PACKING: TYPE/NO OF RINGS	Carbon/4 per box
STEAM INLET: SIZE/RATING/FACING	600#/ASA R1 3 inch
STEAM OUTLET: SIZE/RATING/FACING	150#/ASA R1 8 inch
CPLG TYPE/FURN BY	See Pump
TURBINE MANUFACTURER:	Worthington Corporation
TYPE & SIZE	Model S2? Class II
NET WEIGHT (TURBINE ONLY)/SERIAL NUMBER	1740#
INSPECTION?/DYNAMIC BALANCING OF ROTOR?	Yes/Yes
PERFORMANCE TEST?/WITNESSED?	Yes/No
(PO NO) (REQ'N NO.) (SPEC NO)/COST CODE	ES0-421



AUXILIARY STEAM TURBINE DATA SHEET

AUXILIARY FEEDWATER PUMP
TURBINE DRIVER

JOB No 3246
San Onofre Nuclear
Generating Station,
Unit 1
REV.

11-2
8-56

AUX. FEE WATER PUMP (TURBINE DRIVEN)

G-10

1. MATERIAL

BASE PLATE - A36

BOLTS A307 4 - 1/4" ϕ PUMP
 8 - 3/4" ϕ TURBINE
 10 - 7/8" ϕ FOUNDATION/CHANNEL



2. WEIGHT


BASE PLATE \approx 400 #
PUMP \approx 2590 #
TURBINE (TOT.) \approx 2200 #
FLUID IN PUMP \approx 260 #

3. NOZZLE AND VESSEL THICKNESS

	NOZZLE THICK.	VESSEL THICK.
1/2" NOZZLES	.109"	1.25"
3" NOZZLE	1.25"	1.25"
4" NOZZLE	1.25"	1.25"

4. FOUNDATION DETAILS





T. Field Measurements and Sketches



PLAN

STEAM DRIVEN-AUX. FEEDWATER PUMP
(G-10)

NOTE: ALL DIMENSIONS
IN THIS DRAWING


AUX. F.W. PUMP
(G-10)

PEDESTAL



base (channel) dimensions

CALCULATION/PROBLEM COVER SHEET



Calculation/Problem No: EQ-06
 Title: SEAL WATER HEAT EXCHANGER, E-34
 Client: SCE Project: SONGS-1
 Job No: 0310-036

Design Input/References:

SEE SECTION 3-0

Assumptions:

AS NOTED

Method:

EQUVALENT STATIC ANALYSIS

Remarks:

QUALIFIED, NO MODIFICATIONS REQUIRED W/ 7/26/84

REV. NO.	REVISION	APPROVED	DATE
0	<u>ORIGINAL</u>	<u>W/R B. J.</u>	<u>7/27/84</u>

CONTENTS

	PAGE
COVER SHEET	1.
CONTENTS	2.
1.0 SUMMARY OF RESULTS	3.
2.0 INTRODUCTION	5.
3.0 REFERENCES	6.
4.0 COMPUTER MODEL	8
5.0 FREQUENCY ANALYSIS	19
6.0 NOZZLE LOADS	22.
7.0 STRUCTURAL ANALYSIS	29
7.1 ELEMENT TYPE 1 (C6x10.5)	36
7.2 ELEMENT TYPE 2 (W6x20)	39
7.3 ELEMENT TYPE 3 (W4x13)	42
7.4 ELEMENT TYPE 4 (C4x5.4)	45
7.5 SUPPORT SADDLES	48
7.6 SADDLE BOLTS	53
8.0 BASE PLATE EVALUATIONS	58
8.1 GROUP 1	59
8.2 GROUP 2	73
8.3 GROUP 3	79
8.4 GROUP 4	80
9.0 WELDS	<u>87</u>

APPENDIX A - REFERENCE MATERIAL
(NOT INCLUDED IN TOTAL PAGES,
FOR INFORMATION ONLY)

D	WI				IMPELL <small>CORPORATION</small>		JOB NO 0310-035	PAGE	
REV	BY	DATE	CHECKED	DATE			CALC NO	2	
							EQ-06	OF	
								87	


1.0 RESULTS SUMMARY

<u>COMPONENT</u>	<u>CALCULATED STRESS</u>	<u>ALLOWABLE STRESS</u>	<u>REMARKS</u>
C6x10.5	.41 (INTERACTION)	1.0	OK, LEVEL A LIMITS
W6x20	.05 (INTERACTION)	1.0	OK, LEVEL A LIMITS
W4x13	.30 (INTERACTION)	1.0	OK, LEVEL A LIMITS
C4x5.4	.07 (INTERACTION)	1.0	OK, LEVEL A LIMITS
GROUP 1 BASE-PLATES			
ANCHOR BOLTS	.61 (INTERACTION)	1.0	OK, F.S. = 4.0
BASE PLATE	REQUIRED THICK- NESS = .49in	ACTUAL THICK- NESS = .75"	OK, LEVEL A LIMITS
GROUP 2 BASE PLATES			
ANCHOR BOLTS	1.0 (INTERACTION)	1.0	OK, FS = 2.0 (NOTE 1)
BASE PLATE	15.6 Ksi	21.6 Ksi	OK, LEVEL A LIMITS

0	WS	7/25/84	SSX	7/26/84	IMPELL CORPORATION		JOB NO CALC NO	1210-030 ER-06	PAGE OF	3 87
REV	BY	DATE	CHECKED	DATE						

RESULTS SUMMARY, CONT.

<u>COMPONENT</u>	<u>CALCULATED STRESS</u>	<u>ALLOWABLE STRESS</u>	<u>REMARKS</u>
GROUP 3 BASEPLATES			
ANCHOR BOLT } BASE PLATE }	LOADS EXTREMELY LOW, BY INSPECTION		QUALIFIED
GROUP 4 BASEPLATES			
ANCHOR BOLTS	.27 (INTERACTION)	1.0	OK, FS=4.0
BASE PLATE	10 KSI	21.6 KSI	OK, LEVEL A LIMITS
SUPPORT SADDLES	.31 (INTERACTION)	1.0	OK, LEVEL A ALLOWABLES
SADDLE BOLTS	.82 (INTERACTION)	1.0	OK, LEVEL A ALLOWABLES
WELDS : QUALIFIED BASED ON EXTREMELY LOW LOADS IN STRUCTURAL MEMBERS. (MAX. INTERACTION IS .41;)			
NOTE 1: RESULTS ARE BASED ON A MINIMUM EMBEDMENT LENGTH OF 3/4" FOR A 3/4" DIAMETER BOLT. ACTUAL EMBEDMENT IS PROBABLY MUCH GREATER, ∴ RESULTS ARE CONSERVATIVE			

REV	BY	DATE	CHECKED	DATE		JOB NO 0310-036	PAGE 4
0	WI	7/25/84	gr	7-26-84		CALC NO ER-06	OF 87

2.0 INTRODUCTION.

THE ANALYSIS OF THE SEAL WATER HEAT EXCHANGER SUPPORT FRAME WILL BE PERFORMED USING THE EDGAP COMPUTER CODE. A MODE/FREQUENCY ANALYSIS WILL BE PERFORMED TO DETERMINE THE FIRST NATURAL FREQUENCY OF THE STRUCTURE. THE SEISMIC ACCELERATIONS CORRESPONDING TO THE FUNDAMENTAL FREQUENCY WILL THEN BE APPLIED TO THE STRUCTURE USING AN EQUIVALENT STATIC METHOD.

DIMENSIONS FOR THE MODEL ARE OBTAINED FROM SUPPORT SKETCHES AND FIELD MEASUREMENTS (SEE [1] + [2]). THE DIMENSIONS USED IN THE MODEL CORRESPOND AS CLOSELY AS POSSIBLE TO THE CENTERLINES OF THE AS-BUILT FRAME. SMALL OFFSETS FROM THE ACTUAL MEMBER CENTERLINES ARE NOT SIGNIFICANT AND WILL NOT AFFECT RESULTS.


THE DIRECTIONAL RESPONSES FROM EACH OF THE THREE SEISMIC LOADS WILL BE COMBINED BY SRSS. THE RESULT IS THEN COMBINED WITH THE GRAVITATIONAL LOADS BY ASUM (ABSOLUTE SUM) AND NOZZLE

					SCE E-34 HX	
					JOB NO 0310 036	
					CALC NO	
0	WE	6/5/84	SL	1/20/84	EQ-06	
REV	BY	DATE	CHECKED	DATE	PAGE 5 OF 8	



3.0 REFERENCES

1. BECHTEL POWER CORPORATION LETTER NO. BPC/V-84-160, DATED MARCH 30, 1984. FROM J. D. DUFFIN (BECHTEL) TO W. D. GALLO (IMPELL); SUPPORT SKETCHES FOR SEAL WATER HEAT EXCHANGER, E-34
2. WALKDOWN NOTES AND PHOTOGRAPHS OF SEAL WATER HEAT EXCHANGER (E-34) DATED 5-14-84, INCLUDED IN APPENDIX A
3. AISC MANUAL OF STEEL CONSTRUCTION, 8TH EDITION, AMERICAN INSTITUTE OF STEEL CONSTRUCTION, CHICAGO, ILLINOIS.
4. BASCO, INC. DRAWING FOR SEAL WATER HEAT EXCHANGER, DATED 11-18-64, DWG NO (ILLEGIBLE) (ATTACHMENT TO [1]).
5. EDGAP USERS MANUAL VERSION 3/1/80. IMPELL CORPORATION, SAN FRANCISCO CA.
6. HILTI FASTENING SYSTEMS, TEST DATA FOR 1" DIAMETER HILTI-KWIK-BOLTS (INCLUDED IN APPENDIX A)
7. COMPUTER RUN ACCQACRY, DATED 84/06/09, MODE/FREQUENCY ANALYSIS FOR THE SCE SEAL WATER HEAT EXCHANGER.
8. COMPUTER RUN ACCQACRY, DATED 84/06/09 EQUIVALENT STATIC ANALYSIS FOR THE SCE SEAL WATER HEAT EXCHANGER.
9. BECHTEL POWER CORP. CALC. NO. MC-384-9, E-34 SEAL WATER HEAT EXCHANGER, FOR INFORMATION ONLY

					E-34 Hx	
						
0	WI	6/10/84	5/2	7-20-84	JOB NO 0310-036	PAGE 6
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-06	OF 87

10. FIELD NOTES (DATA FILLED IN ON TELECOPY FROM WARD INGLES TO PIUS KAO) BASE PLATE DIMENSIONS, SEE APPENDIX A
11. ROARK AND YOUNG, "FORMULAS FOR STRESS AND STRAIN", 5TH EDITION, MCGRAW-HILL BOOK CO. NEW YORK, 1975
12. "BASE PLATE DESIGN PROCEDURE" IMPELL CORP TECHNICAL PROCEDURE NO. 2.6.1, REV 1, 5/28/83
13. CV-11 SUPPORT LOADS GENERATED BY BECHTEL, ME 10L ANALYSIS FOR CVCS SYSTEM, DATED 031684 (SEE APPENDIX
14. IMPELL CALCULATION NO SUP-CV-11-01 "PIPE SUPPORT EVALUATION FOR PIPE FUNCTIONALITY" JOB NO 0310-033-1355, REV. A, 5/23/84
15. EDGBAP ANALYSIS FOR NOZZLE LOADS ON SEAL WATER HEAT EXCHANGER, DATED 25-JUL-1984 10:40.

						JOB NO 0310-036	PAGE 7
						CALC NO EQ-06	OF 87
10	WT	7/20/84	SL	7/26/84			
REV	BY	DATE	CHECKED	DATE			



4.0 COMPUTER MODEL

THE EDSGAP ([5]) COMPUTER MODEL IS DESCRIBED ON THE FOLLOWING PAGES. THE MODEL CONTAINS TWO SUPPORTING STRUCTURES, DESIGNATED FRAME 'A' AND FRAME 'B', THE HEAT EXCHANGER SHELL AND THE SADDLE SUPPORTS CONNECTING THE SHELL TO THE SUPPORT FRAMES. THE SADDLE SUPPORTS ARE ASSUMED TO HAVE THE SAME SECTION AND MATERIAL PROPERTIES AS THE EXCHANGER SHELL.


DIMENSIONS ARE FROM [1], [2], AND [4].

THE FOLLOWING ASSUMPTIONS ARE USED IN THE MODEL.

- BOTH SADDLES ARE RIGIDLY ATTACHED TO THE SUPPORT FRAMES
- SADDLES HAVE THE SAME SECTION PROPERTIES AS THE EXCHANGER SHELL.
- VESSEL IS FULL OF FLUID, NO SLOSHING
- OTHERS AS NOTED

					SCE E-34 HX		
						JOB NO 0310-036	PAGE 8
						CALC NO	OF 87
0	WI	6/6/81	SSE	7.7.84		EQ-06	
REV	BY	DATE	CHECKED	DATE			

IMPELL
CORPORATION




EDSGAP MODEL OF SEAL WATER HEAT EXCHANGER - E-34

					SCE E-34 HX		
						JOB NO 0310-036	PAGE 9
						CALC NO EQ-06	OF 87
0	WI	6/5/84	SCE	1/18/84			
REV	BY	DATE	CHECKED	DATE			




FRAME "A", ED SGAP MODEL




NODE	X	Y	Z
1	31.	5.	99.
2	31.	24.0	↓
3	31.	43.	↓
4	67.	0.	↓
5	49.0	21.5	↓
6	31.	13.	130.
7	31.	28.0	114.5
8	31.	43.	130.
9	31.	43.	114.5
10	31.	51.5	99.
11	31.	60.	↓
12	24.0	60.	↓

NODE	X	Y	Z
13	24.0	51.5	99.
14	0.	60.	↓
15	8.5	60.	↓
16	0.	48.	↓
17	8.5	54.0	↓
18	17.	60.	↓

X = NODE NUMBERS
 (X) = ELEMENT NUMBERS

				E-34 HX	
				SCE	
0	WI	6/5/84	SXL	7-21-84	
REV	BY	DATE	CHECKED	DATE	
					
					JOB NO 0310 - 036 CALC NO EQ-06
					PAGE 10 OF 87

FRAME B




NODE	X	Y	Z
30	17.	60.	0.
31	8.5	60.	0.
32	0.	60.	0.
33	8.5	54.0	0.
34	0.	48.	0.
35	21.7	60.	0.
36	24.0	51.5	0.
37	26.5	60.	0.
38	31.	60.	0.
39	} 0,0,0	} NOT USED	}
40			
41			
42	31.0	30.0	-17.
43	21.0	0.	-34.
44	13.3	60.	15.6
45	0.	60.	31.3

NODE	X	Y	Z
46	31.	51.5	0
47	31.	43.	0
48	31.	24.	0
49	31.	5.	0
50	49.0	21.5	0
51	67.	0	0

					CCE E-34 HX	
					JOB NO 0310-036	
					CALC NO	
0	WI	6/5/84	SJR	7-20-84	EQ-06	
REV	BY	DATE	CHECKED	DATE	PAGE 11 OF 87	



HEAT EXCHANGER SHELL



NODE	X	Y	Z
19	17."	72."	135.
20	↓	↓	117.
21	↓	↓	99.
22	↓	↓	82.5
23	↓	↓	66.
24	↓	↓	49.5
25	↓	↓	33.
26	↓	↓	16.5
29	↓	↓	0.
27	↓	↓	-12.
28	17."	72"	-24.

X = NODE NUMBERS
 (X) = ELEMENT NUMBERS


NOTE: DISTANCES FROM 19-21 AND 29-28 ARE REVERSED, NO AFFECT ON RESULTS

SLE E-34 HX				
0	WI	6/5/84	[Signature]	7:05/84
REV	BY	DATE	CHECKED	DATE
				JOB NO 0210-036 CALC NO EQ-06
				PAGE 12 OF 37


BOUNDARY CONDITIONS

ALL CONNECTIONS ARE ASSUMED FIXED WITH THE FOLLOWING EXCEPTIONS.

- THE CONNECTIONS AT NODES 1 (FRAME A) AND NODE 49 (FRAME B) ARE NOT ASSUMED TO RESIST ANY MOMENTS. THESE CONNECTIONS ARE ASSUMED TO RESIST FORCES ONLY.
- THE CONNECTIONS AT NODES 14 (FRAME A) AND NODE 32 (FRAME B) ARE ASSUMED TO ALLOW ROTATION ABOUT THE GLOBAL Z AXIS.



BASE PLT @ NODES 1, 49




BASE PLT @ NODES 14, 32

					SCE E-34 HX
0	WI	6/6/84	SCE	7.18.84	
REV	BY	DATE	CHECKED	DATE	
					JOB NO 0310-036 CALC NO EQ-06
					PAGE 13 OF 87

BOUNDARY CONDITIONS CONT.

- THE CONNECTION AT NODE 45 IS ASSUMED TO ALLOW FREE ROTATION ABOUT THE GLOBAL Y AXIS:




- THE CONNECTIONS BETWEEN THE SADDLE SUPPORTS AND THE SUPPORT FRAMES ARE ASSUMED TO BE RIGID.

					SCE HX E-34		
0	WI	6/6/87	SM	7-14-84	JOB NO 0310-036		PAGE 14
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-06		OF 87



ELEMENT TYPE 1, C6x10.5 ([3], p. 1-36)



$$A = 3.09 \text{ in}^2$$

$$A_{22} = 2b_f t_f = 2(2.034)(.343) = 1.395 \text{ in}^2$$

$$A_{33} = t_w d = (.314 \text{ in})(6.00 \text{ in}) = 1.884 \text{ in}^2$$

$$I_{22} = 15.2 \text{ in}^4$$

$$S_{22} = 5.06 \text{ in}^3$$

$$I_{33} = .866 \text{ in}^4$$


$$S_{33} = .564 \text{ in}^3$$

$$\text{ASSUME } J = .01 \text{ in}^4$$

$$r = .529$$

ELEMENT TYPE 2,

FROM [2], $d \approx 6.25"$, $b_f \approx 6.00"$; FROM [1], MEMBER IS SPECIFIED AS W6x15.5, W6x15.5 IS NOT INCLUDED IN [3], \therefore ASSUME CURRENT MEMBERS WERE USED, W6x20



$$A = 5.87 \text{ in}^2$$

$$A_{22} = 2t_f b_f = 4.39 \text{ in}^2$$

$$A_{33} = t_w \cdot d = (.260 \text{ in})(6.20 \text{ in}) = 1.61 \text{ in}^2$$

$$I_{22} = 41.4 \text{ in}^4$$

$$S_{22} = 13.4 \text{ in}^3$$

$$I_{33} = 13.4 \text{ in}^4$$

$$S_{33} = 4.41 \text{ in}^3$$


$$r_{\text{MIN}} = 1.50 \text{ in}$$

$$J = .24 \text{ in}^4 \text{ [3], p. 1-114}$$

					CCE E-34 HX	
					JOB NO 0310-036	
					CALC NO	
0	WI	5/19/84	SSC	7-19-84	EQ-06	
REV	BY	DATE	CHECKED	DATE	PAGE 15 OF 87	



ELEMENT TYPE 3, W4x13



$$A = 3.83 \text{ in}^2$$

$$A_{22} = 2 b_f t_f = 2(4.06)(.345) = 2.80 \text{ in}^2$$

$$A_{33} = d t_w = (4.16)(.280) = 1.16 \text{ in}^2$$


$$I_{22} = 11.3 \text{ in}^4 \quad S_{22} = 5.46 \text{ in}^3$$

$$I_{33} = 3.86 \text{ in}^4 \quad S_{33} = 1.90 \text{ in}^3$$

$$J = .15 \text{ in}^4 \text{ [3] p. 1-114}$$

$$r = 1.00 \text{ in}$$

ELEMENT TYPE 4, ASSUME C4x5.4



$$A = 1.59 \text{ in}^2$$

$$A_{22} = t_w d = (4.00 \text{ in})(.184 \text{ in}) = .736 \text{ in}^2$$

$$A_{33} = 2 t_f b_f = 2(.296 \text{ in})(1.584 \text{ in}) = .938$$

$$I_{22} = .319 \text{ in}^4 \quad S_{22} = .283 \text{ in}^3$$

$$I_{33} = 3.85 \text{ in}^4 \quad S_{33} = 1.93 \text{ in}^3$$

$$\text{ASSUME } J = .01 \text{ in}^4$$

$$r = .449 \text{ in}$$

ELEMENT TYPE 5, HEAT EXCHANGER SHELL

TOTAL WT. = 3705 lb (ASSUMED, [9], p. 14)

TOTAL LENGTH \approx 159"

SHELL OD = 18"

$t_{\text{shell}} \approx .312$ " (ASSUMED, [1], p. 8)

$$\therefore ID = OD - 2t$$

$$= 18" - 2(.312") = 17.376 \text{ in}$$

					SCE E-34 HX	
					JOB NO 0310-036	
					PAGE 16	
					CALC NO EQ-06	
					OF 37	
REV	BY	DATE	CHECKED	DATE		
0	WI	6/5/84	SJL	7-18-84		

$$A = \frac{\pi}{4} (OD^2 - ID^2) = \frac{\pi}{4} [(18.1\text{ in})^2 - (17.376\text{ in})^2]$$

$$= 17.34\text{ in}^2$$

$$A_{22} = A_{33} = A/2 = 8.67\text{ in}^2$$

$$I = \frac{\pi}{64} (OD^4 - ID^4)$$

$$= \frac{\pi}{64} [(18.1\text{ in})^4 - (17.376\text{ in})^4] = 678.21\text{ in}^4$$

$$J = 2I = 1356.42\text{ in}^4$$

					SLE E-34 HX	
0	WI	6/5/84	SXL	7-18-84	JOB NO 0310-036	PAGE 7
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-06	OF 37



MATERIAL TYPE 1 - SA-36 CARBON STEEL

$$E \approx 29.0 \times 10^6 \text{ psi}$$

$$\nu = .3$$

$$\rho_m = \frac{.284 \text{ lb/in}^3}{386.4 \text{ in/s}^2} = 7.35 \times 10^{-4} \frac{\text{lb} \cdot \text{s}^2}{\text{in} \cdot \text{in}^3}$$

MATERIAL TYPE 2 - EXCHANGER SHELL

$$w = \frac{3705 \text{ lb}}{159 \text{ in}} = 23.3 \text{ lb/in}$$

$$A = 17.34 \text{ in}^2$$

$$\gamma A = w \quad \text{where } \gamma = \rho g$$

$$\rho g A = w$$

$$\rho = \frac{w}{A g} = \frac{23.3 \text{ lb/in}}{(17.34 \text{ in}^2)(386.4 \text{ in/s}^2)}$$
$$= 3.48 \times 10^{-3} \frac{\text{lb} \cdot \text{s}^2}{\text{in} \cdot \text{in}^3}$$

					SCE E-34-HX		
						JOB NO 0310-036	PAGE 16
						CALC NO	OF 87
0	WE	6/5/84	SSL	7-18-84	IMPELL CORPORATION	EQ-06	
REV	BY	DATE	CHECKED	DATE			

FREQUENCY ANALYSIS

AS DESCRIBED IN THE INTRODUCTION, AN EDGAP MODEL (DESCRIBED IN THE PREVIOUS SECTION) WAS USED TO CALCULATE THE FUNDAMENTAL FREQUENCY OF THE STRUCTURE. THE INPUT FOR THIS ANALYSIS IS SHOWN ON THE FOLLOWING PAGES.

THE FREQUENCY ANALYSIS [7], SHOWS THAT THE FUNDAMENTAL FREQUENCY IS GREATER THAN 33 HZ IN ALL DIRECTIONS. THEREFORE THE ZPA ACCELERATIONS WILL BE APPLIED TO THE STRUCTURE ($f_1 = 49 \text{ Hz}$):


HORIZONTAL DIRECTIONS

$$a_x = a_z = .67g$$

VERTICAL DIRECTION

$$a_y = \frac{2}{3}(.67g) \\ = \pm .45g$$

$$a_{dw} = 1.00g \downarrow$$

					SCC E-34 HX			
							JOB NO 0310-036	
							CALC NO	
0	WI	6/6/84	SRL	7-18-84			EQ-06	
REV	BY	DATE	CHECKED	DATE			OF 87	

FREQUENCY ANALYSIS INPUT DATA

SCE SONGS-1 SEAL WATER HEAT EXCHANGER - E-34

52 1 0 3 1 10000 0									
1	1	1	1				31.	5.	99.
2							31.	24.0	99.
3							31.	43.	99.
4	1	1	1	1			67.	0.	99.
5							49.0	21.5	99.
6	1	1	1	1	1	1	31.	13.	130.
7							31.	28.0	114.5
8	1	1	1	1	1	1	31.	43.	130.
9							31.	43.	114.5
10							31.	51.5	99.
11							31.	60.	99.
12							24.0	60.	99.
13							24.0	51.5	99.
14	1	1	1	1	1	0	0.	60.	99.
15							8.5	60.	99.
16	1	1	1	1	1	1	0.	48.	99.
17							8.5	54.0	99.
18							17.	60.	99.
19							17.	72.	135.
20							17.	72.	117.
21							17.	72.	99.
22							17.	72.	82.5
23							17.	72.	66.
24							17.	72.	49.5
25							17.	72.	33.
26							17.	72.	16.5
29							17.	72.	0.
27							17.	72.	-12.
28							17.	72.	-24.
30							17.	60.	
31							8.5	60.	
32	1	1	1	1	1	0	0.	60.	
33							8.5	54.0	
34	1	1	1	1	1	1	0.	48.	
35							21.7	60.	
36							24.0	51.5	
37							26.5	60.	
38							31.	60.	
39	1	1	1	1	1	1	0.	0.	
40	1	1	1	1	1	1	0.	0.	
41	1	1	1	1	1	1	0.	0.	
42							31.0	30.0	-17.0
43	1	1	1	1	1	1	31.	0.	-34.
44							13.3	60.	15.6
45	1	1	1	1	0	1	0.	60.	31.3
46							31.	51.5	
47							31.	43.	
48							31.	24.	
49	1	1	1	1	0	0	31.	5.	
50							49.	21.5	
51	1	1	1	1	1	1	67.	0.	
52	1	1	1	1	1	1	0.	43.	99.

1	3.0E-06	7.35E-04	SA-36 CARBON STEEL	
2	3.0E-06	7.35E-04	EXCHANGER W/FLUID	
1	3.39	1.395	1.884	.1 15.2 .866 C6 X 10.5
2	5.87	4.35	1.61	.24 41.4 13.4 W6 X 20
3	3.83	2.86	1.16	.15 11.7 3.86 W4 X 13
4	1.59	.725	.915	.1 .310 3.85 C4 X 5.4
5	17.74	8.67	8.67	1356. 678.2 678.2 EXCHANGER SHELL

					SCE HX E-34	
0	WT	GLO/BJ	SSE	7-18-84	JOB NO 0310-036	PAGE 20
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-06	OF 87


FREQUENCY ANALYSIS INPUT, CONT

1	1	2	16	1	1	
2	2	3	16	1	1	
3	3	1	16	1	1	
4	10	11	16	1	1	C6x10.5
5	11	12	16	1	1	
6	12	18	16	1	1	
7	18	15	16	1	1	
8	15	14	16	1	1	
9	4	5	8	1	2	W6x20
10	5	3	8	1	2	
11	3	13	8	1	3	
12	13	18	8	1	3	
13	16	17	34	1	3	
14	17	18	34	1	3	W4x13
15	6	7	52	1	3	
16	7	3	52	1	3	
17	8	9	52	1	3	
18	9	3	52	1	3	
19	49	48	34	1	1	
20	48	47	34	1	1	
21	47	46	34	1	1	
22	46	38	34	1	1	C6x10.5
23	38	37	34	1	1	
24	37	35	34	1	1	
25	35	30	34	1	1	
26	39	31	34	1	1	
27	31	32	34	1	1	
28	51	50	3	1	2	W6x20
29	50	47	3	1	2	
30	47	36	3	1	3	
31	36	30	3	1	3	W4x13
32	30	33	16	1	3	
33	33	34	16	1	3	
34	38	42	4	1	2	W6x20
35	42	43	4	1	2	
36	37	44	32	1	4	C4x5.4
37	44	45	32	1	4	
38	19	20	18	2	5	
39	20	21	18	2	5	
40	21	22	18	2	5	
41	22	23	18	2	5	
42	23	24	18	2	5	
43	24	25	18	2	5	SHELL
44	25	26	18	2	5	
45	26	29	18	2	5	
46	29	27	18	2	5	
47	27	28	18	2	5	
48	18	21	30	2	5	SADDLES
49	30	29	18	2	5	

SUPPORT FRAME 'A'

SUPPORT FRAME 'B'

HEAT EXCHANGER

					SCE HX E-34	
O	WI	6/16/84	SJK	7-14-84	JOB NO	0310-036
REV	BY	DATE	CHECKED	DATE	CALC NO	EQ-06
						PAGE 21 OF 37

NOZZLE LOADS

BASED ON A REVIEW OF [1], THE NOZZLE LOADS FROM [13] ARE APPLICABLE TO THE SEAL WATER HEAT EXCHANGER. THESE LOADS ARE APPLIED TO THE TUBE SIDE INLET AND OUTLET.

THE LOADS APPLIED TO THE SHELL SIDE NOZZLES ARE ASSUMED EQUAL TO THOSE LISTED IN [9].

THE EDGAP MODEL USED TO CALCULATE MEMBER FORCES RESULTING FROM THE NOZZLE LOADS IS SHOWN ON THE FOLLOWING PAGE. THE LOADS WERE APPLIED TO THE MODEL AS DESCRIBED BELOW:


- 1) SHELL SIDE INLET LOADS NODE 20
- 2) SHELL SIDE OUTLET LOADS NODE 27
- 3) TUBE SIDE INLET AND OUTLET LOADS NODE 28

ALL LOADS WERE APPLIED SIMULTANEOUSLY IN THE POSITIVE DIRECTION(S) TO THE CENTERLINE OF THE VESSEL.

REV	BY	DATE	CHECKED	DATE
0	WF	7/25/84	SA	7/26/84

JOB NO. 0310-036 PAGE 22 OF 57
CALC NO. EQ-06

IMPELLER
CORPORATION



SHELL SIDE INLET LOADS APPLIED TO
NODE 20

SHELL SIDE OUTLET LOADS APPLIED TO
NODE 27

TUBE SIDE LOADS APPLIED TO
NODE 28

— ALL NOZZLE LOADS ARE ASSUMED
TO ACT ON THE CENTER LINE OF
THE SHELL.

0	WI	7/25/84	5/8	7.26.84	IMPELL CORPORATION	JOB NO 0310-036	PAGE 23
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-06	OF 87

ASSUMED NOZZLE LOADS ([9], p. 52)

NODE 120, 4" WATER OUTLET (SHELL SIDE)

F _x	476	lb	} MAXIMUM LOADS COMBINED USING ASUM
F _y	1810	lb	
F _z	71	lb	
M _x	30	ft.-lb (360 in.-lb)	
M _y	197	ft.-lb (2364 in.-lb)	
M _z	1501	ft.-lb (18012 in.-lb)	

NODE 175, 4" WATER INLET (SHELL SIDE)

F _x	210	lb	} MAXIMUM LOADS OBTAINED USING ALGEBRAIC SUM
F _y	708	lb	
F _z	607	lb	
M _x	304	ft.-lb (3648 in.-lb)	
M _y	738	ft.-lb (8856 in.-lb)	
M _z	697	ft.-lb (8364 in.-lb)	

0	WI	7/25/84	SK	N. No. 9A		JOB NO 0310-036	PAGE 24
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-06	OF 37



NOZZLE LOADS [13]


NODE 260, 3" WATER INLET (TUBE SIDE)

	THERMAL	SAM	DW	SSE	ASUM
F _x	-4	0	-3	±43	50.
F _y	+26	0	-38	±28	92.
F _z	+69	0	-1	±109	179.
M _x	+76	0	-11	±50	137.
M _y	+4	0	+5	±23	32.
M _z	-10	0	-1	±14	25

NODE 650, 3" WATER OUTLET (TUBE SIDE)

	THERMAL	SAM	DW	SSE	ASUM
F _x	+22	0	-32	±127	181
F _y	+23	0	-228	±102	353
F _z	+40	0	42	±149	231
M _x	+17	0	-30	±36	83
M _y	-45	0	-58	±157	260
M _z	+38	0	-206	±96	340


NOTE: FORCES IN LBS.
MOMENTS IN FT. LBS.

0	WI	7/15/84	HL	1/26/84					
REV	BY	DATE	CHECKED	DATE					
							JOB NO 0310-036 CALC NO EQ-06		PAGE 25 OF 37

COMBINED TUBE SIDE LOADS

$$\begin{aligned}
 F_x &= 50 + 181 = 231.1b \\
 F_y &= 92 + 353 = 445.1b \\
 F_z &= 179 + 231 = 410.1b
 \end{aligned}$$

$$\begin{aligned}
 M_x &= 137 + 83 = 220 \text{ ft}\cdot\text{lb} = 2640 \text{ in}\cdot\text{lb} \\
 M_y &= 32 + 260 = 292 \text{ ft}\cdot\text{lb} = 3504 \text{ in}\cdot\text{lb} \\
 M_z &= 25 + 340 = 365 \text{ ft}\cdot\text{lb} = 4380 \text{ in}\cdot\text{lb}
 \end{aligned}$$

0	WI	7/25/84	SXL	7/26/84		JOB NO 03D-036	PAGE 20
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-06	OF 37

EDSGAP INPUT, NOZZLE LOAD ANALYSIS

SCE SONGS-1 SEAL WATER HEAT EXCHANGER - E-34 (NOZZLE LOADS)

	1	1	0	0	10000	0			
1	1	1	1	0	0	0	31.	5.	99.
2							31.	24.0	99.
3							31.	43.	99.
4	1	1	1	1	1	1	67.	0.	99.
5							49.0	21.5	99.
6	1	1	1	1	1	1	31.	13.	130.
7							31.	28.0	114.5
8	1	1	1	1	1	1	31.	43.	130.
9							31.	43.	114.5
10							31.	51.5	99.
11							31.	60.	99.
12							24.0	60.	99.
13							24.0	51.5	99.
14	1	1	1	1	1	0	0.	60.	99.
15							8.5	60.	99.
16	1	1	1	1	1	1	0.	48.	99.
17							8.5	54.0	99.
18							17.	60.	99.
19							17.	72.	123.
20							17.	72.	112.
21							17.	72.	99.
22							17.	72.	82.5
23							17.	72.	66.
24							17.	72.	49.5
25							17.	72.	33.
26							17.	72.	16.5
29							17.	72.	0.
27							17.	72.	-10.
28							17.	72.	-26.
30							17.	60.	
31							8.5	60.	
32	1	1	1	1	1	0	0.	60.	
33							8.5	54.0	
34	1	1	1	1	1	1	0.	48.	
35							21.7	60.	
36							24.0	51.5	
37							26.5	60.	
38							31.	60.	
39	1	1	1	1	1	1	0.	0.	
40	1	1	1	1	1	1	0.	0.	
41	1	1	1	1	1	1	0.	0.	
42							31.0	30.0	-17.0
43	1	1	1	1	1	1	31.	0.	-34.
44							13.3	60.	15.6
45	1	1	1	1	0	1	0.	60.	31.3
46							31.	51.5	
47							31.	43.	
48							31.	24.	
49	1	1	1	0	0	0	31.	5.	
50							49.0	21.5	
51	1	1	1	1	1	1	67.	0.	
52	1	1	1	1	1	1	0.	43.	99.
2	49	5	0	2					
1	30.0E06			.3	7.35E-04				
2	30.0E06			.3	3.48E-03				
1	3.09			1.395	1.884		.01	15.2	.866
2	5.87			4.39	1.61		.24	41.4	13.4
3	3.83			2.80	1.16		.15	11.3	3.86
4	1.59			.736	.938		.01	.319	3.85
5	17.34			8.67	8.67		1356.	678.2	678.2
386.4									

O	WI	7/25/81	SSE	72684	IMPELL CORPORATION		JOB NO D310-036
REV	BY	DATE	CHECKED	DATE	CALC NO		PAGE
					EQ-06		27 OF 87

EDSGAP INPUT, CONT.

		386.4		386.4			
1	1	2	16	1	1		
2	2	3	16	1	1		
3	3	10	16	1	1		
4	10	11	16	1	1		
5	11	12	16	1	1		
6	12	18	16	1	1		
7	18	15	16	1	1		
8	15	14	16	1	1		
9	4	5	8	1	2		
10	5	3	8	1	2		
11	3	13	8	1	3		
12	13	18	8	1	3		
13	16	17	34	1	3		
14	17	18	34	1	3		
15	6	7	52	1	3		
16	7	3	52	1	3		
17	8	9	52	1	3		
18	9	3	52	1	3		
19	49	48	34	1	1		
20	48	47	34	1	1		
21	47	46	34	1	1		
22	46	38	34	1	1		
23	38	37	34	1	1		
24	37	35	34	1	1		
25	35	30	34	1	1		
26	30	31	34	1	1		
27	31	32	34	1	1		
28	51	50	3	1	2		
29	50	47	3	1	2		
30	47	36	3	1	3		
31	36	30	3	1	3		
32	30	33	16	1	3		
33	33	34	16	1	3		
34	38	42	4	1	2		
35	42	43	4	1	2		
36	37	44	32	1	4		
37	44	45	32	1	4		
38	19	20	18	2	5		
39	20	21	18	2	5		
40	21	22	18	2	5		
41	22	23	18	2	5		
42	23	24	18	2	5		
43	24	25	18	2	5		
44	25	26	18	2	5		
45	26	29	18	2	5		
46	29	27	18	2	5		
47	27	28	18	2	5		
48	18	21	30	2	5		
49	30	29	18	2	5		
20	1	210.	708.	607.	3648.	8856.	8364.
27	1	476.	1810.	71.	360.	2364.	18012.
28	1	231.	445.	410.	2640.	3504.	4380.

0	WI	7/25/84	SL	7.26.84	JOB NO 0310-036		PAGE 28
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-06		OF 37



7.0 STRUCTURAL ANALYSIS


THE LOADS IN THE STRUCTURE ARE DETERMINED BY APPLYING SEISMIC LOAD FACTORS EQUAL TO THE ZPA'S. IN THE THREE GLOBAL DIRECTIONS.

WORST CASE LOADS ARE DETERMINED FOR EACH TYPE OF STRUCTURAL ELEMENT (i.e. W4X13, W6X20, C6X10.5 + SO ON). MAXIMUM LOADS ARE COMBINED REGARDLESS OF THE LOCATION WHERE THEY OCCUR. THIS RESULTS IN A WORST CASE LOAD FOR EACH ELEMENT TYPE. SEISMIC LOADS IN EACH DIRECTION ARE COMBINED USING SRSS, THE RESULT IS THEN COMBINED WITH THE DEAD WEIGHT LOAD USING ASUM:

$$\text{LOAD} = \left[(X_{\text{SEISMIC}})^2 + (Y_{\text{SEISMIC}})^2 + (Z_{\text{SEISMIC}})^2 \right]^{1/2} + \text{D.W.}$$

THIS COMBINATION IS USED FOR EACH OF THE FOLLOWING 6 LOADS.

- R1 = AXIAL LOAD
- R2 = SHEAR IN LOCAL 2 DIRECTION
- R3 = " " " 3 " "
- M1 = TORSIONAL MOMENT
- M2 = BENDING ABOUT LOCAL 2 AXIS
- M3 = " " " 3 " "

					SCE HX E-34			
							JOB NO 17310-036	
							CALC NO	
0	WT	6/10/84	SCE	7-14-84			PAGE 24	
REV	BY	DATE	CHECKED	DATE			EQ-06	

ALLOWABLE STRESSES

ASSUME: $F_y = 36 \text{ ksi}$
 $F_u = 58 \text{ ksi}$ } SA-36 CARBON STEEL

FROM ASME CODE, SUBSECTION NF

$$\left. \begin{aligned} F_b &= .6 F_y = 21.6 \text{ ksi} \\ F_v &= .4 F_y = 14.4 \text{ ksi} \\ F_c &= .6 F_y = 21.6 \text{ ksi} \end{aligned} \right\} \text{LEVEL A}$$

FOR RETURN TO SERVICE LEVEL D ALLOWABLES MAY BE USED. (APPENDIX F, F-1370)

$$F_c = F_a = \min(1.2 F_y, .7 F_u)$$
$$\left. \begin{aligned} 1.2 F_y &= 1.2(36) = 43.2 \\ .7 F_u &= .7(58) = 40.6 \end{aligned} \right\} \underline{40.6 \text{ ksi}}$$

$$F_v = \min(.8 F_y, .42 F_u)$$
$$\left. \begin{aligned} .8(36) &= 28.8 \text{ ksi} \\ .42(58) &= 24.4 \text{ ksi} \end{aligned} \right\} \underline{24.4 \text{ ksi}}$$

					SCE HX-E-34	
0	WI	6/9/84	SXL	7/20/84	JOB NO 031a 036	PAGE 30
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-06	OF 87




THE INPUT FOR THE STRUCTURAL EVALUATION IS SHOWN ON THE FOLLOWING PAGES. THE INPUT SHOWS THE FOUR LOAD CASES:

1: $a_x = .67g$

2: $a_y = .45g$

3: $a_y = 1.00g$ (DEAD WT)


4: $a_z = .67g$

						JOB NO 0310-036	PAGE
						CALC NO	OF 31
0	WI	6/16/04	<i>[Signature]</i>	1/18/04			EQ-06
REV	BY	DATE	CHECKED	DATE			87

STATIC ANALYSIS, INPUT DATA

SCE SONGS-1 SEAL WATER HEAT EXCHANGER - E-34 (STATIC ANALYSIS)

Node	1	4	0	0	0	0	0	0	10000	U			
1	1	1	1	1	0	0	0	0	0	31.	5.	99.	
2										31.	24.0	99.	
3										31.	43.	99.	
4										67.	0.	99.	
5										49.0	21.5	99.	
6	1	1	1	1	1	1	1	1	1	31.	13.	130.	
7										31.	28.0	119.5	
8	1	1	1	1	1	1	1	1	1	31.	43.	130.	
9										31.	43.	114.5	
10										31.	61.5	99.	
11										31.	60.	99.	
12										24.0	60.	99.	
13										24.0	51.5	99.	
14	1	1	1	1	1	1	1	1	1	0.	60.	99.	
15										8.5	60.	99.	
16										8.5	54.0	99.	
17										8.5	54.0	99.	
18										17.	60.	99.	
19										17.	72.	115.	
20										17.	72.	117.	
21										17.	72.	99.	
22										17.	72.	99.	
23										17.	72.	66.	
24										17.	72.	49.5	
25										17.	72.	33.	
26										17.	72.	16.0	
27										17.	72.	8.	
28										17.	72.	-24.	
30										17.	60.		
31										8.5	60.		
32										0.	60.		
33										8.5	54.0		
34										0.	40.		
35										21.7	60.		
36										24.0	51.5		
37										26.5	60.		
38										31.	60.		
39	1	1	1	1	1	1	1	1	1	0.	0.		
40	1	1	1	1	1	1	1	1	1	0.	0.		
41	1	1	1	1	1	1	1	1	1	0.	0.		
42										31.0	30.0	-17.0	
43	1	1	1	1	1	1	1	1	1	31.	0.	-34.	
44										13.3	60.	13.6	
45	1	1	1	1	1	0	1	1	1	0.	60.	31.3	
46										31.	51.5		
47										31.	43.		
48										31.	24.		
49	1	1	1	0	0	0	0	0	0	31.	5.		
50										49.0	21.5		
51	1	1	1	1	1	1	1	1	1	67.	0.		
52	1	1	1	1	1	1	1	1	1	0.	43.	99.	
2	49	5	0	2									
1	30.0E06			.3	7.35E-04								
2	30.0E06			.3	1.49E-03								
1	3.09			1.395	1.884				.01	15.2		.266	
2	0.07			0.39	1.61				.24	41.4		13.4	
3	3.83			2.81	1.16				.15	11.3		3.86	

SCE HX-E-34				
O	WE	6/10/84	SPL	1-18-84
REV	BY	DATE	CHECKED	DATE
				
				JOB NO 0310-036 CALC NO EQ-06
				PAGE 32 OF 37

STATIC ANALYSIS, INPUT DATA, CONT.

4	1.59	.736	.938	.01	.319	3.85
5	17.34	8.67	8.67	1356.	678.2	678.2
386.4						
386.4						
386.4						
} GRAVITATIONAL ACCELERATION						
386.4 m/s ²						
1	1	2	16	1	1	
2	2	3	16	1	1	
3	3	10	16	1	1	
4	10	11	16	1	1	
5	11	12	16	1	1	
6	12	18	16	1	2	
7	18	18	16	1	1	
8	15	14	16	1	1	
9	4	5	8	1	2	
10	5	3	8	1	2	
11	5	13	8	1	3	
12	13	16	8	1	3	
13	16	17	16	1	3	
14	17	18	34	1	3	
15	6	7	52	1	3	
16	7	3	52	1	3	
17	3	1	52	1	3	
18	3	1	52	1	3	
19	48	47	34	1	1	
20	48	47	34	1	1	
21	47	46	34	1	1	
22	46	38	34	1	1	
23	38	37	34	1	1	
24	37	35	34	1	1	
25	35	34	34	1	1	
26	30	31	34	1	1	
27	31	32	34	1	1	
28	51	50	3	1	2	
29	50	47	3	1	2	
30	47	38	3	1	2	
31	38	38	3	1	2	
32	30	33	16	1	3	
33	33	34	16	1	3	
34	38	42	4	1	2	
35	42	43	4	1	2	
36	37	44	32	1	4	
37	44	45	32	1	4	
38	19	20	18	2	5	
39	20	21	18	2	5	
40	21	22	18	2	5	
41	22	23	18	2	5	
42	23	24	18	2	5	
43	24	25	18	2	5	
44	25	26	18	2	5	
45	26	29	18	2	5	
46	29	27	18	2	5	
47	27	28	18	2	5	
48	18	21	30	2	5	
49	30	29	18	2	5	

LOAD CASE 1, $a_x = .67g$

LOAD CASE 2, $a_y = .45g$

LOAD CASE 3, DEAD WT, $a_y = 1.0g$

LOAD CASE 4, $a_z = .67g$

					SCE HX - E-34	
0	WI	6/10/84	SCE	7-18-84	JOB NO 0310-036	
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-06	
					PAGE OF 37	



ALLOWABLE COMPRESSIVE STRESSES

C6x10.5

MAX $l \approx 60''$ (FRAME HEIGHT) - CONSERVATIVE
 $r = .529$ in

ASSUME $K = 1.0$ (PINNED - PINNED, [3], P. 5-124)

$$\frac{Kl}{r} = \frac{(1.0) 60 \text{ in}}{.529 \text{ in}} = 114$$

$\therefore F_a = 11.13$ Ksi [3] p. 574 (level A)

W4x13

$l_{MAX} \approx 43''$ (ELEMENTS 15, 16)

$r = 1.00$ in

ASSUME $K = 1.00$

$$\frac{Kl}{r} = \frac{1.00 (43 \text{ in})}{1.00 \text{ in}} = 43.0$$

$\therefore F_a = 18.95$ Ksi level A, ([3], p. 5-74)

					SCE HX E-34			
					JOB NO 0310-036		PAGE 34	
					CALC NO		OF 37	
0	WI	6/9/84	SRL	7-20-84	EQ-06			
REV	BY	DATE	CHECKED	DATE				



C4x5.4

$$l \approx 41" \quad ([2])$$

$$r = .449 \text{ in}$$

ASSUME $K = 1.0$

$$\frac{Kl}{r} = \frac{41 \text{ in}}{.449 \text{ in}} = 91.3$$

$$\therefore F_a = 13.97 \text{ ksi, level A, (p. 5-74 [3])}$$

W6x20

$$l_{\text{MAX}} \left(\begin{array}{l} \text{ELEMENTS } 34, 35 \\ \text{NODE } 38 \quad (31.0, 60.0, 0) \\ \text{NODE } 43 \quad (31.0, 0, -34.0) \end{array} \right) \} l \approx 69"$$

$$\text{let } l = 70", \quad r = 1.50 \text{ in}$$

ASSUME $K = 1.00$

$$\frac{Kl}{r} = \frac{(1.00)(70 \text{ in})}{1.50 \text{ in}} = 46.7$$

$$\therefore F_a = 18.61 \text{ ksi level A, ([3], p. 5-74)}$$

					SCE HX E-34		
						JOB NO 0310 036	PAGE 35
						CALC NO EQ-06	OF 37
REV	BY	DATE	CHECKED	DATE	IMPELL CORPORATION		
0	WI	6/10/84	SKL	7-18-84			

MAXIMUM LOADS C6X10.5 (ELEMENT TYPE 1)

FRAME A

	R1	R2	R3	M1	M2	M3
a _x	1176.0 ⁽⁶⁾	100.7 ⁽⁵⁾	20.3 ⁽⁵⁾	NEGLIGIBLE	345.6 ⁽³⁾	1088.0 ⁽⁶⁾
a _y	270.0 ⁽⁷⁾	14.6 ⁽⁵⁾	40.9 ⁽⁷⁾		358.1 ⁽⁸⁾	127.9 ⁽⁶⁾
a _z	70.8 ⁽¹⁾	4.6 ⁽⁵⁾	855.0 ⁽⁸⁾		7600.0 ⁽⁸⁾	48.6 ⁽⁶⁾
SRSS	1209.	102.	856.	.	7616.	1097.
DW	600.0 ⁽⁷⁾	32.5 ⁽⁵⁾	90.9 ⁽⁷⁾	.	795.7 ⁽⁸⁾	284.2 ⁽⁶⁾
TOTAL	1809.	134.	947.	.	8412.	1381.

FRAME B

	R1	R2	R3	M1	M2	M3
a _z	1001.0 ⁽²⁷⁾	111.3 ⁽²⁴⁾	116.2 ⁽²⁴⁾	NEGLIGIBLE	1282.0 ⁽²⁵⁾	1104.0 ⁽²³⁾
a _y	217.7 ⁽²⁷⁾	25.8 ⁽²³⁾	38.1 ⁽²⁴⁾		344.8 ⁽²⁵⁾	157.4 ⁽²³⁾
a _x	405.9 ⁽²⁴⁾	31.2 ⁽²⁴⁾	808.2 ⁽²⁷⁾		6960.0 ⁽²⁷⁾	266.6 ⁽²³⁾
SRSS	1102.	118.	817.	.	7085.	1147.
DW	483.7 ⁽²⁷⁾	57.2 ⁽²³⁾	84.7 ⁽²⁴⁾	.	766.2 ⁽²⁵⁾	349.9 ⁽²³⁾
TOTAL	1586.	176.	902.	.	7851.	1496.

REV 0
BY WJ
DATE 6/9/84
CHECKED SJK
DATE 7-20-84



SEE HX E-34

JOB NO D31D D36
CALC NO E0-06


PAGE 3
OF 57

NOZZLE LOADS, C6x10.5

	FRAME A		FRAME B	
R1	288.2	①	523.4	⑰
R2	54.0	⑤	138.0	⑳
R3	584.7	⑦	205.5	㉑
M1	0.		0	
M2	5284.	⑧	2104.	㉒
M3	584.0	⑥	1191.	㉓

MAXIMUM COMBINED LOADS (SEISMIC + NOZZLE)

R1 =	1809	Ⓐ	+	523.4	Ⓑ	=	2332. lb
R2 =	176	Ⓑ	+	138.0	Ⓑ	=	314. lb
R3 =	947	Ⓐ	+	584.7	Ⓐ	=	1532. lb
M1 =	0		+	0		=	0
M2 =	8412	Ⓐ	+	5284.	Ⓐ	=	13696. in-lb
M3 =	1496	Ⓑ	+	1191.	Ⓑ	=	2687. in-lb

0	WI	7/25/84	SL	1.26.84					JOB NO 0310-036 CALC NO EQ-06	PAGE 37 OF 87
REV	BY	DATE	CHECKED	DATE						

STRESS CHECK

C6x10.5

$$f_a = \frac{R1_{MAX}}{A} = \frac{2332 \text{ lb}}{3.09 \text{ in}^2} = .75 \text{ ksi}$$

$$f_{b2} = \frac{M2_{MAX}}{S_{22}} = \frac{13696 \text{ in}\cdot\text{lb}}{5.06 \text{ in}^3} = 2.71 \text{ ksi}$$

$$f_{b33} = \frac{M3_{MAX}}{S_{33}} = \frac{26857 \text{ in}\cdot\text{lb}}{5.64 \text{ in}^3} = 4.76 \text{ ksi}$$

$$f_{v2} = \frac{R2}{A_{22}} = \frac{314 \text{ lb}}{1.395 \text{ in}^2} = .23 \text{ ksi}$$

$$f_{v3} = \frac{R3}{A_{33}} = \frac{1532 \text{ lb}}{1.884 \text{ in}^2} = .81 \text{ ksi}$$

INTERACTION:

$$\frac{.75}{11.13} + \frac{2.71}{21.6} + \frac{4.76}{21.6} = .41 < 1$$

SHEAR:

$$f_{v2} < 14.4$$

$$f_{v3} < 14.4$$

∴ QUALIFIED USING LEVEL A LIMITS.

					SCE HX - E-34	
					JOB NO 0310-036	
					CALC NO EQ-06	
0	WI	6/9/84	GR	7868A	PAGE 38	
REV	BY	DATE	CHECKED	DATE	OF 87	



MAXIMUM LOADS, W6x20 (ELEMENT TYPE 2)

FRAME A

	R1	R2	R3	M1	M2	M3
a _x	343.4 (9)	2.1 (9)	32.1 (9)	NEGLIGIBLE	734.6 (10)	69.9 (10)
a _y	530.9 (9)	.7 (9)	20.4 (9)	.	549.5 (10)	28.1 (10)
a _z	129.0 (9)	34.0 (10)	8.5 (9)	.	264.0 (10)	932.8 (10)
SRSS	630.	34.	39.	.	955.	936.
DW	1180. (9)	1.5 (9)	45.4 (10)	.	1221. (10)	62.3 (10)
TOTAL	1810.	36.	84.	.	2176.	998.

FRAME B

	R1	R2	R3	M1	M2	M3
a _z	235.1 (28)	8.8 (25)	32.7 (25)	NEGLIGIBLE	676.4 (25)	210.1 (25)
a _y	431.7 (28)	7.5 (25)	17.7 (29)	.	467.2 (29)	148.1 (25)
a _x	401.9 (25)	27.0 (25)	20.5 (25)	.	613.5 (29)	621.6 (25)
SRSS	635.	29.	42.	.	1026.	673.
DW	959.4 (28)	16.7 (25)	39.3 (29)	.	1038. (29)	329.2 (25)
TOTAL	1594.	46.	82.	.	2064.	1002.

REV 0

BY WTC

DATE 6/19/84

CHECKED SXL

DATE 7-20-84



SUE
HR
E-34

JOB NO 0310-036
CALC NO E0-06


PAGE 39
OF 87

NOZZLE LOADS, W6x20

	FRAME A	FRAME B
R1	64.0	1061. (28)
R2	10.5	6.5 (34)
R3	6.8	45.5 (28)
M1	0	0
M2	396.0	1754. (29)
M3	411.2	265.9 (34)

MAXIMUM COMBINED LOADS (SEISMIC + NOZZLE)

R1	=	1810 (A)	+	1061 (B)	=	2871.	lb
R2	=	46 (B)	+	10.5 (A)	=	57.	lb
R3	=	84 (A)	+	45.5 (B)	=	130.	lb
M1	=	0	+	0	=	0	
M2	=	2176 (A)	+	1754 (B)	=	3930.	in. lb
M3	=	1002 (B)	+	411.2 (A)	=	1413.	in. lb

0	WE	7/25/84	SSL	7-26-84		JOB NO 0310-026	PAGE 40
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-06	OF 87

STRESS CHECK

W6x20

$$f_a = \frac{R1_{MAX}}{A} = \frac{2871 \text{ lb}}{5.87 \text{ in}^2} = .49 \text{ Ksi}$$

$$f_{b2} = \frac{M2_{MAX}}{S_{22}} = \frac{3930 \text{ in}\cdot\text{lb}}{13.4 \text{ in}^3} = .29 \text{ Ksi}$$

$$f_{b3} = \frac{M3_{MAX}}{S_{33}} = \frac{1413 \text{ in}\cdot\text{lb}}{4.41 \text{ in}^3} = .32 \text{ Ksi}$$

$$f_{r2} = \frac{R2_{MAX}}{A_{22}} = \frac{57 \text{ lb}}{4.39 \text{ in}^2} = .01 \text{ Ksi}$$

$$f_{r3} = \frac{R3_{MAX}}{A_{33}} = \frac{130 \text{ lb}}{1.61 \text{ in}^2} = .08 \text{ Ksi}$$

INTERACTION

$$\frac{.49}{18.61} + \frac{.29 + .32}{21.6} = .05 < 1$$

$$f_{r2} + f_{r3} < 14.4 \text{ Ksi}$$

∴ QUALIFIED USING LEVEL
A LIMITS

					SCE HX E-34	
0	WI	6/1/81	SSL	7-26-84	IMPPELL CORPORATION	JOB NO 0310-036 CALC NO EQ-06
REV	BY	DATE	CHECKED	DATE		PAGE 41 OF 37

REV	0	BY	WIC	DATE	6/9/84	MAXIMUM LOADS W4x13, ELEMENT TYPE 3					
CHECKED	SS	DATE	7-28-84	FRAME A							
						R1	R2	R3	M1	M2	M3
						ax	11.9 (15)	441.6 (14)	NEGLIGIBLE	7495. (17)	137.6 (15)
						ay	14.4 (11)	79.4 (13)		824.5 (13)	164.0 (12)
						az	186.1 (13)	47.2 (18)		1073. (18)	2046. (13)
						SRSS	1118.	187.			7616.
						DW	1836. (13)	31.9 (11)		1832. (13)	364.3 (12)
						TOTAL	2954.	219.		9448.	2421.
FRAME B											
						R1	R2	R3	M1	M2	M3
						az	20.2 (33)	428.8 (32)	NEGLIGIBLE	7229. (32)	256.7 (32)
						ay	10.6 ↓	63.6 (33)		664.1 (33)	143.7 (31)
						az	169.7 ↓	27.1 (33)		343.5 (30)	1854. (33)
						SRSS	171.	434.			7268.
						DW	1485. (33)	23.5 (33)		1476. (33)	319.3 (31)
						TOTAL	2454.	195.		8744.	2196.



SCE HY-E-34


JOB NO 03/D 036
 CALC NO EN-06
 PAGE 42 OF 87

NOZZLE LOADS, W4 x 13

	FRAME A		FRAME B	
R1	265.1	(11)	2133.	(33)
R2	140.1	(13)	34.0	(33)
R3	244.2	(13)	358.8	(30)
M1	0		4.	(31)
M2	4101.	(14)	6049.	(31)
M3	1520.	(14)	585.2	(32)

COMBINED LOADS (SEISMIC + NOZZLE)

R1 =	2954.	(A)	+	2133	(B)	=	5087.
R2 =	219.	(A)	+	140.1	(A)	=	359.
R3 =	628.	(A)	+	358.8	(B)	=	987.
M1 =	0		+	4	(D)	=	NEGLECTIBLE
M2 =	9448.	(A)	+	6049	(B)	=	15497.
M3 =	2421.	(D)	+	1520	(A)	=	3941.

10	WE	7/25/84	5/2	7/26/84		JOB NO 0310-036	PAGE 43
REV	BY	DATE	CHECKED	DATE		CALC NO ED-06	OF 87

W4 x 13

$$f_a = \frac{R1_{MAX}}{A} = \frac{5087 \text{ lb}}{3.83 \text{ in}^2} = 1.33 \text{ Ksi}$$

$$f_{b2} = \frac{M2_{MAX}}{S_{22}} = \frac{15497 \text{ in. lb}}{5.46 \text{ in}^3} = 2.84 \text{ Ksi}$$

$$f_{b3} = \frac{M3_{MAX}}{S_{33}} = \frac{3941 \text{ in. lb}}{1.90 \text{ in}^3} = 2.07 \text{ Ksi}$$

$$f_{v2} = \frac{R2_{MAX}}{A_{22}} = \frac{359 \text{ lb}}{2.80 \text{ in}^2} = .13 \text{ Ksi}$$

$$f_{v3} = \frac{R3_{MAX}}{A_{33}} = \frac{987 \text{ lb}}{1.16 \text{ in}^2} = .85 \text{ Ksi}$$

INTERACTION

$$\frac{1.33}{18.95} + \frac{2.84 + 2.07}{21.6} = .30 < 1$$

$$f_{v2} + f_{v3} < F_v = 14.4 \text{ Ksi}$$

∴ QUALIFIES USING LEVEL
A ALLOWABLES

					SCE HX E-34		
0	WE	7/25/84	SS	7.26.84	IMPELL CORPORATION	JOB NO 0310-036 CALC NO EQ-06	PAGE 44 OF 87
REV	BY	DATE	CHECKED	DATE			

MAXIMUM LOADS, C4x5.4 FRAME B

REV	BY	DATE	CHECKED	DATE		R1	R2	R3	M1	M2	M3	
0	WT	6/9/84	SK	7-18-84		a _x	48.7	3.3	.2	NEGLIGIBLE	6.7	36.8
						a _y	16.2	.5	2.9		33.8	22.0
						a _z	658.0	14.3	0.0		2.3	495.2
						SRSS	660.	15.	3.		35.	497.
						DW	35.9	1.2	6.4		75.0	48.9
						TOTAL	696.	16.	9.		110.	546.
SC E												
H X												
E-34												
						R1	R2	R3	M1	M2	M3	
						a _z	
						a _y	
						a _x	
						SRSS	
						DW	
						TOTAL	



JOB NO 0310-036
 CALC NO E0-06
 PAGE 15
 OF 37

NOZZLE LOADS, C4 x 5.4

R1 60.0
 R2 3.3
 R3 0
 M1 0
 M2 9.7
 M3 135.8

COMBINED LOADS

R1 696 + 60.0 = 756 lb
 R2 16 + 3.3 = 19 lb
 R3 9 + 0 = 9 lb
 M1 0 + 0 = 0
 M2 110 + 9.7 = 120 lb.in
 M3 546 + 135.8 = 682 lb.in

0	WJ	7/25/84	SX	12/6/84	IMPELL CORPORATION	JOB NO 0310-036	PAGE 46
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-06	OF 87

C4x5.4

$$f_a = \frac{R1_{MAX}}{A} = \frac{756 \text{ lb}}{1.59 \text{ in}^2} = .48 \text{ ksi}$$

$$f_{b2} = \frac{M2_{MAX}}{S_{22}} = \frac{120 \text{ in-lb}}{.283 \text{ in}^3} = .42 \text{ ksi}$$

$$f_{b3} = \frac{M3_{MAX}}{S_{33}} = \frac{682 \text{ in-lb}}{1.93 \text{ in}^3} = .35 \text{ ksi}$$

$$f_{v2} = \frac{R2_{MAX}}{A_{22}} = \frac{19 \text{ lb}}{.736 \text{ in}^2} = .03 \text{ ksi}$$

$$f_{v3} = \frac{R3_{MAX}}{A_{33}} = \frac{9 \text{ lb}}{.938 \text{ in}^2} = .01 \text{ ksi}$$

INTERACTION

$$\frac{.48}{13.97} + \frac{.42 + .35}{21.6} = .07$$


QUALIFIED USING LEVEL A
ALLOWABLES

					SCE HX - E-34			
0	WI	7/25/84	SXL	7/26/84	JOB NO 0310-036		PAGE 47	
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-06		OF 37	



SUPPORT SADDLES

DIMENSIONS FROM [1]



$$I_{22} = I_A + 2(I_B + A_B d_B^2)$$

$$I_A = \frac{(50 \text{ in})(14 \text{ in})^3}{12} = 114.3 \text{ in}^4$$

$$I_B = \frac{(4.5 \text{ in})(.5 \text{ in})^3}{12} = .047 \text{ in}^4$$

$$A_B = (4.5 \text{ in})(.5 \text{ in}) = 2.25 \text{ in}^2$$

$$d_B = 5 \text{ in}$$

$$I_{22} = 114.3 \text{ in}^4 + 2 [(.047 \text{ in}^4) + (2.25 \text{ in}^2)(5 \text{ in})^2] = 227. \text{ in}^4$$

0	WI	7/25/04	SL	7/20/04	IMPELL CORPORATION	JOB NO 0310-036	PAGE 48
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-06	OF 87


$$I_{33} = (I_A + A_A \bar{d}_A^2) + 2(I_B + A_B \bar{d}_B^2)$$

$$I_A = \frac{(14 \text{ in})(.5 \text{ in})^3}{12} = .146 \text{ in}^4$$

$$I_B = \frac{(.5 \text{ in})(4.5 \text{ in})^3}{12} = 3.80 \text{ in}^4$$

$$A_A = (14 \text{ in})(.5 \text{ in}) = 7.0 \text{ in}^2$$

$$A_B = (.5 \text{ in})(4.5 \text{ in}) = 2.25 \text{ in}^2$$



$$\bar{x}_A = 4.5'' + .5''/2 = 4.75''$$

$$\bar{x}_B = 4.5''/2 = 2.25''$$

$$\bar{d} = \frac{\bar{x}_A A_A + 2(\bar{x}_B A_B)}{A_A + 2A_B}$$

$$= \frac{(4.75 \text{ in})(7.0 \text{ in}^2) + 2(2.25 \text{ in})(2.25 \text{ in}^2)}{(7.0 + 2(2.25)) \text{ in}^2} = 3.77 \text{ in}$$

$$\begin{aligned} \therefore \bar{d}_A &= \bar{x}_A - \bar{d} \\ &= 4.75 - 3.77 \\ &= .98 \text{ in} \end{aligned}$$

$$\begin{aligned} \bar{d}_B &= |\bar{x}_B - \bar{d}| \\ &= 3.77 \text{ in} - 2.25 \text{ in} \\ &= 1.52 \text{ in} \end{aligned}$$

$$\begin{aligned} I_{33} &= [.146 \text{ in}^4 + (7.0 \text{ in}^2)(.98 \text{ in})^2] + 2[(3.80 \text{ in}^4) + (2.25 \text{ in}^2)(1.52 \text{ in})^2] \\ &= 24.87 \text{ in}^4 \end{aligned}$$

$$C_{33} = \text{MAX}[(3.77), (5 - 3.77)] = \underline{3.77 \text{ in}}$$

0	WI	7/25/84	4/26/84			JOB NO 0310-036	PAGE 49
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-06	OF 87

IMPELL CORPORATION

$$A = A_A + 2A_B = (7.0 \text{ in}^2) + 2(2.25 \text{ in}^2) = 11.50 \text{ in}^2$$

$$A_{22} = 2(5.0 \text{ in})(.5 \text{ in}) = 5 \text{ in}^2$$

$$A_{33} = (4.0 \text{ in})(.5 \text{ in}) = 2.00 \text{ in}^2$$


LOADS (EL 48 + 49)

	R1	R2	R3	M1	M2	M3
ax	1.1	21.0	1466.		16390.	313.
ay	998.3	74.7	4.2	NOTE 1	31.0	1098.
az	356.4	1480.	78.3		997.6	18860.
SRSS	1060.	1482.	1468		16420.	18895.
DW	2129.	165.9	9.2		68.9	2441.
NOZZ	2669.	850.3	674.3		18970.	11720.
TOTAL	5858.	2498.	2152		35459.	33056

NOTE 1: THE ACTUAL TORSIONAL STIFFNESS OF THE SADDLES IS LOW, THUS THE TORSIONAL LOADS WILL ALSO BE VERY LOW. \therefore TORSIONAL LOADS WILL CAUSE INSIGNIFICANT STRESSES AND ARE NEGLECTED

0	WI	7/25/04	SLR	7-26-04	JOB NO	030-036	PAGE
REV	BY	DATE	CHECKED	DATE	CALC NO	EQ-06	50
							OF
							87





$$\frac{KL}{r} = \frac{(1.0)(3.0)}{1.47} = 2.0$$

$$\therefore F_a = 21.5 \text{ ksi (AISC, P. 5-71, LEVEL A)}$$

INTERACTION

$$\frac{.51}{21.5} + \frac{1.09 + 5.01}{21.6} = .31 < 1$$

\therefore SADDLES QUALIFIED


0	WI	7/25/84	SL	7.26.84		JOB NO 030 036	PAGE 52
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-06	OF 87



SADDLE BOLTS

BASED ON $13/16"$ DIA HOLES (4), ASSUME $3/4"$ BOLTS

$$\left. \begin{aligned} A_{ROOT} &= .302 \text{ in}^2 \\ A_{TENSILE} &= .334 \text{ in}^2 \end{aligned} \right\} [3], \text{ p. 4-141}$$



LOADS AT THE SADDLE BASES ARE
 TABULATED ON THE FOLLOWING PAGE.
 DESIGN LOADS ARE SELECTED AS

$$\begin{aligned} R_1 &= 1772 \text{ lb} \\ R_2 &= 2211 \text{ lb} \\ R_3 &= 1891 \text{ lb} \end{aligned}$$

$$\begin{aligned} M_2 &= 26592 \text{ in}\cdot\text{lb} \\ M_3 &= 4100 \text{ in}\cdot\text{lb} \end{aligned}$$

0	WI.	7/25/84	W.L.	7-26-84	IMPELL CORPORATION	JOB NO 0210-036 CALC NO EQ-06	PAGE 33 OF 37
REV	BY	DATE	CHECKED	DATE			


BOLT LOADS

48I

	R1	R2	R3	M1	M2	M3
ax	1.1	21.0	1466.	NOTE 1 P.50	16390.	61.0
ay	998.3	74.7	4.2		18.9	202.3
az	356.4	1192.	78.3		57.6	2125.
SRSS	1060	1195.	1468	}	16390.	2135.
DW NOZZ	-2129. 293.8	165.9 850.3	9.2 242.7		42.0 8877.	449.7 1515.
TOTAL	-775.	2211	1720.		25309	4100.

49I

	R1	R2	R3	M1	M2	M3	
ax	1.1	21.0	1205.	}	15670.	44.9	
ay	795.9	74.7	4.2		18.9	190.1	
az	356.4	1480.0	78.3		57.6	1103.	
SRSS	872.	1482.	1208	}	15670	1120	
DW NOZZ	-1769. 2669	165.9 237.7	9.2 674.3		NOTE 1 P.50	42.0 10880.	422.4 674.4
TOTAL	1772	1886	1891		26592.	2217.	

0	WE	7/23/84	SSR	7/26/84		JOB NO 0310-036	PAGE 54
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-06	OF 87

SHEAR BOLT FORCE

$$V = \frac{[(R2)^2 + (R3)^2]^{\frac{1}{2}}}{2 \text{ bolts}}$$

$$= \frac{[(2211.1b)^2 + (1891.1b)^2]^{\frac{1}{2}}}{2 \text{ bolts}} = 1455 \text{ lb/bolt}$$

BOLT STRESS:

$$F_{bc} = \frac{T}{A_{TENS}} = \frac{4330 \text{ lb}}{.334 \text{ in}^2} = 13.0 \text{ ksi}$$


$$F_{bv} = \frac{V}{A_{ROOT}} = \frac{1455 \text{ lb}}{.302 \text{ in}^2} = 4.82 \text{ ksi}$$

ALLOWABLES (ASSUME A 307 BOLTS, $S_u = 60 \text{ ksi}$)

$$F_{bT} = \frac{S_u}{2} = \frac{60 \text{ ksi}}{2} = 30 \text{ ksi}$$

$$F_{vb} = \frac{.62 S_u}{3} = \frac{.62 (60 \text{ ksi})}{3} = 12.4 \text{ ksi}$$

LEVEL A
NF-33246

0	WI	7/25/84	SSR	7/26/84		JOB NO 0310 036	PAGE 56
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-06	OF 87

INTERACTION:

$$\frac{13.0}{30.0} + \frac{4.82}{12.4} = .82 < 1$$

∴ QUALIFIED USING LEVEL A ALLOWABLES.

REV	BY	DATE	CHECKED	DATE	JOB NO	CALC NO	PAGE OF
0	WE	7/25/01	SR	7.26.01	0310-036	EQ-06	57 OF 87



B.O BASE PLATE EVALUATION.

BASE PLATES (INCLUDING ANCHOR BOLTS) ARE DIVIDED INTO FOUR GROUPS. EACH GROUP IS EVALUATED SEPERATLY.

GROUP 1. - BASE PLATES WITH FOUR ANCHORS AND ATTACHED TO A WF MEMBER. INCLUDES PLATES AT ELEMENT NOS. 13I, 33J, 9I, 28I, 15I, 17I, 35J.

GROUP 2 - MAIN CHANNEL CONNECTIONS TO WALL, ELEMENTS 8J, 27J

GROUP 3 - CONNECTION OF VERTICAL CHANNEL TO FLOOR, ELEMENTS 1I, 19I

GROUP 4 - CONNECTION OF MEMBER 37J TO WALL.

					SCE HX E-34			
0	WE	6/14/84	58	1-20-84	JOB NO 0310-036		PAGE 58	
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-06		OF 87	



B.1 GROUP 1

BASE PLATES (13I, 33J, 9I, 28I, 15I, 17I, 35J)


A CONSERVATIVE EVALUATION WILL BE PERFORMED USING THE FOLLOWING ASSUMPTIONS:

- BENDING IS ASSUMED ABOUT THE C OF THE BASE PLATE
- BEARING LOADS AND ANCHOR BOLT LOADS WILL BE CALCULATED ASSUMING A 14" SQUARE BASE PLATE.
- BEARING LOADS WILL BE APPLIED TO A 16" SQUARE PLATE (MAXIMUM SIZE). LOADING WILL BE ASSUMED UNIFORM AND REQUIRED THICKNESS CALCULATED USING [3], p. 3-99
- BASED ON THE LOADS CALCULATED ON THE FOLLOWING PAGES THE FOLLOWING LOADS ARE SELECTED TO CHECK BASE PLATE ADEQUACY:

AXIAL = 4647
 SHEAR 1 = 3616
 SHEAR 2 = 1918
 TORSION = 2125
 BENDING 1 = 3035
 BENDING 2 = 4673


WORST CASE RESULTANT LOADS, SEE TABLE ON p. 67

THESE LOADS ARE SELECTED FROM THE LOADS FOR 13I, 33J, 9I, 28I. THEY ENVELOPE THE LOADS FOR 15I, 17I, 35J BY OBSERVATION.

					SEE HX - E-34				
0	WI	6/8/84	SL	12684				JOB NO 0310-036	PAGE 59
REV	BY	DATE	CHECKED	DATE				CALC NO EQ-06	OF 87

SEISMIC LOADS @ BASE PLATES
 BASE PLATE LOADS (LOCAL COORDINATES)

		X	Y	Z	SRSS	DW	TOTAL
R ₁	15I	229.5	87.7	128.8	277.	194.9	472.
	17I	129.9	34.4	348.3	373.	76.5	450.
	35J	179.1	82.6	401.9	448	183.5	631.
R ₂	15I	11.9	3.0	3.6	13.	6.6	19.
	17I	6.1	5.7	8.7	12.	12.6	25.
	35J	8.8	7.5	27.0	29.	16.7	46.
R ₃	15I	5.4	7.6	20.2	22.	17.1	39.
	17I	15.5	12.7	47.2	51.	28.2	79.
	35J	32.7	2.8	20.5	39.	6.3	45.
M ₁	15I	.4	.2	.1	/	.5	} NEGLIGIBLE
	17I	.9	.2	.1		.4	
	35J	.1	.1	2.1		.2	
M ₂	15I	122.2	108.9	248.4	297.	242.0	539.
	17I	247.6	145.7	390.1	484.	323.9	808.
	35J	676.4	77.3	458.7	821.	171.8	993.
M ₃	15I	137.6	66.1	63.1	165.	146.9	312.
	17I	38.5	103.8	111.3	157.	230.6	388
	35J	210.1	148.1	621.6	673.	329.2	1002.

REV	0
BY	WIE
DATE	6/10/01
CHECKED	SKC
DATE	7-18-01
	
JOB NO	0310-036
CALC NO	EQ-06
PAGE	60
OF	87

SC E
HX E-34

SEISMIC LOADS @ BASE PLATES

REV	BY	DATE	CHECKED	DATE		X	Y	Z	SRSS	D W	TOTAL
0	WF	6/10/84		7-18-84							
					R1	13I 667.7 33J 591.9 9I 313.4 28I 235.1	826.3 668.2 530.9 431.7	278.0 376.1 129.0 8.7	1098. 969. 630. 492.	1836. 1485 1180. 959.4	2934. 2454 1810 1451.
					R2	13I 2.2 33J 20.2 9I 2.1 28I 2.1	11.9 10.6 .7 1.6	186.1 169.7 2.6 19.6	186. 171. 3. 20.	26.4 23.5 1.5 3.6	213. 195 5. 23.
					R3	13I 437.3 33J 424.5 9I 32.1 28I 28.7	79.4 63.6 6.9 4.1	25.1 22.2 8.5 14.5	445. 430. 34. 32.	176.4 141.4 15.4 9.2	622. 571. 49. 42.
					M1	13I .2 33J .5 9I .2 28I .3	.2 .5 .2 .2	.9 1.7 .8 1.4	1. 2. 1. 1.	.4 1.2 .5 .5	} NEGLIGIBLE
					M2	13I 1650. 33J 1649. 9I 389.4 28I 299.0	824.5 664.1 218.0 145.0	240.7 138.0 213.3 346.7	1860. 1783. 495. 480.	1832. 1476. 484.4 322.2	
					M3	13I 1.5 33J 162.6 9I 47.5 28I 56.8	116.9 83.8 10.1 32.0	2046. 1854. 93.9 482.5	2049. 1863. 106. 487.	259.8 186.2 22.6 71.1	2309. 2049 128. 558.



SCE
HX
E-34


JOB NO 031D-036
CALC NO

EQ-06


PAGE 61
OF 87

NOZZE LOADS @ BASEPLATES

	R1	R2	R3	M1	M2	M3
13I 33J	231.7 2133.	140.1 34.0	244.2 139.6	0 4.	980.6 416.1	1396. 122.3
9I 28I	64.0 1061.	10.5 2.6	6.8 45.8	0 0	15.5 796.5	177.6 86.5
15I 17I 35J	101.2 227.8 301.9	1.2 9.5 6.5	9.2 13.0 17.0	0 0 0	74.6 29.4 361.6	31.2 122.2 179.0

0	WI	7/25/84	SL	1.26.84					
REV	BY	DATE	CHECKED	DATE			JOB NO 0310-036 CALC NO EQ-06		PAGE OF 62 87

BASE PLATES @ 13I, 33J



$$(X, Y)_{16} = (0, 48.0)$$

$$(X, Y)_{17} = (8.5, 54.0)$$

$$\theta = \text{ARCTAN} \left(\frac{\Delta Y}{\Delta X} \right)$$

$$\theta = \text{ARCTAN} \left(\frac{54.0 - 48.0}{8.5 - 0.0} \right) = 35^\circ$$

SELECT MAXIMUM LOADS (SEISMIC + WIND)

$$R_1 = 2934 \text{ lb (13I)} + 2133 \text{ lb (33J)} = 5067 \text{ lb}$$

$$R_2 = 213 \text{ lb (13I)} + 140 \text{ lb (13I)} = 353 \text{ lb}$$

$$R_3 = 622 \text{ lb (33I)} + 244.2 \text{ (13I)} = 866 \text{ lb}$$

M1 = NEGLIGIBLE

$$M_2 = 3692 \text{ in-lb (13I)} + 980.6 \text{ (13I)} = 4673 \text{ in-lb}$$

$$M_3 = 2309 \text{ in-lb (13I)} + 1396 \text{ (13I)} = 3705 \text{ in-lb}$$

$$F_x = R_1 \cos \theta + R_3 \sin \theta \quad (\text{NOTE 1})$$

$$= 5067 \cos 35^\circ + 866 \sin 35^\circ$$

$$= 4647 \text{ lb (INTO WALL)}$$

$$F_y = R_3 \cos \theta + R_1 \sin \theta$$

$$= 866 \cos 35^\circ + 5067 \sin 35^\circ$$

$$= 3616 \text{ lb}$$

NOTE 1 : NEGLECT DIRECTIONAL EFFECTS. (CONSERVATIVE)

					SCE HX E-34	
					JOB NO 0310-036	
					CALC NO	
0	WI	7/25/84	SL	7/26/84	EQ-06	
REV	BY	DATE	CHECKED	DATE	PAGE 63 OF 87	

$$F_z = R_z = 353 \text{ lb}$$

$$M_x = M_1 \cos \theta + M_3 \sin \theta$$

$$= (3705 \text{ in}\cdot\text{lb}) \sin 35^\circ$$


$$= 2125 \text{ in}\cdot\text{lb} \quad (\text{TORSION})$$

$$M_y = M_1 \sin \theta + M_3 \cos \theta$$

$$= (3705 \text{ in}\cdot\text{lb}) \cos 35^\circ$$


$$= 3035 \text{ in}\cdot\text{lb}$$

$$M_z = M_2 = 4673 \text{ in}\cdot\text{lb}$$



					SCE HX E-34			
0	WI	6/13/84	58	7/26/84	JOB NO 0310-036		PAGE	
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-06		OF 87	

BASE PLATES @ 9I, 28I



$$(X, Y)_3 = (31.0 \quad 43.0)$$

$$(X, Y)_4 = (67.0, 0)$$

$$\theta' = \text{ARCTAN} \left(\frac{\Delta Y}{\Delta X} \right) = \text{ARCTAN} \left(\frac{43.0 - 0}{31.0 - 67} \right)$$

$$\theta' = 50^\circ$$

$$\begin{aligned} \theta_1 &= 180^\circ - 90^\circ - \theta' \\ &= 180^\circ - 90^\circ - 50^\circ \\ &= 40^\circ \end{aligned}$$

$$F_x = R_3 \cos \theta_1 + R_1 \sin \theta_1$$

$$M_x = M_3 \cos \theta_1 + M_1 \sin \theta_1$$

$$F_y = R_3 \sin \theta_1 + R_1 \cos \theta_1$$

$$M_y = M_3 \sin \theta_1 + M_1 \cos \theta_1$$

$$M_z = M_z$$

$$F_z = F_z$$

NEGLLECT DIRECTIONAL
EFFECTS, CONSIDER
ALL OPERATIONS AS
ABSOLUTE SUMS

					SCE HX E-34			
0	WT	6/7/84	SL	7.18.84	JOB NO 0310-036		PAGE	
REV	BY	DATE	CHECKED	DATE	CALC NO		OF	
					EQ-06		65 87	



USE MAXIMUM LOADS (GAS MIL + NOZZLE)

$$\begin{aligned}
 R_1 &= 1810 \text{ lb (9I)} + 1061 \text{ (28I)} = 2871 \text{ lb} \\
 R_2 &= 23 \text{ lb (28I)} + 10.5 \text{ (9I)} = 34 \text{ lb} \\
 R_3 &= 49 \text{ lb (9I)} + 45.8 \text{ (28I)} = 95 \text{ lb}
 \end{aligned}$$

$$\begin{aligned}
 M_1 &= \text{NEGLECTIBLE} \\
 M_2 &= 979 \text{ lb-in (9I)} + 796.5 \text{ (28I)} = 1776 \text{ lb-in} \\
 M_3 &= 558 \text{ in-lb (28I)} + 177.6 \text{ (9I)} = 736 \text{ lb-in}
 \end{aligned}$$

$$F_x = R_3 \cos \theta_1 + R_1 \sin \theta_1 = 95 \cos 40 + 2871 \sin 40 = 1918 \text{ lb}$$


$$F_y = R_3 \sin \theta_1 + R_1 \cos \theta_1 = 95 \sin 40 + 2871 \cos 40 = 2260 \text{ lb (AXIAL)}$$

$$F_z = R_2 = 34 \text{ lb}$$

$$\begin{aligned}
 M_x &= M_3 \cos \theta_1 + M_1 \sin \theta_1 \\
 &= 736 \cos 40 + 0 = 564 \text{ lb-in}
 \end{aligned}$$


$$\begin{aligned}
 M_y &= M_3 \sin \theta_1 + M_1 \cos \theta_1 \\
 &= 736 \sin 40 = 473 \text{ in-lb}
 \end{aligned}$$

$$M_z = M_2 = 1776 \text{ in-lb}$$

					SCE HF E-34			
							JOB NO 0310-036	
							PAGE 66	
0	WI	7/25/84	GL	1-26-84			CALC NO	
REV	BY	DATE	CHECKED	DATE			EQ-06	


SUMMARY OF BASEPLATE (GROUP 1) LOADS

	AXIAL	SHEAR 1	SHEAR 2	TORSION	BEND 1	BEND 2
13E/335	4647.*	3616*	353	2125*	3035*	4673*
9E/28E	2260	1918*	34	473	564	1776




* NOTE: MAXIMUM LOADS SELECTED TO EVALUATE BASEPLATE & ANCHOR BOLTS.

0	WE	7/25/81	SL	7-26-81					JOB NO 0310-036 CALC NO EQ-06	PAGE 61 OF 87
REV	BY	DATE	CHECKED	DATE						



ANCHOR BOLTS

ASSUMING 14" SQUARE PLATE W/ BOLTS 2" FROM EACH EDGE, ROTATION ABOUT C OF PLATE



TENSILE BOLT LOAD


$$f_t = \frac{\text{AXIAL}}{4 \text{ BOLTS}} + \frac{\text{BENDING 1} + \text{BENDING 2}}{2(10")}$$

					SCE HX E-34	
					JOB NO 0310-036	
					CALC NO	
0	WT	6/8/04	SSC	126 SA	EQ-06	
REV	BY	DATE	CHECKED	DATE	PAGE 68 OF 87	

$$f_c = \frac{4647 \text{ lb}}{4} + \frac{3035 \text{ lb} \cdot \text{in} + 4673 \text{ lb} \cdot \text{in}}{2(10 \text{ in})}$$

$$= 1547 \text{ lb/bolt}$$

SHEAR BOLT LOAD



$$V_1 = \frac{\text{SHEAR 1}}{4} + \cos 45^\circ \frac{\text{TORSION}}{4(5\sqrt{2})}$$

$$V_2 = \frac{\text{SHEAR 2}}{4} + \sin 45^\circ \frac{\text{TORSION}}{4(5\sqrt{2})}$$

$$F_v = \sqrt{V_1^2 + V_2^2}$$

$$V_1 = \frac{3616 \text{ lb}}{4} + \frac{2125 \text{ in} \cdot \text{lb}}{4(5\sqrt{2} \text{ in})} \cos 45^\circ = 957.16$$

$$V_2 = \frac{1918 \text{ lb}}{4} + \frac{2125 \text{ in} \cdot \text{lb}}{4(5\sqrt{2} \text{ in})} \sin 45^\circ = 533.16$$

$$F_v = \left[(957.16)^2 + (533.16)^2 \right]^{1/2} = 1095 \text{ lb/bolt}$$

					SCE HX E-34	
0	WI	7/25/84	SAL	7/26/84	JOB NO	0310-036
REV	BY	DATE	CHECKED	DATE	CALC NO	EQ-06
					PAGE 69 OF 87	



ANCHOR BOLT ALLOWABLES

NUT SIZE $1\frac{1}{2}$ " FLAT-FLAT [2]

∴ ASSUME 1" DIAMETER CONCRETE EXPANSION BOLTS ([3], p. 4-136)

FROM [6] THE MINIMUM ULTIMATE LOADS FOR 1" BOLTS, ASSUMING 2000 PSI CONCRETE AND 4 1/2" (MINIMUM) EMBEDMENT

ULT. TENSION = 14,000 lb
 ULT. SHEAR = 27,355 lb

APPLYING A SAFETY FACTOR OF 4.0

$$F_t = \frac{14,000 \text{ lb}}{4} = 3500 \text{ lb}$$

$$F_r = \frac{27,355 \text{ lb}}{4} = 6840 \text{ lb}$$


INTERACTION:

$$\frac{1547 \text{ lb}}{3500 \text{ lb}} + \frac{1095 \text{ lb}}{6840 \text{ lb}} = 0.60 < 1$$

∴ BOLTS QUALIFY (FS=4.0)

					SCE HX-E34		
0	WI	7/25/84	SL	7/26/84	IMPPELL CORPORATION	JOB NO 0310-036 CALC NO EW-06	PAGE 70 OF 87
REV	BY	DATE	CHECKED	DATE			

BASEPLATE (USE IMPELL BASEPLATE PROCEDURE [12])



$$\left. \begin{aligned} b_{y \text{ eff}} &= .80(4.00 \text{ in}) = 3.20 \text{ in} \\ b_{x \text{ eff}} &= .95(4.16 \text{ in}) = 3.95 \text{ in} \end{aligned} \right\} [12], \text{ p. D1, fig D2.2}$$

$$t \geq \left[\frac{6 T_b}{A_p F_B} \right]^{\frac{1}{2}} \quad [12], \text{ p. 4}$$

WHERE, $T_b = \text{BOLT LOAD} = 1547 \text{ lb}$

$F_B = .6(36) = 21.6 \text{ (Level A)}$

0	WT	7/20/01	SL	12.8.0		JOB NO 0310-036	PAGE 71
REV	BY	DATE	CHECKED	DATE	IMPELL CORPORATION	CALC NO EQ-06	OF 87

$$A_p = \min \left[\left(\frac{d_y + \frac{b_y}{2}}{d_x'} \right), \left(\frac{d_x + \frac{b_x}{2}}{d_y'} \right) \right]$$

$$d_y = \frac{16'' - 3.20''}{2} = 6.40''$$

$$d_x = \frac{16'' - 3.95''}{2} = 6.03''$$

$$d_y' = d_y - 2'' = 6.40'' - 2'' = 4.40''$$

$$d_x' = d_x - 2'' = 6.03'' - 2.0'' = 4.03''$$

[12], fig B-1, p. viii


$$\frac{d_y + \frac{b_y}{2}}{d_x'} = \frac{6.40 \text{ in} + 3.20 \text{ in} / 2}{4.03 \text{ in}} = 1.99$$

$$\frac{d_x + \frac{b_x}{2}}{d_y'} = \frac{6.03 \text{ in} + 3.95 \text{ in} / 2}{4.40 \text{ in}} = 1.82$$

$$\therefore t_{\min} = \left[\frac{6 \cdot 1547 \text{ lb}}{(1.82)(21.6 \text{ ksi})} \right]^{\frac{1}{2}} = .49 \text{ in}$$


$$t_{\text{ACTUAL}} = .75''$$

\therefore BASE PLATE ADEQUATE

0	WE	7/25/84	SA	7/26/84		JOB NO 0310-036	PAGE 72
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-06	OF 87

GROUP 2

BASE PLATES @ NODES 14, 32 (ELEMENTS 8J, 27J)



PER [2] THE NUT SIZES ARE 1" FLAT-FLAT. REF [3] DOES NOT LIST 1" NUTS (P. 4-136). SIZES LISTED ARE:

NUT SIZE (FLAT-FLAT)	BOLT SIZE
5/16"	5/8"
1/8"	3/4"

BASED ON [9] (P. 29) THE BOLT SIZE IS 3/4"

∴ ASSUME 3/4" DIA. HILTI QUIL BOLTS

NOTE (L): REF [9] LISTS THIS DIMENSION AS 5" USING 4" WILL RESULT IN HIGHER BOLT FORCES. (CONSERVATIVE)


					SCE HX E-34	
0	WI	6/7/84	SCL	7.19.84	JOB NO 0310-036	PAGE 73
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-06	OF 87



SEISMIC LOADS		X	Y	Z	SRSS	DW	TOTAL
R1	8J 27J	1176. 1001.	270.0 217.7	32.6 227.0	1207. 1049	600. 483.7	1807. 1533.
R2	8J 27J	45.9 44.1	6.0 5.0	1.8 2.4	46. 44.	13.4 11.1	60. 56.
R3	8J 27J	5.8 84.1	40.9 16.7	855.0 808.2	856. 813.	90.9 37.1	947. 850.
M1	8J 27J	0 0	0 0	0 0	} NEGLI- GIBNE	0 0	} NEGLIGIBLE
M2	8J 27J	76.7 444.3	358.1 136.2	7600. 6960.	7609. 6975.	795.7 302.6	8405. 7278.
M3	8J 27J	0 0	0 0	0 0	} 30	0 0	} 30

NOZZLE LOADS		8J	27J
R1		51.5	377.0
R2		24.1	18.5
R3		584.7	82.7
M1		0	0
M2		465.7	865.1
M3		0	0

SCE HX E-34

REV	BY	DATE	CHECKED	DATE		JOB NO	0310-036	PAGE	74
0	WT	7/25/84	SM	7.26.84		CALC NO	EQ-06	OF	87

BASE PLT @ 14,32, CONT

LOADS @ BT (LOADS @ BT ENVELOPE LOADS @ 32J)

AXIAL LOAD, $R_1 = 1807 + 52 = 1859$ lb

SHEAR LOAD

$$R_2 = 60 + 24 = 84 \text{ lb}$$

$$R_3 = 947 + 585 = 1532 \text{ lb}$$

$$\begin{aligned} R &= [(R_2)^2 + (R_3)^2]^{\frac{1}{2}} \\ &= [(84 \text{ lb})^2 + (1532 \text{ lb})^2]^{\frac{1}{2}} \\ &= 1534 \text{ lb} \end{aligned}$$

MOMENT (OVERTURNING)

$$\begin{aligned} M_2 &= 8405 \text{ in}\cdot\text{lb} + 4657 \text{ in}\cdot\text{lb} \\ &= 13062 \text{ in}\cdot\text{lb} \end{aligned}$$

BOLT LOADS

TOTAL AXIAL BOLT LOAD IS CALCULATED BY ASSUMING THE MOMENT IS RESISTED BY A FORCE COUPLE IN THE BOLTS.

$$\begin{aligned} P &= \frac{1859 \text{ lb}}{2 \text{ bolts}} + \frac{13062 \text{ in}\cdot\text{lb}}{4''} \\ &= 4195 \text{ lb} \end{aligned}$$

						JOB NO 0310-036	PAGE 75
						CALC NO EQ-06	OF 87
0	WI	7/25/84	SL	12/84			
REV	BY	DATE	CHECKED	DATE			

IMPELL CORPORATION

ASSUME 3/4" EXPANSION BOLTS W/MINIMUM
 EMBEDMENT IN 4000psi CONCRETE STRENGTH
 (4000 psi + 3/4"). AVERAGE ULTIMATE
 CAPACITIES ARE:

PULLOUT 10150 lb
 SHEAR 17133 lb

USING A FACTOR OF SAFETY OF
 2.0 FOR RTS ALLOWABLES

$$F_T = \frac{10150}{2} = 5075 \text{ lb}$$

$$F_V = \frac{17133}{2} = 8567 \text{ lb}$$

CHECK INTERACTION

$$\frac{4195 \text{ lb}}{5075 \text{ lb}} + \frac{1534 \text{ lb}}{8567 \text{ lb}} = 1.0$$

BOLTS QUALIFY USING RTS
 ALLOWABLES (FS=2.0)

					SCF HX E-34			
							JOB NO 0310-036	
							CALC NO	
0	WE	7/25/84	LJR	12/10/84	IMPELL CORPORATION		EQ-06	
REV	BY	DATE	CHECKED	DATE			PAGE 76 OF 87	

BASE PLT @ 14,32, CONT

STRESS IN THE PLATE ARE EVALUATED ASSUMING THE PLATE IS A WIDE CANTILEVER WITH A POINT LOAD OF 3005 lb.




PLATE WIDTH $\times 7 \frac{1}{2} = 3.5$ "
CANTILEVER LENGTH a ,

$$a \approx 5" - \frac{3}{8}" = 4.625$$


DISTANCE TO LOAD, c

$$c \approx 5" - \frac{3}{8}" - 2" = 2.625"$$

NOTE 1; SEE [11] (ROARK) ART 7.11, PP. 188-191

0	WI	7/20/84	LSX	7.20.84		JOB NO D310-036	PAGE 77
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-6	OF 37

BASE PLATE 1.



X : $1 \frac{1}{4}$ "
 $\underline{\hspace{1cm}}$
 X₂ : $4 \frac{1}{8}$ "
 $\underline{\hspace{1cm}}$
 X₃ : $1 \frac{3}{4}$ "
 $\underline{\hspace{1cm}}$

PLATE THICKNESS:
 $\underline{\hspace{1cm}}$
 $\frac{1}{2}$ "

BASE PLATE 2.


SAME DIMENSIONS AS SHOWN ABOVE

X₁ : $1 \frac{1}{2}$ "
 $\underline{\hspace{1cm}}$
 X₂ : 4"
 $\underline{\hspace{1cm}}$
 X₃ : $1 \frac{1}{2}$ "
 $\underline{\hspace{1cm}}$

PLATE THICKNESS: $\frac{1}{2}$ "

REV	BY	DATE	CHECKED	DATE					JOB NO 0310-036	PAGE 3
									CALC NO	

BASEPLATE 3




- $X_1 = 1\frac{1}{2}"$
- $X_2 = 1\frac{1}{2}"$
- $X_3 = 2\frac{1}{4}"$

PLATE THICKNESS: $\frac{1}{2}"$

REV	BY	DATE	CHECKED	DATE	JOB NO	CALC NO	PAGE OF
					0310-036		44
	W/SO	6/20/84	G/SO				



CALCULATION/PROBLEM COVER SHEET



Calculation/Problem No: EQ-09
 Title: QUALIFICATION OF CHARGING PUMPS G-8A, B
 Client: SCE Project: SONGS-1 RTS
 Job No: 0310-036

Design Input/References:

SEE SECTION 1.0

Assumptions:

AS NOTED WITHIN

Method:

Remarks:

QUALIFIED, NO MODIFICATIONS REQUIRED

REV. NO.	REVISION	APPROVED	DATE
0	ORIGINAL ANALYSIS	M/Bred J	7/18/94

TABLE OF CONTENTS

COVER SHEET	1
CONTENTS	2
1.0 REFERENCES	3
2.0 INTRODUCTION / PROCEDURE	5
3.0 SEISMIC LOADS	
3.1 SYSTEM FREQUENCY	6
3.2 FLOOR RESPONSE SPECTRUM	7
3.3 LOADS	8
4.0 ALLOWABLE STRESSES	9
5.0 NOZZLE LOADS	11
6.0 MOTOR HOLD DOWN BOLTS	17
7.0 PUMP HOLD DOWN BOLTS	19
8.0 FOUNDATION ANCHOR BOLTS	25
9.0 BASE CHANNEL	34
10.0 SUMMARY	36

APPENDIX A - REFERENCES (PROVIDED FOR INFORMATION, NOT INCLUDED IN TOTAL PAGES)

0	WI	6/29/84	as	7/10/84	IMPELL CORPORATION				JOB NO 0310-036	PAGE
REV	BY	DATE	CHECKED	DATE					CALC NO	2
									EQ-09	OF 36

1.0 REFERENCES

1. BECHTEL POWER CORP. LETTER NO. BPC/V-84-156, DATED: MARCH 23, 1984, FROM J.D. DUFFIN TO W. D. GALLO (IMPELL). SUBJECT: SONGS-1 SAFE SHUTDOWN EQUIPMENT DATA, CHARGING PUMPS G-8A/B
2. AISC MANUAL OF STEEL CONSTRUCTION, 8TH EDITION, AMERICAN INSTITUTE OF STEEL CONSTRUCTION, CHICAGO.
3. PACIFIC PUMPS INC FOUNDATION PLAN, DWG NO FC-38771, REV. 4, 11-1-65, FOUNDATION PLAN FOR SONGS-1 CHARGING PUMPS, TRANSMITTED TO IMPELL WITH [1] ABOVE.
4. MEMO FROM CALVIN WONG AND JIM WAGONER (IMPELL) TO WARD INGLES (IMPELL), DATED 6/13/84, SUBJECT: NOZZLE LOADS FOR CHARGING PUMPS G-8A + G-8B.
5. PRELIMINARY CALCULATION, BECHTEL POWER CORP. CALCULATION MC-384-1 FOR CHARGING PUMPS G8A/B. NOT APPROVED - USED FOR INFORMATION ONLY.
6. ASME BOILER + PRESSURE VESSEL CODE, SECTION III, DIVISION 1, 1983 EDITION.
7. ROARK AND YOUNG, "FORMULAS FOR STRESS AND STRAIN," 5TH EDITION, MCGRAW-HILL BOOK CO. N.Y. 1975
8. "AVERAGE ULTIMATE TENSILE AND SHEAR LOADS" FOR HILTI-KWIK BOLTS, FROM HILTI CATALOG (INCLUDED IN APPENDIX A)

0	WE	6/29/84	CS	7/10/84		JOB NO 0310-036	PAGE 3
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-09	OF 36



— BLANK —

REV	BY	DATE	CHECKED	DATE	JOB NO	CALC NO	PAGE OF
0	WI	6/29/84	AS	7/13/84	0310-036	EQ-09	4 OF 36




2.0 INTRODUCTION / PROCEDURE

THIS CALCULATION CONTAINS THE EVALUATION OF THE SUPPORTS FOR THE CHARGING PUMPS G-BA + G-BB AT SONGS-1.

THE EVALUATION ADDRESSES THE PUMP AND MOTOR MOUNTING BOLTS, THE FOUNDATION ANCHOR BOLTS, AND THE BASE CHANNEL. ACCEPTANCE CRITERIA ARE BASED ON THE ASME CODE (SECTION III, SUBSECTION NF) AND THE PROJECT TECHNICAL INSTRUCTIONS.

THE EVALUATION IS PERFORMED USING AN EQUIVALENT STATIC ANALYSIS AND THE PEAK OF THE APPROPRIATE FRs. RESULTS ARE SUMMARIZED IN SECTION 10.0.


0	WE	6/29/84	WS	7/9/84					
REV	BY	DATE	CHECKED	DATE					
									
						JOB NO 0310-036		PAGE 5	
						CALC NO EQ-09		OF 36	

3.0 SEISMIC LOADS

3.1 SYSTEM FREQUENCY


THE DATA NEEDED TO DETERMINE THE FUNDAMENTAL FREQUENCY OF VIBRATION OF THE PUMP/MOTOR IS NOT CURRENTLY AVAILABLE.

THE PUMP AND MOTOR CAN BE REPRESENTED AS SDOF SYSTEMS BY MODELING EACH COMPONENT AS A RIGID FRAME TYPE STRUCTURE. THE COMMON SUPPORT SKID IS OBVIOUSLY RIGID. AS THE COMPONENTS CAN BE MODELED AS SDOF SYSTEMS, AN EQUIVALENT STATIC ANALYSIS USING A STATIC LOAD EQUAL TO THE PEAK OF THE FLOOR RESPONSE SPECTRUM WILL BE USED.

0	WJ	6/29/84	CS	7/1/84	IMPELL CORPORATION 	JOB NO 0310-036	PAGE 6
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-09	OF 36

3.2 FLOOR RESPONSE SPECTRUM

BASED ON [5], THE FOLLOWING SPECTRUM IS ASSUMED TO BE APPLICABLE TO THE CHARGING PUMPS.




REV	BY	DATE	CHECKED	DATE		JOB NO 0310-036	PAGE 7 OF 36
0	WE	6/29/84	AS	7/9/84		CALC NO EQ-09	

3.3 LOADS

SUPPORT CALCULATIONS WILL BE PERFORMED
ASSUMING 4% DAMPING (REACTOR AUX. BLDG
@ EL +5' + -2', SEE [5]) AND RESPONSE
AT THE SPECTRAL PEAK.

$$a_H = 1.05 g$$

$$a_v = \frac{2}{3}(1.05g) = 0.70g$$

12	WI	6/29/84	AS	7/9/84	IMPELL CORPORATION 	JOB NO 0310-036	PAGE 8	
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-09	OF 36	

4.0 ALLOWABLE STRESSES

• STRUCTURAL STEEL

ASSUME SA-36 STEEL:

$$F_y = 36 \text{ Ksi}, F_u = 58 \text{ Ksi} \quad ([6], \text{TABLE I-7.1})$$

ALLOWABLE AXIAL/BENDING STRESS, LEVEL D

$$F_a = F_b = \min(1.2 F_y, .7 F_u) \quad ([6], \text{Subsection NF})$$

$$1.2(36) = 43.2 \text{ Ksi}$$

$$.7(58) = 40.6 \text{ Ksi}$$

$$\therefore F_a = F_b = 40.6 \text{ Ksi}$$

ALLOWABLE SHEAR

$$F_v = \min(.8 F_y, .42 F_u)$$

$$.8(36) = 28.8 \text{ Ksi}$$

$$.42(58) = 24.4 \text{ Ksi}$$

$$\therefore F_v = 24.4 \text{ Ksi}$$

• BOLTING (NF-3324.6, TABLE NF-3225.2-1)

ASSUME SA-307 (GR B) BOLTS

$$F_u = 60.0 \text{ Ksi} \quad ([6], \text{TABLE I-7.3})$$

LEVEL A
LIMITS
NF-3324.6

$$\left\{ \begin{array}{l} F_{vb} = \frac{.62 S_u}{3} = \frac{.62(60 \text{ Ksi})}{3} = 12.4 \text{ Ksi} \\ F_{tb} = \frac{S_u}{2} = 30 \text{ Ksi} \end{array} \right.$$

0	WIE	6/29/84	DS	7/2/84					
REV	BY	DATE	CHECKED	DATE					
						IMPELL CORPORATION		JOB NO 0310-036 CALC NO EQ-09	PAGE 9 OF 36

LEVEL D BOLT LOADS (F-1335)
 $S_y = 36 \text{ ksi}$ (TABLE I-13.3)

$$F_{eb} = \text{MIN}(.7S_u, S_y)$$

$$.7S_u = .7(60) = 42.0 \text{ ksi}$$

$$S_y = 36 \text{ ksi}$$

$$\therefore F_{eb} = 36 \text{ ksi}$$

$$F_{vb} = \text{MIN}(.42S_u, .6S_y)$$

$$.42S_u = .42(60) = 25.2 \text{ ksi}$$

$$.6S_y = .6(36) = 21.6 \text{ ksi}$$

$$\therefore F_{vb} = 21.6 \text{ ksi}$$

• ANCHOR BOLTS

ANCHOR BOLTS ARE ASSUMED TO BE HILTI-KWIK BOLTS [8] (SEE APPENDIX A) THIS IS AN EXTREMELY CONSERVATIVE ASSUMPTION. THE BOLTS ARE PROBABLY EMBEDMENTS WHICH ARE TIED TO THE RE-BAR IN THE CONCRETE FLOOR.

FROM [1], THE ANCHOR BOLTS ARE 5/8" DIA.

0	WI	6/29/84	CS	7/9/84		JOB NO 0310-026	PAGE 10
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-09	OF 36



S.O NOZZLE LOADS

NOZZLE LOADS ARE OBTAINED FROM [4].
 LINE NUMBERS ARE ASSUMED BASED
 ON DATA IN [5]. FROM [3] EACH PUMP
 HAS THE FOLLOWING CONNECTIONS:


- 3" - SCH 80 - SUCTION ([3] - MARK A)
- 2" - SCH 160 - DISCHARGE ([3] - MARK B)

FROM [5], EACH PUMP HAS A 1" NOZZLE
 (LINE NOS. 2022-1" - 151R (G-BA) AND 2084-1" -
 151R (G-BB)). LOCATION OF THESE
 NOZZLES IS NOT CLEAR FROM [3],
 THEREFORE THESE LOADS WILL BE
 LUMPED WITH THE LOADS AT THE
 SUCTION & DISCHARGE NOZZLES.

MAXIMUM LOADS AT THE 1" NOZZLES [4]

GLOBAL COORD.	MAX. LOAD
F _x	15
F _y	9
F _z	27
M _x	11
M _y	18
M _z	2

NOTE: ALL FORCES IN POUNDS, ALL MOMENTS
 IN FOOT-POUNDS.

0	WI	6/29/84	AB	7/9/84				
REV	BY	DATE	CHECKED	DATE				
						JOB NO	0310-036	PAGE
						CALC NO	EQ-09	11 OF 36

NOZZLE LOADS, 2" DISCHARGE LINES

THERMAL LOADS (REV. O. BECHTEL, SEE [4])


DIRECTION (GLOBAL)	G-8A	G-8B
F _x	-415 lb	+143 lb
F _y	-21 lb	-95 lb
F _z	423 lb	410 lb
M _x	116 lb-ft	95 lb-ft
M _y	-109 lb-ft	158 lb-ft
M _z	-9 lb-ft	33 lb-ft

GRAVITY/SSE LOADS (IMPELL, SEE [4])

DIRECTION (GLOBAL)	DIRECTION (LOCAL)	G-8A		G-8B	
		D.W	SSE	D.W	SSE
F _x	F _y	9	±196.	-22	±144
F _y	-F _x	-888	±2073.	-79	±121
F _z	F _z	846	±2496.	-56	±370
M _x	M _y	187	±6618.	25	±76
M _y	-M _x	-342	±181.	-27	±157
M _z	M _z	104	±168.	-45	±149

THE LOADS LISTED ABOVE ARE COMBINED ON THE FOLLOWING PAGE

NOTE FORCES IN POUNDS
MOMENTS IN FOOT-POUNDS

0	WI	6/27/84	CS	7/13/84				
REV	BY	DATE	CHECKED	DATE				
						JOB NO 0310-036	PAGE 12	
						CALC NO EQ-09	OF 36	

NOZZLE LOADS, 2" LINES (CONT.)

G-BA

GLOBAL COORD.	DW	TH	DW+TH	SSE
F _x	9	-415	-406	±196.
F _y	-888	-21	-909	±2073.
F _z	846	423	+1269	±2490
M _x	187	116	+303	±6618
M _y	-342	-109	-451	±181
M _z	104	-9	+95	±168

G-8B

F _x	-22	+143	+121	±144
F _y	-79	-95	-174	±121
F _z	-56	410	+354	±370
M _x	25	95	+120	±76
M _y	-27	158	+131	±157
M _z	-45	33	-12	±149

FORCES IN POUNDS
MOMENTS IN FOOT-POUNDS

0	WT	6/29/84	AS	7/13/84		JOB NO 0310-036	PAGE 13
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-09	OF 36



NOZZLE LOADS, 3" SUCTION LINES

G-8A


GLOBAL COORD.	LOCAL COORD.	DW	TH	DW+TH	SSE
F _x	F(S1)	-4	+ 379	375	± 148
F _y	F(A1)	+ 65	+198	263	± 55
F _z	F(S2)	-6	+544	538	± 236
M _x	M(B1)	-41	+ 1	40	± 40
M _y	M(TDR)	-8	-101	109	± 151
M _z	M(B2)	+ 4	-115	111	± 54

G-8B

F _x	F(S1)	18	-87	69	± 132
F _y	F(A1)	+181	+95	276	± 164
F _z	F(S2)	1	71	72	± 205
M _x	M(B1)	-116	-19	135	± 134
M _y	M(TDR)	37	-35	2	± 137
M _z	M(B2)	-78	-19	97	± 71

NOTE: COORDINATE SYSTEM TRANSFORMATION IS BASED ON STANDARD PIPING PROCEDURES. WHEN THE PIPE AXIS IS VERTICAL (GLOBAL Y), THE LOCAL Y (OR Z) AXIS DEFAULTS TO THE GLOBAL X.

: FORCES IN POUNDS
MOMENTS IN FOOT-POUNDS

0	WE	6/29/84	AS	7/9/84			JOB NO 0310-036	PAGE 14	
REV	BY	DATE	CHECKED	DATE			CALC NO EQ-09	OF 36	

TOTAL NOZZLE LOAD @ FOUNDATION


TOTAL LOAD IS SET EQUAL TO THE ABSOLUTE SUM OF THE (DW+TH) LOADS OF THE SUCTION AND DISCHARGE LINES AND THE LOADS ON THE 1" LINES PLUS THE SRSS OF THE SEISMIC LOADS FROM THE SUCTION + DISCHARGE LINES.

$$\text{TOTAL} = (DW+TH)_{\text{SUC.}} + (DW+TH)_{\text{DIS}} + (1" \text{ LOADS}) + \text{SRSS}(SSE_{\text{SUC.}} SSE_{\text{DIS}})$$


ENVELOPING LOADS FROM THE 2 PUMPS WILL BE USED

	(DW+TH) _S	(DW+TH) _D	1" /	SSE _S	SSE _D	TOTAL
Fx	375	406	15	148	196	1042.
Fy	276	909	9	164	2073	3273.
Fz	538	1269	27	236	2490	4335.
Mx'	135	303	11	134	6618	7068.
My'	109	451	18	151	181	814
Mz'	111	95	2	71	168	390.

ASSUMING THE LOADS ARE APPLIED AT THE ENDS OF THE NOZZLES (38" ABOVE THE FLOOR) AND AT THE CENTROID OF THE BOLT PATTERN, RESULTS IN THE FOLLOWING MOMENTS

0	WE	6/29/04	DB	7/13/04		JOB NO 0310-036	PAGE 15 OF 36
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-09	

MOMENT DUE TO NOZZLE LOAD




$$M_x = M_x' + F_z \cdot 38''$$

$$= (1068 \text{ ft-lb})(12 \text{ in/ft}) + (4335 \text{ lb})(38 \text{ in}) = 2.50 \times 10^5 \text{ in-lb}$$

$$M_z = M_z' + F_x \cdot 38''$$


$$= (390 \text{ ft-lb})(12 \text{ in/ft}) + (1042 \text{ lb})(38 \text{ in}) = 4.43 \times 10^4 \text{ in-lb}$$

$$M_y = M_y' = (814 \text{ ft-lb})(12 \text{ in/ft}) = 9768 \text{ in-lb}$$

0	WI	6/29/84	CS	7/13/84		JOB NO 0310-036	PAGE 16
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-09	OF 36

6.0 MOTOR HOLD DOWN BOLTS

4 - 1/2" DIAMETER BOLTS (DIMENSIONS FROM [1])



HEIGHT OF CG ABOVE BASE, ASSUME 24" (DIST FROM FLOOR TO PUMP AND MOTOR [3])

ASSUME BOLTS RESIST OVERTURNING MOMENTS THROUGH FORCE COUPLES. (NOTE 1)

$$T_B = \frac{M_z}{(2 \text{ bolts})(26.5 \text{ in})} + \frac{M_x}{(2 \text{ bolts})(37.125 \text{ in})} + \frac{F_y}{4 \text{ bolts}}$$

$$F_y = (a_v) W_m \\ = (-.30g)(5250 \text{ lb}) \\ = -1575 \text{ lb}$$

$$M_x = M_z = W_m a_H \bar{x} \\ = (5250 \text{ lb})(1.05g)(24 \text{ in}) \\ = 132,300 \text{ in}\cdot\text{lb}$$

$$T_B = \frac{132,300 \text{ in}\cdot\text{lb}}{(2 \text{ bolt})(26.5 \text{ in})} + \frac{132,300 \text{ in}\cdot\text{lb}}{(2 \text{ bolt})(37.125 \text{ in})} + \frac{-1575 \text{ lb}}{4 \text{ bolt}} \\ = 3884 \text{ lb/bolt}$$

$$V_B = \frac{(F_x^2 + F_z^2)^{1/2}}{4 \text{ bolt}} = \frac{[(W_m a_H_x)^2 + (W_m a_H_z)^2]^{1/2}}{4 \text{ bolt}}$$

NOTE 1: SEISMIC LOADS ARE ASSUMED - CONSERVATIVE

					SCE / SDNGS-1			
0	WI	5/15/84	WB	7/9/84	IMPELL CORPORATION		JOB NO 0310-036	PAGE 17
REV	BY	DATE	CHECKED	DATE			CALC NO EQ-09	OF 36

$$\begin{aligned}
 V_B &= \frac{W_m}{4 \text{ bolt}} \sqrt{a_H^2 + a_H^2} \\
 &= \frac{5250 \text{ lb}}{4 \text{ bolts}} [(1.05g)^2 + (1.05g)^2]^{\frac{1}{2}} \\
 &= 1950 \text{ lb}
 \end{aligned}$$

NOTE: BOLT PRELOAD AND FRICTIONAL RESISTANCE WERE CONSERVATIVELY NEGLECTED.

ASSUME A307 BOLTS, FROM [1], BOLTS ARE 1/2" DIA.

$$A_{\text{ROOT}} = 1.29 \text{ in}^2 \quad ([2], \text{ p. 4-141})$$

$$f_{vb} = \frac{1950 \text{ lb}}{1.29 \text{ in}^2} = 1.51 \text{ ksi}$$


$$f_{cb} = \frac{3884 \text{ lb}}{1.29 \text{ in}^2} = 3.01 \text{ ksi}$$

INTERACTION:

$$\left(\frac{f_{vb}}{F_{vb}}\right)^2 + \left(\frac{f_{cb}}{F_{cb}}\right)^2 = ?$$


$$\left(\frac{1.51 \text{ ksi}}{12.4 \text{ ksi}}\right)^2 + \left(\frac{3.01 \text{ ksi}}{30.0 \text{ ksi}}\right)^2 = 0.02 < 1$$

∴ QUALIFIED USING LEVEL A LIMITS


					SCE/SONGS-1	
0	WI	5/15/84	AB	7/13/84	JOB NO 0310-036	PAGE 18
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-09	OF 36
						

7.0 PUMP HOLD DOWN BOLTS

GEOMETRY (SEE [1])



NOZZLE LOCATIONS



0	WT	6/29/87	AG	7/9/88			
REV	BY	DATE	CHECKED	DATE			
					JOB NO 0310-036 CALC NO EQ-09		PAGE 19 OF 36

SEISMIC LOADS

ASSUME ROTATION ABOUT ϕ 'S OF BOLT
 PATTERN. BOLTS RESIST OVERTURNING
 MOMENTS THROUGH FORCE COUPLES. (NOTE 1)

$$T_B = \left[\left(\frac{M_x}{(2 \text{ bolts})(43.4 \text{ in})} \right)^2 + \left(\frac{M_z}{(2 \text{ bolts})(18.5 \text{ in})} \right)^2 + \left(\frac{F_y}{4} \right)^2 \right]^{1/2} - DW/4$$

$$M_x = M_z = W_p \cdot a_H \cdot \bar{x}$$

$W_p =$ Pump WT, 9480 lb [1]

$a_H = 1.05g$

$\bar{x} = 24"$ (DIST FROM FLOOR TO ϕ OF
 SHAFT, [3]) ASSUMED CG

$$M_x = M_z = (9480 \text{ lb})(1.05g)(24 \text{ in})$$

$$= 2.39 \times 10^5 \text{ in}\cdot\text{lb}$$

$$F_y = (.7g)(W_p)$$

$$= (.7g)(9480 \text{ lb}) = 6636 \text{ lb}$$

$$\therefore T_B = \left[\left(\frac{2.39 \times 10^5 \text{ lb}\cdot\text{in}}{2(43.4 \text{ in})} \right)^2 + \left(\frac{2.39 \times 10^5 \text{ lb}\cdot\text{in}}{2(18.5 \text{ in})} \right)^2 + \left(\frac{6636 \text{ lb}}{4} \right)^2 \right]^{1/2} - \frac{9480}{4}$$


$$= 4845 \text{ lb/bolt}$$

SHEAR:

$$V_{Bx} = V_{Bz} = \frac{a_H W_p}{4 \text{ bolts}} = \frac{(9480 \text{ lb})(1.05g)}{4}$$

$$= \frac{9954 \text{ lb}}{4 \text{ bolts}} = 2489 \text{ lb}$$

NOTE 1: SEISMIC LOADS ARE SRSS'ed TO DECOUPLE THE EFFECTS OF THE THREE DIRECTIONAL ACCELERATIONS

0	WE	6/29/84	AS	7/9/84	IMPELL CORPORATION	JOB NO 0310-036	PAGE
REV	BY	DATE	CHECKED	DATE		CALC NO	20
						EQ-09	OF 36

LOADS DUE TO NOZZLE LOADS -
 ASSUME ALL LOADS ACT @ CENTROID OF BOLT PATTERN

• TENSION


$$T_B = \frac{M_x}{2(43.4 \text{ in})} + \frac{M_z}{2(18.5 \text{ in})} + \frac{F_y}{4 \text{ bolts}}$$

$$= \frac{2.50 \times 10^5 \text{ in}\cdot\text{lb}}{2(43.4 \text{ in})} + \frac{4.43 \times 10^7 \text{ in}\cdot\text{lb}}{2(18.5 \text{ in})} + \frac{3273}{4}$$

$$= 4896 \text{ lb./bolt}$$

• SHEAR

• DUE TO M_y (TORSION)



$$x' = \frac{18.5}{2} = 9.25''$$

$$d = \frac{[(18.5'')^2 + (43.4'')^2]^{\frac{1}{2}}}{2}$$

$$= 23.6''$$

$$\theta = \text{ARCTAN} \left(\frac{18.5}{43.4} \right) = 23^\circ$$

$$M_y = 4d \cdot F$$

$$F = \frac{M_y}{4d}$$

$$F_1 = \frac{M_y}{4d} \cdot \sin \theta$$

$$F_2 = \frac{M_y \cdot \cos \theta}{4d}$$

0	WI	6/29/84	CS	7/13/84		JOB NO 0310-036	PAGE 21
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-09	OF 36



$$F_1 = \frac{9768 \text{ in. lb} \sin 23^\circ}{4(23.6")} = 40.1 \text{ lb}$$

$$F_2 = \frac{9768 \text{ in. lb} \cos 23^\circ}{4(23.6")} = 95 \text{ lb}$$

• DUE TO X SHEAR

$$V_{Bx}' = \frac{F_x}{4 \text{ bolts}} = \frac{1042}{4} = 261 \text{ lb}$$

• DUE TO Z SHEAR

$$V_{Bz}' = \frac{F_z}{4} = \frac{4335}{4} = 1084 \text{ lb}$$

Let

$$V_{Bx} = V_{Bx}' + F_1 = 261 \text{ lb} + 40.1 \text{ lb} = 301 \text{ lb}$$

$$V_{Bz} = V_{Bz}' + F_2 = 1084 \text{ lb} + 95 \text{ lb} = 1179 \text{ lb}$$

0	WI	6/29/84	AS	7/13/84		JOB NO 0310-036	PAGE 22
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-09	OF 36



TOTAL BOLT FORCES (SEISMIC + WDEZE)

$$\text{TENSION: } 4845 \text{ lb} + 4896 \text{ lb} = 9741 \text{ lb/bolt}$$

SHEAR

$$X: 2489 \text{ lb} + 261 \text{ lb} = 2750 \text{ lb/bolt}$$

$$Z: 2489 \text{ lb} + 1092 \text{ lb} = 3581 \text{ lb/bolt}$$

$$\begin{aligned} \text{RESULTANT} &= \text{SRSS}(2750, 3581) \\ &= 4515 \text{ lb/bolt} \end{aligned}$$

BOLT STRESSES:

FOR 1" DIA BOLTS;

$$A_{\text{ROOT}} = .551 \text{ in}^2 \text{ ([2], p. 4-141)}$$

$$\therefore f_{bt} = \frac{9741 \text{ lb}}{.551 \text{ in}^2} = 17.7 \text{ ksi}$$

$$F_{bt} = 30 \text{ ksi}$$

} OK

$$f_{vb} = \frac{4515 \text{ lb}}{.551 \text{ in}^2} = 8.2 \text{ ksi}$$

$$F_{vb} = 12.4 \text{ ksi}$$

} OK

REV	BY	DATE	CHECKED	DATE	JOB NO	CALC NO	PAGE
0	WT	6/29/84	UB	7/13/84	0310-036	EQ-09	23
							OF
							36




INTERACTION

$$\left(\frac{F_{bc}}{F_{bt}}\right)^2 + \left(\frac{F_{vb}}{F_{rb}}\right)^2$$



$$= \left(\frac{17.7}{30.0}\right)^2 + \left(\frac{8.2}{12.40}\right)^2 = \underline{.79} < 1$$

∴ PUMP HOLD DOWN BOLTS QUALIFY
 USING LEVEL A LIMITS +
 CONSERVATIVE ASSUMPTIONS.

0	WE	6/29/84	ab	7/13/84		JOB NO 0310-036	PAGE 24
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-09	OF 36

8.0 FOUNDATION ANCHOR BOLTS

10 - 5/8" DIAMETER BOLTS - DIMENSIONS FROM [1] + [3]




FROM THE "ANCHOR BOLT AND FOUNDATION DETAILS" PROVIDED WITH [1], (SEE APPENDIX A, SHEET WAS EXCERPTED FROM "REACTOR AUXILIARY BUILDING SECTIONS & DETAILS, SHEET 6) THE FOUNDATION BOLTS ARE J BOLTS WITH

0	WE	6/29/84	AB	7/9/84		JOB NO 0310-036	PAGE 25
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-09	OF 36



AN EMBEDDED LENGTH EXCEEDING 1 FC. IN ADDITION, THE CONCRETE BASE IS TIED TOGETHER WITH RE-BAR WHICH ALSO EXTENDS 1 FC INTO THE FLOOR.

FIGURE EXCERPTED FROM [1]:



BASED ON THE CONFIGURATION OF THE PUMP ANCHORAGE, THE FOLLOWING ASSUMPTIONS ARE MADE.

SHEAR LOADS DUE TO SSE INERTIA AND NOZZLE LOADS APPLIED TO THE PUMP AND/OR MOTOR ARE TRANSFERRED TO THE SKID THROUGH THE MOUNTING BOLTS (EVALUATED IN SECTION 6.0 & 7.0). THE SHEAR FORCES ARE THEN TRANSFERRED INTO THE FLOOR THROUGH THE GROUT AND CONCRETE. THE FOUNDATION BOLTS DO NOT RESIST THE SHEAR FORCES. (SEE FIGURE ON PRECEDING PAGE) BASED ON THE FOUNDATION DWG, SHOWN ABOVE, THE FOUNDATION BOLTS

REV	BY	DATE	CHECKED	DATE
0	WJ	6/29/84	QS	7/9/84



JOB NO 0310-036

CALC NO

EQ-09

PAGE

26

OF

36

PASS THROUGH A 2" DIAMETER SLEEVE,
 THEREFORE THE BOLTS ARE
 UNABLE TO RESIST SHEAR FORCES. THUS
 THE ASSUMPTION IS REASONABLE.

0	WE	6/29/84	CS	7/9/84		JOB NO 0310-036	PAGE 27
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-09	OF 36



FOUNDATION BOLTS, CONT.

THE LOADS ON THE PUMP/MOTOR/SKID ARE LISTED BELOW.

• MOTOR:

SEISMIC LOADS

$$F_x = F_z = (1.05g)W_m = (1.05)(5250 \text{ lb}) = 5513 \text{ lb}$$

$$F_y = (.7g)(5250 \text{ lb}) = 3675 \text{ lb.}$$

$$M_x = M_z = 132,300 \text{ lb}\cdot\text{in}$$

$$M_y = 0$$

DEAD LOAD

$$F_y = -5250 \text{ lb}$$

• PUMP

SEISMIC LOADS

$$F_x = 9954 \text{ lb}$$

$$F_y = 6636 \text{ lb}$$

$$F_z = 9954 \text{ lb}$$

$$M_x = 2.39 \times 10^5 \text{ in}\cdot\text{lb}$$

$$M_y = -0-$$

$$M_z = 2.39 \times 10^5 \text{ in}\cdot\text{lb}$$

NOZZLE LOADS

$$F_x = 1042 \text{ lb}$$

$$F_y = 3273 \text{ lb}$$

$$F_z = 4335 \text{ lb}$$


$$M_x = 2.50 \times 10^5 \text{ in}\cdot\text{lb}$$

$$M_y = 9768 \text{ in}\cdot\text{lb}$$

$$M_z = 4.43 \times 10^4 \text{ in}\cdot\text{lb}$$

DEAD LOAD

$$F_y = -9480 \text{ lb}$$

0	WI	6/29/84	US	7/13/84		JOB NO 0310-036	PAGE 29
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-09	OF 36
							

$$\frac{z}{a} = \frac{3.5''}{4.625''} = .757$$

$$\frac{c}{a} = \frac{2.625''}{4.625''} = .568$$

by INTERPOLATION ([11], p. 190):

z/a	c/a	K_m	z/a	c/a	K_m
.757	.75	.210	.757	.568	.155
.757	.50	.134			

MAXIMUM BENDING STRESS:

$$f_b = K_m \left(\frac{6P}{c^2} \right)$$


$$P = \text{MAX BOLT LOAD} = 3005 \text{ lb}$$

$$c = \frac{1}{2}'' \text{ ([10])}$$

$$\therefore f_b = .155 \left[\frac{6(4195 \text{ lb})}{(.50 \text{ in})^2} \right] = 15.6 \text{ ksi}$$

$$F_b (\text{MW}) = .6(36 \text{ ksi}) = 21.6 \text{ ksi (LEVEL A)}$$

\therefore PLATE QUALIFIES


0	WI	7/25/84	SJC	7/22/84		JOB NO 040-036	PAGE 78
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-06	OF 87

GROUP 3

BASE PLATES @ NODES 1, 49 (ELEMENTS 1I, 19I)

SEISMIC LOADS

		a_x	a_y	a_z	RESULTANT SEISMIC	DW
R1	1I 19I	390.6 413.9	137.8 133.9	70.8 212.3	420. 484.	306.3 297.5
R2	1I 19I	4.3 4.2	.5 .4	.2 .3	4. 4.	1.0 .8
R3	1I 19I	0. 1.7	2.0 1.1	22.6 22.7	23. 23.	4.5 2.5



LOADS ARE INSIGNIFICANT RELATIVE TO THE CAPACITY OF 1" ANCHORS.

∴ QUALIFIED


NOTE: LOADS DUE TO NOZZLE LOADS ARE ALSO SMALL

SCE HX E-34

0	WI	7/25/84	SCE	7-26-84	JOB NO 0310-036	PAGE 79
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-02	OF 87



GROUP 4, Baseplate @ 37J (NODE 45)



LOADS @ 37J (SEISMIC)

	R1	R2	R3	M1	M2	M3
α_x	48.7	1.5	.2	.2	6.8	0
α_y	16.2	.5	2.9	0	33.8	0
α_z	658.0	14.3	0	0	2.3	0
SRSS	660.0	14.4	2.9	NEGUGIBLE	34.6	0
DW	35.9	1.2	6.4	0	75.0	0
TOTAL	696.	16.	9.	NEGUGIBLE	110.	0

0	WE	7/20/84	SAL	7.28.84
REV	BY	DATE	CHECKED	DATE



JOB NO 0310-036

CALC NO

EQ-06

PAGE


OF 80
37

NOZZLE LOADS @ 375


$R1 = 60.0 \text{ lb}$
 $R2 = 3.3 \text{ lb}$
 $R3 = 0 \text{ lb}$
 $M1 = 0$
 $M2 = 9.7 \text{ in-lb}$
 $M3 = 0$

TOTAL LOADS (SEISMIC + NOZZLE)

$R1 = 696. + 60. = 756. \text{ lb}$
 $R2 = 16. + 3.3 = 19. \text{ lb}$
 $R3 = 9. + 0. = 9. \text{ lb}$
 $M1 = \text{NEGLECTIBLE}$
 $M2 = 110. + 9.7 = 120. \text{ in-lb}$
 $M3 = 0$

0	WI	7/23/84	LSL	7.26.84		JOB NO 0310-036	PAGE 81
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-06	OF 87


TRANSFORM LOADS TO GLOBAL COORDINATES



$$(x, y, z)_{37} = (26.5, 60.0, 0.0)$$

$$(x, y, z)_{45} = (0.0, 60.0, 31.3)$$

• NODE 37



$$\theta = \text{ARCTAN} \left(\frac{26.5''}{31.3''} \right)$$

$$\theta \approx 40^\circ$$

NOTE: NEGLECT DIRECTIONAL EFFECTS IN TRANSFORMATION, CONSERVATIVELY, ASSUME ALL COMBINATIONS ARE ASUM.

$$\begin{aligned} R_X &= R_1 \sin \theta + R_2 \cos \theta \\ &= 756 \sin 40^\circ + 19 \cos 40^\circ \\ &= 501 \text{ lb} \end{aligned}$$

$$R_Y = R_3 = 9 \text{ lb}$$

$$\begin{aligned} R_Z &= R_1 \cos \theta + R_2 \sin \theta \\ &= 756 \cos 40^\circ + 19 \sin 40^\circ \\ &= 591 \text{ lb} \end{aligned}$$


$$\begin{aligned} M_X &= M_1 \sin \theta + M_2 \cos \theta \\ &= 120 \cos 40^\circ \\ &= 92 \text{ in-lb} \end{aligned}$$

$$M_Y = M_3 = 0$$

$$\begin{aligned} M_Z &= M_1 \cos \theta + M_2 \sin \theta \\ &= 120 \sin 40^\circ \\ &= 77 \text{ in-lb} \end{aligned}$$

0	WE	7/25/84	SW	7/25/84		JOB NO	0310-036
REV	BY	DATE	CHECKED	DATE		CALC NO	EQ-06
							PAGE
							82
							OF
							87





DISTANCE BETWEEN BOLTS:

$$l = 7'' - 1.5'' - 1.5'' = 4''$$

SHEAR FORCES IN BOLTS

$$V_y = R_y / 2 = \frac{9.1b}{2} = 5.1b / \text{bolt}$$

$$V_z = \frac{R_z}{2} + \frac{M_z}{4''} = \frac{591.1b}{2 \text{ bolts}} + \frac{92 \text{ in}\cdot\text{lb}}{4 \text{ in}} = 319.1b / \text{bolt}$$

$$V_{\text{RESULTANT}} = (V_x^2 + V_z^2)^{1/2} = [(5.1b)^2 + (319.1b)^2]^{1/2} = 319.1b$$

TENSILE FORCES

$$T = \frac{R_x}{2 \text{ bolts}} + \frac{M_z}{4 \text{ inches}} = \frac{501.1b}{2} + \frac{77 \text{ in}\cdot\text{lb}}{4 \text{ in}} = 270.1b / \text{bolt}$$

REV	BY	DATE	CHECKED	DATE			JOB NO 0310-036 CALC NO EQ-06
	WE	7/25/84	SA	7-26-84			PAGE 43 OF 87

ANCHOR BOLT ALLOWABLES

ANCHOR BOLTS - 1" FLAT-FLAT (HEAD SIZE) [2]

• FROM [3], P. 4-136, ASSUME 5/8" DIAMETER BOLTS.

• ASSUME HILTI-KWIK BOLTS, FROM [6], FOR 5/8" BOLTS IN 4000 PSI CONCRETE, W/ EMBEDDED LENGTH OF 2 3/4" (MINIMUM) THE ULTIMATE CAPACITIES ARE:

$$TENSILE = 6600 \text{ lb}$$

$$SHEAR = 11562 \text{ lb}$$

APPLY A SAFETY FACTOR OF 4.0

$$T_A = \frac{6600 \text{ lb}}{4} = 1650 \text{ lb}$$


$$V_A = \frac{11562 \text{ lb}}{4} = 2891 \text{ lb}$$

INTERACTION:


$$\frac{T}{T_A} + \frac{V}{V_A}$$

$$= \frac{270 \text{ lb}}{1650 \text{ lb}} + \frac{319 \text{ lb}}{2891 \text{ lb}} = 0.27 < 1$$

∴ BOLTS QUALIFY (FS=4.0)

0	WE	7/25/84	588	7/25/84		JOB NO 0310-036	PAGE 84
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-06	OF 87

MODEL THE PLATE AS A
WIDE CANTILEVER: SEE [II], ART. 7.11, P. 188-191



NOTE: THIS MODEL
NEGLECTS THE SUPPORT
PROVIDED BY THE
CHANNEL WEBS, ∴
CONSERVATIVE.

$$a \approx 7'' - 3.15'' = 3.85''$$

$$c \approx 7 - 3.15'' - 1.5'' = 2.35''$$

$$z \approx 7.5''$$

$$P = \text{BOLT LOAD} = 270 \text{ lb (TENSILE)}$$


$$\frac{c}{a} = \frac{2.35}{3.85} = .61$$

$$\frac{z}{a} = \frac{7.5}{3.85} = 1.95 \quad (\text{let } z/a = 2.00 \text{ FOR SIMPLICITY})$$

INTERPOLATE for $c/a = .61$

$$z/a = 2.0$$

$$\left. \begin{array}{l} c/a = .50, k_m = .011 \\ c/a = .75, k_m = .023 \end{array} \right\} c/a = .61, k_m \approx .016$$

REV	BY	DATE	CHECKED	DATE	JOB NO	CALC NO	PAGE
0	WI	7/25/84	<i>[Signature]</i>	7/27/84	0310-036	EQ-06	85 OF 87
							

STRESS, $f_b = \frac{K_m G P}{e^2}$

$t = 1/2" [10]$

$f_b = \frac{.016 (6.0)(270 \text{ lb})}{(.50 \text{ in})^2} = .10 \text{ Ksi}$

$F_b (\text{MIN}) = .6(36) = 21.6 \text{ Ksi} \quad (\text{LEVEL A})$

∴ PLATE IS QUALIFIED

0	WE	7/25/84	EX	7/26/84		JOB NO 0310-036	PAGE
REV	BY	DATE	CHECKED	DATE		CALC NO	OF
						EQ-06	86
							87



WELDS:


BASED ON THE EXTREMELY LOW STRESSES IN THE STRUCTURAL MEMBERS MAXIMUM INTERACTION OF ϕ_1 WITH NEGLIGIBLE SHEAR, THE WELDS WILL NOT BE EVALUATED.

1. WELDS ARE QUALIFIED BY INSPECTION.

						JOB NO 0310-036	PAGE
						CALC NO	87
0	WT	7/25/84	SKL	7-26-84		EQ-06	OF
REV	BY	DATE	CHECKED	DATE			87



APPENDIX - REFERENCE MATERIAL

0	WI						
REV	BY	DATE	CHECKED	DATE			JOB NO 0310-036 CALC NO EQ-06
							PAGE OF

13 - 3/8" OVERALL

10'-2"

4" - 150"


18" O.D.

4" - 150" ASA RF
COMPONENT COOLING WATER INLET

3/4" NPT
DRAIN

12"

2'-2"



2 13/16 X 1 1/2 SLOTTED
HOLES IN THIS
GRACLE

NOTE

1. ALL BOLT HOLES TO STRADDLE E.S.

DIMENSIONS & DATA
CERTIFIED FOR
CUST. ORDER 54-P-1432
OUR ORDER 206-64-1580
BY DATE 3-29-65
BASCO, INC.

UNITS REQ
P.O. 54-P-
DESIGN PR
TEST PRE
DESIGN T
SURFACE

Bechtel Power Corporation

Engineers - Constructors

12400 East Imperial Highway

Norwalk, California 90650

MAIL ADDRESS

P.O. BOX 60860 - TERMINAL ANNEX, LOS ANGELES, CALIFORNIA 90060
TELEPHONE (213) 807-2000



March 30, 1984

BPC/V-84-160

Mr. W. D. Gallo
Project Manager
Advanced Engineering
Impell Corporation
350 Lennon Lane
Walnut Creek, CA 94598

Subject: San Onofre Nuclear Generating Station, Unit 1
Bechtel Job No. 15691-384
Safe Shutdown Equipment Data For:
a) Seal Water Supply Filter G2A and G2C
b) Seal Water Supply Filter G2B
~~Charging Pump Oil Coolers - Water Cooled~~
d) Charging Pump Oil Coolers - Water Cooled
e) Charging Pump Oil Coolers - Air Cooled

Dear Mr. Gallo:

The enclosed information is forwarded for your use in performing calculations to determine seismic capability of the subject equipment. Should you require further information, please contact Rick Gold at (213) 807-2466.

Very truly yours,

BECHTEL POWER CORPORATION

A handwritten signature in dark ink, appearing to read "John Duffin". The signature is fluid and cursive, with a long horizontal stroke extending to the right.
J. D. Duffin
Project Engineering Manager

RKG:jem/1925L

Enclosure: 1. Summary of Equipment Data
Transmittal to Impell
2. Equipment Data

cc: A. R. Guerrero
W. L. Nelson
G. W. Gartland
All with Enclosure 1 only

Ref [1]

ENCLOSURE 1

SUMMARY OF EQUIPMENT
DATA TRANSMITTAL TO IMPELL

Equipment No.	Description	Type of Data Provided
G-2A/2C	Seal Water Supply Filter	<ol style="list-style-type: none">1. Component weight, material, nozzle and vessel thickness and foundation information.2. Filter support information.3. Filter assembly dwg.4. Manufacturers' filter data.
G-2B	Seal Water Supply Filter	<ol style="list-style-type: none">1. Component weight, material, nozzle and vessel thickness and foundation information.2. Filter support information.3. Filter assembly dwg.4. Manufacturers' filter data.
E-34 ✓	Seal Water Heat Exchanger	<ol style="list-style-type: none">1. Component weight, material and nozzle and vessel thickness.2. Heat exchanger outline dwg.3. Heat exchanger support structure detail and pictorial (2 sheets).4. Structural support assembly (3 sheets).5. Manufacturers' equipment data.
N.A. ✓	Charging Pump Oil Coolers - (water cooled) for G8A and G8B	<ol style="list-style-type: none">1. Component weight, material, nozzle and vessel thickness, oil cooler outline dimensions and mounting and foundation details.
N.A	Charging Pump Oil Coolers - (air cooled) for G8A and G8B	Information not available.

SEAL WATER HEAT EXCHANGER E-34

1. WEIGHT

HX - DRY WT. 2515 #
HX - FLOODED WT. 3705 #

2. MATERIAL

HX - CARBON STEEL
BOLTS (ALL) - SA193 GR. 38
HX SADDLE - A36


3. NOZZLE AND VESSEL THICKNESS

	NOZZLE THICK.	VESSEL THICK.
3" NOZZLES	.12"	.375"
4" NOZZLES	.237"	.375"

ATTACHMENTS TO BECHTEL POWER CORP. LETTER
BPC/V-84-160, MARCH 30, 1984, FROM J.D. DUFFIN TO
W. D. GALLO (IMPELL), SUBJECT: SONGS-1, BECHTEL JOB
NO.: 15691-384 (INCLUDED IN JOB FILE)

WI 5/1/84


SEAL WATER HEAT EXCHANGER E-34
 SUPPORT STRUCTURE (ELEVATION VIEW)




SECTION A-A

SEAL WATER HEAT EXCHANGER E-34


HX SUPPORT STRUCTURE (PICTORIAL)



HX SADDLE X-SECTION





ITEM NO	NO REQ'D	PART NO	SIZE	DESCRIPTION	WT	ATSC	NOTES
A	2		R 1/2 X 7 X 0'-7" (SA-36)			X	
B	2		W 4 X 13 X 2'-0" (CUT TO SUIT) (SA-36)			X	
C	2		W 6 X 15.5 X 5'-2" (CUT TO SUIT) (SA-36)			X	
D	2		R 1/2 X 7 X 1'-0" (SA-36)			X	
E	2		R 1/2 X 7 X 1'-0" (SA-36)			X	
F	2		R 3/4 X 13 1/2 X 1'-1 1/2" (SA-36)			X	
G	B		1" Ø CONC. EXP BOLTS MIN EMBED = 4 1/2"				
H	B		3/4" Ø CONC EXP BOLTS MIN EMBED = 3 1/4"				
J	1		W 6 X 15.5 X 5'-10" (SA-36) (CUT TO SUIT)			X	
K	1		R 1/2 X 7 X 0'-8" (SA-36)			X	
L	1		R 3/4 X 13 1/2 X 1'-1 1/2" (SA-36)			X	
M	4		1" Ø CONC. EXP. BOLTS MIN EMBED = 4 1/2"				



0	ISSUE FOR CONSTRUCTION	5/13/72	FSM	4/16/72	156	for CM	
NO.	REVISIONS	DATE	DR.	CHK.	EGS.		PE CAE.
BECHTEL POWER CORPORATION DOWNEY, CALIFORNIA		I.G. NO.		SAN ONOFRE NUCLEAR GENERATING STATION			
		FILE		PIPE SUPPORT ASSEMBLY			
ISS. NO. 14000-300	DATE NA	APPROVED NA		SOUTHERN CALIFORNIA EDISON COMPANY SCALE: NTS LOS ANGELES, CALIF.			

ITEM NO.	NO REQ'D	PART NO	SIZE	DESCRIPTION	WF	AISC	NOTES
N	1		W4X13X3'-0" (CUT TO SUIT) (SA-36)			X	
P	1		W4X13X4'-0" (CUT TO SUIT) (SA-36)			X	
Q	1		R 3/4 X 16 X 1'-4" * (SA-36)			X	
R	8		1" Ø CONC EXP. BOLTS MIN EMBED. 4 1/2"				
S	1		R 1/2 X 5 X 0'-5" (SA-36)			X	
T	2		W4X13X2'-3" (SA-36)			X	
U	2		R 5/8 X 10 X 0'-10" (SA-36) *			X	
* SEE SHEET 1 FOR NOTE							



LOCATION PLAN
AREA NO.

DESIGN CODE		TYPE		
PROJ CL	PIPE	SR		MAX. TEMP
QUAL CL	STEEL	X	Y	Z
DESIGN	M			
	(PT-LOG)			
	P			
	(LOG)			

PROG. NO. _____ FT. NO. _____
SPOOL NO. _____

REF. DWGS. { NO. _____
PIPE _____
STEEL _____

SECTION A-A


NOTE:- FOR EAST LEG.

TAG NO. _____ SH. 2 OF 3


NO.	REVISIONS	DATE	DR	CHK	EGS	RE	QAE
BECHTEL POWER CORPORATION BORWALK, CALIFORNIA		I.O. NO. _____		SAN ONOFRE NUCLEAR GENERATING STATION			
JOB NO. 100-300		DATE NA		APPROVED NA		FILE _____	
SCALE: NTS		SOUTHERN CALIFORNIA EDISON COMPANY LOS ANGELES, CALIF.					

35
4

ITEM NO.	NO. RECD.	PART NO.	SIZE	DESCRIPTION	QTY	AISC	NOTES



SECTION A-A
NOTE:-FOR WEST LEG



LOCATION PLAN
AREA NO.

DESIGN CODE		TYPE		
PROJ CL	PIPE			MAX. TEMP
QUAL CL	STEEL SR			▼
DESIGN		X	Y	Z
	M			
	WY-LOG			
	R			
	(LOG)			

PROJ. NO. _____ PT. NO. _____
SPOOL NO. _____

REF. DWGS. {
NO _____
PIPE _____
STEEL _____

TAG NO. SH. 3 OF 3

NO.	REVISIONS	DATE	DR.	CHK.	EGS.	PE.	O.A.E.

BECHTEL POWER CORPORATION BORWALK, CALIFORNIA			I.O. NO.	SAN ONDRE NUCLEAR GENERATING STATION			
			FILE	PIPE SUPPORT ASSEMBLY			
DES. NO. <u>14000-300</u>	DATE <u>NA</u>	APPROVED <u>NA</u>	SOUTHERN CALIFORNIA EDISON COMPANY LOS ANGELES, CALIF.				

REF [6]

File No. H2189-S1
Report No. 8783R

KWIK-BOLT

AVERAGE ULTIMATE TENSILE & SHEAR LOADS*

CONCRETE STRENGTH		2000 PSI		4000 PSI		6000 PSI	
Diameter	Embedment	Tension	Shear	Tension	Shear	Tension	Shear
1/4"	1 1/8"	975	1653	1455	2612	1755	2389
	1 1/2"	1875	1653	2225	2612	2935	2389
	1 3/4"	2275	1653	2700	2612	3300	2389
	2"	2525	1653	3125	2612	3350	2389
	2 1/4"	2680	1653	3310	2612	3350	2389
	2 1/2"	2800	1653	3350	2612	3350	2389
3/8"	1 5/8"	2245	3748	2355	5107	2810	6266
	2"	2725	3748	3025	5107	3650	6266
	2 1/2"	3075	3748	3900	5107	4450	6266
	3"	3300	3792	4300	5419	5000	6266
	3 1/2"	3425	3792	4600	5419	5275	6266
	4"	3520	3792	4750	5419	5375	6266
	4 1/2"	3580	3792	4800	5419	5400	6266
1/2"	2 1/4"	4545	7444	5510	8316	6845	9341
	2 3/4"	5800	7444	7200	8316	9800	9341
	3 1/2"	7000	7444	9450	8316	13200	9341
	4 1/2"	7275	8897	11225	10232	14550	11522
	5 1/2"	8250	8897	12050	10232	15150	11522
	6"	9000	8897	12300	10232	15300	11522

Actual Concrete Strengths

2178 psi 4027 psi 6119 psi

*See sheet A-3 for notes

A-1

ABBOT A. HANKS, TESTING LABORATORIES, SAN FRANCISCO, CA. 94107

REF [6]

KWIK-BOLT

AVERAGE ULTIMATE TENSILE & SHEAR LOADS*

CONCRETE STRENGTH		2000 PSI		4000 PSI		6000 PSI	
Diameter	Embedment	Tension	Shear	Tension	Shear	Tension	Shear
5/8"	2 3/4"	5410	11198	6600	11562	7700	13500
	3 1/2"	6250	11198	9100	11562	9560	13500
	4 1/2"	7000	11198	12000	11562	14500	13500
	5 1/2"	7550	13378	14300	15437	20300	15437
	6 1/2"	8025	13378	16000	15437	21000	15437
	7 1/2"	9000	13378	17000	15437	21000	15437
3/4"	3 1/4"	8155	13257	10150	17133	10860	18102
	4"	9700	13257	13400	17133	13700	18102
	5"	11700	13257	16500	17133	17600	18102
	6"	13800	15195	18000	18466	22500	21009
	7"	15800	15195	21000	18466	23600	21009
	8"	16000	15195	23000	18466	23600	21009
	9"	16000	15195	23500	18466	23600	21009
1"	4 1/2"						
	5"						
	6"						
	7"						
	8"						
	9"						

Actual Concrete Strengths

2178 psi 4027 psi 6119 psi

*See sheet A-3 for notes

A-2

ABBOT A. HANKS, TESTING LABORATORIES, SAN FRANCISCO, CA. 94107

REF [6]



CORPORATE HEADQUARTERS

P.O. BOX 45400, TULSA, OK 74145, (918) 627-9711

REVISED

**1" DIAMETER HILTI KWIK-BOLT AVERAGE
ULTIMATE TENSILE AND SHEAR LOADS**

ANCHOR EMBEDMENT DEPTH (INCHES)	CONCRETE STRENGTH					
	2000 PSI		4000 PSI		6000 PSI	
	ULTIMATE TENSION	ULTIMATE SHEAR	ULTIMATE TENSION	ULTIMATE SHEAR	ULTIMATE TENSION	ULTIMATE SHEAR
4½	14000	27355	16000	26879	20500	32112
5	15500	27355	18900	26879	23441	32112
6	17600	27355	23441	26879	23441	32112
7	18200	27355	23441	26879	23441	32112
8	18200	27355	23441	34491	23441	36394
9	18200	27355	23441	34491	23441	36394
10	18200	27355	23441	34491	23441	36394

NOTE: The maximum working loads should not exceed ¼ of the average ultimate values listed. Actual factor of safety to be used depends on the application.

ACTIONS ON SUPPORTS AND ANCHORS

ME101/J5

DATE 031684

PAGE 109

TITLE : CHEM VOL CONTROL SYSTEM

PROJECT NUMBER : 15691-300

PROBLEM NUMBER : CVCS-11

USER : KHICIGANI

LOAD CASE : THRM1

GLOBAL FORCES (LB)

GLOBAL MOMENTS (FT-LB)

DATA PT	TYPE	TITLE	FX	FY	FZ	MX	MY	MZ
5	ANC	PENETR. E-8	81.	72.	0.	-253.	153.	84.
47	RAD		-40.	0.	0.	0.	0.	0.
47	RAD		0.	0.	-3.	0.	0.	0.
60	RAD		0.	-68.	0.	0.	0.	0.
60	RAD		0.	0.	-104.	0.	0.	0.
75	RAD		-31.	0.	0.	0.	0.	0.
75	RAD		0.	-17.	0.	0.	0.	0.
78	RAD		-12.	0.	0.	0.	0.	0.
78	RAD		0.	16.	0.	0.	0.	0.
80	RAD		3.	0.	0.	0.	0.	0.
80	RAD		0.	-4.	0.	0.	0.	0.
81	RAD		0.	14.	0.	0.	0.	0.
81	RAD		1.	0.	0.	0.	0.	0.
83	RAD		-9.	0.	0.	0.	0.	0.
83	RAD		0.	-1.	0.	0.	0.	0.
84	RAD		82.	0.	0.	0.	0.	0.
85	RAD		0.	3.	0.	0.	0.	0.
86	RAD		-131.	0.	0.	0.	0.	0.
86	RAD		0.	-15.	0.	0.	0.	0.
88	RAD		-3739.	0.	0.	0.	0.	0.
88	RAD		0.	1.	0.	0.	0.	0.
90	RAD		3790.	0.	0.	0.	0.	0.
90	RAD		0.	43.	0.	0.	0.	0.
97	RAD		26.	0.	0.	0.	0.	0.
97	RAD		0.	0.	65.	0.	0.	0.
105	RAD		-64.	0.	0.	0.	0.	0.
105	RAD		0.	-17.	0.	0.	0.	0.
137	RAD		112.	0.	0.	0.	0.	0.
137	RAD		0.	0.	41.	0.	0.	0.
154	RAD		0.	0.	-2.	0.	0.	0.
175	ANC		64.	-22.	-19.	-0.	-2.	8.
237	RAD		-10.	0.	0.	0.	0.	0.
260	ANC		0.	0.	0.	0.	0.	0.
290	ANC		116.	41.	-64.	-30.	-10.	7.
367	RAD		-106.	0.	0.	0.	0.	0.

REF- [13]
P. 1 of 8

DATA	TYPE	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)		
			FX	FY	FZ	MX	MY	MZ
367	RAC		0.	-275.	0.	0.	0.	0.
610	ANC		39.	4.	38.	14.	53.	12.
463	ANC		17.	0.	0.	0.	0.	0.
463	RAD		0.	0.	4.	0.	0.	0.
470	RAD		-3.	0.	0.	0.	0.	0.
470	RAD		0.	-37.	0.	0.	0.	0.
487	RAD		-34.	0.	0.	0.	0.	0.
487	RAD		0.	0.	-484.	0.	0.	0.
505	ANC		-9.	294.	407.	-27.	-17.	-39.
718	RAD		-130.	0.	0.	0.	0.	0.
718	RAD		0.	0.	-57.	0.	0.	0.
740	ANC		124.	68.	39.	11.	80.	-155.
854	ANC		-88.	-126.	22.	-187.	52.	9.

REF [13]
p. 2 of 8

TITLE : CHEM VOL CONTROL SYSTEM
 PROJECT NUMBER : 15691-300
 PROBLEM NUMBER : CVCS-11
 USER : KHCIGANI
 LOAD CASE : SAPI

GLOBAL FORCES (LB)

GLOBAL MOMENTS (FT-LB)

DATA PT	TYPE	TITLE	FX	FY	FZ	MX	MY	MZ
5	ANC	PENETR. E-8	122.	59.	19.	147.	299.	206.
47	RAD		127.	0.	0.	0.	0.	0.
47	RAD		0.	0.	29.	0.	0.	0.
60	RAD		0.	66.	0.	0.	0.	0.
60	RAD		0.	0.	7.	0.	0.	0.
75	RAD		31.	0.	0.	0.	0.	0.
75	RAD		0.	19.	0.	0.	0.	0.
78	RAD		22.	0.	0.	0.	0.	0.
78	RAD		0.	15.	0.	0.	0.	0.
80	RAD		5.	0.	0.	0.	0.	0.
80	RAD		0.	3.	0.	0.	0.	0.
81	RAD		0.	1.	0.	0.	0.	0.
81	RAD		1.	0.	0.	0.	0.	0.
83	RAD		0.	0.	0.	0.	0.	0.
83	RAD		0.	0.	0.	0.	0.	0.
85	RAD		1.	0.	0.	0.	0.	0.
85	RAD		0.	0.	0.	0.	0.	0.
86	RAD		7.	0.	0.	0.	0.	0.
86	RAD		0.	0.	0.	0.	0.	0.
88	RAD		1.	0.	0.	0.	0.	0.
88	RAD		0.	2.	0.	0.	0.	0.
90	RAD		0.	0.	0.	0.	0.	0.
90	RAD		8.	1.	0.	0.	0.	0.
97	RAD		4.	0.	0.	0.	0.	0.
97	RAD		0.	0.	8.	0.	0.	0.
105	RAD		0.	0.	0.	0.	0.	0.
105	RAD		0.	1.	0.	0.	0.	0.
137	RAD		0.	0.	0.	0.	0.	0.
137	RAD		0.	0.	0.	0.	0.	0.
154	RAD		0.	0.	0.	0.	0.	0.
175	ANC		0.	0.	0.	0.	0.	0.
237	RAD		0.	0.	0.	0.	0.	0.
260	ANC		0.	0.	0.	0.	0.	0.
290	ANC		0.	0.	0.	0.	0.	0.
367	RAD		0.	0.	0.	0.	0.	0.

REF. [13]
 P. 3 of 8

GLOBAL FORCES (LB)

GLOBAL MOMENTS (FT-LB)

DATA PT	TYPE	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)		
			FX	FY	FZ	MX	MY	MZ
367	RAD		0.	0.	0.	0.	0.	0.
610	ANC		0.	0.	0.	0.	0.	0.
650	ANC		0.	0.	0.	0.	0.	0.
463	RAD		0.	0.	0.	0.	0.	0.
463	RAD		0.	0.	0.	0.	0.	0.
470	RAD		0.	0.	0.	0.	0.	0.
470	RAD		0.	0.	0.	0.	0.	0.
487	RAD		0.	0.	0.	0.	0.	0.
487	RAD		0.	0.	0.	0.	0.	0.
505	ANC		0.	0.	0.	0.	0.	0.
718	RAD		0.	0.	0.	0.	0.	0.
718	RAD		0.	0.	0.	0.	0.	0.
740	ANC		0.	0.	0.	0.	0.	0.
854	ANC		0.	0.	0.	0.	0.	0.

REF [13]
P. 4 of 8

ACTIONS ON SUPPORTS AND ANCHORS

ME101/J9

DATE 031684

PAGE 175

TITLE : CHEM VOL CONTROL SYSTEM

PROJECT NUMBER : 15491-300

PROBLEM NUMBER : CVCS-11

USER : KHOIGANI

LOAD CASE : WT1

GLOBAL FORCES (LBS)

GLOBAL MOMENTS (FT-LB)

DATA PT	TYPE	TITLE	FX	FY	FZ	MX	MY	MZ
47	RAD	PENETR. 1-8	-4.	-428.	4.	567.	-2.	140.
47	RAD		0.	0.	0.	0.	0.	0.
60	RAD		0.	-164.	0.	0.	0.	0.
60	RAD		0.	0.	-2.	0.	0.	0.
75	RAD		-10.	0.	0.	0.	0.	0.
75	RAD		0.	-97.	0.	0.	0.	0.
78	RAD		7.	0.	0.	0.	0.	0.
78	RAD		0.	-2.	0.	0.	0.	0.
80	RAD		-2.	0.	0.	0.	0.	0.
80	RAD		0.	-45.	0.	0.	0.	0.
81	RAD		0.	-30.	0.	0.	0.	0.
81	RAD		0.	0.	0.	0.	0.	0.
83	RAD		-0.	0.	0.	0.	0.	0.
83	RAD		0.	-34.	0.	0.	0.	0.
85	RAD		1.	0.	0.	0.	0.	0.
85	RAD		0.	-30.	0.	0.	0.	0.
86	RAD		-3.	0.	0.	0.	0.	0.
86	RAD		0.	-34.	0.	0.	0.	0.
88	RAD		1.	0.	0.	0.	0.	0.
88	RAD		0.	-27.	0.	0.	0.	0.
90	RAD		1.	0.	0.	0.	0.	0.
90	RAD		0.	-9.	0.	0.	0.	0.
97	RAD		3.	0.	0.	0.	0.	0.
97	RAD		0.	0.	7.	0.	0.	0.
105	RAD		-2.	0.	0.	0.	0.	0.
105	RAD		0.	-100.	0.	0.	0.	0.
137	RAD		44.	0.	0.	0.	0.	0.
137	RAD		0.	0.	8.	0.	0.	0.
146	RAD		0.	-176.	0.	0.	0.	0.
154	RAD		0.	0.	-12.	0.	0.	0.
175	ANC		-10.	-267.	-5.	3.	2.	-8.
237	RAD		-18.	0.	0.	0.	0.	0.
250	RAD		0.	-50.	0.	0.	0.	0.
269	ANC		0.	0.	0.	0.	0.	0.

REF [13]
P. 5 of 8

DATA PT	TYPE	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)		
			FX	FY	FZ	MX	MY	MZ
290	ANC		-31.	-70.	-4.	1.	-2.	1.
367	RAD		0.	0.	0.	0.	0.	0.
367	RAD		0.	-153.	0.	0.	0.	0.
610	ANC		10.	-111.	-46.	-100.	-133.	192.
650	ANC		22.	-220.	42.	10.	50.	205.
463	RAD		3.	0.	0.	0.	0.	0.
463	RAD		0.	0.	-9.	0.	0.	0.
470	RAD		10.	0.	0.	0.	0.	0.
470	RAD		0.	-189.	0.	0.	0.	0.
487	RAD		3.	0.	0.	0.	0.	0.
487	RAD		0.	0.	19.	0.	0.	0.
505	ANC		5.	-101.	1.	-64.	3.	10.
718	RAD		-0.	0.	0.	0.	0.	0.
718	RAD		0.	0.	2.	0.	0.	0.
740	ANC		-3.	-19.	0.	2.	2.	34.
854	ANC		22.	-166.	2.	-114.	-19.	1.

REF [13]
 p. 6 of 8

ACTIONS ON SLPPCRTS AND ANCHRS

ME101/J5

DATE 031684

PAGE 384

TITLE : CHEM VOL CONTROL SYSTEM
 PROJECT NUMBER : 15491-300
 PROBLEM NUMBER : CVCS-11
 USER : KHCIGANI
 LOAD CASE : SEISI

GLOBAL FORCES (LB)

GLOBAL MOMENTS (FT-LB)

DATA PT	TYPE	TITLE	FX	FY	FZ	MX	MY	MZ
5	ANC	PENETR. E-8	253.	187.	278.	320.	309.	213.
47	RAD		112.	0.	0.	0.	0.	0.
47	RAD		0.	0.	57.	0.	0.	0.
60	RAD		0.	91.	0.	0.	0.	0.
60	RAD		0.	0.	67.	0.	0.	0.
75	RAD		146.	0.	0.	0.	0.	0.
75	RAD		0.	93.	0.	0.	0.	0.
78	RAD		100.	0.	0.	0.	0.	0.
78	RAD		0.	68.	0.	0.	0.	0.
80	RAD		42.	0.	0.	0.	0.	0.
80	RAD		0.	20.	0.	0.	0.	0.
81	RAD		0.	13.	0.	0.	0.	0.
81	RAD		17.	0.	0.	0.	0.	0.
83	RAD		24.	0.	0.	0.	0.	0.
83	RAD		0.	15.	0.	0.	0.	0.
85	RAD		37.	0.	0.	0.	0.	0.
85	RAD		0.	13.	0.	0.	0.	0.
86	RAD		173.	0.	0.	0.	0.	0.
86	RAD		0.	16.	0.	0.	0.	0.
88	RAD		29.	0.	0.	0.	0.	0.
88	RAD		0.	23.	0.	0.	0.	0.
90	RAD		18.	0.	0.	0.	0.	0.
90	RAD		0.	35.	0.	0.	0.	0.
97	RAD		104.	0.	0.	0.	0.	0.
97	RAD		0.	0.	259.	0.	0.	0.
105	RAD		43.	0.	0.	0.	0.	0.
105	RAD		0.	70.	0.	0.	0.	0.
137	RAD		125.	0.	0.	0.	0.	0.
137	RAD		0.	0.	91.	0.	0.	0.
154	RAD		0.	0.	184.	0.	0.	0.
175	ANC		237.	206.	71.	13.	9.	74.
237	RAD		59.	0.	0.	0.	0.	0.
260	ANC		43.	20.	109.	60.	23.	11.
290	ANC		66.	40.	24.	8.	3.	3.
367	RAD		99.	0.	0.	0.	0.	0.

REF [13]
 p. 7 of 8

DATA PT	TYPE	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)		
			FX	FY	FZ	MX	MY	MZ
367	PAD		0.	75.	0.	0.	0.	0.
610	ANC		59.	52.	107.	52.	195.	96.
650	ANC		12.	102.	146.	56.	187.	94.
463	RAD		172.	0.	0.	0.	0.	0.
463	FAD		0.	0.	128.	0.	0.	0.
470	PAD		23.	0.	0.	0.	0.	0.
470	RAD		0.	184.	0.	0.	0.	0.
487	RAD		37.	0.	0.	0.	0.	0.
487	RAD		0.	0.	261.	0.	0.	0.
505	ANC		31.	47.	157.	35.	12.	51.
718	PAD		0.	0.	0.	0.	0.	0.
718	RAD		0.	0.	18.	0.	0.	0.
740	ANC		18.	9.	10.	4.	15.	17.
854	ANC		26.	82.	80.	57.	16.	4.

REF [13]
p. 8 of 8

Memorandum

File: 0310-036-1356

To: SUSAN CHAO, RAYMOND Hsu


Copy:

From: WARD INGLES


Date: MAY 21, 1984

Subject: SCE EQUIPMENT WALKDOWNS, AUX FW DUMP (G-109)
SEAL WATER HX (E-34)

ATTACHED ARE WALKDOWN NOTES + PHOTOS FOR THE
SUBJECT EQUIPMENT. PLEASE LET ME KNOW
IF ADDITIONAL DATA IS REQUIRED




AUX. FW PUMP
G-105




AUX. FW. PUMP
G-105

THE PUMP'S SKID LOOKS LIKE :




ALSO ATTACHED ARE THE PUMP DRAWINGS WITH
THE REQUESTED DIMENSIONS INDICATED 006

					RFI #006			
					AUX FW PUMP G-105			
					JOB NO		PAGE	
					CALC NO		1	
REV	BY	DATE	CHECKED	DATE			OF	
	DJP	5-16-84	WTW	5/16/84			3	

Pacific Pumps, Inc. Dwg # FC-42768

PLAN

2/3




21"

7.64"

RFI #006
BY: QJP 5-16-84
CHK: WJW 5/16/84

RFI #006
H. POP 5-1-68
CHK: MTW/SLH




ELEVATION

Pacific Pumps, Inc. DWG # FC-42768


APPENDIX D
SHEET 4 OF 4

3/3




					RFI #006			
							E-34	
REV	BY	DATE	CHECKED	DATE	IMPELL CORPORATION		JOB NO	PAGE
	DJA	5-14-84	UJW	5/15/84	CORPORATION		CALC NO	1
								OF
								2

FRAME A DETAILS




4 BOLTS
 NUT SIZE = 1 1/2" FLAT TO FLAT
 3/4" THICK PLATE




THIS STUD IS BENT
 BOTTOM/LEFT



4 BOLTS
 NUT SIZE = 1 1/2" FLAT TO FLAT
 3/4" THICK PLATE



4 BOLTS
 NUT SIZE = 1 1/2" FLAT TO FLAT
 3/4" THICK PLATE
 THIS BOLT IS OFF LINE 3 1/2" FROM
 BOTTOM; 2" FROM SIDE - BOTTOM/RIGHT



4 BOLTS
 NUT SIZE 1 1/2" FLAT TO FLAT
 3/4" THICK PLATE

					RFI # 006			
					E-34			
REV	BY	DATE	CHECKED	DATE	IMPELL CORPORATION		JOB NO	PAGE
	DJP	5-14-84	WJH	5/15/84	CORPORATION		CALC NO	2
								OF
								8

FRAME A, DETAIL 1 AND 2


CHANNEL WELDED TO PLATE ALL AROUND
HYPOTENUSE OF WELD = 3/8"

PLATE WELDED TO CHANNEL AT CONTACT LINES. Hypotenuse of weld = 3/8"


PLATE 7" WIDTH (ACROSS CHANNEL) X 16 1/2" LENGTH (ALONG CHANNEL) X 1/2" THICKNESS

ANGLE WELDED TO CHANNEL

WELDED ALL AROUND THIS SIDE OF PLATE ONLY



WELDED TO PLATE BOTH SIDES ALL ALONG CONTACT LINE



1/2" THICK WELDED TO CHANNEL AND WIDE FLANGE

WELDED ALL AROUND EXCEPT AREAS WITH SHARP ANGLES BETWEEN WIDE FLANGE & PLATE





PLATE WELDED TO CHANNEL

TO FLOOR = 37"

NOTE: A 3X3 ANGLE IRON PIPE SUPPORT RESTS ON CHANNEL 6" OUT FROM WALL 3 GUIDES SUPPORTING 3 PIPES ARE SUPPORTED OFF OF THIS ANGLE (FRAME A ONLY)

					RFI #006			
					E-34			
REV	BY	DATE	CHECKED	DATE	JOB NO		PAGE	
	JJP	5-14-84	WJW	5/15/84	CALC NO		3 OF 8	

FRAME B



- ①' = ① FRAME A
- ②' = ② FRAME A
- ⑤' = ⑤ FRAME A
- ⑥' = ⑥ FRAME A
- ①' = ① FRAME A
- ②' = ② FRAME A
- ③' = ③ FRAME A
- ④' = ④ FRAME A
- ⑤' = ⑤ FRAME A
- ⑥' = ⑥ FRAME A
- A' = A FRAME A
- B' = B FRAME A
- C' = C FRAME A
- D' = D FRAME A
- H' = H FRAME A

ALL SIMILAR DIMENSIONS FROM FRAME A TO FRAME B ARE THE SAME



DISTANCE BETWEEN ⑤ FRAME A ; ⑤' FRAME B = 100'

FRAME B

					RFI # 006			
					E-34			
REV		BY	DATE	CHECKED	DATE	JOB NO		PAGE
		DJP	5-14-84	W.S.W	5/15/84	CALC NO		4
						IMPELL CORPORATION		8


FRAME B DETAILS

E' = 41" LONG CHANNEL



2 ANCHOR BOLTS 1" FROM
FLAT TO FLAT (SIZE)
CHANNEL WELDED TO
PLATE ALL AROUND.

(F) = 6 X 6 1/4" WIDE FLANGE AS H'




4 BOLTS NOT SIZE = 1 1/2"
FLAT TO FLAT.

MEMBER F' CONNECTS TO CHANNEL A' AT TOP
WITH A PLATE BETWEEN. E' IS WELDED TO
THE PLATE; THE PLATE IS WELDED TO THE
CHANNEL. THIS PLATE IS 13" X 7 1/2" X 1/2"
AND IS OFFSET UP ABOVE THE CHANNEL 2".


NOTE: A 2X2 ANGLE IRON PIPE SUPPORT IS ATTACHED
TO MEMBER E'. IT IS LOCATED 11" ALONG
E' FROM CHANNEL A'.
THIS PIPE GUIDE SUPPORT IS IDENTIFIED W/
SUPPORT # 51-08-2028-H002

THERE IS ALSO 1 PIPE SUPPORT ATTACHED TO
THE CHANNEL A' NEAR BASE PLATE (1')


					RFI = 006				
					E-34				
REV	BY	DATE	CHECKED	DATE				JOB NO CALC NO	PAGE 5 OF 8
	QDP	5-14-84	WIN	5/15/84					




FRAME A: MEMBERS
E, F, D, H (FOREGROUND)



FRAME A: DETAIL OF
CHANNEL D SUPPORT
AT FLOOR



FRAME A: DETAIL 1 AS
SHOWN IN SKETCH (B & C)




FRAME A: DETAIL
OF SADDLE PLATE
(TYPICAL OF FRAME B)


					RFI # 006			
					SEAL WATER HEAT EXCHANGER E-34			
400P		5-14-84	WJW	5/15/84	JOB NO		PAGE	
REV	BY	DATE	CHECKED	DATE	CALC NO		6 OF 8	




FRAME A: SHOWING CONN
OF B & C FROM BACK. NO WELDS




FRAME B:




FRAME B



FRAME B


					RFI #006		
					E-34		
					JOB NO		PAGE
					CALC NO		7
REV	BY	DATE	CHECKED	DATE			8
	QJP	5-14-84	WJW	5/15/84			



BOLT = 1 1/8" ANCHOR BOLT

SADDLE DETAIL TYPICAL

SEE ALSO PHOTO'S

					RFI #006			
					E-34			
						JOB NO		PAGE
						CALC NO		8
REV	BY	DATE	CHECKED	DATE			OF 8	
	ADP	5-14-84	WJW	5/15/84				

Memorandum

File: 0310-036-1356

To: JOB FILE 0310-036-1356

Copy: S. J. CHAO (W/D)
W. R. BAK
R. C. HOM

From: WARD INGLES

Date: MAY 7, 1984

Subject: SCE / SONGS-1 EQUIPMENT WALKDOWNS.

ATTACHED ARE WALKDOWN NOTES AND PHOTOS FOR THE FOLLOWING EQUIPMENT ITEMS:


- SEAL WATER HEAT EXCHANGER (E-34)
- CHARGING PUMPS (GBA, B)
- CHARGING PUMP OIL COOLER (WATER COOLED)
- CHARGING PUMP OIL COOLER (AIR COOLED)

THIS INFORMATION WAS OBTAINED BY DONNA POWELL AND JIM WAGONER ON MAY 4, 1984.

Equipment Walkdowns 5/4/84 BY: DGP 5/4/84
CKD: WJW 5/4/84

• Seal Water Heat Exchanger E-34:


Modifications have been completed
see photo below to show bracing



SEAL WATER HEAT EXCHANGER

SEAL WATER HEAT EXCHANGER

• Charging Pumps G8A ; G8B



CALCULATION SHEET

APPENDIX D

158

CALC. NO. AC-1

JRE Joseph A. Ayre DATE 6/22/81

CHECKED AK DATE 2/11/82

ECT SONGS-1

JOB NO. 14000-165

SUBJECT AVY. COOLANT FROM E-34 TO 3037-14"-152N


SHEET 1 OF 3 SHEETS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35

3.4 SUMMARY OF NOZZLE LOADS

B-1
AS-BUILT CONDITION

Orientation of nozzle and component



EQUIPMENT	NODE POINT	DIRE	LOADING CONDITIONS				TOTAL \pm	RESULTANT	ALLOWABLE*
			DW	T _H	SSE	SAM			
Seal Water HT. EXCH. E-34 LINE NO. 3093-4-152N OUTLET	120	Fx	-3	439	± 34		476	1872	
		Fy	-26	1775	± 9		1810		
		Fz	0	-11	± 60		71		
		Mx	-3	0	± 27		30		
		My	-17	4	± 176		197		
		Mz	8	-1472	± 91		1561		
		Fx							
		Fy							
		Fz							
		Mx							
		My							
		Mz							

*Ref:

EXCERPTED FROM [9]

to find out if modified or not.

CALCULATION SHEET

APPENDIX D
CALC. NO. Ac 160/02

J. Hoch

DATE 7-1-81

CHECKED Ac DATE 2/11/82

SONGS-1

JOB NO. 14000-165


SUBJECT _____

SHEET 74 OF 3 SHEETS

3.4 SUMMARY OF NOZZLE LOADS

AS-BUILT CONDITION B-3

Orientation of nozzle and component



EQUIPMENT	NODE POINT	DIRE	LOADING CONDITIONS				TOTAL	RESULTANT	ALLOWABLE*
			DW	T _H	± SSE	SAM			
SEAL WATER HEAT EXCH. (E-34) LINE NO. 305B-4-152N (INLET)	175	F _x	22.	.69.	119.		210. (LE)	956.	
		F _y	116.	173.	419.		708		
		F _z	-77.	93.	530.		-607		
		M _x	-42.	58.	262.		-304 (RT-LE)		
		M _y	-106.	151.	632.		-738		
		M _z	-93.	-212.	392.		-697		
		F _x							
		F _y							
		F _z							
		M _x							
		M _y							
		M _z							

*Ref: See calc. on 3.4.1 (pp. 15 & 16).

EXCERPTED FROM
[9]

Ref. [10] p. 1 of 5

0310-036-1356



WESTERN REGION TELECOPY

350 LENNON LANE WALNUT CREEK, CA 94598

AUTOMATIC TELECOPY: 415/943-4521

CENTRE POINTE TELECOPY: 415/943-4885

SWITCHBOARD/VERIFICATION: 415/943-4500

TO: COMPANY: SCE
ATTENTION OF: PIUS KAO X59359
SUBJECT(S): _____

FROM: NAME: WARD INGLES EXT. 720
DATE: 6/13/84
JOB NUMBER: 0310-036-1356
NUMBER OF FOLLOWING PAGES: 4

INSTRUCTIONS/COMMENTS: TELETYPE NO 714-492-7700
X 56157
X 1303

[0], p 2 of 5

REQUEST FOR FIELD DIMENSIONS FOR SEAL WATER HEAT EXCHANGER, E-24


NOTE: THE EXCHANGER IS LOCATED ON A STEEL FRAME ON THE NORTH WALL OF THE CHARGING PUMP ROOM. THE EXCHANGER IS BEHIND A "HIGH RAD" ROPE.

DIMENSIONAL DATA IS NEEDED FOR THREE BASE PLATES ATTACHED TO THE WALL. THE LOCATIONS OF THE BASE PLATES ARE ON THE NORTH WALL AND ARE SHOWN IN THE SKETCH ON THE FOLLOWING PAGE.

THE INFORMATION NEEDED CAN BE PROVIDED BY FILLING IN THE BLANKS ON THE FOLLOWING PAGES

REV	BY	DATE	CHECKED	DATE			JOB NO 0310-036 CALC NO PAGE 1 OF 4

EDSGAP MODEL OF SEAL WATER HEAT EXCHANGER - E-34



REV	BY	DATE	CHECKED	DATE		JOB NO 0312-026 Dwg No ED-06	PAGE OF 2 4
0	WI	6/5/84					

• SKID, WEIGHT = 1700 lb

THE SKID IS OBVIOUSLY RIGID IN THE RANGE OF SEISMIC LOADS,

$$\therefore a_H = .67g$$

$$a_v = \frac{2}{3}(.67g) = .45g$$

THE MAXIMUM SHEAR LOADS GENERATED BY THE SKID WILL BE:

$$F_x = F_z = (.67g)(1700 \text{ lb}) \\ = 1140 \text{ lb}$$

UPLIFT:


$a_v = \pm .45g$, \therefore UPLIFT WILL NOT OCCUR, THE DOWNWARD VERTICAL LOAD WILL RESIST THE UPLIFT/OVERTURNING LOADS APPLIED TO THE PUMP + MOTOR.

$$F_y = (1.0 - .45)g \cdot 1700 \text{ lb} = -935.1 \text{ lb}$$

OVERTURNING MOMENTS

ASSUME THE CG OF THE SKID IS AT ITS GEOMETRIC CENTER.

\therefore THE CG IS 3" (HALF OF THE 6" CHANNEL) ABOVE THE BASE



$$M_x = M_z = 3" (F_x) = 3" (1140 \text{ lb}) = 3420 \text{ in}\cdot\text{lb}$$


0	WI	6/29/84	AS	7/10/84		JOB NO 0310-036	PAGE 29
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-09	OF 36

IMPELL CORPORATION

TOTAL LOADS @ FOUNDATION BOLTS

LOAD	MOTOR		PUMP			SKID SEISMIC/DW	TOTAL
	SEISMIC	DEAD	SEISMIC	DEAD	NOZZLE		
F _x	5513	-	9954	-	1042	1140	17,650.
F _y	3675	-5250	6636	-9480	3273	-935	-2080.
F _z	5513	-	9954	-	4335	1140	20,950
M _x	132,300	-	2.39 × 10 ⁵	-	2.50 × 10 ⁵	3420	625 × 10 ⁵
M _y	0	-	0	-	9768	0	9768.
M _z	132,300	-	2.39 × 10 ⁵	-	4.43 × 10 ⁴	3420	4.19 × 10 ⁵


- LOADS ARE COMBINED BY ASUM (EXCEPT FOR DEAD WT.)
- TORSIONAL MOMENT (M_y) IS NEGLIGIBLE
- RESULTANT SHEAR = $\left[(17,650 \text{ lb})^2 + (20,950 \text{ lb})^2 \right]^{1/2}$
= 27,400 lb

REV	0
BY	WTE
DATE	6/29/87
CHECKED	WJ
DATE	7/13/87
	
JOB NO	0310-036
CALC NO	EQ-09
PAGE	30
OF	36

TENSILE BOLT LOAD:

ASSUME OVERTURNING MOMENTS ABOUT CENTROID OF BOLT GROUP.

M_x :



$$M_x = 2(2F_2 \cdot 41'') + 2(2F_1 \cdot 82'')$$

$$= 4F_2 \cdot 41'' + 4F_1 \cdot 82''$$


$$F_2 = F_1/2$$

$$M_x = 4(F_1/2) \cdot 41'' + 328'' \cdot F_1$$

$$= 410'' \cdot F_1$$

$$F = M_x / 410''$$

M_z



$$M_z = SF(36'')$$

$$= 180'' \cdot F$$

$$F = M_z / 180''$$

$$\therefore f_{bc} = \frac{M_x}{410 \text{ in}} + \frac{M_z}{180 \text{ in}} + \frac{F_y}{4}$$

$$= \frac{6.25 \times 10^5 \text{ in} \cdot \text{lb}}{410 \text{ in}} + \frac{4.19 \times 10^5 \text{ in} \cdot \text{lb}}{180 \text{ in}} - \frac{2080 \text{ lb}}{10 \text{ bolts}}$$

$$= 3644 \text{ lb/bolt}$$

0	WT	6/29/84	CS	7/13/84		JOB NO 0310-036	PAGE 31
REV	BY	DATE	CHECKED	DATE		CALC NO EQ-09	OF 36

ALLOWABLE BOLT LOAD

TO DETERMINE THE ACTUAL ALLOWABLE ANCHOR BOLT PULLOUT WOULD REQUIRE MORE DETAILS ABOUT THE AS-BUILT CONFIGURATION THAN ARE PRESENTLY AVAILABLE. THEREFORE THE BOLTS WILL BE ASSUMED TO BE HILTI-KWIK-BOLTS [8]

FOR 5/8" DIAMETER BOLTS THE MAXIMUM EMBEDMENT TABULATED IN THE LOAD DATA IS 7 1/2" (COMPARED TO THE ACTUAL 1'-1 1/2"). THE CONCRETE STRENGTH IS ASSUMED TO BE 4000psi. THE AVERAGE ULTIMATE PULLOUT IS: 17000lb, APPLYING A SAFETY FACTOR OF 4.0.

$$F_{bE} = \frac{17000 \text{ lb}}{4.0} = 4250 \text{ lb}$$

$$F_{bE} < F_{bC}$$

$$3644 < 4250$$

∴ FOUNDATION BOLTS QUALIFY.

0	WE	6/29/84	CS	7/13/84	IMPELL CORPORATION				JOB NO 0210-036 CALC NO EQ-09	PAGE 32 OF 36
REV	BY	DATE	CHECKED	DATE						

NOTE ON SHEAR

THE RESULTANT SHEAR FORCE IS:

$$FV = 27,400 \text{ lb}$$

THE CROSS-SECTIONAL AREA OF THE GROUT/CONCRETE INTERFACE IS:


$$A \approx (3') (14' - 8'') \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right)$$

$$\approx (3') (14.6') (144 \text{ in}^2/\text{ft}^2) = 6300 \text{ in}^2$$

∴ THE REQUIRED SHEAR STRENGTH OF THE GROUT/CONCRETE INTERFACE (NEGLECTING FRICTIONAL EFFECTS) IS:


$$FV_{\text{REQ}} = \frac{27,400 \text{ lb}}{6,300 \text{ in}^2} = 4.3 \text{ psi}$$

THIS REQUIRED STRENGTH IS VERY LOW, ∴ INTERFACE IS ADEQUATE.

0	WI	6/29/84	CS	7/13/84		JOB NO 0310-036	PAGE 33 OF 36
REV	BY	DATE	CHECKED	DATE		CALC NO	

9.0 BASE CHANNEL

THE TENSILE LOAD IN THE ANCHOR BOLTS IS DISTRIBUTED INTO THE CHANNEL BY STEEL BLOCKS. (SEE [4] + [3])



FROM [4], THE BLOCK HAS A DEPTH OF 1 3/4" AND THE CHANNEL A TOTAL DEPTH OF 2". ∴ THE CHANNEL IS ASSUMED 1/4" THICK.

THE BLOCK WILL ELIMINATE BENDING IN THE FLANGE OF THE CHANNEL AND TRANSFER THE LOAD DIRECTLY TO THE WEB, WHERE IT WILL BE CARRIED AS AN AXIAL LOAD.

HOWEVER, AS A CONSERVATIVE CHECK THE FLANGE WILL BE MODELED AS A POINT LOAD [7], p. 188-190, ART. 7.11

REV	BY	DATE	CHECKED	DATE
0	WJ	6/29/84	CS	7/10/84



JOB NO 0310-036

CALC NO


EQ-04

PAGE

34

OF

36



$$\begin{aligned}
 a &= \text{FLANGE WIDTH} - \text{WEB THICKNESS} \\
 &= 2.00'' - .25'' \\
 &= 1.75''
 \end{aligned}$$

$$z = \text{BLOCK WIDTH} = 3.00''$$

$$c' = .75'' [3]$$

$$c = a - c' = 1.75 - .75 = 1.00''$$

$$\left. \begin{aligned}
 z/a &= 3.00/1.75 = 1.71 \\
 c/a &= 1.00/1.75 = .571
 \end{aligned} \right\} K_m \approx .059 \text{ (MAX)}$$

$$\therefore \sigma_b \approx K_m \left(\frac{6P}{t^2} \right) \quad P = \text{BOLT LOAD} = 3644 \text{ lb}$$

$$= .059 \left(\frac{6 \cdot 3644 \text{ lb}}{(25 \text{ in})^2} \right)$$

$$= 20.6 \text{ ksi}$$

THIS CONSERVATIVELY CALCULATED STRESS IS LESS THAN THE LEVEL A ALLOWABLE FOR BENDING IN COMPACT SECTIONS (.66 · 36 = 23.76 ksi)

∴ BASE ANGLE QUALIFIES


0	WT	6/29/84	CS	7/13/84	JOB NO 0310-036	PAGE 35
REV	BY	DATE	CHECKED	DATE	CALC NO EQ-09	OF 36



10.0 SUMMARY.


COMPONENT	CALCULATED STRESS	ALLOWABLE STRESS	REMARKS
MOTOR HOLD DOWN BOLTS	.02 (INTERACTION)	1.0	OK, USING LEVEL A LIMITS
Pump Hold Down Bolts	.79 (INTERACTION)	1.0	OK, USING LEVEL A LIMITS
FOUNDATION ANCHOR BOLTS	3694 lb.	4250 lb	OK, F.S. = 4.0 NOTE 1
BASE CHANNEL	20.6 ksi	23.76 ksi	OK, USING LEVEL A ALLOWABLES

NOTE 1: FOUNDATION BOLTS ARE J-bolts WITH AN EMBEDMENT EXCEEDING 12". ALLOWABLE IS BASED ON EXPANSION BOLT WITH 7 1/2" EMBEDMENT IN 4000psi CONCRETE. RESULTS ARE CONSERVATIVE

0	WE	6/29/84	WB	7/13/84				
REV	BY	DATE	CHECKED	DATE				
						JOB NO	0310-036	PAGE 36 OF 36
						CALC NO	EQ-09	

APPENDIX A

REFERENCE DOCUMENTS

0	WE							
REV	BY	DATE	CHECKED	DATE			JOB NO 0312 036 CALC NO EQ-09	PAGE OF

Bechtel Power Corporation

Engineers - Constructors

12400 East Imperial Highway

Norwalk, California 90650

MAIL ADDRESS

P.O. BOX 60860 - TERMINAL ANNEX, LOS ANGELES, CALIFORNIA 90060

TELEPHONE: (213) 807-2000



March 23, 1984

BPC/V-84-156

ROUTE :

WDGALLO

RLGOMEZ

ASEIKEN

WRBAK

DGOMEZ

Mr. W. D. Gallo
Project Manager
Advanced Engineering
Impell Corporation
350 Lennon Lane
Walnut Creek, CA 94598


Subject: San Onofre Nuclear Generating Station, Unit 1
Bechtel Job No. 15691-384
Safe Shutdown Equipment Data

Dear Mr. Gallo:

The information indicated on attachment 1 is forwarded for your use in performing calculations to determine seismic capability of the equipment. If you require any additional information, please contact Rick Gold at (213) 807-2466.

Very truly yours,

BECHTEL POWER CORPORATION


J. D. Duffin
Project Engineering Manager

RKG:cwe/1925L

Attachment: 1. Summary of Equipment Data
transmitted to Impell
2. Equipment Data

cc: A. R. Guerrero
W. L. Nelson
G. W. Gartland
All with Attachment 1 only

REFERENCE [1] TO
IMPELL CALL NO EQ-09
JOB # 0310-036-1356

11C-384

ATTACHMENT 1

SUMMARY OF EQUIPMENT
DATA TRANSMITTAL TO IMPELL

Equipment No.	Description	Type of Data Provided
G-8A/B	Charging Pumps	<ol style="list-style-type: none"><li data-bbox="873 676 1409 735">1. Equipment weights and holddown bolt sizes.<li data-bbox="873 767 1409 825">2. Field sketch of holddown bolting pattern (3 sheets).<li data-bbox="873 864 1187 892">3. Pump data sheet.<li data-bbox="873 929 1333 987">4. Anchorbolt and foundation details.<li data-bbox="873 1026 1284 1084">5. Certified pump outline drawing.<li data-bbox="873 1123 1377 1149">6. Nozzle and vessel thickness.

CHARGING PUMPS G - 8A/B

EQUIPMENT WEIGHTS AND HOLDDOWN BOLT SIZES

EQUIPMENT DATA:

PUMP WT. = 9480. lbs.

MOTOR WT. = 5250. lbs.

BASE WT. = 1700. lbs.

TOTAL = 16430. lbs.

FND ANCHOR BOLTS = 10 - $5/8$ ϕ BOLTS.

PUMP BOLTS = 4 - 1 ϕ BOLTS.

MOTOR BOLTS = 4 - $1\frac{1}{2}$ ϕ BOLTS.

* NOTE:

BOLT DIAMETERS ARE OBTAINED FROM ACTUAL FIELD MEASUREMENTS AND SKETCHES OF THE BOLT HEADS.

PUMP HOLDDOWN BOLTS



FROM AISC 8th EDITION P. 4-136 → BOLT DIAM. = 1 "


MOTOR HOLDDOWN BOLTS



BOLT DIAM. = $1\frac{1}{2}$ "

FIELD SKETCH OF HOLD DOWN BOLTING PATTERN


1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36



CHARGING PUMPS

FIELD SKETCH OF HOLDDOWN BOLTING PATTERN


20F3



Charging Pumps

FIELD SKETCH OF HOLDDOWN BOLTING PATTERN


30F3



CHARGING 6 PUMPS

DATE		LIQUID PUMPED	3% Bor Acid
APPROVALS		FLOW: NORMAL/DESIGN _____ (GPM) (CHECKED)	136/213
BATL		FLOW TEMP/SPECIFIC GRAVITY WATER = 1.0	130 F/1.05 max.
SUPV		VISCOSITY (CEN) / VAPOR PRESS. (PSIA)	0.52 cp/2.3
CHK		PRESSURE: SUCTION/DISCHARGE _____ (PSIA)	115 max./2495 max.
DR		DIFFERENTIAL: FEET/PSI	5200/2300
ENG		NPSH: AVAILABLE/REQUIRED _____ (FT)	30/11
REV.		SERVICE	Charging
		SYSTEM	Chemical and Volume Control
		BHP/DRIVER HP/EFFICIENCY (AT RATINGS)	550/600/41 at 136 gpm
		IMPELLER DIAMETER: BID/MAX	10-1/8 / 10-1/4
		IMPELLER EYE: AREA/ENTRANCE VEL:	12.7 sq. in. / 4.36 ft/sec
		RPM/ROTATION (FACING COUPLING)	3570/CCW
		MAX. ALLOW WORK PRESS./NO. STAGES	2750#/12
		WEAR RING (OR IMPELLER) CLEARANCE	0.016 in. (Diametral)
		CASE MATERIAL : INNER/OUTER*	A351, CF8/A266, II, lined w/304 SS
		IMPELLER MATERIAL	A351/CF8
		WEAR RING MTL: CASE/IMPELLER	A336, F8M/A336, F8M w/Colmonoy #6
		SHAFT: MATERIAL/DIAMETER	A336, F8M/2-1/4 in.
		SHAFT SLEEVE MTL/EXTEND THRU GLAND?	A336, F8M/Yes
		COUPLING: TYPE/MANUFACTURER	Flexible/Thomas DBZ
		COUPLING GUARD REQUIRED?	Yes
		BASEPLATE: TYPE/MATERIAL	Drain Rim/Fabricated Steel
		SHAFT SEAL: TYPE/SEALING CONN?	Teflon Packing/Drain Conn.
		BEARINGS: TYPE: THRUST/RADIAL	True Kingsbury/Sleeve
		LUBRICATION: THRUST/RADIAL	Forced Feed with Pump, Strainer & Cooler
		SUCTION CONNECTION: SIZE/RATING/FACING (DOUBLE) (SINGLE)/POSITION	3"/Weld End Preparation Single/Top
		DISCHARGE CONNECTION: SIZE/RATING/FACING POSITION	2"/Weld End Preparation Top
		PUMP MANUFACTURER	Pacific Pumps, Inc.
		TYPE & SIZE	2" Type Z 12 Stages
		NET WEIGHT (PUMP ONLY)/SERIAL NUMBER	
		DRIVER MFG./PURN BY	Westinghouse/Pacific
		(MOTOR)(TURB.)/(INTEGRAL)(CPLD.)	Motor/Flexible Coupling
		SERIAL NUMBER/DRAWING REFERENCE	
		INSPECTION/HYDROSTATIC TEST?	Yes/Yes
		PERFORMANCE TEST?/WITNESSED?	Yes/Yes
		COST CODE	
		(XXXXXX)(XXXX) (SPEC NO)	E-Spec. No. 675229
		*Materials are specified by ASTM Number	
		Pump Weight	9480 lbs
		Driver Weight	5250 lbs
		Base Weight	1700 lbs
		Total Weight	16430 lbs

VPS-E32-12/90


BECHTEL CORPORATION

POWER DIVISION ENGINEERING

HORIZONTAL CENTRIFUGAL PUMP DATA SHEET
 CHARGING PUMPS, G-8A AND B

JOB No 3246
 San Onofre Nuclear Generating Station Unit No. 1

REV.

Anchor Bolt and Foundation Details APPENDIX C



SCALE 1/4" = 1'-0"

NOTE:

- FOR GENERAL NOTES SEE 320 86292
- FOR MISC. NOTES SEE 38-560123
- ANCHOR BOLT DIAMETER SPAC, BOUN BRUNT, HOLES & CONC. PAD SIZE & HEIGHT HAVE BEEN FIELD VERIFIED PER AS-BUILT CONDITION FOR SECT. 8/180, 8/180, 8/180, 8/180 & DET. 1/12, 9/12.

SECTION SEAL WATER FILTER SUPPORT
 *DETAIL 14
 SCALE 1/4" = 1'-0"

***NUCLEAR SAFETY RELATED (AS NOTED)**

UNIT 1

REV	DATE	BY	CHKD	APP'D	DESCRIPTION
1	12-20-50	JAC	JAC	JAC	ISSUED FOR CONSTRUCTION
2	1-15-51	JAC	JAC	JAC	REVISIONS
3	2-1-51	JAC	JAC	JAC	REVISIONS
4	2-1-51	JAC	JAC	JAC	REVISIONS
5	2-1-51	JAC	JAC	JAC	REVISIONS

LOCATION SAN ONOFRE NUCLEAR GEN. STATION
REACTOR AUXILIARY BUILDING
SECTIONS & DETAILS
SHEET 6
 SOUTHERN CALIFORNIA EDISON COMPANY
 SCALE AS NOTED SEE MODEL BILLS

CHARGING PUMP G-8A/B
NOZZLE AND VESSEL THICKNESS

NOZZLE THICKNESS VESSEL THICKNESS

1" NOZZLE	.18"	1.5"
2" NOZZLE	.4"	1.75"
3" NOZZLE	.3"	1.75"

Memorandum

File: 0310-036-1356

To: Ward Ingles

Copy:

From: Calvin Wong^{uw} / Jim Wagoner^{WJW}

Date: 6/13/84

Subject: Nozzle Loads for Charging Pumps G-8A & G-8B

Attached please find the following nozzle loads requested:

Lines 2022-1"-151R & 2084-1"-151R - Analysis CV-307 ✓

Lines 2000-3"-151R & 2001-3"-151R - Analysis CV-12

Lines 2002-2"-2501R & 2003-2"-2501R - Analysis CV-13

Note that for CV-13 data, the thermal loads should be taken from the rev.0 Bechtel load sheet attached. Gravity and seismic loads should be taken from the Impell summary sheet.

Also note that loads for CV-12 are preliminary at this time.

REF [4], CALC NO EQ-09

JOB NO 0310-036-1356

SIGNATURE A. SOLTANI

DATE 10-22-82

CHECKED Amh.tj

DATE 10-29-82

PROJECT SONGS-1


JOB NO 14000-300

SUBJECT CHEMICAL VOLUME CONTROL SYSTEM

SHEET 19 OF 37 SHEETS

3.4 SUMMARY OF NOZZLE LOADS

Orientation of nozzle and component



EQUIPMENT	NODE POINT	DIRE	LOADING CONDITIONS				TOTAL	RESULTANT	ALLOWABLE*
			DN	TH	SSE	SAY			
PUMP G-8A	5	Fx	1	-10	±5		15		
		Fy	-5	5	±3		8	→ 32.	Fr(max)=65
		Fz	0.	21	±6		27		
		Mx	2	-9	±2.		11		
		My	0.	-16	±2.		18.	→ 22.	Mr(max)=43
		Mz	-1.	0.	±1		2		
PUMP G-8B	105	Fx	0	-10.	±5		15		
		Fy	-5.	6.	±3.		9.	→ 32.	Fr(max)=65
		Fz	0.	19.	±7.		26.		
		Mx	2.	-8.	±2.		10		
		My	0.	-15.	±2.		17	→ 20.	Mr(max)=43
		Mz	-1.	0.	±1.		2		

*Ref: Bechtel guide lines P-2.6.1.11 & attached calculation pages


$$\frac{F_r}{F_{r(max)}} + \frac{M_r}{M_{r(max)}} = \frac{32}{65} + \frac{22}{43} = 1.004 > 1 \text{ @ } 5$$

Fx, Fy & Fz are in @
 Ms, My & Mz are in @

$$\frac{32}{65} + \frac{20}{43} = .96 < 1 \text{ @ } 105$$

RESULT SUMMARY - B) NOZZLE LOAD SUMMARY

Load direction shown here are positive and act on the nozzle.



LOADS (lbs./ft.-lbs.)

Nozzle I.D.	Nominal Pipe Size	Load Force Components	LOADS (lbs./ft.-lbs.)			Remarks
			Gravity	SSE Inertia	SSE Resultant	
Changing Pump G-8A	2"	Fx	89+799 = 888	85+1988 = 2073	3046	
		Fy	9	196		
		Fz	26+820 = 846	448+2042 = 2490		
		Mx	10+332 = 342	181	663	
		My	25+162 = 187	101+2131+4386 = 6618		
		Mz	70+34 = 104	168		
Changing Pump G-12E	2"	Fx	79	121	415	
		Fy	-22	144		
		Fz	-56	370		
		Mx	27	157	230	
		My	25	76		
		Mz	-45	149		

Ref P&ID# See P. 28 ; isometric # See P. 28 ; Bechtel calc. # See P. 28
NOTE

REV	BY	DATE	CHECKED	DATE
0	RCH	1/5/83	GUM	11/28/83
SONGS-1 Safe Shutdown Piping Functionality Assessment				
IMPELL CORPORATION				
CALC NO 0310-022-1352 CV-12				
PAGE	OF			
22	29			





CALCULATION SHEET

CALC. NO. PI-CV.13SIGNATURE W. WANG DATE 2/20/83CHECKED R. Bennett DATE 3/3/83PROJECT SONGS-1JOB NO. 14000-300SUBJECT CHEMICAL VOLUME & CONTROLSHEET 25 OF 54 SHEETS

3.4 SUMMARY OF NOZZLE LOADS

Orientation of nozzle and component



EQUIPMENT	NODE POINT	DIRE	LOADING CONDITIONS				TOTAL	RESULTANT	ALLOWABLE*
			D _x	T _y	SSE	SAY			
CHARGING PUMP G-8B	5	F _x	-22	-415	±144				
		F _y	-79	-21	±121				
		F _z	56	423	±370				
		M _x	25	116	±76				
		M _y	-27	-109	±157				
		M _z	-45	-9	±149				
CHARGING PUMP G-8A	210	F _x	9	143	±196				
		F _y	-89	-95	±85				
		F _z	26	410	±448				
		M _x	25	95	±101				
		M _y	10	158	±181				
		M _z	70	33	±168				

SEE SHT. 26

SEE SHT. 27

*Ref. Boetzel guide lines P-2.6.1.11 & attached calculation pages.

F_x, F_y & F_z are in lb
 M_x, M_y & M_z are in ft-lb

SOUTHERN CALIFORNIA EDISON, SAN ONOFRE UNIT 1
 SAFE SHUTDOWN PIPING FUNCTIONALITY CRITERIA EVALUATION
 CALC. NO: CV-12

PROBLEM # CV12 REV. # 3 SUBMITTED: 12-JUN-84 17:48:58

ANCHOR LOAD SUMMARY.

NAME: AN1 LOCATION: AN1 AXIS: LOCAL
 PUMP G-8A NOZZLE

LOAD CONDITION	FORCES (LB)				MOMENTS (LBFT)			
	F (AX)	F (S1)	F (S2)	F (SR)	M (TOR)	M (B1)	M (B2)	M (BR)
DWGT (+/-)	55. 55.	-4. -4.	-5. -5.	7 7	-8. -8.	-41. -41.	4 4	41. 41.
THRM (+/-)	198. 0.	379. 0.	544. 0.	553. 0	0. -121.	1. 0.	3. -115.	1. 115.
SSEI (+/-)	55. -55.	148. -148.	236. -236.	279. 279.	151. -151.	40. -40.	54. -54.	67. 67.
SAMS (+/-)	0. 0.	0. 0.	0. 0.	0. 0.	0. 0.	0. 0.	0. 0.	0. 0.
DESN (+/-)	318. 10.	523. -152.	774. -242.	934. 256.	143. -290.	0. -82.	57. -164.	57. 183.

Preliminary

SOUTHERN CALIFORNIA EDISON, SAN GONDORE UNIT 1
 SAFE SHUTDOWN PIPING FUNCTIONALITY CRITERIA EVALUATION
 CALC. NO: CV-12

PROBLEM # CV12 REV. # 3 SUBMITTED: 12-JUN-84 17:48:58

ANCHOR LOAD SUMMARY (CONT'D)

NAME: AN2 LOCATION: AN2 AXIS: LOCAL

PUMP G-BB NOZZLE

LOAD CONDITION	FORCES (LB)				MOMENTS (LBFT)			
	F(AX)	F(S1)	F(S2)	F(SR)	M(TOR)	M(B1)	M(B2)	M(BR)
DWGT (+/-)	181 181	18 18	1 1	18 18	37 37	-116 -116	-78 -78	140 140
THRM (+/-)	95 0	0 -87	71 0	71 87	0 -35	0 -19	0 -19	0 27
SSSEI (+/-)	164 -164	132 -132	205 -205	244 244	137 -137	134 -134	71 -71	152 152
SAMS (+/-)	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0
DESN (+/-)	440 17	150 -201	277 -204	315 256	174 -135	18 -268	-7 -168	19 217

Preliminary

KWIK-BOLT

AVERAGE ULTIMATE TENSILE & SHEAR LOADS*

CONCRETE STRENGTH		2000 PSI		4000 PSI		6000 PSI	
Diameter	Embedment	Tension	Shear	Tension	Shear	Tension	Shear
1/4"	1 1/8"	975	1653	1455	2612	1755	2389
	1 1/2"	1875	1653	2225	2612	2935	2389
	1 3/4"	2275	1653	2700	2612	3300	2389
	2"	2525	1653	3125	2612	3350	2389
	2 1/4"	2680	1653	3310	2612	3350	2389
	2 1/2"	2800	1653	3350	2612	3350	2389
3/8"	1 5/8"	2245	3748	2355	5107	2810	6266
	2"	2725	3748	3025	5107	3650	6266
	2 1/2"	3075	3748	3900	5107	4450	6266
	3"	3300	3792	4300	5419	5000	6266
	3 1/2"	3425	3792	4600	5419	5275	6266
	4"	3520	3792	4750	5419	5375	6266
1/2"	4 1/2"	3580	3792	4800	5419	5400	6266
	2 1/4"	4545	7444	5510	8316	6845	9341
	2 3/4"	5800	7444	7200	8316	9800	9341
	3 1/2"	7000	7444	9450	8316	13200	9341
	4 1/2"	7275	8897	11225	10232	14550	11522
	5 1/2"	8250	8897	12050	10232	15150	11522
	6"	9000	8897	12300	10232	15300	11522

Actual Concrete Strengths

2178 psi 4027 psi 6119 psi

*See sheet A-3 for notes

A-1

REF [B] TO IMPAL

CALC NO EQ-09

JOB NO 0310-036-1356

ABBOT A. HANKS, TESTING LABORATORIES, SAN FRANCISCO, CA. 94107

KWIK-BOLT

AVERAGE ULTIMATE TENSILE & SHEAR LOADS*

CONCRETE STRENGTH		2000 PSI		4000 PSI		6000 PSI	
Diameter	Embedment	Tension	Shear	Tension	Shear	Tension	Shear
5/8"	2 3/4"	5410	11198	6600	11562	7700	13500
	3 1/2"	6250	11198	9100	11562	9560	13500
	4 1/2"	7000	11198	12000	11562	14500	13500
	5 1/2"	7550	13378	14300	15437	20300	15437
	6 1/2"	8025	13378	16000	15437	21000	15437
	7 1/2"	9000	13378	17000	15437	21000	15437
3/4"	3 1/4"	8155	13257	10150	17133	10860	18102
	4"	9700	13257	13400	17133	13700	18102
	5"	11700	13257	16500	17133	17600	18102
	6"	13800	15195	18000	18466	22500	21009
	7"	15800	15195	21000	18466	23600	21009
	8"	16000	15195	23000	18466	23600	21009
	9"	16000	15195	23500	18466	23600	21009
1"	4 1/2"						
	5"						
	6"						
	7"						
	8"						
	9"						

Actual Concrete Strengths

2178 psi 4027 psi 6119 psi

*See sheet A-3 for notes

A-2

ABBOT A. HANKS, TESTING LABORATORIES, SAN FRANCISCO, CA. 94107

REVISED

1" DIAMETER HILTI KWIK-BOLT AVERAGE
ULTIMATE TENSILE AND SHEAR LOADS

ANCHOR EMBEDMENT DEPTH (INCHES)	CONCRETE STRENGTH					
	2000 PSI		4000 PSI		6000 PSI	
	ULTIMATE TENSION	ULTIMATE SHEAR	ULTIMATE TENSION	ULTIMATE SHEAR	ULTIMATE TENSION	ULTIMATE SHEAR
4½	14000	27355	16000	26879	20500	32112
5	15500	27355	18900	26879	23441	32112
6	17600	27355	23441	26879	23441	32112
7	18200	27355	23441	26879	23441	32112
8	18200	27355	23441	34491	23441	36394
9	18200	27355	23441	34491	23441	36394
10	18200	27355	23441	34491	23441	36394

NOTE: The maximum working loads should not exceed ¼ of the average ultimate values listed. Actual factor of safety to be used depends on the application.

KWIK-BOLT

AVERAGE ULTIMATE TENSILE & SHEAR LOADS*

CONCRETE STRENGTH		2000 PSI		4000 PSI		6000 PSI	
Diameter	Embedment	Tension	Shear	Tension	Shear	Tension	Shear
1 1/4"	5 1/2"	19000	36750	23000	35680	31200	45195
	6 1/2"	21600	36750	27100	35680	36500	45195
	7 1/2"	23600	36750	31100	35680	42000	45195
	8 1/2"	25100	39843	34600	35680	44400	47098
	9 1/2"	26200	39843	37800	35680	44400	47098
	10 1/2"	26800	39843	40900	35680	44400	49596

Actual Concrete Strengths

2178 psi 4027 psi 6119 psi

*Tension values obtained from best fit curve through mean values of test data. Curves and test data contained in A. A. Hanks Report No. 8784 (HILTI No. TR-111A).

Shear values are minimum mean values at each embedment based on failure across threaded section of the anchor.