

Enclosure 6
DNB Methodology Topical Report Slides
(Redacted)

generation

mPower

DNB Methodology Topical Report

*December 10, 2013
(Redacted Version)*

This material is based upon work supported by the Department of Energy under Award Number DE-NE0000583.

This report was prepared as an account of work sponsored by an agency of the United States Government.

Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

© 2013 GENERATION MPOWER LLC and © 2013 Babcock & Wilcox mPower, Inc. ALL RIGHTS RESERVED.

This document is the property of Generation mPower LLC ("GmP") and Babcock & Wilcox mPower, Inc. (B&W mPower)

This is a pre-application document and includes preliminary B&W mPower Reactor design or design supporting information and is subject to further internal review, revision, or verification.



Meeting Objective

- B&W mPower intends to seek NRC's approval of methods for demonstrating adequate protection of the DNB regulatory limit.
- The objective of this meeting is to provide information and elicit feedback from the staff on the proposed content of the B&W mPower™ Reactor DNB Methodology Topical Report.

generation
mPower

Agenda

- Introduction
 - Meeting Objective
 - Fuel Thermal-Hydraulic Topical Reports and DCD Section 4.4
 - Topical Report Table of Contents
 - Introduction to DNB Methodology
 - B&W mPower™ Reactor Characteristics
 - T-H Comparisons to New Reactors

- Background
 - Key Parameters to Consider for DNB
 - Example Power Distributions – Axial
 - Example Power Distributions – Radial
 - Process Parameter Ranges

- Methodology
 - Deterministic Approach
 - Statistical Approach
 - SDL Determination Process
 - Δ DNBR Sample Population
 - SDL Derived From Δ DNBR

Agenda (cont.)


- Factors Affecting DNB
 - Fuel Rod Bow
 - CRA Misoperation
 - CRA Drop
 - CRA Withdrawal
 - CRA Misalignment
- Core Safety Limit Lines
- Pressure-Temperature Curves
- Summary / Conclusions



PRELIMINARY

Introduction

Fuel Thermal-Hydraulic Topical Reports and DCD 4.4





Topical Report Table of Contents

1.	INTRODUCTION.....	7
1.1	Deterministic Protection of the SAFDL	7
1.2	Statistical Protection of the SAFDL	8
2.	BACKGROUND.....	8
2.1	Key Parameters for Calculation of DNB.....	8
2.2	Power Distributions	10
3.	METHODOLOGY	14
3.1	Range of Application	14
3.2	Deterministic DNB Calculations	15
3.3	Statistical DNB Calculations.....	20
3.4	Calculation of Hot Channel Factors	32
3.5	Calculation of CRA Misoperation Radial Power Augmentations	37
3.6	Core Safety Limit Lines and Pressure-Temperature Curves	42
3.7	Application of Deterministic and Statistical Methods	44
4.	SUMMARY/CONCLUSIONS	44
5.	DEFINITIONS, ABBREVIATIONS, AND ACRONYMS.....	45
5.1	Definitions.....	45
5.2	Abbreviations and Acronyms	45
6.	REFERENCES.....	47
6.1	Code of Federal Regulations	47
6.2	U.S. Nuclear Regulatory Guidance	47
6.3	U.S. Industry Guidance	47
6.4	Other Documentation (if needed).....	47
	Appendix A – Example Statistical Design Limit Calculation	A-1




Introduction to DNB Methodology

- Prevention of DNB ensures integrity of the fuel cladding
 - Required by 10 CFR Part 50, Appendix A, General Design Criteria 10 (GDC 10)
 - Required during normal operation (NO) and all anticipated operational occurrences (AOO)
- DNB Methodology describes how DNB is prevented
 - How parameter uncertainties are accounted for
 - How hot channel factors are accounted for
 - Deterministic method and its application
 - Statistical method and its application

B&W mPower Reactor Characteristics

- Integral PWR (iPWR)
- 530 MWt
- 69 fuel assemblies
 - standard 17x17
 - 95 inch heated length
 - ≤ 5 w/o ^{235}U
- Reactivity control
 - No chemical shim
 - Gd_3O_2 in fuel matrix
 - Discrete BPR in lattice
 - Control rods in every FA





T-H Comparison to New Reactors

	B&W mPower	AP1000 ¹	U.S. EPR ²	US-APWR ³	B&W 177 ⁴
LHGR (kW/ft)	[5.72	5.22	4.65	5.8
Mass Flux (Mlbm/hr-ft ²)		2.40	2.80	2.25	2.71
Power-to-Flow Ratio]	2.38	1.86	2.07	2.14
System Pressure (psia)	2060	2190	2250	2250	2200
Saturation Temp. (°F)	640	649	653	653	650
Outlet Temp. (°F)	606	612	624	617	606
Outlet Subcooling (°F)	34	37	29	36	44

- 1) AP1000 Design Control Document; Tier 2, Ch. 4
 2) U.S. EPR Final Safety Analysis Report; Tier 2, Ch. 4

- 3) US-APWR Design Control Document; Tier 2, Ch. 4
 4) Oconee Nuclear Station Final Safety Analysis Report; Ch. 4



Background

PRELIMINARY

Key Parameters to Consider for DNB

RCS/Process Parameters

Pressurizer pressure
RCS temperatures
Core flow
Core thermal power

Engineering/Analytical Parameters

Enthalpy rise uncertainty
Local heat flux uncertainty
Fuel rod bow penalty
Fuel assembly bow penalty
Hot channel pitch reduction
Clad outer diameter variations
Radial peaking
Axial Flux Shape
Flux quadrant tilt
 $F_{\Delta H}$ augmentations
Core bypass fraction
CHF correlation uncertainty

Key Parameters cover all uncertainties



Power Distributions – Axial

[

PRELIMINARY

AFS varies throughout the cycle



Power Distributions – Axial (cont.)

[

PRELIMINARY

]



Power Distributions – Radial

[

PRELIMINARY

]

$F_{\Delta H}$ varies throughout the cycle



Process Parameter Ranges


PARAMETER		VALUE	NOTES
Pressure (psia)	Lower	[<input type="text"/>]	
	Nominal	2060	
	Upper	[<input type="text"/>]	
Temperature (Hot) (°F)	Lower	[<input type="text"/>]	
	Nominal	606	
	Upper	[<input type="text"/>]	
Power (MW)	Lower	0	
	Nominal	530	
	Upper	[<input type="text"/>]	
Flow (Mlbm/hr)	Lower	[<input type="text"/>]	
	Nominal	31.0	Inlet
	Upper	[<input type="text"/>]	

Methodology

PRELIMINARY


Deterministic Approach

- Conventional methods
- Penalties, uncertainties, and factors (PUFs) compounded at their worst levels in DNBR calculation
- CHF correlation uncertainty added to DNBR = 1.0 to create deterministic SAFDL
- DNBR limiting AFS and $F_{\Delta H}$ are used



Statistical Approach


- Penalties, uncertainties, and factors (PUFs) treated probabilistically
- Sampling is random
- VIPRE-01 used directly in calculations (No Response Surface Model)
- PUFs added to $DNBR = 1.0$ to create a Statistical Design Limit (SDL)
- DNBR calculated with Best Estimate (BE) conditions



Uncertainties accommodated statistically in the SDL


Statistical Approach (cont.)

- Reference power distribution
 - One power distribution for all safety analyses
 - Bias in the SDL
- DNBR allowances
 - Reserved thermal margin
 - Absorb future DNB decrements



Power distribution variations accommodated in SDL

Statistical Approach (cont.)



Covers a large population of AFSs, reactor states, and PUFs



SDL Determination Process

PRELIMINARY

Δ DNBR Sample Population

- Δ DNBR accommodates PUFs and power distributions
- Δ DNBR used to set SDL
- Large Δ DNBR population
[
- Δ DNBR are ordered in ascending order
- Tolerance limits are found from order statistics to set a 95/95 limit on Δ DNBR]

Non-Parametric Order Statistics

- Calculate tolerance limits using methods from Wilks, Murphy, Somerville, et. al.

$$\gamma \cong I_{1-p}(m, n - m + 1) \quad (1)$$

where $m = r + s$

- Incomplete beta function:

$$I_x(p, q) = \frac{\Gamma(p+q)}{\Gamma(p)\Gamma(q)} \int_0^x t^{p-1}(1-t)^{q-1} dt \quad (2)$$

- Find m that satisfies (1) with:


$$\gamma = 0.95$$

$$P = 0.95$$

$$n = \text{number of samples}$$

SDL Derived From Δ DNBR

- Δ DNBR accommodates
 - PUFs
 - Reference power distribution
 - CHF correlation uncertainty
- Δ DNBR is added to DNBR = 1.0 to create the SDL






Factors Affecting DNBR

PRELIMINARY

Fuel Rod Bow

- Impacts mid-span channel geometry
- Can reduce flow-affecting DNBR
- Characterized as an augmentation of hot rod $F_{\Delta H}$
- Impact on neutronics is accounted for



Fuel rod bow can provide a significant penalty to DNBR



CRA Mis-operation (CRA Drop)

PRELIMINARY



CRA Mis-operation (CRA Withdrawal)

PRELIMINARY



CRA Mis-operation (CRA Misalignment)

PRELIMINARY



Core Safety Limit Lines

PRELIMINARY



Pressure-Temperature Curves

PRELIMINARY

generation
mPower

Summary and Conclusions

- B&W mPower reactor conditions for DNB protection []
- Deterministic approach
 - Conventional
 - Used when DNB is less limiting than other constraints
- Statistical approach
 - Evolutionary but tailored to the B&W mPower reactor
 - Uses subchannel T-H code rather than a Response Surface Model
 - Incorporates reference power distributions into the SDL
 - Used when DNB margins matter the most
- CSLL and P-T curves provide context for reactor operation



Abbreviations

AFS – Axial Flux Shape
AOO – Anticipated Operational Occurrences
BE – Best Estimate
BPR – Burnable Poison Rod
CHF – Critical Heat Flux
DNB(R) – Departure from Nucleate Boiling (Ratio)
FA – Fuel Assembly
GDC – General Design Criteria
LHGR – Linear Heat Generation Rate
NO – Normal Operation
PUFs – Penalties, Uncertainties and Factors
PWR – Pressurized Water Reactor
RCS – Reactor Coolant System
RSM – Response Surface Model
SAFDL – Specified Allowable Fuel Design Limit
SDL – Statistical Design Limit
TDL – Thermal Design Limit