

## UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

November 17, 1981

Local PDR
ORB Reading
NSIC
DCrutchfield

-Docket

NRC PDR

DCrutchfield HSmith SNowicki OELD

DISTRIBUTION

01&E (3 [ ACRS (10) SEPB

Docket No. 50-206 LS05-81-11-031

Mr. R. Dietch
Vice President
Nuclear Engineering and Operations
Southern California Edison Company
2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770



Dear Mr. Dietch:

SUBJECT: SAN ONOFRE UNIT 1 AUXILIARY FEEDWATER AUTOMATIC INITIATION

AND FLOW INDICATION - TMI ACTION PLAN ITEM 11.E.1.2

We are continuing our review of the auxiliary feedwater automatic initiation and flow indication and request that you respond to the enclosed request for additional information concerning the San Onofre Unit 1 Auxiliary Feedwater System. Your response is requested by December 15, 1981.\* If you have any questions please contact your project manager Stanley J. Nowicki.

Sincerely,

ORIGINAL SIGNED BY THOMAS V. WAMBACH FOR

Dennis M. Crutchfield, Chief Operating Reactors Branch #5 Division of Licensing

Enclosure:
Request for Additional
Information

cc w/enclosure: See next page

\*Since this request is being sent only to Southern California Edison Company and relates to an approval requested by Southern California Edison concerning an issue specific to San Onofre Unit 1, no clearance from the Office of Management and Budget (OMB) is required.

OFFICE PL. DEB.	#5 DL.		,	`.		<del></del>
SURNAME SNOWICK	i:cc//DCru	tchfield	B11210004 PDR ADOCK	05000206	··	 ***************************************
DATE	70\ 111   117	17/8/	( P	PDR	)	
	\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \				<u>.                                    </u>	

cc w/enclosure:
Charles R. Kocher, Assistant
General Counsel
James Beoletto, Esquire
Southern California Edison Company
Post Office Box 800
Rosemead, California 91770

David R. Pigott Orrick, Herrington & Sutcliffe 600 Montgomery Street San Francisco, California 94111

Harry B. Stochr San Diego Gas & Electric Company P. O. Box 1831 San Diego, California 92112

Resident Inspector/San Onofre NPS c/o U. S. NRC P. O. Box 4329 San Clemente, California 92672

Mission Viejo Branch Library 24851 Chrisanta Drive Mission Viejo, California 92676

Mayor City of San Clemente San Clemente, California 92672

Chairman
Board of Supervisors
County of San Diego
San Diego, California 92101

California Department of Health ATTN: Chief, Environmental Radiation Control Unit Radiological Health Section 714 P Street, Room 498 Sacramento, California 95814

U. S. Environmental Protection Agency Region IX Office ATTN: Regional Radiation Representative 215 Freemont Street San Francisco, California 94111

- 1. Electrical schematic/elementary diagrams for:
  - (a) Auxiliary feedwater (AFW) automatic initiation circuits including that circuitry from the channel outputs (channel level relay contacts), through the actuation logic, to the final actuation (slave) relays.
  - (b) AFW pump control circuits for both motor and turbine driven pumps.
  - (c) AFW valve control circuits for all control/isolation valves in the AFW flow paths and valves in the steam supply lines to the turbine driven AFW pump.
- 2. AFW system automatic initiation logic diagram.
- Piping and Instrumentation diagram (P&ID) of the San Onofre Unit 1 AFW system (including steam supply lines for the turbine driven AFW pump).
- 4. Describe the steam generator level instrumentation at the San Onofre Unit 1 facility. This description should include:
  - a) Type and number of level channels per steam generator including the range of each channel.
  - b) The specific source (vital bus) from which each of these channels is powered.
  - c) Capability for testing and calibration including intervals between tests.
  - d) The specific indication available in the control room for each channel.
- 5. Describe the periodic surveillance performed to verify operability of the San
  Onofre Unit 1 AFW automatic initiation circuits. This description should include
  channel checks, channel functional tests, AFW automatic initiation <u>logic</u> tests,

- 2 -

channel calibrations, and system functional tests. Indicate where these tests/calibrations are required by the plant Technical Specifications or propose changes to the Specifications to include AFW automatic initiation system surveillance.