## LICENSEE EVENT REPORT

•	CONTROL BLOCK: (PLEASE PRINT OR ALL REQUIRED INFORMATION)
0 1	C A S O S 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 5 CAT 58 5  B LICENSEE CODE 14 2 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58
CON'T 0 1 7 8	REPORT LL 6 0 5 0 0 0 2 0 6 7 1 1 0 7 7 9 8 1 1 2 1 7 9 9  EVENT DESCRIPTION AND RECORD OF CONSEQUENCES (1)
0 2	EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  During normal operation with the unit at full power, the control operator tripped
0 3	the reactor following loss of power to several electrical systems and a 4KV room
0 4	fire alarm. The No. 1 480V bus supply breaker automatically tripped. Redundant
0 5	systems were not available. In accordance with Technical Specification 3.7.2(F)
0 6	the unit was placed in cold shutdown. There was no effect on public health and
0 7	safety as a result of the event.
08	9
0 9	SYSTEM CAUSE CODE SUBCODE COMPONENT CODE SUBCODE SUBCODE  E B (1)
	LERIRO EVENT YEAR SEQUENTIAL REPORT NO.  REPORT NUMBER 21 22 23 24 26 27 28 29 30 31 31 32
	ACTION FUTURE COMPLANT SHUTDOWN HOURS 22 ATTACHMENT SUBMITTED FORM SUB. PRIME COMP. COMPONENT MANUFACTURER  D 18 F 19 A 20 B 21 0 1 0 9 N 23 N 24 A 25 W 1 2 0 7  CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10	The No. 1 480V Bus experienced a short circuit due to a rodent bridging two energized
11	phases or phase to ground. The 480V switchgear was completely inspected and all
1 2	damaged equipment repaired or replaced. Areas permitting rodent entrance to switch-
1 3	gear will be modified to prevent such an occurrence.
1 4 7 8	9 80
1 5	FACILITY SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32  E 28 1 0 0 29 NA A A A A A A A A A A A A A A A A A A
	CTIVITY CONTENT ELEASED OF RELEASE AMOUNT OF ACTIVITY 35    Z   33   Z   34   NA   NA   NA    PERSONNEL EXPOSURES AMOUNT OF ACTIVITY 35   NA   NA   NA   NA   NA   NA   NA   N
1 7 8	NUMBER TYPE DESCRIPTION (39)  O O O 37 Z 33 NA  PERSONNEL INJURIES  NA  80
1 8	NUMBER DESCRIPTION (41)  NA  NA  NA
1 9	LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION  D 42 Damage to 480V Bus No. 1  7911290
7 8	PUBLICITY ISSUED DESCRIPTION (45)  Y (44) SCE Press Release November 7, 1979
7 8	