

February 24, 1989

Docket No.: 50-206

DISTRIBUTION

Docket File ACRS(10)  
NRC & LPDRs DWigginton  
CTrammell (2)  
MVirgilio  
JLee  
OGC-White Flint  
PD5 Plant File  
EJordan  
BGrimes

Mr. Kenneth P. Baskin  
Vice President  
Southern California Edison Company  
2244 Walnut Grove Avenue  
Post Office Box 800  
Rosemead, California 91770

Dear Mr. Baskin:

SUBJECT: PERFORMANCE TESTING OF RELIEF AND SAFETY VALVES - NUREG-0737, ITEM II.D.1 (TAC NO. 67322)

Re: San Onofre Nuclear Generating Station, Unit No. 1

We have completed our review of your responses to NUREG-0737 item II.D.1, "Performance Testing of BWR and PWR Relief and Safety Valves." The enclosed Technical Evaluation Report (TER) was prepared by EG&G Idaho as consultant to the NRC staff. The NRC staff has reviewed the TER and endorses its findings with respect to San Onofre Unit No. 1.

As shown in detail in the TER, SCE has met all of the requirements for NUREG-0737 item II.D.1 with the exception of the items summarized in Section 5.2 (pp. 26 and 27) of the TER.

You are requested to address these items which we consider to be not fully resolved at this point and have your response available on-site for future audit. You are requested to have all aspects of this item fully resolved and any additional corrective action completed by the end of fuel cycle XI refueling.

Please advise us when you are prepared to show us your response to each of the items identified in Section 5.2.

Please contact us should you have any questions regarding this matter.

Sincerely,

original signed by

Charles M. Trammell, Senior Project Manager  
Project Directorate V  
Division of Reactor Projects - III,  
IV, V and Special Projects

Enclosure: TER

cc: w/enclosure  
See next page

DRSP/PD5  
CTrammell:  
2/24/89

DRSP/PD5  
GKnighon  
2/24/89

OFFICIAL RECORD COPY

8903080270 890224  
PDR ADOCK 05000206  
P PDC

*See Rpt*

*rpt. came in  
w/ memo dtd 1/30/89  
DFOI  
1/1  
m/A-2*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

February 24, 1989

Docket No.: 50-206

Mr. Kenneth P. Baskin  
Vice President  
Southern California Edison Company  
2244 Walnut Grove Avenue  
Post Office Box 800  
Rosemead, California 91770

Dear Mr. Baskin:

SUBJECT: PERFORMANCE TESTING OF RELIEF AND SAFETY VALVES - NUREG-0737, ITEM II.D.1 (TAC NO. 67322)

Re: San Onofre Nuclear Generating Station, Unit No. 1

We have completed our review of your responses to NUREG-0737 item II.D.1, "Performance Testing of BWR and PWR Relief and Safety Valves." The enclosed Technical Evaluation Report (TER) was prepared by EG&G Idaho as consultant to the NRC staff. The NRC staff has reviewed the TER and endorses its findings with respect to San Onofre Unit No. 1.

As shown in detail in the TER, SCE has met all of the requirements for NUREG-0737 item II.D.1 with the exception of the items summarized in Section 5.2 (pp. 26 and 27) of the TER.

You are requested to address these items which we consider to be not fully resolved at this point and have your response available on-site for future audit. You are requested to have all aspects of this item fully resolved and any additional corrective action completed by the end of fuel cycle XI refueling.

Please advise us when you are prepared to show us your response to each of the items identified in Section 5.2.

Please contact us should you have any questions regarding this matter.

Sincerely,

A handwritten signature in cursive script that reads "Charles M. Trammell".

Charles M. Trammell, Senior Project Manager  
Project Directorate V  
Division of Reactor Projects - III,  
IV, V and Special Projects

Enclosure: TER

cc: w/enclosure:  
See next page

Mr. Kenneth P. Baskin  
Southern California Edison Company

San Onofre Nuclear Generating  
Station, Unit No. 1

cc  
Charles R. Kocher, Assistant  
General Counsel  
James Beoletto, Esquire  
Southern California Edison Company  
Post Office Box 800  
Rosemead, California 91770

Mr. Jack McGurk, Acting Chief  
Radiological Health Branch  
State Department of Health  
Services  
714 P Street, Office Bldg. 8  
Sacramento, California 95814

David R. Pigott  
Orrick, Herrington & Sutcliffe  
600 Montgomery Street  
San Francisco, California 94111

Mr. Hans Kaspar, Executive Director  
Marine Review Committee, Inc.  
531 Encinitas Boulevard, Suite 105  
Encinitas, California 92024

Mr. Robert G. Lacy  
Manager, Nuclear  
San Diego Gas & Electric Company  
P. O. Box 1831  
San Diego, California 92112

Resident Inspector/San Onofre NPS  
U.S. NRC  
P. O. Box 4329  
San Clemente, California 92672

Mayor  
City of San Clemente  
San Clemente, California 92672

Chairman  
Board of Supervisors  
County of San Diego  
1600 Pacific Highway Room 335  
San Diego, California 92101

Director  
Energy Facilities Siting Division  
Energy Resources Conservation &  
Development Commission  
1516 - 9th Street  
Sacramento, California 95814

Regional Administrator, Region V  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596