

38 ~~of~~ K

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V-88-62 Date 11/21/88

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by Region V staff on this date.

FACILITY: SOUTHERN CALIFORNIA EDISON
SONGS UNIT 1, 2, 3
DOCKET NO. 50-206, 361, 362
SAN CLEMENTE, CA

Emergency Classification
 Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: EARTHQUAKE NEAR SAN ONOFRE

At 9:39 p.m. PST on November 19, 1988, an earthquake measuring 4.6 on the Richter Scale (as measured in Berkeley, CA) occurred approximately 30 miles west of San Clemente. The earthquake was felt by personnel in the Unit 1 control room; however, no seismic instrumentation alarms were received. The earthquake was also felt in other areas of the plant. The licensee performed a visual inspection of Unit 1 and found no damage. The licensee also performed a flux map of the Unit 2 and 3 reactors and found no anomalies.

This information is current as of 11:30 a.m. PST, November 21, 1988.

CONTACT: P. Johnson R. Huey
 FTS 463-3745 (714) 492-2641/42

DISTRIBUTION BY 5520:

Date 11/21 Time 1:40
Chairman Zech EDO
Comm. Roberts AEOD
Comm. Carr PAO
Comm. Rogers SLITP
Comm. Curtiss NRR
SECY NMSS
PDR ARM
OGC OI
ACRS OIA
GPA RES
CA

FAX TO:

Date 11/21 Time 11:45
INPO
NSAC
LICENSEE
RESIDENT INSPECTOR
HQS. OPERATIONS OFFICER

MAIL TO:

DCS (Original)
DOT:(Trans. Only, Applicable State)

RV FORM 211
Revised: 8/19/87

8811300176 881121
PDR I&E
PNO-V-88-062 PDC

0/1
IE-34