

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8502190277 DOC. DATE: 85/02/14 NOTARIZED: YES DOCKET #
 FACIL: 50-206 San Onofre Nuclear Station, Unit 1, Southern California 05000206
 AUTH. NAME AUTHOR AFFILIATION
 BASKIN, K. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards Amend Application 126 to License DPR-13, revising
 Tech Specs re emergency diesel generator testing. Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 40 SIZE: 2+22
 TITLE: OR Submittal: General Distribution

NOTES: J Hanchett 1cy PDR Documents. NRR/DL/SEP 1cy. 05000206
 OL: 03/27/67

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR ORB5 BC	01	7	7			
INTERNAL:	ACRS	09	6	6	ADM/LFMB		1 0
	ELD/HDS2		1	0	NRR/DE/MTEB		1 1
	NRR/DL DIR		1	1	NRR/DL/ORAB		1 0
	NRR/DL/TSRG		1	1	NRR/DSI/METB		1 1
	NRR/DSI/RAB		1	1	<u>REG FILE</u>	04	1 1
	RGNS		1	1			
EXTERNAL:	LPDR	03	1	1	NRC PDR	02	1 1
	NSIC	05	1	1			
NOTES:			2	2			

w/check #150-
 # 7034092

Southern California Edison Company



P. O. BOX 800

2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

KENNETH P. BASKIN
VICE PRESIDENT

TELEPHONE
818-302-1401

February 14, 1985

Office of Nuclear Reactor Regulation
Attention: Mr. H. R. Denton, Director
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-206
Amendment Application No. 126
San Onofre Nuclear Generating Station
Unit 1

- References: A) Letter D. M. Crutchfield (NRC) to K. P. Baskin (SCE),
November 19, 1984, TDI Diesel Engine Reliability and
Operability
- B) Letter M. O. Medford (SCE) to J. A. Zwolinski (NRC),
December 19, 1984, TDI Diesel Engine Reliability and
Operability

By Reference A, the NRC requested that Southern California Edison (SCE) propose Technical Specification changes to the San Onofre Unit 1 Provisional Operating License. These proposed changes would, on an interim basis, limit emergency diesel engine loading to 4500 kw \pm 5% for engine testing and emergency service requirements. Additionally, the proposed changes would eliminate fast engine starts from the monthly surveillance testing, but retain the refueling interval fast start test which simulates design basis emergency power requirements. By Reference B, SCE informed you that proposed Technical Specification changes as requested by Reference A will be submitted to the NRC by approximately February 1, 1985, but will not include any loading limits pertaining to emergency service, which will be handled by the San Onofre Unit 1 Emergency Operating Instructions.

Enclosed are three executed and forty conformed copies of Amendment Application No. 126 to Provisional Operating License No. DPR-13. Amendment Application No. 126 consists of Proposed Change No. 147, which is a change to the Appendix A Technical Specifications incorporated into Provisional Operating License No. DPR-13. Proposed Change No. 147 is intended to fulfill the commitment made in Reference B and also includes two additional changes deemed appropriate by the Licensee.

8502190277 850214
PDR ADDCK 05000206
P. PDR

Handwritten notes:
A-100
w/ check \$150
T034092

Mr. H. R. Denton

-2-

February 14, 1985



Pursuant to 10 CFR 170.12, SCE's Check No. T034092 in the amount of \$150 is enclosed to cover the fee for Amendment Application No. 126.

If you have any questions, please contact me.

Very truly yours,

Kenneth P. Baskin

Enclosures

cc: W. A. Paulson, NRC/NRR, San Onofre Unit 1 Project Manager
F. R. Huey (NRC Senior Resident Inspector, Units 1, 2 and 3)
J. B. Martin, NRC Region V, Regional Administrator
J. O. Ward, California Department of Health Services