

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8703240567 DOC. DATE: 87/03/20 NOTARIZED: YES DOCKET #
 FACIL: 50-206 San Onofre Nuclear Station, Unit 1, Southern California 05000206
 AUTH. NAME AUTHOR AFFILIATION
 BASKIN, K. P. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards Application 139 to amend License DPR-13, consisting of Proposed Change 155, clarifying 10CFR50, App J leak test requirements for containment personnel airlocks. Fee paid.

DISTRIBUTION CODE: A017D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+11
 TITLE: OR Submittal: Append J Containment Leak Rate Testing

NOTES: License Exp date in accordance with 10CFR2, 2.109. 05000206

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
PWR-A ADTS	1	1	PWR-A EB	1	1
PWR-A EICSB	2	2	PWR-A FOB	1	1
PWR-A PD1 LA	1	0	PWR-A PD1 PD	5	5
DUDLEY, R	1	1	PWR-A PSB	1	1
PWR-A RSB	1	1			

INTERNAL: ADM/LFMB	1	0	NRR BWR ADTS	1	1
NRR PWR-A ADTS	1	1	NRR PWR-B ADTS	1	1
NRR/DSRO/EIB	1	1	NRR/DSRO/RSIB	1	1
QGC/HDS2	1	1	<u>REG FILE</u> 01	1	1
EXTERNAL: LPDR	1	1	NRC PDR	1	1
NSIC	1	1			

W/check \$150

A-786765

Southern California Edison Company

P. O. BOX 800
2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

KENNETH P. BASKIN
VICE PRESIDENT

TELEPHONE
818-302-1401

March 20, 1987

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-206
Amendment Application No. 139
San Onofre Nuclear Generating Station
Unit 1

Enclosed is Amendment Application No. 139 to Provisional Operating License No. DPR-13. Amendment Application No. 139 consists of Proposed Change No. 155 which is a request to revise Appendix A, Technical Specifications, of Provisional Operating License No. DPR-13.

Proposed Change No. 155 is a request to revise Appendix A Technical Specifications to provide clarification of the applicable 10 CFR Part 50, Appendix J, leak testing requirements for containment personnel airlocks. The changes to the existing specification are primarily editorial in nature and consistent with the Westinghouse Standard Technical Specifications. In addition to the editorial changes, Proposed Change No. 155 will reduce the lower pressure airlock test pressure from 10 psig to 3 psig. This change is consistent with the airlock manufacturer's recommendation in order to reduce the potential for airlock seal damage from testing at 10 psig.

Pursuant to 10CFR 170.12, the review of the Proposed Change 155 contained in Amendment Application No. 139 has been determined to require a fee of \$150.00. Accordingly, SCE's check in the amount of \$150.00 is enclosed.

Very truly yours,

Kenneth P. Baskin

Enclosure

cc: R. F. Dudley, NRR Project Manager, San Onofre Unit 1
J. B. Martin, Regional Administrator, NRC Region V
F. R. Huey, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3
J. O. Ward, California Department of Health Services

8703240567 870320
PDR ADDCK 05000206
P PDR

*A017 w/check
\$150
A-786765*