

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8707240040 DOC. DATE: 87/05/27 NOTARIZED: YES DOCKET #
 FACIL: 50-206 San Onofre Nuclear Station, Unit 1, Southern Californ 05000206
 AUTH. NAME AUTHOR AFFILIATION
 BASKIN, K. P. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards Application 141 for amend to License DPR-13
 consisting of Proposed Change 167 to revise Tech Spec
 Section 4.11 re teating requirements for air treatment sys &
 change 175 concerning Section 4.1.6 on valves. Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+18
 TITLE: OR Submittal: General Distribution

NOTES: License Exp date in accordance with 10CFR2.2.109.

05000206

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	1 0	PD5 PD	5 5
	DUDLEY, R	1 1		
INTERNAL:	ARM/DAF/LFMB	1 0	NRR/DEST/ADE	1 1
	NRR/DEST/ADS	1 1	NRR/DEST/CEB	1 1
	NRR/DOEA/TSB	1 1	NRR/PMAS/ILRB	1 1
	OGC/HDS2	1 0	<u>REG FILE</u> 01	1 1
	RES/DE/EIB	1 1		
EXTERNAL:	EG&G BRUSKE, S	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 17

ORIGINAL
Rec'd at NRC
6/3/87
Southern California Edison Company

P. O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

KENNETH P. BASKIN
VICE PRESIDENT

TELEPHONE
818-302-1401

May 27, 1987

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-206
Amendment Application No. 141
San Onofre Nuclear Generating Station
Unit 1

Applicant.....
Check No. <i>809680</i>
Amount <i>\$150.00</i>
Date of Check <i>4/22/87</i>
Date Check Rec'd <i>6/4/87</i>
Received By <i>K. Phillips</i>

Enclosed is Amendment Application No. 141 to Provisional Operating License No. DPR-13. Amendment Application No. 141 consists of Proposed Change Nos. 167 and 175 which request revision of the Appendix A, Technical Specifications.

Proposed Change No. 167 is a request to revise Appendix A Technical Specification Section 4.11, Control Room Emergency Air Treatment System to include testing requirements of a planned modification, to revise the surveillance standards to more closely reflect system design and to revise the technical specifications to more closely follow the Standard Technical Specifications and the current regulatory guidance. The planned modification is the installation of the control room emergency air treatment system duct heaters discussed in SCE's letter dated July 24, 1986. Proposed Change No. 175 is a request to revise Appendix A Technical Specification Section 4.1.6, Pressurizer Relief Valves, to allow for the suspension of PORV Block Valve surveillance testing during periods when the block valves are being maintained closed in order to satisfy the action requirements of Specification 3.1.5.

Pursuant to 10CFR 170.12, the review of Proposed Changes 167 and 175 contained in Amendment Application No. 141 have been determined to require a fee of \$150.00. Accordingly, SCE's check in the amount of \$150.00 is enclosed.

Very truly yours,

Kenneth P. Baskin

Enclosure

cc: R. F. Dudley, NRR Project Manager, San Onofre Unit 1
J. B. Martin, Regional Administrator, NRC Region V
F. R. Huey, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3
J. O. Ward, California Department of Health Services

8707240040 870527
PDR ADDCK 05000206
P PDR

REC'D W/CHECK
809680

ADOL
1/1