

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8912190204 DOC. DATE: 89/12/07 NOTARIZED: NO DOCKET #
 FACIL: 50-206 San Onofre Nuclear Station, Unit 1, Southern Californ 05000206
 AUTH. NAME AUTHOR AFFILIATION
 JOHNSON, P. Region 5, Ofc of the Director
 CALDWELL, C. Region 5, Ofc of the Director
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: PNO-V-89-071: on 891206, unscheduled shutdown due to containment isolation valve.

DISTRIBUTION CODE: IE34D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Preliminary Notification-Occurrence/Non-Routine Event/Safeguards Even

NOTES: License Exp date in accordance with 10CFR2,2.109. 05000206

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
INTERNAL:	ACRS/SIESS	1 1	AEOD/DSP/TPAB	1 1
	NRC OP CNTR	1 1	NRR/DRIS/RSGB9D	1 1
	NRR/DRIS/RSIB9A	1 1	NRR/DRIS/RVIB9D	1 1
	NRR/PMAS/ILRB12	1 1	NUDOS-ABSTRACT	1 1
	OE DIR	1 1	REG FILE 02	1 1
	RES BROOKS, B	1 1	RES DE	1 1
	RES FILE	1 1	RES/DE	1 1
	RES/DRA	1 1	RES/DSIR	1 1
	RES/DSIR/EIB	1 1	RES/DSR DEPY	1 1
	RES/PMPDAS	1 1	RGN5 FILE 01	1 1
EXTERNAL:	DOE BARBER EV34	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 24

AJ-4

17
B1

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V-89-71 Date: 12/7/89

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by Region V staff on this date.

an

FACILITY: SOUTHERN CALIFORNIA EDISON
San Onofre Unit 1
Docket No. 50-206
San Clemente, California

Emergency Classification
 Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: UNSCHEDULED SHUTDOWN DUE TO INOPERABLE CONTAINMENT ISOLATION VALVE

The licensee determined at 2:18 p.m. (all times PST) on December 6, 1989 that pressure regulators for the backup nitrogen system on valve HV-851A were inoperable. This valve is the "A" feedwater/safety injection pump discharge valve to the reactor coolant system, and also serves as a containment isolation valve. Although the valve is not listed in the Technical Specifications as a containment isolation valve, the licensee administratively applied the Action Statement of Technical Specification 3.6.2. A plant shutdown was initiated at 8:18 p.m., and was completed at 11:49 p.m. The licensee is repairing the pressure regulator system, and anticipates unit restart when repairs are completed.

The resident inspectors are following the licensee's outage activities.

The licensee has issued a press release regarding this event.

This information is current as of 8:00 a.m. PST on December 7, 1989.

CONTACT: P. Johnson
FTS 463-3745

C. Caldwell
(714) 492-2641

DISTRIBUTION BY 5520:

Date	Time	
Chairman Carr	EDO	RI
Comm. Roberts	AEOD	RII
Comm. Rogers	PAO	RIII
Comm. Curtiss	SLITP	RIV
Comm. Remick	NRR	RES
ACRS	NMSS	
OE	IRM	
GPA	OIG	
OGC	ASLAP	
CA	RES	

FAX TO:

Date	Time
INPO	
NSAC	
LICENSEE	
RESIDENT INSPECTOR	
HQS. OPERATIONS OFFICER	
PDR (202)634-3343	

MAIL TO:

DCS (Original)
DOT:(Trans. Only, Applicable State)