

Southern California Edison Company

P. O. BOX 800 2244 WALNUT GROVE AVENUE ROSEMEAD, CALIFORNIA 91770

* M. O. MEDFORD MANAGER OF NUCLEAR ENGINEERING AND LICENSING

December 9, 1987

TELEPHONE (818) 302-1749

U. S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-206 Engineered Safety Features Single Failure Analysis San Onofre Nuclear Generating Station Unit 1

By letter dated December 8, 1987, SCE provided additional information regarding the better estimate end of life analysis of the core response during a main steam line break to support justification for continued operation. This information was provided in response to NRC Staff questions on the better estimate analysis submitted by letter dated December 1, 1987. SCE, at the request of NRC Staff, also committed to provide the minimum value of DNBR resulting from this transient analysis. The purpose of this letter is to provide this value.

Provided as Enclosure 1 is the calculation of DNBR for the better estimate end of life steamline break for San Onofre Unit 1. As this enclosure contains information proprietary to Westinghouse Electric Corporation, it is supported by an affidavit (Enclosure 2) signed by Westinghouse, the owner of the information. The affidavit sets forth the basis on which the information may be withheld from public disclosure by the Commission and addresses with specificity the considerations listed in paragraph (b) (4) of Section 2.790 of the Commission's regulations. Accordingly, it is respectfully requested that the information which is proprietary to Westinghouse be withheld from public disclosure in accordance with 10CFR Section 2.790 of the Commission's regulations.

If you have any questions regarding this submittal, please contact me.

Very truly yours,

m.o. medfal

cc: J. O. Bradfute, NRR Project Manager, San Onofre Unit 1

871214027

J. B. Martin, Regional Administrator, NRC Region V

F. R. Huey, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3

5	871209 05000206 PDR				