

May 14, 1990

Docket No. 50-206

FACILITY: SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 1

LICENSEE: SOUTHERN CALIFORNIA EDISON COMPANY

SUBJECT: SUMMARY OF MEETING HELD AT ONE WHITE FLINT NORTH ON MAY 7, 1990, RE:  
THERMAL SHIELD REPAIR

On May 7, 1990, the NRC staff met with representatives of Southern California Edison Company (SCE) to discuss SCE's thermal shield repair plans. Persons attending the meeting are identified in Enclosure 1.

The meeting was held to discuss the details of SCE's Amendment Application No. 181 dated April 20, 1990, on this subject to facilitate NRC review efforts. SCE has requested NRC approval of the thermal shield repair plans by July 15, 1990, to support the Cycle XI outage schedule.

As a result of the meeting, SCE has agreed to provide additional information to support NRC review efforts. The information required is included in Enclosure 2.

Viewgraphs used at the meeting are included in Enclosure 3.

original signed by James E. Tatum

James E. Tatum, Project Manager  
Project Directorate V  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Enclosures:

1. List of Attendees
2. Additional Information Required
3. Viewgraphs

DISTRIBUTION

Docket File  
NRC & Local PDRs  
FMiraglia  
JPartlow  
PDV Reading  
JLarkins  
JTatum  
OGC  
EJordan  
NRC Participants  
ACRS (10)  
JRogge (17G21)

DRSP/PDV  
JTatum:sg  
5/15/90

(A)DRSP/PDV  
JLarkins  
5/15/90

9005230221 900514  
PDR ADDCK 05000206  
P PDC

*Memorandum 4*  
*sub*  
DF01  
11



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

May 14, 1990

Docket No. 50-206

FACILITY: SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 1

LICENSEE: SOUTHERN CALIFORNIA EDISON COMPANY

SUBJECT: SUMMARY OF MEETING HELD AT ONE WHITE FLINT NORTH ON MAY 7, 1990, RE:  
THERMAL SHIELD REPAIR

On May 7, 1990, the NRC staff met with representatives of Southern California Edison Company (SCE) to discuss SCE's thermal shield repair plans. Persons attending the meeting are identified in Enclosure 1.

The meeting was held to discuss the details of SCE's Amendment Application No. 181 dated April 20, 1990, on this subject to facilitate NRC review efforts. SCE has requested NRC approval of the thermal shield repair plans by July 15, 1990, to support the Cycle XI outage schedule.

As a result of the meeting, SCE has agreed to provide additional information to support NRC review efforts. The information required is included in Enclosure 2.

Viewgraphs used at the meeting are included in Enclosure 3.

A handwritten signature in cursive script that reads "James E. Tatum".

James E. Tatum, Project Manager  
Project Directorate V  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Enclosures:

1. List of Attendees
2. Additional Information Required
3. Viewgraphs

Mr. Harold B. Ray  
Southern California Edison Company

San Onofre Nuclear Generating  
Station, Unit No. 1

cc  
David R. Pigott  
Orrick, Herrington & Sutcliffe  
600 Montgomery Street  
San Francisco, California 94111

Mr. Richard J. Kosiba, Project Manager  
Bechtel Power Corporation  
12440 E. Imperial Highway  
Norwalk, California 90650

Mr. Robert G. Lacy  
Manager, Nuclear  
San Diego Gas & Electric Company  
P. O. Box 1831  
San Diego, California 92112

Mr. Phil Johnson  
U.S. Nuclear Regulatory Commission  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

Resident Inspector/San Onofre NPS  
U.S. NRC  
P. O. Box 4329  
San Clemente, California 92672

Mayor  
City of San Clemente  
San Clemente, California 92672

Chairman  
Board of Supervisors  
County of San Diego  
1600 Pacific Highway Room 335  
San Diego, California 92101

Regional Administrator, Region V  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

Mr. John Hickman  
Senior Health Physicist  
Environmental Radioactive  
Management Unit  
Environmental Management Branch  
State Department of Health Services  
714 P Street, Room 616  
Sacramento, California 95814

Mr. Don Womeldorf  
Chief, Environmental Management  
California Department of Health  
714 P Street, Room 616  
Sacramento, California 95814

LIST OF ATTENDEES

NRC

J. Larkins  
D. Terao  
C. Trammell  
J. Tatum  
C. Hinson  
L. Wharton  
J. Rajan  
R. Hermann  
A. Wang  
M. Hum  
C. Sellers

WESTINGHOUSE

C. Boyd  
J. Goossen  
B. Bevilacqua  
D. Dominicis  
D. Forsyth

SCE

F. Nandy  
J. Reilly  
R. Ashe-Everest  
R. Ornelas  
M. Motamed  
G. Stawniczy

OTHER

J. Porowski  
(O'Donnell & Assoc)  
T. Landgraf  
(Bechtel-KWU-Alliance)  
M. Mundt (SDG&E)

Additional Information Required to Facilitate NRC Review

1. Details of ALARA considerations, including dose assessments and time-motion studies.  
Approximate Submittal Date: 5/20/90
2. Details and results of qualification testing for fasteners (torque vs. preload).  
Approximate Submittal Date: 5/30/90
3. Final drawing details.  
Approximate Submittal Date: 5/30/90
4. Material Specifications for KWU and Westinghouse fasteners.  
Approximate Submittal Date: Not Established
5. Details and justification for exception to ASME fatigue design requirements.  
Approximate Submittal Date: 5/30/90
6. Final design criteria.  
Approximate Submittal Date: 6/15/90
7. Description of measures being taken to assure RCS cleanliness during repair evolution and prior to returning the unit to service. (This item was discussed with SCE following the meeting).  
Approximate Submittal Date: 5/20/90
8. Description of followup inspections planned following repair of the thermal shield, and frequency for conducting inspections.  
Approximate Submittal Date: Not Established

**TECHNICAL PRESENTATION**  
**ON**  
**THERMAL SHIELD SUPPORT SYSTEM REPLACEMENT**  
**AND**  
**CYCLE 11 MONITORING PROGRAM**  
**FOR SAN ONOFRE UNIT 1**

**SOUTHERN CALIFORNIA EDISON**

**MAY 7, 1990**

**SONGS 1 REACTOR VESSEL  
THERMAL SHIELD SUPPORT REPLACEMENT**

**AGENDA**

May 7, 1990

- |   |                 |
|---|-----------------|
| I. INTRODUCTION                                       | R. ORNELAS      |
| II. TECHNICAL OVERVIEW                                | R. ASHE-EVEREST |
| III. DESIGN OF NEW SUPPORT SYSTEM                     | R. ASHE-EVEREST |
| A. Comparison of SONGS I and<br>Haddam Neck Design    | J. GOOSSEN      |
| B. Implementation                                     |                 |
| C. Design Criteria                                    |                 |
| D. Response to NRC Questions                          |                 |
| IV. FUTURE INSPECTIONS                                | R. ASHE-EVEREST |
| V. THERMAL SHIELD MONITORING SYSTEM<br>(AS REQUESTED) | R. ASHE-EVEREST |
| VI. LICENSING ACTIONS                                 | R. ORNELAS      |
| VII. QUESTIONS AND SUMMARY                            | ALL             |

# THERMAL SHIELD SUPPORT REPLACEMENT


## SAN ONOFRE NUCLEAR STATION - UNIT 1


### OVERVIEW

- o Commercial Operation - January 1, 1968
- o Effective Full Power Years - 12 Years
- o Prior to Cycle X refueling, several thermal shield inspections performed with no unacceptable degradation observed
- o Cycle X refueling thermal shield inspection revealed limited support degradation
  - Five of six flexures broken (four were known to be broken from prior inspections)
  - Three of thirty support block bolts broken
  - One dowel pin in lower support block had a broken tack weld
- o Analysis performed and monitoring systems added to allow operation through Cycle X
- o NRC required inspection of thermal shield support system
- o SCE has elected to replace the support system during the 1990 actual outage
- o Thermal shield material and core barrel material are 304SS SA240






# SONGS Reactor Internals






# Existing Design



Mtl.  
Bolts and Dowel Pins  
316 Strain Harden Stainless Steel


# New Design



# Section A-A

Support Block Mtl.  
304 Stainless Steel


Thermal Shield      Core Barrel



# Section B-B

Thermal Shield

Core Barrel



Support Block

## LOWER SUPPORT BLOCK

### NEW DESIGN


### OLD DESIGN

- 
- |  |  |
|--|--|
| o 11" wide; more than three times contact area thermal shield and support blocks | 8" wide                                    |
| o Seven bolts<br>75% increase in area  | Five bolts                                 |
| o Five dowel pins<br>150% increase in area                                       | Four dowel pins                            |
| o Dowel pins designed for interference fit                                       | Shrink fit                                 |
| o Bolts & dowel pins will be restrained by a locking nut or crimped head         | Bolts - welded lock bar<br>Dowels - welded |






# New Design




# New Thermal Shield Flexure Assembly

Mtl. XM-19 High Alloy  
Stainless Steel



# New Thermal Shield Flexure Assembly



## FLEXURE DESIGN COMPARISON

### NEW DESIGN

### OLD DESIGN

---

o Material SA-479 XM-19 high alloy stainless steel (annealed)	ASTM A-276 type 304SS
Tensile 100 KSI	Tensile 75 KSI
Yield 55 KSI	Yield 30 KSI
Hardness 293 Brinell	Hardness 202 Brinell
o Flexure fabricated in one piece (no welds)	Welded in web area
o Preloaded flexure web area	No preload
o Web geometry improved to reduce stress	--
o One flexure will be moved to reduce loading	--

**MATERIAL DATA COMPARSION  
316ss vs XM-19**

**CHEMICAL REQUIRMENTS : 1986 EDITION ASME B&PVC**

**% COMPOSITION  
SA-479**

<b>ELEMENT</b>	<b>316ss</b>	<b>XM-19</b>
<b>C</b>	<b>.03</b>	<b>.06</b>
<b>MN</b>	<b>2.0</b>	<b>4/6</b>
<b>P</b>	<b>.045</b>	<b>.04</b>
<b>S</b>	<b>.03</b>	<b>.03</b>
<b>SI</b>	<b>1.</b>	<b>1.</b>
<b>CR</b>	<b>16/18</b>	<b>20.5/23.5</b>
<b>NI</b>	<b>10/14</b>	<b>11.5/13.5</b>
<b>MO</b>	<b>2/3</b>	<b>1.5/3.0</b>
<b>N</b>	<b>.1</b>	<b>.2/.4</b>
<b>CB</b>	<b>-</b>	<b>.1/.3</b>
<b>V</b>	<b>-</b>	<b>.1/.3</b>

**MATERIAL DATA COMPARISON  
316SS vs XM-19**

**CORROSION RESISTANCE  
PROPERTIES  
LABORATORY TEST DATA  
(SUPPLIED BY ARMC0 STEEL)**

TEST MEDIUM	CORROSION RATE INCHES PER YEAR (UNLESS SPECIFICALLY INDICATED)	
	XM-19 (ANNEALED)	316SS (ANNEALED)
10%FECL3 (25 C PLAIN)	<.001 G/IN2	0.011 G/IN2
10%FECL3 (25 C CREVICED)	<.001 G/IN2	0.186 G/IN2
1%H2S04 (80 c )	<.001	0.002
2%H2S04 (80 c )	<.001	0.011
5%H2S04 (80 c )	<.001	0.060
5%H2S04 (BOILING )	<.194	0.26
1%HCL (35 c )	<.001	0.012
2%HCL (35 c )	0.024	0.021
65%HN03 (BOILING )	0.010	0.012
70%H3P04 (BOILING )	0.203	0.202
33%ACETIC ACID (BOILING )	<.001	<.001

TESTING PERFORMED ON 5/8" DIA X 5/8" LONG MACHINED CLINDERS. RESULTS AN AVE. OF FIVE 48 HR. PERIODS.

**MATERIAL DATA COMPARSION  
316ss vs XM-19**

**MECHANICAL REQUIRMENTS : SA-479 1986 EDITION ASME**

**MECHANICAL PROPERTIES**

<b>MECHANICAL PROPERTIES (MAT TYPE)</b>	<b>TENSILE STRENGTH (KSI)</b>	<b>YIELD MIN (KSI)</b>	<b>ELONGATION 2 IN MIN %</b>	<b>REDUCTION AREA MIN %</b>	<b>BRINELL MIN HARDNESS MAX</b>
<b>316ss</b>	<b>70</b>	<b>25</b>	<b>30</b>	<b>40</b>	<b>-</b>
<b>XM-19</b>	<b>100</b>	<b>55</b>	<b>35</b>	<b>55</b>	<b>293</b>

# THERMAL SHIELD SUPPORT


## SONGS 1

## HADDAM NECK

- 
- |  |   |
|--|---|
| o Replace lower support with larger design.                              | Original blocks retained.                                 |
| o Interference fit lower support between thermal shield and core barrel. | No adjustments made.                                      |
| o Bolting and dowel pin system has been redesigned.                      | New bolts installed; only backed out dowel pins replaced. |
| o Dowel pins installed with interference fit.                            | Clearance fit installation of new dowels.                 |
| o Four new limiter keys.   | No refurbishment of original keys.                        |
| o Six new, improved flexures (no wear surfaces).                         | Six new limiter key and keyways.                          |
| o New support system incorporates lessons learned from Haddam Neck.      |   |



# San Onofre Unit 1 Reactor Cavity With Core Barrel and Upper Internals Removed



PERFORMANCE OF THE QUALIFICATION TESTS  
INTERFERENCE FIT

Test No.	Diameter	1	2	3	4
D1	.8125"	0.0002"	0.0005"	0.0008"	0.0011"
D2	1.25"	0.0003"	0.0007"	0.001"	0.0013"
D3	1.75"	0.0004"	0.0008"	0.0011"	0.0014"

**LOCKING SYSTEM QUALIFICATION TEST**

<u>TEST NO.</u>	<u>BOLT 1 DOWEL PIN DIMENSION</u>	<u>DIMENSIONAL CHECK</u>	<u>VISUAL EXAM.</u>	<u>DETORQUING OF LOCKED SPECIMEN</u>	<u>METALLURGICAL TEST SECTION</u>		<u>PRESS IN AND PUSH OUT</u>	<u>ORIGINAL MATERIAL</u>
					<u>A-A</u>	<u>B-B</u>		
B1	(4) 1.00-8x2 long SCH CAP SCR	(4)	(4)	(3)	(1)	--	--	x
B2	(4) 0.500-13x2.75 long SCH CAP SCR	(4)	(4)	(3)	--	(1)	--	x
D4	(2) 1.75"-4." long dowel pin	(2)	(2)	--	--	--	(2)	--
D5	(2) 1.25"-5.219" long dowel pin	(2)	(2)	--	--	--	(2)	--
D6	(2) .8125"-4.045" long dowel pin	(2)	(2)	--	--	--	(2)	--
B3	(2) 1.00-8x2 long SCH CAP SCR	(2)	(2)	<i>Detorque measurement on unlocked locked bolts 1)</i>				--
D7	(2) 1.25-5.215 long dowel pin	(2)	(2)	<i>Cyclic loading test 2)</i>			(2)	x

NOTES: 1) Measurement of effect of crimping on bolt preload by detorquing the nuts instead of bolt head.  
 2) Test parameters see paragraph 3.2e.

## QUALIFICATION TEST PRELIMINARY TOOLING TESTS

1. Removal of the old parts:
  - EDM of locking on fasteners (bars, washers, dowel pins).
  - Pull out of dowel pins.
  - Detorque of bolts.
  - Removal of remaining parts of broken fasteners.
  
2. Preparation for installation of new design:
  - EDM pilot holes and counterboring.
  - EDM recess for mechanical locking of fasteners.
  - EDM recess for flexure and key.
  - EDM thread 1.5".
  - Thread cutting 1".
  - Reaming.
  
3. Final installation:
  - Press in dowels.
  - Torque bolts.
  - Locking of fasteners.

Tool testing in addition with original tools and equipment on mock ups.

# SCE THERMAL SHIELD SUPPORT SYSTEM REPLACEMENT DESIGN CRITERIA

- o DESIGN LIFE
  - Goal of 15 operating years
- o ASME CODE
  - The ASME Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, Section III, Subsection NG, does not apply to the thermal shield.
  - However, for conservatism the 1986 edition of the ASME Code, Section III, Subsection NG, will be used.
- o LOAD COMBINATIONS
  - Normal and Upset Conditions
    - o Deadweight + pressure + FIV
    - o Deadweight + pressure + seismic + FIV
    - o Deadweight + pressure + thermal + FIV
    - o Deadweight + pressure + seismic + thermal + FIV
  - Faulted Conditions
    - o Deadweight + pressure + seismic
- o NSSS OPERATING CONDITIONS
  - Flexure preload will be established based on 100% full power with reduced Tav<sub>g</sub> conditions.
  - Evaluations will also be performed to show acceptability at 92% full power at reduced Tav<sub>g</sub> conditions.
- o SEISMIC
  - Seismic condition loads will be considered in the design of the Thermal Shield Support System. The San Onofre Design Basis Earthquake Spectra used at the Reactor Vessel Supports is commonly referred to as the .67 g Modified Hausner Earthquake.



## DRAFT

### PROPOSED CODE CASE

Alternate limit on primary plus secondary stress intensity range permitted for austenitic stainless steel to use Design Fatigue Curve A in Figure I-9.2.2, Section III, Division 1.

**Inquiry:** When using the Design Fatigue Curve on Figure I-9.2.2 for austenitic stainless steel, is it permissible to limit the primary plus secondary stress intensity range excluding thermal bending to the elastic portion of the applicable cyclic stress-strain curve in lieu of meeting the specified value of 27.2 ksi?

**Reply:** It is permitted to use the minimum elastic limit of 44 ksi for austenitic stainless steel in the fatigue analysis in lieu of the specified value of 27.2 ksi to determine the acceptability of using Design Fatigue Curve A on Figure I-9.2.2. Keeping the primary plus secondary stress intensity range below this value of 44 ksi assures the fatigue analysis is independent of whether the applied loading is strain or load controlled.

## NRC QUESTIONS

- Q What is the material for the fastener locking devices?
- A Bolts & dowel pins 316 strain harden SS. 304 SS threaded locking plug for the 1.25" diameter dowel pins.
- Q Have these fasteners been corrosion tested after locking process? Has some surveillance or procedure documented results with respect to corrosion properties? Is there a qualification program?
- A No corrosion testing is performed because of extensive use in Europe. Approximately 4500 bolts have been installed in higher temperature and higher radiation fields than seen in this design. No failures observed to date.
- Q What is the material for the limiter keys, support blocks, flexures, and the thermal shield? Have they been corrosion tested after peening?
- A Limiter keys 304SS, support block 304SS, flexure XM-19, thermal shield SA-240 304 SS - no peening will be used.
- Q What is the method for ISI of new material? Have they been proven by industry? What confidence do we have that they won't break?
- A The lower support block fasteners will be ultrasonically tested next refueling. Future inspections will be incorporated into the ISI Program (VT3).
- Q Baffles - Westinghouse had problems with lateral flow, cross-flow through mechanical joints. Westinghouse did some peening to impede flow. Have these peened baffles exhibited cracking? Has anyone (Westinghouse) looked at this?
- A
1. No peening will be performed to lock the fasteners.
  2. No baffle cross flow fuel damage observed at SONGS 1.
  3. SONGS is an up-flow, not a down-flow design.
  4. SONGS does not have a high delta pressure drop across the baffle plates.



- Q Is there a contingency plan to remove the thermal shield?
- A Yes, Westinghouse is doing a feasibility study. Also, Pacific Nuclear is doing preliminary engineering on cask preparations.
- Q Why are neck down bolts used as fasteners in the support blocks?
- A Higher fatigue strength - more flexibility in the joint lower stresses in the bolt (1" bolts and .881" shank).
- Q Preloading will minimize stress in the flexure web area at operating temperatures and power levels. Is the operating condition used 92% power and reduced Tavg, or rated conditions? Will this impact the licensed power rating of SONGS 1 ?
- A Reduced temperature conditions were used for preload of the flexure. Preload will be established at 100% power with reduced Tavg. The design stress criteria will be met for 92% power and reduced Tavg.
- Q How does moving the location of one flexure reduce loading?
- A Analysis showed that moving the 21 degree flexure to 352 degrees reduced the stresses more than 10%.
- Q If water from the spent fuel pool drained to the cavity, could water level drop below the top of fuel assemblies in the pool?
- A The reactor cavity water level will be higher than the spent fuel pool water level.

Both the fuel transfer gate valve and the transfer gate will be closed. Hence, a double isolation is established.

Upon a postulated failure of the double isolation, and if the cavity water level should drop, approximately 3' of water will be maintained above the top of the fuel assemblies due to the presence of the wier wall.

## **CYCLE 12 REFUELING THERMAL SHIELD INSPECTIONS**

During the Cycle 11 support replacement, additional inspection ports will be added through the core barrel flange. These inspection ports will allow camera access through ports in the flange when the core barrel is in the reactor vessel. The planned inspections during the Cycle 12 refueling are as follows:

- A) Visually inspect the six upper flexures.
- B) Visually inspect the four upper limiter keys.
- C) Visually inspect the six lower supports.
- D) Ultrasonically examine the lower support fasteners at all six support blocks.
- E) Visually inspect a representative sample of the surveillance capsules and baskets.
- F) Visually inspect the lower vessel head region for debris.

This inspection plan, in conjunction with the continued monitoring system, will enable the condition of the thermal shield to be assessed.