

Group D
RECORDS BEING WITHHELD IN PART

<u>NO.</u>	<u>DATE</u>	<u>DESCRIPTION/(PAGE COUNT)/EXEMPTIONS</u>
1	04/27/09	Non-Concurrence Process on Evaluation of Duke September 26, 2008 Response Related to External Flooding at Oconee (19 pages) Exemption 7F
2	04/29/11	Oconee Nuclear Site, Units 1, 2, 3, Response to Confirmatory Action Letter (CAL) 2-10-003 (16 pages) Exemption 7F

NON-CONCURRENCE PROCESS

SECTION A - TO BE COMPLETED BY NON-CONCURRING INDIVIDUAL

TITLE OF DOCUMENT

ADAMS ACCESSION NO.

Evaluation of Duke September 26, 2008 Response Related to External Flooding at Oconee

ADAMS ACCESSION NO.

DOCUMENT SPONSOR

SPONSOR PHONE NO.

Joseph Gutter

301-415-1453

NAME OF NON-CONCURRING INDIVIDUAL

PHONE NO.

Melanie A. Galloway

301-415-2884

DOCUMENT AUTHOR



DOCUMENT CONTRIBUTOR

DOCUMENT REVIEWER



NON-CONCURRENCE

TITLE

ORGANIZATION

Deputy Director, Division of Risk Assessment

Office of Nuclear Reactor Regulation

REASON FOR NON-CONCURRENCE

See attached.

Note document is Official Use Only--Security-Related Information

CONTINUED IN SECTION D

Melanie A. Galloway

DATE
4/6/09

SUBMIT FORM TO DOCUMENT SPONSOR AND COPY TO YOUR IMMEDIATE SUPERVISOR AND
DIFFERING VIEWS PROGRAM MANAGER

NON-CONCURRENCE PROCESS

TITLE OF DOCUMENT

ADAMS ACCESSION NO.
ML090570779

**SECTION B - TO BE COMPLETED BY NON-CONCURRING INDIVIDUAL'S SUPERVISOR
(THIS SECTION SHOULD ONLY BE COMPLETED IF SUPERVISOR IS DIFFERENT THAN DOCUMENT SPONSOR.)**

NAME

Mark Cunningham

TITLE

Director, Division of Risk Assessment

PHONE NO.

301-415-2884

ORGANIZATION

NRR

COMMENTS FOR THE DOCUMENT SPONSOR TO CONSIDER


I HAVE NO COMMENTS

I HAVE THE FOLLOWING COMMENTS

1. I believe that the main points needing to be made in the document of concern were that:
 - a. The probabilistic evaluation being performed by the licensee could not demonstrate that dam failure was an "incredible" event, and thus such a failure had to be considered in the licensee's response to the 50.54(f) letter.
 - b. The licensee, therefore, had to perform deterministic evaluations of flood height. These had to consider a defensible range of key parameters affecting the predicted flood height.
2. In my judgment, other issues noted in Ms. Galloway's non-concurrence statement could be addressed in subsequent correspondence. That is, I judged it more important that this letter be sent to make the points noted above, rather than further delay its issuance to include discussion of these other issues.
3. I have encouraged and will continue to encourage Ms. Galloway to communicate her thoughts on this challenging issue. I believe her thoughts will help NRC to make appropriate and defensible decisions.

CONTINUED IN SECTION D

SIGNATURE



DATE

4/6/09

SUBMIT THIS PAGE TO DOCUMENT SPONSOR

~~OFFICIAL USE ONLY – SECURITY-RELATED INFORMATION~~

4/6/2009

I am non-concurring on the NRC response letter entitled "Evaluation of Duke Energy Carolinas, LLC (Duke) September 26, 2008, Response to Nuclear Regulatory Commission (NRC) Letter Dated August 15, 2008, Related to External Flooding at Oconee Nuclear Station, Units 1, 2, and 3 (Oconee) (TAC Nos. MD8224, MD8225, and MD8226)" (ML090570779) for the following two overarching reasons:

- (1) We do not require the licensee to perform its inundation analysis in a way that will allow the NRC to conclude with high confidence and sufficient safety margins that adequate protection is provided.
- (2) As a result, the letter does not clearly define a success path to timely resolution consistent with the significance of the issue.

The adequate protection issue arises from no defense in depth should the Standby Shutdown Facility (SSF) be inundated—with resultant core damage, containment failure, and damage to fuel in the spent fuel pool—and the lack of safety margin in the licensee's current analyses.

Background and explanation of significance of the issue

- No other potential initiating event at Oconee is as risk significant. The probability of core damage from a Jocassee Dam failure is three times higher than the sum total probability of core damage from all other initiating events. Duke has acknowledged that, given a Jocassee Dam failure with subsequent site inundation, all three Oconee units will go to core damage; that is, given a dam failure, the conditional core damage probability (CCDP) is 1.0. Thus, for a Jocassee Dam failure frequency of $2E-4$, there is a conditional core damage frequency (CCDF) of $2.0E-4$ ($CCDF = IEF \times CCDP$).
- For a Jocassee Dam failure, using potentially optimistic assumptions, Duke estimates that containment will fail approximately 59 to 68 hours after dam failure without mitigating actions.
- Under the dam break conditions, resultant flood waters and infrastructure damage would affect public evacuation and potentially affect Emergency Operations Facility response capability. Duke has not demonstrated that its radiological emergency plan actions can be adequately implemented under these conditions.
- To reduce risk from other, unrelated initiators, Duke is currently performing several modifications to the Oconee site. As the table below indicates, these modifications will improve risk less than improvements that would mitigate a Jocassee Dam failure.

~~OFFICIAL USE ONLY – SECURITY-RELATED INFORMATION~~

~~OFFICIAL USE ONLY – SECURITY-RELATED INFORMATION~~**Risk Reduction from
Ongoing Modifications**

Initiating Event	Decrease in CCDF
Tornado	6.8E-6
Internal Events	1.4E-5
HELB	1.0E-5
Fire	5.0E-5
Total of above	8.1E-5
(b)(7)(F)	

Explanation of specific reasons for non-concurrence

The overarching reasons for my non-concurrence above are supported by the following specific points. The specific points explain why I believe that the letter does not clearly communicate that information needed by NRC to resolve adequate protection of the Oconee units against external flooding.

1. NRC's regulations and guidance documents consistently convey the need to assess the most severe flooding, worst-case occurrences, highest water surface elevation, etc. (Refer to the attached document entitled "Applicable Regulatory Guidance Documents to External Flooding Issues Related to the Oconee Nuclear Site.") This letter does not communicate this information which would guide the licensee's assessment and appropriately define the regulatory criteria that will be used to ensure a sufficient and timely decision is rendered. Duke does not currently plan to perform an analysis which would ensure that such boundaries are considered consistent with NRC's deterministic licensing requirements, use current, state-of-the-art practices (probable maximum precipitation assumptions) nor does the letter as written request Duke to do so.
2. The letter does not take into account the insights gained by NRC technical experts nor insights conveyed to us by another Federal agency (Federal Energy Regulatory Commission) that would allow the licensee to be better positioned to provide the information we need to resolve this adequate protection issue. (Refer to the draft memo, "Transmittal of NRO Staff Technical Evaluation of Duke Power Company's Assessment of Postulated Jocassee Dam Failure Impacts on Oconee Nuclear Station" (ML090570570) for documentation of insights.) I have attached an e-mail dated March 11, 2009, and include excerpts from the two attachments to that e-mail to include two alternate paragraphs, either of which could be added to the letter to address this point.
3. The letter does not request Duke to consider more current information related to whether an overtopping event can occur at Jocassee Dam. The current Duke analysis of the probable maximum precipitation does not consider an antecedent storm or the saturated soil conditions that would result from an antecedent storm. Doing so is current practice and could impact whether the dam overtops. Given the greater volume of water, dam overtopping results in the most significant inundation, and, given

~~OFFICIAL USE ONLY – SECURITY-RELATED INFORMATION~~

~~OFFICIAL USE ONLY - SECURITY-RELATED INFORMATION~~

- the significance of the issue, needs to be considered to ensure demonstration of adequate protection. I recommend that the letter be modified such that the phrase "reservoir levels" read as "reservoir levels including overtopping."
4. The letter does not request that Duke answer questions on the seismic capability of the Jocassee Dam. Questions in the seismic arena were raised by an agency seismology expert as a result of his review of a 2007 fragility study that Duke submitted in relation to the Reactor Oversight Process issue regarding the hole in the SSF wall. The seismic issue needs to be resolved before NRC can conclude that adequate protection against external flooding is provided. The letter should include the seismic questions that were conveyed at the December 4, 2008, meeting or refer to another communication with an indication that an adequate response is expected as part of our adequate protection determination.
 5. The letter, by not requesting a due date for the analyses, implies that we will accept November 2009 as a submittal date. I recommend that the letter reflect our statement at the November 5, 2008, management meeting that technical resolution be achieved within one year. As such, the letter should reflect a date for Duke to submit its inundation/sensitivity studies consistent with practicality in use of the HEC-RAS code (2-4 months from date of letter) that will support and more likely assure agreed-upon technical resolution by November 2009.

Summary

Given the high safety significance of the issue, it behooves the NRC to ensure the most efficient path to resolution; my concerns surround the fact that the letter does not achieve that objective. Given the significant staff expertise in flood analysis, seismic engineering, and probabilistic risk assessment, I believe that the technical analysis done by these staff to date is sound and supports a clear communication to the licensee regarding our needs to resolve this issue. The staff's expertise in these areas was augmented through face-to-face meetings with representatives of FERC. The analysis done by these staff and the interactions need to be brought to bear in this letter. Further, the letter as currently written, may result in more than one iteration of analysis with the licensee which will burden both staff and licensee resources and add months of additional time to reach resolution. Results of the staff's flooding and seismic analyses were presented to the licensee at meetings on November 5 and December 4, 2008, so not doing so now seems to imply that we are backing away from our earlier positions. I also am concerned that an approach that does not seek the most efficient path is not one that the agency can defend well to outside stakeholders. In conclusion, I remain concerned that this approach is not in the best interest of public health and safety and security, regulatory stability, and our role as a strong regulator.

~~OFFICIAL USE ONLY - SECURITY-RELATED INFORMATION~~

APPLICABLE REGULATORY GUIDANCE DOCUMENTS TO EXTERNAL FLOODING ISSUES RELATED TO POTENTIAL DAM FAILURES

EXECUTIVE SUMMARY

The following text provides a summary of applicable regulatory guidance on external flooding issues related to potential dam failures, with emphasis on failures due to causes other than severe precipitation and seismic activity (i.e., covering random dam failures).

The references covered include General Design Criterion (GDC) 2, per 10CFR Part 50, Regulatory Guides, Standard Review Plans, and applicable industry standards.

Four Standard Review Plans (SRPs) are directly related to the issue of external flooding. Evaluation of flooding analysis to appropriate postulations of the "worst-case flooding scenario" is mentioned for sites on streams and rivers. For flood waves resulting from a dam breach or failure, the resulting "highest water surface elevation" affecting an SSC important to safety is indicated as an area for review, where failure of a single upstream dam that has the "most severe impact on the site" should be evaluated using conservative assumptions. All four SRPs make explicit reference to Regulatory Guide 1.59 to be used as guidance by the staff "as supplemented by best current practices."

Regulatory Guide (RG) 1.59 indicates that the conditions resulting from the "worst site-related flood probable" at the reactor site (plus attendant wave-activity) constitutes the design basis flood conditions that safety-related SSCs "should be designed to withstand and retain capability for cold shutdown and maintenance thereof." The specific guidance provided in RG 1.59 for such cases indicates that combinations where the probability of occurrence is "at least comparable" to the most severe hydrometeorological or seismically induced flood should be considered. Appendix A to RG 1.59 incorporates by reference the standard N170-1976, "Standards for Determining Design Basis Flooding at Power Reactor Sites" (for which the most recent revision is ANSI/ANS-2.8-1992). This 1992 revision of the standard is also referred to in the SRPs mentioned above.

ANSI/ANS-2.8-1992 states that "Nuclear reactor safety from flooding needs to be ensured not only in floods from extreme precipitation but in floods from other causes as well. Surges from upstream dam failures from nonhydrologic causes constitute potential threats." ANSI/ANS-2.8-1992 includes in the events that shall be considered to determine the controlling flood elevations (single or in combination) the failures of upstream dams from "hydrologic, seismic, or other causes."

Regulatory Issue Summary (RIS) 2001-02 also delineates a process that can be used when NRC's responsibility to ensure reasonable assurance of adequate protection at a site needs to go beyond the regulation.

APPLICABLE REGULATORY GUIDANCE DOCUMENTS TO EXTERNAL FLOODING ISSUES RELATED TO POTENTIAL DAM FAILURES

GDC 2 and Pre-GDC 2 Oconee UFSAR Commitments

The Oconee Nuclear Site (ONS) UFSAR Section 3.1.2 contains a description of the station's design criterion titled "Criterion 2 – Performance Standards (Category A)," which is hereafter called "Pre-GDC 2 Criterion." Oconee's Pre-GDC 2 criterion requires that:

Those systems and components of reactor facilities which are essential to the prevention of accidents which could affect the public health and safety or to mitigation of their consequences shall be designed, fabricated and erected to performance standards that will enable the facility to withstand, without loss of the capability to protect the public, the additional forces that might be imposed by natural phenomena such as earthquakes, tornadoes, flooding conditions, winds, ice, and other local site effects. The design bases so established shall reflect: (a) appropriate consideration of the most severe of these natural phenomena that have been recorded for the site and the surrounding area and (b) an appropriate margin for withstanding forces greater than those recorded to reflect uncertainties about the historical data and their suitability as a basis for design.

The Oconee UFSAR Section 3.1.2 includes "earthquake" as one of the natural phenomena, which the SSCs should be able to withstand, without loss of capability to protect the public, the additional forces that might be imposed by natural phenomena. It further states that the designs are based upon the most severe of the natural phenomena recorded for the vicinity of the site, with an appropriate margin to account for uncertainties in the historical data.

The Oconee Station's pre-GDC 2 requirements appear to be quite similar, in their scope, to those of the current GDC 2 criterion included in 10 CFR Part 50 Appendix A:

SSCs important to safety shall be designed to withstand the effects of natural phenomena such as earthquakes, tornadoes, hurricanes, floods, tsunami, and seiches without loss of capability to perform their safety functions. The design bases for these SSCs shall reflect: (1) Appropriate consideration of the most severe of the natural phenomena that have been historically reported for the site and the surrounding area, with sufficient margin for the limited accuracy, quantity and period of time in which the historical data have been accumulated, (2) appropriate combinations of the effects of normal and accident conditions with the effects of the natural phenomena, and (3) the importance of the safety functions to be performed.

Applicable Standard Review Plans (SRPs)

Four SRPs are directly related to the issue of external flooding: 2.4.2, 2.4.2, 2.4.3, 2.4.4, and 2.4.10. All four SRP make the following reference to RG 1.59:

Appropriate sections of the following Regulatory Guides are used by the staff for the identified acceptance criteria: ... Regulatory Guide 1.59, as supplemented by best current practices, provides guidance for developing the hydrometeorological design bases ...

Furthermore, all SRPs reference the standard ANSI/ANS-2.8-1992 in either the main text or the reference list. In particular, SRP 2.4.2 states the following:

ANSI/ANS-2.8-1992 provides guidance for determination of appropriate combinations of flooding mechanisms along with their relative severity within the combined events. The staff uses the recommendations of ANSI/ANS-2.8-1992, supplemented with best current practices, to review the applicant's submittal in order to ensure that the most severe flood at the plant site has been determined.

A brief summary is provided below, followed by additional excerpted main statements (blue italic) from the individual SRPs:

SRP 2.4.2 "Floods"

This SRP provides guidance in performing safety reviews of historical flooding bases with respect to individual types of flood-producing phenomena and combinations thereof. Guidance related to dam failure includes consideration of stream flooding with review of the PMF with coincident wind-induced waves due to dam failure potential.

The flood history and the potential for flooding are reviewed for the sources and events listed below. . . . The review covers the following specific areas:

Section 2 Stream Flooding

The application should include documentation of the potential sources of flood and flood response characteristics. Depending on the hydrology in the watershed where the proposed site is located, estimates of tributary contributing area, PMF, coincident wind-induced waves, floods produced due to dam failures, and combinations of less severe river floods with coincident surges and seiches should be provided.

Section 6 Seismically Induced Dam Failures (or Breaches)

The application should include the flooding hazard at the plant site resulting from seismically induced dam failure upstream of the site location.

Section 9 Combined Events Criteria

The staff reviews the combinations of individual flooding mechanisms that are reasonably possible. It is possible that a combination of two or more flooding mechanisms that individually result in floods less severe than their respective worst-case occurrences may combine due to dependence among themselves and result in a more severe flood than the worst case of any one of the mechanisms occurring in isolation.

SRP Section 2.4.3, "Probable Maximum Flood (PMF) on Streams and Rivers"

"Probable Maximum Flood (PMF) on Streams and Rivers" describes the procedures for determining the PMF using the information related to the reservoirs in the region available from the US Army Corps of Engineers, U.S. Geological Survey and the National Inventory of Dams.

The staff's review should include evaluation of pertinent information to determine if these criteria are appropriately used in postulation of the worst-case flooding scenario at the proposed plant site and in the adjacent streams and rivers.

SRP Section 2.4.4, "Potential Dam Failures"

This SRP section deals directly with guidance on the review of potential failure of onsite, upstream, and downstream water control structures. Specific areas identified with respect to dam failure include dynamic effects (flood waves), cascading failures, and failure of onsite water control or storage structures.

Flood Waves from Severe Breaching of an Upstream Dam: Flood waves resulting from a dam breach or failure, including those due to hydrologic failure as a result of overtopping for any reason, routed to the site and the resulting highest water surface elevation that may result in flooding of SSC important to safety

Flood Waves from Severe Breaching of an Upstream Dam: The location of dams and potentially "likely" or severe modes of failure are identified. Failure of a single upstream dam that has the most severe impact on the site should be evaluated using a conservative mode of dam failure, consideration of reservoir level at full pool, and appropriate combination of antecedent flows as described by ANSI/ANS-2.8-1992.

Domino-Type or Cascading Dam Failures: To meet the requirements of GDC 2, 10 CFR 52.17, 10 CFR Part 100, and 10 CFR 100.23(d), an appropriate configuration of the cascade of dam failures and its potential to produce the largest flood adjacent to the plant site is needed. Several possible cascading dam failures should be investigated, including those induced by seismic and hydrological failures.

SRP Section 2.4.10, "Flooding Protection Requirements"

SRP 2.4.10 provides guidance on the comparison between the information reviewed in previous sections regarding the design-basis flood conditions and the potential effects on safety-related facilities for a given location and elevation. Also included in the guidance are considerations of types of flood protection (e.g., "hardened facilities", sandbags, bulkhead, etc.) and emergency procedures, as outlined in RG 1.102.

In this section of the safety analysis report (SAR), the hydrological design basis is developed to ensure that any potential hazard to the safety-related facilities due to the failure of onsite, upstream, and downstream water control structures are considered in plant design.

Regulatory Guides

The following two Regulatory Guides provide guidance directly related to external flooding issues:

Regulatory Guide 1.59, "Design Basis Floods for Nuclear Power Plants", Rev. 2, 1977

This Regulatory Guide describes acceptable methods of determining design basis floods, referencing the American National Standards Institute (ANSI) Standard N170-1976 (ANS 2.8), "Standards for Determining Design Basis Flooding at Power Reactor Sites" almost in its entirety as the source for estimating Probable Maximum Floods (PMF), with the exception of specific portions related to the evaluation of erosion failure. GDC 2 is explicitly mentioned in RG 1.59.

Nuclear power plants should be designed to prevent the loss of capability for cold shutdown and maintenance thereof resulting from the most severe flood conditions that can reasonably be predicted to occur at a site as a result of severe hydrometeorological conditions, seismic activity, or both.

The conditions resulting from the worst site-related flood probable at the nuclear power plant (e.g., PMF, seismically induced flood, seiche, surge, severe local precipitation) with attendant wind-generated wave activity constitute the design basis flood conditions that safety-related structures, systems, and components identified in Regulatory Guide 1.291 should be designed to withstand and retain capability for cold shutdown and maintenance thereof.

For sites along streams, the PMF generally provides the design basis flood. For sites along lakes or seashores, a flood condition of comparable severity could be produced by the most severe combination of hydrometeorological parameters reasonably possible, ... or a reasonable combination of less severe phenomenologically caused flooding events should be considered in arriving at design basis flood conditions comparable in frequency of occurrence with a PMF on streams.

The material previously contained in Appendix A has been replaced by American National Standards Institute (ANSI) Standard N170-1976, "Standards for Determining Design Basis Flooding at Power Reactor Sites," with the following exception:

Sections 5.5.4.2.3 and 5.5.5 of ANSI N170-1976 contain references to methods for evaluating the erosion failure of earth fill or rock fill dams and determining the resulting outflow hydrographs. The staff has found that some of these methods may not be conservative because they predict slower rates of erosion than have historically occurred. Modifications to the models may be made to increase their conservatism. Such modifications will be reviewed by the NRC staff on a case-by-case basis.

Regulatory Guide 1.102, "Flood Protection for Nuclear Power Plants", Rev. 1, 1976, describes the acceptable types of flood protection for the structures, systems and components (see also SRP 2.4.10).

For purposes of this guide, the Design Basis Flooding Level (DBFL) is defined as the maximum water elevation attained by the controlling flood, including coincident wind-generated wave effects. The wind-generated wave component of elevation is generally controlled by fetch and water depth and may differ at locations around the plant. Further distinction must be made between estimates of "structural" effects (i.e., static and dynamic forces) and flooding or inundation effects. Additionally, the controlling flood event may be different for evaluating structural effects than for evaluating inundation effects. For example, the Probable Maximum Flood (PMF) may produce the highest water level and static forces on a given structure, but the total static and dynamic forces on the structure may be greater during a smaller (in elevation) flood wave from the seismically induced failure of an upstream dam.

Applicable Standards

The following two standards provide guidance directly related to external flooding issues:

ANSI/ANS-2.8-1992, "Determining Design Basis Flooding at Power Reactor Sites"

This standard was prepared by the American Nuclear Standard (ANS) Working Group ANS-2.8. It was first revised in 1981 (and published as ANSI/ANS-2.8-1981), with a second and latest revision performed in 1992 (ANSI/ANS-2.8-1992), being withdrawn in 2002. ANSI/ANS-2.8-1992 provides guidance on plant safety related to flooding; including considerations of hydrological and nonhydrological dam failures; and evaluation criteria for combinations of events.

Section 4.2.1 Flood-Causing Event

No single flood causing event is an adequate design base for a power reactor. Usual principal factors are precipitation, antecedent moisture, and wind, but special factors include dam failures from differing causes. Events that shall be considered to determine the controlling flood elevations are one, or appropriate combination of any, of the following as outlined in Section 9, Combined Events Criteria: (2) Failure of dams and other man-made structures from hydrologic, seismic, or other causes upstream, downstream, and on site.

Analyses of dam failures are complex, many failures not being completely understood. The principal uncertainty involves likely mode and degree of failure. Uncertainties can be circumvented in situations where it can be shown that the complete and sudden disappearance of a dam or dams will not endanger the nuclear plant. Otherwise, reasonable failure postulations shall be used.

Section 5.5.4.2.3 Earth and Rockfill

Earth and rock embankments shall be evaluated for breaching from overtopping. If there are two or more independent embankments, it may be necessary to fail only one if it produces the most critical flood wave. ... If no overtopping is demonstrated, the evaluation may be terminated and the embankment may be declared safe from hydrologic failure. ... Caution shall be exercised in the selection of the method to be used for each site-specific problem. Additionally, the sensitivity to parameter changes and event timing shall be thoroughly investigated for each analysis.

Section 6.3 Dam Failures from Other Causes

Potential dam failures from earthquakes are associated with sharply defined natural events of a few moments' duration and failures from extreme floods with natural events of a few hours', days', or weeks' duration. Dam failures from other onsite causes might result from gradual changes in, under, and adjacent to the dam. With proper inspection and monitoring, gradual changes threatening dam safety might be detected and adequate corrective measures can be taken.

Section 6.3.2 Failure Causes

On-site potential causes of partial or complete dam failure include the following:

- (1) Deterioration of concrete due to cracking, weathering, or chemical growth.
- (2) Deterioration of embankment protection such as riprap or grass cover.
- (3) Excessive saturation of downstream face or toe of embankment.
- (4) Excessive embankment settlement.
- (5) Cracking of embankment due to uneven settlement.
- (6) Erosion or cavitation in waterways and channels, including spillways.
- (7) Excessive pore pressure in structure, foundation, or abutment.
- (8) Failure of spillway gates to operate during flood because of mechanical or electrical breakdown or clogging with debris.
- (9) Buildup of silt load against dam.
- (10) Excessive leakage through foundation
- (11) Leakage along conduit in embankment.
- (12) Channels from tree roots or burrowing
- (13) Excessive reservoir rim leakage.
- (14) Landslide in reservoir.

Section 9.2.4 Nonhydrologic and Nonseismic Dam Failures

No specific guidance or specific event combinations are provided in this standard because of uncertainty in postulating a realistic dam failure from nonhydrologic and nonseismic causes. Refer to 6.3

ANSI/ANS-2.12-1978, "Guidelines for Combining Natural and External Man-Made Hazards at Power Reactor Sites," withdrawn

While no ONS reference was found to RG 1.59 or ANS-2.8 standards, ANSI/ANS-2.12-1978 is referenced in Ocone's Unit 1 & 2 IPEEE submittal (December, 1995) under the General Methodology section. "Natural and man-made external events of interest were identified using other PRAs, NSAC/60, ANSI/ANS-2.12 (Ref. 2.3), and the aforementioned NUREG/CR-2300."

The purpose of this standard, as stated, is "to establish a methodology for identifying combinations of natural hazards and external man-made hazards for consideration in plant design. As existing standards do not cover all of the individual external man-made hazards, this standard can also serve as a reference which a designer can use in examining a specific site for protection against individual external man-made hazards." Although mentioned in ANSI/ANS-2.8, no specific guidance is provided for combinations including flooding due to dam failures from causes other than seismic and severe precipitation in ANSI/ANS-2.8 itself. A particular type of hazard identified in ANSI/ANS-2.12 is a "retaining structure failure" which encompasses failure of a dam due to causes "other than flood, earthquake or tsunami" as a man-made hazard "which occurs external to a nuclear power generating station" with the potential to affect safety-related structures.

ANSI/ANS-2.12 uses 10^{-7} per year as a screening threshold, in order to "establish a division between combinations of natural hazards and external manmade hazards which must be considered in the plant design and those which need not be considered." Additionally, ANSI/ANS-2.12 explicitly cautions that "overall safety risk to the public due to a hazard is

concerned (sic) not only with the probability of occurrence of the hazardous event but also with the probability that an essential safety function is significantly impaired by the event such that there is release of radioactivity. Specific evaluation of such consequences is beyond the scope of this standard, but should be considered in the final selection of combined events to be used for plant design." In other words, the designer must consider not only the probability of occurrence (i.e., initiating event frequency) but also the consequence of the occurrence (i.e., conditional core damage probability). Duke has stated in their letter to the NRC dated September 26th, 2008 that the CCDF for an inundation of the ONS is 1.0.

This standard provides a conservative dam failure screening frequency of 10^{-4} per dam-years. It further states that it would be up to the "plant designer to further investigate the failure probabilities for dams and other water retaining structures in his area to determine whether lower hazard probabilities are justifiable."

STATUTORY AUTHORITY ABOVE AND BEYOND EXISTING REGULATION

The Regulatory Issue Summary (RIS) 2001-02, "Guidance on Risk-Informed Decisionmaking in License Amendment Reviews," describes the use of risk information in license amendment activities. It states in part:

"When a license amendment request complies with the regulations and other license requirements, there is a presumption by the Commission of adequate protection of public health and safety (Maine Yankee, ALAB-161, 6 AEC 1003 (1973)). However, circumstances may arise in which new information reveals an unforeseen hazard or a substantially greater potential for a known hazard to occur, such as identification of a design vulnerability or an issue that substantially increases risk. In such situations, the NRC has the statutory authority to require licensee action above and beyond existing regulations to maintain the level of protection necessary to avoid undue risk to public health and safety."

The above guidance clearly directs the NRC to look beyond the existing regulation to ensure adequate protection in license applications. In a draft Davis Besse order on reactor head nozzles circumferential cracking sent to the Commissioners dated November 21, 2001 (ML022700327), the EDO states:

"Regulatory Issue Summary 2001-02, ... provides a process for the staff to consider whether a special circumstance exists which may rebut the presumption that compliance with the regulations provides adequate protection of public health and safety. Although developed as a tool for staff reviews of license amendment requests, the process in Regulatory Issue Summary 2001-02 is appropriate for other regulatory decisionmaking purposes because it addresses a fundamental requirement for operation of a nuclear reactor, i.e., reasonable assurance of adequate protection of public health and safety."

This RIS delineates a process and the EDO's memo requires the NRC needs to look beyond the regulation to ensure compliance with the Atomic Energy Act adequate protection mandate if a licensee is found to meet all the applicable regulation but a significant safety issue still persists.

From: Melame Galloway
Sent: Wednesday, March 11, 2009 3:13 PM
To: Mark Cunningham; David Skeen; Patrick Hiland; Joseph Glitter; Jack Grobe; Bruce Boger
Cc: Allen Howe; Nitesh Chokshi; Scott Flanders; Brian Holian
Subject: two versions reflecting 2 options on sensitivity study

All

I've attached two versions illustrating two different options for requesting the sensitivity studies

V2 includes the request that I understood came from the 2/26 meeting with Joe, Pat, Dave, Jack and Brian
V3 includes the request that I worked on with NRO.

Both versions have the same result in that they provide clearer expectations to the licensee in terms of the bounds of the sensitivity analysis and resolve several issues I see with the current wording. Namely:

1. Either version will provide a higher degree of likelihood that the licensee's analyses will meet our expectations with only one request, creating efficiency for both the licensee in their analysis and us in review.
2. As a result of item 1., we should have a quicker path to resolution and thus put this issue behind us.
3. The +/- 50% is an arbitrary request and one we are hard pressed to explain. By contrast, the two versions rely on current methods and/or FERC guidelines (depending on which version you look at) that provide a defensible basis we can rely on when asking Duke to perform sensitivity analysis.

Also, note that I have included a request for Duke to consider overtopping reservoir levels when doing the sensitivity analysis. When considering adequate protection, we are to look at current information and standards and doing so gives rise to saturated soil and runoff considerations not included in Duke's current analysis.

These issues likely require additional discussion. I know Jack said there would be another meeting but with the RIC this week and new versions being offered, I don't want to wait to present these alternate views.

Melanie

Excerpts from Attachments to March 11, 2009, E-Mail Showing Alternate Paragraphs that Could be Added to Letter to Address Points 2 and 3 of Non-Concurrence
(note that exact wording is not important but rather the concept is what is important)

Option 1: Includes Calculated Staff Values as Boundaries for Duke to Perform Sensitivity Studies

In your response to the 50.54(f) letter, Duke committed to perform inundation studies using the more advanced HEC-RAS model. The response also indicated that Duke would perform sensitivity studies using the more advanced HEC-RAS model to further understand the effects on flood levels at the SSF. The NRC agrees that a study with the more advanced model and a sensitivity analysis is necessary because of the uncertainty involved in predicting dam failure and resultant flood levels at the Oconee site. Key parameters (breach size, reservoir levels including overtopping, time to dam failure, etc.) should be varied over a sufficient range (as shown in Table 1) to provide an understanding of how changes to those parameters impact the flood height estimates. These values were obtained from NRC calculations using current methods, referenced in U.S. Army Corps of Engineers and U.S. Bureau of Reclamation documents. This sensitivity analysis should not be limited to one-at-a-time parameter variations. You will note that the sensitivity analysis requested includes an assessment across possible NRCS curve numbers. Variation of this parameter is included because your chosen curve number does not appear reflective of the precipitation and runoff expected during a probable maximum precipitation (PMP) event. Should you choose ranges different from those presented in Table 1, you should provide the associated justification for doing so.

Table 1
Jocassee Dam Model Input Parameters

Parameter	Minimum Value	Maximum Value
Jocassee Dam base breach width (ft.)	150	430
Jocassee Dam top breach width (ft.)	1445	1770
Jocassee Dam bottom breach elevation (ft. MSL)	730	800
Jocassee Dam time to failure (hrs.)	1	2
Jocassee Reservoir level (ft. MSL)	1105	1125
Keowee Reservoir level	730	815
NRCS Curve number	55	80

MSL = mean sea level

Option 2: Includes Qualitative Discussion to Guide Duke's Sensitivity Studies

In your response to the 50.54(f) letter, Duke committed to perform inundation studies using the more advanced HEC-RAS model. The response also indicated that Duke would perform sensitivity studies using the more advanced HEC-RAS model to further understand the effects on flood levels at the SSF. The NRC agrees that a study with the more advanced model and a sensitivity analysis is necessary because of the uncertainty involved in predicting dam failure and resultant flood levels at the Oconee site. Key parameters (breach size, reservoir levels including overtopping, time to dam failure, etc.) should be varied over a sufficient range to provide an understanding of how

changes to those parameters impact the flood height estimates. The parameters selected and the ranges of those parameters should be justified and should represent a conservative range of hypothetical conditions. The NRC has reviewed the Federal Energy Regulatory Commission guidance regarding breach size and time to failure. The FERC guidelines represent appropriate ranges for a sensitivity analysis. We have also conducted assessments using current methods, referenced in U.S. Army Corps of Engineers and U.S. Bureau of Reclamation documents. Our resulting calculated values for some of the critical parameters, including breach size and time to failure, for Joeassee Dam analyses are within the ranges of the FERC guidelines and confirm the appropriateness of these guidelines for a sensitivity analysis. In your sensitivity analysis, you should evaluate whether additional parameters, beyond those identified by the staff, need to be varied over appropriate ranges to estimate the inundation flood levels. Your analysis should consider variation of several parameters simultaneously. We recommend that we meet to discuss your sensitivity analysis plan before you undertake the analysis to establish mutual understanding and avoid unnecessary reiterative efforts

NON-CONCURRENCE PROCESS

TITLE OF DOCUMENT Evaluation of Duke September 26, 2008 Response Related to External Flooding at Oconee	ADAMS ACCESSION NO. ML090570779
---	---

SECTION C - TO BE COMPLETED BY DOCUMENT SPONSOR

NAME
Joseph Güttler

TITLE Director Division of Operating Reactor Licensing	PHONE NO. 301-415-1453
--	----------------------------------

ORGANIZATION
NRR

ACTIONS TAKEN TO ADDRESS NON-CONCURRENCE (This section should be revised, as necessary, to reflect the final outcome of the non-concurrence process, including a complete discussion of how individual concerns were addressed.)

See the attached response.

CONTINUED IN SECTION D

SIGNATURE - DOCUMENT SPONSOR <i>Joseph G. Güttler</i>	DATE 4/27/09	SIGNATURE - DOCUMENT SIGNER <i>Joseph G. Güttler</i>	DATE 4/27/09
--	------------------------	---	------------------------

NON-CONCURRING INDIVIDUAL (To be completed by document sponsor when process is complete, i.e., after document is signed):

- | | |
|---|---|
| <input type="checkbox"/> CONCURS | <input type="checkbox"/> WANTS NCP FORM PUBLIC |
| <input checked="" type="checkbox"/> NON-CONCURS | <input checked="" type="checkbox"/> WANTS NCP FORM NON-PUBLIC |
| <input type="checkbox"/> WITHDRAWS NON-CONCURRENCE (i.e., discontinues process) | |

Document Sponsor Response to Non-concurrence on the Evaluation of Duke September 26, 2008 Response Related to External Flooding at Oconee

Background and basis for letter

The potential safety significance of this issue was the basis for the NRC's issuance of a 10 CFR 50.54(f) letter to Duke in August 2008. One of the key drivers for the NRC's letter was the recognition that the previous estimates for the probability of a random dam failure were an order of magnitude smaller than they should have been.

The purpose of the NRC's letter to Duke Energy was to convey the following key points as summarized below:

- Duke's September response to the 50.54(f) letter did not address NRC's concerns and demonstrate that Oconee will be adequately protected in the long term from external flooding events. NRC staff's position is that a Jocassee Dam failure is a credible event and needs to be addressed deterministically.
- In the short term, NRC staff has concluded that there is not an immediate safety concern necessitating prompt modification or suspension of the Oconee license for the short term based on FERC inspections, monitoring by Duke, the current low level of the Jocassee Lake, the sufficiently low estimated random failure frequency of the dam, and the timeliness in the failure sequence that would allow for mitigating actions.
- To resolve these issues, Duke must provide a technically defensible inundation study supporting the protection of Oconee from offsite flooding with an associated sensitivity analysis. This study and sensitivity analyses were identified in Duke's 50.54(f) response.
- The sensitivity analyses must include varying key parameters that can affect the on-site flood height (e.g., breach size, reservoir levels, time to dam failure) individually and in combination over a sufficient range to provide an understanding of how changes impact the flood height estimates. The selection of parameters to be varied and the range of variability for those parameters need to be justified.
- The NRC staff expects that the analyses to establish an adequate licensing basis for external flooding be completed by November 2009.

Actions preceding the non-concurrence:

In the course of developing the letter to Duke, NRR management, including the non-concurring person, discussed issues to be addressed in the letter. At these meetings, the non-concurring person's alternate views were discussed and not successfully resolved for the non-concurring person.

The non-concurring person briefed the ET on January 14, 2009, on the safety significance of the issue and the basis for allowing continued operation while the issue was being resolved. At that meeting, the non-concurring person presented a basis for allowing continued operation of the Oconee facility for the next two years, thus defining NRC's timeline for resolution of the issues. As a part of discussing this non-concurrence response with the document sponsor, the non-

concurring person questioned whether the current plans continue to support this 2-year timeline for issue resolution.

Actions taken after the non-concurrence:

The non-concurrence references the need for the letter to address NRC's requirements and guidance as well as consideration of insights from staff and from other Federal agencies. At a meeting on April 3, 2009, and in other discussions prior to that meeting, the need to develop NRC guidelines or criteria for assessing the information provided by the licensee was discussed. Ultimately, NRR must determine the adequacy of Duke's inundation study. Given the complexity of the licensing issues in this case, there may be more than one way to evaluate the licensee's inundation study. It is the licensee's responsibility to perform an adequate external flood analysis and provide justification for the parameters used to the NRC. NRR-DE has initiated the development of a plan to reach final resolution on this issue, including establishing an approach to judge the adequacy of the flood analysis provided by Duke. To that end, DE has engaged the Bureau of Reclamation to provide additional input to NRC in evaluating the information that will be provided by Duke. NRR will consider this and the other developed inputs, including the considerations developed by NRO (currently in draft), to determine the adequacy of the licensee inundation study.

In addition, the non-concurrence references an email describing options for the letter to Duke to stipulate what would be needed to address NRC's concerns. The letter to Duke has been revised to reference FERC guidelines or other applicable industry standards as potential methods to represent appropriate ranges for a sensitivity analysis.

The non concurrence discusses the schedule for resolution of the issue. The letter was revised to include the staff's expectation to hold regularly scheduled meetings with Duke (e.g., monthly) to ensure the licensee is taking action to facilitate timely resolution of this issue. The goal is to reach a conclusion that Oconee is adequately protected in the event of a flood caused by the failure of the Jocassee dam. To that end, NRC will need to reach a decision on an acceptable estimate of the flood height at the site and for the licensee to provide a schedule for making any necessary physical modifications to the plant, by November 2009.

The non-concurrence and the response to the non-concurrence were provided to the individuals involved in concurrence of the letter to Duke.

Conclusion

The letter is intended to be a step in the resolution of this issue, as a final NRC decision has not been made on the adequacy of Oconee's external flood protection. The technical issues raised in the non-concurrence are either addressed above, or will be considered further during final resolution of this matter. Further action to resolve the overall issue is being led by the Division of Engineering. The document sponsor agrees with the non-concurring person's supervisor, that the appropriate issues can be addressed in subsequent correspondence. Finally, in response to selected concerns in the non-concurrence, the letter has been modified to include a reference to FERC guidelines or other industry standards as potential methods to develop sensitivity analysis parameters; and the expectation that the schedule for technical resolution, including NRC review, is November 2009.



~~This letter contains security sensitive information.
Withhold from Public Disclosure under 10CFR 2.390 (d)(1)~~

T. PRESTON GILLESPIE, JR.
Vice President
Oconee Nuclear Station

April 29, 2011

Duke Energy
ON01VP / 7800 Rochester Hwy.
Seneca, SC 29672

864-873-4478
864-873-4208 fax
T.Gillespie@duke-energy.com

Mr. Victor McCree, Regional Administrator
U.S. Nuclear Regulatory Commission – Region II
Marquis One Tower
245 Peachtree Center Ave., NE, Suite 1200
Atlanta, Georgia 30303-1257

Subject: Duke Energy Carolinas, LLC
Oconee Nuclear Site, Units 1, 2, and 3
Renewed Facility Operating License, DPR-38, DPR-47, and DPR-55
Docket Numbers 50-269, 50-270, and 50-287
Oconee Response to Confirmatory Action Letter (CAL) 2-10-003

References:

1. Nuclear Regulatory Commission (NRC) letter from Luis A. Reyes to Dave Baxter (Duke Energy), "Confirmatory Action Letter – Oconee Nuclear Station, Units 1, 2, and 3 Commitments to Address External Flooding Concerns (TAC Nos. ME3065, ME3066, and ME3067)" dated June 22, 2010
2. Nuclear Regulatory Commission (NRC) letter from Eric Leeds to Preston Gillespie (Duke Energy), "Staff Assessment of Duke's Response to Confirmatory Action Letter Regarding Duke's Commitments to Address External Flooding Concerns at the Oconee Nuclear Station, Units 1, 2, and 3 (ONS) (TAC Nos. ME3065, ME3066, and ME3067)" dated January 28, 2011
3. Duke Energy letter from T. Preston Gillespie to Luis Reyes (Nuclear Regulatory Commission), "Oconee Response to Confirmatory Action Letter (CAL) 2-10-003" dated November 29, 2010
4. Duke Energy letter from Dave Baxter to U.S. Nuclear Regulatory Commission, "Oconee External Flood Interim Actions" dated January 15, 2010

The purpose of this letter is to respond to the NRC's request, as noted in the Confirmatory Action Letter dated June 22, 2010 (Reference 1), for a list of all modifications necessary to adequately protect the Oconee site from the impact of a postulated failure of the Jocassee Dam.

~~This letter contains security sensitive information.
Withhold from Public Disclosure under 10CFR 2.390 (d)(1)~~

Victor McCree
Nuclear Regulatory Commission
April 29, 2011
Page 2

Duke Energy agreed to provide this list and the associated implementation dates by April 30, 2011 (Reference 3).

In Reference 2, the NRC found that the documentation previously supplied by Duke Energy provided sufficient justification that the parameters and analysis used to evaluate the inundation of the Oconee Nuclear Station (ONS) site, resulting from the postulated failure of the Jocassee Dam, were bounded. The information provided by Duke Energy was in response to one of the NRC's requests in Reference 1.

Attachment 1 is a proposed strategy for mitigating the external flood impacts from a postulated failure of the Jocassee Dam. Calculations supporting this strategy are in progress and have not been finalized. Attachment 2 is a description of proposed site modifications necessary to implement the mitigation strategy. During design and implementation of these modifications, the actions required by Reference 1 will remain in place. Also, periodic independent assessments and emergency response organization drills of the interim actions will be conducted to verify continued viability.

Design of the modifications is in progress and details may change as the process continues. The capability to provide adequate protection of the Oconee units and the spent fuel from a postulated failure of the Jocassee dam will be documented within the Updated Final Safety Analysis Report (UFSAR).

Duke Energy will submit the design of the Intake Dike Diversion Wall and the Intake Dike Tie Section modification (discussed in Attachment 2) to the Federal Energy Regulatory Commission (FERC). Duke Energy will also submit any License Amendment Requests (LARs) to the NRC that are necessitated by the power block flood wall modification. The modifications identified in Attachment 2 will be completed within a time frame of thirty (30) months plus FERC and NRC LAR review and approval time.

Duke Energy is committed to an orderly and thorough approach to resolution of the external flood mitigation issues at ONS so that the dates provided above and completion of the related modifications can be achieved. Duke Energy is proceeding, consistent with its corporate governance requirements, to obtain necessary internal approvals to fund the implementation of these commitments. Additionally, Duke Energy must undergo additional land acquisitions for relocation of the 100 kV (Fant) line towers.

Since this letter contains security sensitive information, Duke Energy hereby requests the NRC withhold the letter and its attachments from public disclosure pursuant to 10 CFR 2.390(d)(1), "Public inspections, exemptions, requests for withholding."

If you have questions concerning this matter, please contact Bob Meixell, Oconee Regulatory Compliance, at 864-873-3279.

Victor McCree
Nuclear Regulatory Commission
April 29, 2011
Page 3

I declare under penalty of perjury that the foregoing is true and correct. Executed on
April 29, 2011.

Sincerely,

TP GILLESPIE

T. Preston Gillespie, Jr.
Vice President
Oconee Nuclear Station

Attachments:

Attachment 1 – Jocassee Dam Failure Flood Mitigation Strategy
Attachment 2 – Description of Modifications

Victor McCree
Nuclear Regulatory Commission
April 29, 2011
Page 4

cc:

Mr. Joseph G. Gitter, Director
Division of Operating Reactor Licensing
U. S. Nuclear Regulatory Commission
Mail Stop O-8 E1A
Washington, D. C. 20555

Mr. John Stang, Project Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Mail Stop O-8 G9A
Washington, D. C. 20555

Mr. Andy Sabisch
Senior Resident Inspector
Oconee Nuclear Site

Susan E. Jenkins, Manager
Radioactive & Infectious Waste Management
Division of Waste Management
SC Dept. of Health and Environmental Control
2600 Bull Street
Columbia, SC 29201

~~This letter contains security sensitive information.
Withhold from Public Disclosure under 10CFR 2.390 (d)(1)~~

ATTACHMENT 1

JOCASSEE DAM FAILURE FLOOD MITIGATION STRATEGY

~~This letter contains security sensitive information.
Withhold from Public Disclosure under 10CFR 2.390 (d)(1)~~

**Nuclear Regulatory Commission
Attachment 1 – Jocassee Dam Failure Flood Mitigation Strategy
Page 2**

Jocassee Dam Failure Flood Mitigation Strategy

The strategy proposed within this attachment will continue to ensure adequate protection of the Oconee units and spent fuel in the unlikely occurrence of a Jocassee Dam failure. This strategy is provided based on the following initial Oconee site conditions:

- All three units are at power operation
- Unit 1&2 and Unit 3 Spent Fuel Pools (SFP) heat rates are consistent with that associated with all three units at power operation (no full core offload)
- Condenser Circulating Water (CCW) is not dewatered
- The Standby Shutdown Facility (SSF) is available
- (b)(7)(F)
- Credited Systems, Structures, and Components are in normal alignments

When the Oconee site is not within these initial conditions or associated mitigation systems are unavailable, appropriate compensatory measures will be taken based on the insight provided through the 10 CFR 50.65(a)(4) program, as applicable.

Furthermore, the mitigation strategy assumes the following:

- The Jocassee Dam failure does not occur concurrent with design basis accidents, design events, or transients.
- The Jocassee Dam failure does not occur concurrent with an earthquake.
- The occurrence of a single failure, as well as the failure of a control rod to fully insert, is not assumed.
- Systems, Structures, and Components (SSCs) to mitigate a Jocassee Dam failure are not required to be QA-1.

UFSAR Section 2.4.2.2 documents the Flood Design Considerations for both the Keowee and Jocassee Reservoirs. The dams and other hydraulic structures were designed with adequate freeboard and structural safety factors to safely accommodate the effects of Probable Maximum Precipitation (PMP). UFSAR Section 2.4.4 documents that Jocassee has been designed to the same seismic input conditions as Oconee Nuclear Station (ONS). Flooding due to the potential failure of the Jocassee Dam or Keowee Dam was not addressed and was considered to be beyond design basis. Thus, the current ONS licensing basis defines protection from external flooding caused by a Probable Maximum Flood (PMF) applicable to ONS which was analyzed based on the PMP. This basis satisfied General Design Criterion 2 of the UFSAR (Section 3.1.2).

Criterion 2 of the UFSAR imposes design criteria on select (designated as Essential) SSCs associated with the forces and conditions associated with natural phenomena. As such, natural phenomena events are not design basis events at Oconee, instead they impose design criteria

Nuclear Regulatory Commission
Attachment 1 – Jocassee Dam Failure Flood Mitigation Strategy
Page 3

on SSCs identified for mitigation of accidents. As was the original site design for flooding conditions, these design criteria are to remain within the constraints of the PMF applicable to ONS which was analyzed based on the PMP. Therefore, the original PMF analysis will remain as the flood design criteria for the Essential SSCs.

A Jocassee Dam failure can subject the Oconee Nuclear Site to adverse conditions beyond the plant design basis. Specifically, the postulated failure of the Jocassee Dam could result in a loss of off-site and emergency power, loss of external water sources and inundation of a majority of the station's SSCs. As described and accepted within Reference 1, compensatory measures are in place to mitigate these potential adverse consequences. Modifications are planned and discussed in Attachment 2 to improve the capability to maintain the three Oconee units as well as both SFPs in a condition that adequately protects the fuel. Upon completion of these modifications and implementation of the mitigation strategy within station procedures and processes, the compensatory measures described within Reference 1 will no longer be required.

Flood barriers will be designed to protect the credited SSCs including the Turbine Building, Auxiliary Building and the SSF, and the surrounding yard (b)(7)(F) following the postulated Jocassee Dam failure (b)(7)(F)

(b)(7)(F) This ensures a dedicated flood protected power source for plant systems. The new flood protected power source would also allow the SSF to be powered without starting the SSF diesel generator, thus preserving CCW inventory.

(b)(7)(F)

(b)(7)(F)

Thus, mitigation of the Jocassee Dam failure would be limited by the loss of external water sources to ONS. The water inventory trapped in the CCW system piping system would be the credited source of water for core decay heat removal and SFP makeup.

The planned modifications have been assumed to be implemented in the mitigation strategy for establishing and maintaining the three Oconee units as well as both SFPs in a condition that adequately protects the fuel. The mitigation strategy for this scenario has been subdivided into the following phases:

- Phase 1: Reactor shutdown and establishment of Mode 3
- Phase 2: Initiation of Natural Circulation Cooledown of the Reactor Coolant System (RCS) to 250°F
- Phase 3: Maintain RCS at $\leq 250^\circ\text{F}$

Nuclear Regulatory Commission
Attachment 1 – Jocassee Dam Failure Flood Mitigation Strategy
Page 4

Phase 1: Reactor shutdown and establishment of Mode 3

(b)(7)(F)

Actions are taken to establish the flood protective features, such as isolating Turbine Building and yard drain flowpaths and closing flood barrier access openings.

(b)(7)(F)

Following notification, the ONS Switchyards are assumed to remain available to each unit's startup transformer which provides power to normal and emergency systems.

The operators will take actions to shutdown the reactor(s) and establish Mode 3 with T_{ave} and RCS pressure at approximately 525°F and 2155 psig respectively, using normal plant systems. Operator actions will be undertaken to begin boration of the RCS for cold shutdown conditions. Normal secondary plant systems will remain in operation during this phase.

The operators will take actions to disable the Essential Siphon Vacuum System and vent it to prevent reverse siphon flow from the CCW inlet piping back to the Intake Canal when it is lost. The emergency CCW discharge flow path will be disabled by operators to prevent any loss of CCW. Actions will be taken to isolate the High Pressure Service Water (HPSW) outside of the flood protected area to ensure its capability to provide cooling water to the High Pressure Injection (HPI) pump motors.

Phase 2: Initiation of Natural Circulation Cooldown of the Reactor Coolant System to 250°F

(b)(7)(F)

This results in a momentary loss of power to each of the units. The Reactor Coolant Pumps (RCPs) are lost due to the loss of power to the startup transformers from the 230kV switchyard.

(b)(7)(F)

The SSF is normally powered from Unit 2's MFB, but it is load shed. Operator action will be taken to restore power to the SSF from Unit 2's MFB. Following reset of the load shed, power for the SSF would be provided from Unit 2's MFB to minimize any usage of the CCW inventory for SSF diesel operation.

The rising flood water in the ONS Intake Canal is postulated to result in failure of the Lake Keowee impoundment including the intake canal. This requires the shutdown of the Low Pressure Service Water (LPSW) pumps to conserve water inventory in the CCW piping.

**Nuclear Regulatory Commission
Attachment 1 – Jocassee Dam Failure Flood Mitigation Strategy
Page 5**

Heat removal from the Spent Fuel Cooling system is normally provided by the Recirculated Cooling Water (RCW) system. Following the overtopping of the Keowee Dam, the loss of CCW flow results in a loss of RCW cooling. This leaves the Units 1 & 2 shared SFP and the Unit 3 SFP without cooling. The SFP will eventually heat up to the point of boiling. When boiling occurs, the SFP level will decrease. Makeup to the SFP would be initiated from available sources including the water contained within the CCW buried piping to maintain a sufficient water level above the spent fuel stored in the pools.

The shutdown of the LPSW pumps results in a loss of cooling to such items as the Reactor Building, HPI pumps, the Component Cooling System, the motor-driven EFW pumps, and the Low Pressure Injection coolers.

With the shutdown of the CCW and LPSW systems, environmental conditions within the plant would be established as needed by the use of temporary equipment and operation of necessary existing and temporary ventilation systems. The temporary equipment will be powered from a 4160VAC electrical bus that receives power from CT5.

The HPI pumps can continue to operate because backup cooling is provided from the HPSW system via the Elevated Water Storage Tank (EWST). Power to an HPSW pump would be restored and the pump would be operated to replenish the EWST to maintain cooling water to the HPI pump motor coolers. The HPI system operates to maintain pressurizer level at the desired setpoint.

A loss of normal secondary systems is experienced due to the temporary loss of power to the main feeder buses. Decay heat removal would initially be maintained by the EFW System. The motor-driven EFW pumps must be secured due to the loss of LPSW cooling. The turbine-driven EFW pump does not require LPSW for cooling and is therefore allowed to continue to operate to feed the SGs. The loss of condenser cooling will result in the SGs being steamed to atmosphere using the Atmospheric Dump Valves which results in depletion of the condensate inventory.

Upon a loss of normal RCS letdown capability a cooldown is initiated. Since RCPs cannot be operated based on a loss of cooling and power to the pumps, a natural circulation cooldown must be performed. Depressurization of the RCS would be accomplished by means of the Power Operated Relief Valve and/or auxiliary spray.

Core decay heat removal would eventually be transferred to the SSF Auxiliary Service Water (ASW) system to utilize the trapped water inventory in the CCW piping. With the use of the SSF ASW system, valve alignments would be made to maximize the available trapped water inventory in the CCW piping to the SSF ASW pump suction. This would be accomplished by cross-connecting the CCW inlet and discharge piping between all three units.

**Nuclear Regulatory Commission
Attachment 1 – Jocassee Dam Failure Flood Mitigation Strategy
Page 6**

When the cooldown has been completed, the operating HPI pump would be stopped. The SSF ASW system would continue to supply the steam generators (SGs) to maintain decay heat removal.

Phase 3: Maintain RCS at $\leq 250^{\circ}\text{F}$

Core decay heat removal will be maintained by natural circulation of the RCS with the SSF ASW system providing decay heat removal by means of SG feeding and steaming through the ADVs. The HPI system will be operated as needed to maintain RCS water level within an acceptable band. Pressurizer heaters will be operated as necessary to maintain RCS pressure. Water level in the SFP will be maintained at a sufficient level above the spent fuel stored in the pools. The suction source for the SSF ASW system and the SFP makeup system is the water inventory trapped in the CCW piping.

~~This letter contains security sensitive information.
Withhold from Public Disclosure under 10CFR 2.390 (d)(1)~~

ATTACHMENT 2
DESCRIPTION OF MODIFICATIONS

~~This letter contains security sensitive information.
Withhold from Public Disclosure under 10CFR 2.390 (d)(1)~~

Nuclear Regulatory Commission
 Attachment 2 – Description of Modifications
 Page 2

Based on the mitigation strategy discussed within Attachment 1, the following table identifies proposed modifications to mitigate site flooding following the postulated failure of the Jocassee Dam.

Specifically, modifications will be required to protect the required SSCs to meet the mitigation strategy and provide a dedicated flood protected power supply following a postulated Jocassee Dam failure. Protection of the credited SSCs including the Turbine Building, Auxiliary Building, SSF, and the surrounding yard (including CT5 Substation) will be accomplished with flood barriers and associated infrastructure.

(b)(7)(F)

No	Category	Description
1	(b)(7)(F)	(b)(7)(F)
1A	(b)(7)(F)	
1B	CT5 Substation	Modify CT5 Substation to supply the standby bus and a new recovery equipment bus.
2	Protect Required SSCs and the Surrounding Yard	Protect required SSCs and the surrounding yard due to Keowee impoundment failures and rising waters in the tailrace area
2A	Power Block Flood Wall	Install a new flood wall located on the east side of the Oconee site.
2B	Intake Dike Diversion Wall	Install a new diversion wall along the northern side of the ONS intake dike
2C	Turbine Building Drain Isolation	Install barriers to minimize flood waters from entering into the Turbine Building from rising waters in the tailrace area
2D	Yard Drain Isolation	Install barriers to minimize flood waters from entering the site
3	SFP Makeup	Utilizes stored water inventory for makeup to the SFP
3A	SSF Service Water Discharge Flow Path	SSF ASW minimum flow line diverted to outside SSF for transfer to SFP
3B	SFP Level Instrumentation	Install new SFP level instrumentation rated for post-flood conditions

Nuclear Regulatory Commission
Attachment 2 – Description of Modifications
Page 3

Description of Modifications:

1-Dedicated, Flood Protected Power

In order to ensure an adequate dedicated power path to the Oconee site after a Jocassee Dam failure, the following modifications are required:

(b)(7)(F)

1B – CT5 Substation

(b)(7)(F) The Jocassee Dam

failure requires modification of the CT5 Substation to add multiple power paths for mitigation. The initial function of the CT5 Substation will be to provide emergency power to loads required to mitigate the Jocassee Dam failure from the Oconee Standby Buses. Isolation for CT5 to the Standby Bus power path will be provided by a new breaker in the CT5 Substation. A secondary function of the CT5 Substation will be to provide an additional power path to temporary loads used for mitigation. These loads will be powered by a new recovery equipment bus designed for the CT5 Substation. This bus will provide power to portable distribution trailers at voltage levels of 4160V, 600V, 480V, 208V, and 120V for these temporary loads. Isolation/protection of this bus will be provided by a new breaker. Individual loads will be isolated/protected by load-specific fusible gang switches on the load side of this bus.

General Design Parameters:

Loading of CT5 transformer does not exceed the 12/16/20MVA rating consistent with UFSAR Section 8.2.1.4.

2-Protect Required SSCs and the Surrounding Yard

In order to prevent flood waters from flowing into the site from the Keowee impoundment failure and from rising waters in the tailrace area, the following modifications are required:

Nuclear Regulatory Commission
Attachment 2 – Description of Modifications
Page 4

2A - Power Block Flood Wall

The new Power Block Flood Wall will envelope the eastern side and the southern end of the ONS protected area. The wall is comprised of 3 sections: The Discharge Diversion Section, The East Wall, and the Intake Dike Tie Section. The wall will have at least one vehicular access and one personnel access located at the north road crossing, each of which will have flood protection capability.

General Design Parameters:

Classification: Class 3, consistent with UFSAR Section 3.2.1.1.3

Design Loadings:

- Dead + Wind (UFSAR Section 3.3.2.4) or
- Dead + Hydrodynamic (Flood) (Reference 2)

Additional Design Considerations: General erosion; flood scour; debris; leakage from access gates, expansion joints, and unidentified locations (details to be determined); site drainage; and soil exploration and characterization. Interactions of non-seismic SSCs with seismic SSCs will be addressed.

Discharge Diversion Section (approximately 300 ft long)

Wall Height: Top Elev. 830 ft. msl (min), approximately 15 ft. high

Protection Height Margin: Approximately 2 ft.

Wall Thickness: Material dependent

Design Codes: Similar to UFSAR Section 3.8.5.4.3

Design Methodology: UFSAR Section 3.8.5.4.3

East Wall Section (approximately 2000 ft. long)

Wall Height: Top Elev. 808 ft. msl (min), approximately 12 ft. high

Protection Height Margin: Approximately 2 ft.

Wall Thickness: Material dependent

Design Codes: Similar to UFSAR Section 3.8.5.4.3

Design Methodology: UFSAR Section 3.8.5.4.3

Access Barriers: Vehicular access closure is planned to be a gate (sliding or hinged, possibly designed with some mechanical sealing devices), or stop logs (concrete or steel), similar to standard flood gates or other similar barriers.

Nuclear Regulatory Commission
Attachment 2 – Description of Modifications
Page 5

Intake Dike Tie Section (approximately 160 ft. long)

Wall Height: Top Elev. 808 ft. msl (min), approximately 12 ft. high tapering to zero height
Protection Height Margin: Approximately 2 ft.

Wall Thickness: Material dependent. Wall is planned to be a combination of Power Block
Wall transitioning to an embankment (compacted fill) wall tied to the existing Intake Canal
Dike embankment.

Design Codes: Similar to UFSAR Section 3.8.5.4.3

Design Methodology: UFSAR Section 3.8.5.4.3

2B - Intake Dike Diversion Wall

This wall will prevent the rising waters on Lake Keowee, more specifically the Oconee Intake Canal, from flowing over the northern crest of the dike and directly into the yard. The wall will be located on the northern side of the dike crest, going from the northeast corner of the dike to the northwest corner of the dike where it will tie to higher ground. One access gate is planned for the existing roadway connecting the western portion of the nuclear site to the crest of the dike. Design parameters for the Intake Dike Diversion Wall are described below:

General Design Parameters

Classification: Class 3, consistent with UFSAR Section 3.2.1.1.3

Design Loadings:

Dead + Wind (UFSAR Section 3.3.2.4) or

Dead + Hydrodynamic (Flood) (Reference 2)

Additional Design Considerations: General erosion; flood scour; debris; leakage from access gates, expansion joints, and unidentified locations (details to be determined); and soil exploration and characterization. Interactions of non-seismic SSCs with seismic SSCs will be addressed.

Wall Height: Top Elev. 825 ft. msl (min), approximately 10 ft high

Protection Height Margin: Approximately 2 ft.

Wall Thickness: Material dependent

Design Codes: Similar to UFSAR Section 3.8.5.4.3

Design Methodology: UFSAR Section 3.8.5.4.3

Access Barriers: Vehicular access closure is planned to be a gate or stop logs similar to standard flood gates or other similar barriers.

Nuclear Regulatory Commission
Attachment 2 – Description of Modifications
Page 6

2C - Turbine Building Drain Isolation

The free-flowing capability of the Turbine Building drain will be restricted during the site external flood by a flood gate or other similar barrier to minimize water flowing into the Turbine Building from the flooded tailrace area. Design parameters are described below:

Classification: Class 3, consistent with UFSAR Section 3.2.1.1.3
Design Loadings: Dead + Hydrodynamic (Flood) (Reference 2)
Design Code: Sluice gate or valve, standard to be determined

2D - Yard Drain Isolation

This modification adds a flood gate or other similar barrier to minimize the amount of water entering the flood protected area via the yard drains. Design parameters are described below:

Classification: Class 3, consistent with UFSAR Section 3.2.1.1.3
Design Loadings: Dead + Hydrodynamic (Flood) (Reference 2)
Design Code: Sluice gate or valve, standard to be determined

3-SFP Makeup

In order to provide makeup to the Spent Fuel Pools after a Jocassee Dam failure, the following modifications are required:

3A – SSF Service Water Discharge Flow Path

The capability to remove water from the CCW pipe by means of the SSF ASW Minimum Flow Line will be added for collection and transfer to the Units 1 & 2 shared SFP and the Unit 3 SFP.

3B – SFP Level Instrumentation

SFP level instrumentation will be designed to monitor the SFP level to ensure proper level is maintained during SFP boiling conditions.