

CCNPP3eRAIPEm Resource

From: Arora, Surinder
Sent: Monday, December 09, 2013 6:19 AM
To: 'Infanger, Paul'; "UNECC3Project@unistarnuclear.com"
(UNECC3Project@unistarnuclear.com)
Cc: CCNPP3eRAIPEm Resource; Segala, John; Wilson, Anthony; Miernicki, Michael; Clark, Theresa
Subject: CCNPP3 - Draft RAI 407 MEB 7274
Attachments: DRAFT RAI 407 MEB 7274.docx

Paul,

Attached is DRAFT RAI No. 407 (eRAI No. 7274) pertaining to Calvert Cliffs Unit 3 FSAR Section 3.9.3. This RAI relates to an inconsistency between Revision 5 of Areva's design certification application and Revision 9 of your COL application. You have until December 23, 2013 to review the draft question and request a clarification phone call to discuss the RAI before the final issuance. After the clarification phone call or after December 23, 2013, this draft RAI will be finalized and sent to you for your response. You will then have 30 days to provide a technically complete response or an expected response date for the RAI.

Thanks

SURINDER ARORA, PE
LEAD PROJECT MANAGER,
CALVERT CLIFFS U3 COLA PROJECT
Office of New Reactors
US Nuclear Regulatory Commission

Phone: 301 415-1421
FAX: 301 415-6406
Email: Surinder.Arora@nrc.gov

Hearing Identifier: CalvertCliffs_Unit3Col_RAI
Email Number: 348

Mail Envelope Properties (B46615B367D1144982B324704E3BCEED01512B8A4511)

Subject: CCNPP3 - Draft RAI 407 MEB 7274
Sent Date: 12/9/2013 6:19:24 AM
Received Date: 12/9/2013 6:19:25 AM
From: Arora, Surinder

Created By: Surinder.Arora@nrc.gov

Recipients:

"CCNPP3eRAIPEm Resource" <CCNPP3eRAIPEm.Resource@nrc.gov>

Tracking Status: None

"Segala, John" <John.Segala@nrc.gov>

Tracking Status: None

"Wilson, Anthony" <Anthony.Wilson@nrc.gov>

Tracking Status: None

"Miernicki, Michael" <Michael.Miernicki@nrc.gov>

Tracking Status: None

"Clark, Theresa" <Theresa.Clark@nrc.gov>

Tracking Status: None

"Infanger, Paul" <paul.infanger@unistarnuclear.com>

Tracking Status: None

""UNECC3Project@unistarnuclear.com" (UNECC3Project@unistarnuclear.com)"
<UNECC3Project@unistarnuclear.com>

Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	944	12/9/2013 6:19:25 AM
DRAFT RAI 407 MEB 7274.docx		27111

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received:

Request for Additional Information 407 (eRAI 7274)

DRAFT

Issue Date: 12/09/2013

Application Title: Calvert Cliffs Unit 3 - Docket Number 52-016

Operating Company: UniStar

Docket No. 52-016

Review Section: 03.09.03 - ASME Code Class 1, 2, and 3 Components

Application Section: Section 3.9.3

QUESTIONS

03.09.03-5

In Calvert Cliffs 3, FSAR Rev. 9 Subsection 3.9.3.1.1, the applicant stated that Calvert Cliffs 3 Nuclear Project, LLC and UniStar Nuclear Operating Services, LLC shall route Class 1, 2, or 3 piping not included in the U.S. EPR design certification in a manner so that it is not exposed to wind or tornadoes.

In Revision 5 of the U.S. EPR FSAR, COL Item 3.9-5 was revised to include the word "hurricane" in addition to wind and tornadoes. The Calvert Cliffs 3, FSAR Rev. 9 Subsection 3.9.3.1.1 has not yet been addressed in the COL FSAR to include the word "hurricane".

The staff requests the applicant revises the Calvert Cliffs 3, FSAR Rev. 9 Subsection 3.9.3.1.1 to include the word "hurricane".