

CENGSM

a joint venture of



NINE MILE POINT
NUCLEAR STATION

December 9, 2013

U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

ATTENTION: Document Control Desk

SUBJECT: Nine Mile Point Nuclear Station, Unit 1
Renewed Facility Operating License No. DPR-63
Docket No. 50-220

License Amendment Request Pursuant to 10 CFR 50.90: Adoption of NFPA 805, Performance-Based Standard for Fire Protection for Light Water Reactor Electric Generating Plants (2001 Edition) – Response to NRC Request for Additional Information (TAC No. ME8899)

- REFERENCES:**
- (a) Letter from K. Langdon (NMPNS) to Document Control Desk (NRC), dated June 11, 2012, License Amendment Request Pursuant to 10 CFR 50.90: Adoption of NFPA 805, Performance-Based Standard for Fire Protection for Light Water Reactor Electric Generating Plants (2001 Edition)
 - (b) Letter from B. Vaidya (NRC) to C. Costanzo (NMPNS), dated October 9, 2013, Nine Mile Point Nuclear Station, Unit No. 1 – Second Round of Request for Additional Information Regarding License Amendment Request for Adoption of NFPA 805 (TAC No. ME8899)

Nine Mile Point Nuclear Station, LLC (NMPNS) hereby transmits supplemental information requested by the NRC in support of a previously submitted request for amendment to Nine Mile Point Unit 1 (NMP1) Renewed Operating License DPR-63. The initial request, dated June 11, 2012 (Reference a), proposed the adoption of a new risk-informed performance-based (RI-PB) fire protection licensing basis which complies with the requirements in 10 CFR 50.48(a) and 10 CFR 50.48(c); the guidance in Regulatory Guide (RG) 1.205, "Risk-Informed Performance-Based Fire Protection for Existing Light-Water Nuclear Power Plants," Revision 1; and National Fire Protection Association (NFPA) 805, "Performance-Based Standard for Fire Protection for Light Water Reactor Electric Generating Plants," 2001 Edition.

Document Control Desk
December 9, 2013
Page 2


The supplemental information, provided in the attachment to this letter, responds to the Fire Protection Engineering request for additional information (RAI) 11 documented in the NRC's letter dated October 9, 2013 (Reference b).

This supplemental information does not affect the No Significant Hazards Determination analysis provided by NMPNS in Reference (a). Pursuant to 10 CFR 50.91(b)(1), NMPNS has provided a copy of this supplemental information to the appropriate state representative. There are no new regulatory commitments contained in this letter.

Should you have any questions regarding the information in this submittal, please contact Everett (Chip), Perkins Director-Licensing, at (315) 349-5219.

I declare under penalty of perjury that the foregoing is true and correct. Executed on December 9, 2013.

Very truly yours,

A handwritten signature in black ink that reads "Christopher R. Castanzo". The signature is written in a cursive style with a large initial "C" and a distinct "R".

CRC/JJD

Attachment Nine Mile Point Unit 1 - Response to NRC Request for Additional Information
Regarding the Proposed Adoption of NFPA 805 (2001 Edition)

cc: Regional Administrator, Region I, NRC
Project Manager, NRC
Resident Inspector, NRC
A. L. Peterson, NYSERDA