

NRR-PMDAPEm Resource

From: Lyon, Fred
Sent: Monday, December 23, 2013 9:39 AM
To: Wideman Steve G (stwidem@WCNOC.com)
Cc: Muilenburg William T (wimuile@WCNOC.com)
Subject: FW: Wolf Creek Generating Station - Request for Additional Information Re: Transition to Westinghouse Core Design and Safety Analysis (TAC No. MF2574)

Steve, you were right. Please see the revised question below, and replace ESGB-RAI-2 in my RAI letter. You can reference this email in your response. Thanks, Fred

From: Obodoako, Aloysius
Sent: Monday, December 23, 2013 9:31 AM
To: Lyon, Fred
Subject: RE: Wolf Creek Generating Station - Request for Additional Information Re: Transition to Westinghouse Core Design and Safety Analysis (TAC No. MF2574)

Hi Fred,

I reviewed the RAI and draft licensee response and it answers my question. I think I must have confused the reactor vessel environment and the post-LOCA sump analyses. The intent of ESGB-RAI-2 was to request for the following information:

Describe the analysis methodology used to determine the pH in the sump water during the period of 30 days post-LOCA. Include detailed calculations of time dependent pH values in the sump during a 30 day period post-LOCA to demonstrate that the pH remains basic throughout this time period.

How do you propose we move forward. Should I draw up another RAI, which we will issue formally to gather this information or can we modify ESGB-RAI-2 such that it reflects the above request?

Aloysius

From: Lyon, Fred
Sent: Friday, December 20, 2013 8:03 AM
To: Obodoako, Aloysius
Cc: Kulesa, Gloria
Subject: FW: Wolf Creek Generating Station - Request for Additional Information Re: Transition to Westinghouse Core Design and Safety Analysis (TAC No. MF2574)

Please see the proposed answer below to your RAI question. The licensee wants to make sure they understand what you're asking for and why. The question didn't seem to be logical since they didn't use a computer code to do the pH determination. Let me know if you need to chat with them.

Thanks, Fred (x2296)

From: Wideman Steve G [<mailto:stwidem@WCNOC.com>]
Sent: Thursday, December 19, 2013 10:11 AM
To: Lyon, Fred
Cc: Fici Melanie R
Subject: RE: Wolf Creek Generating Station - Request for Additional Information Re: Transition to Westinghouse Core Design and Safety Analysis (TAC No. MF2574)

Fred – per our discussion on December 18, 2013 regarding RAI ESGB-RAI-2, provided below is the draft response for your discussion with the technical branch.

ESGB-RAI-2: “Please describe the ORIGEN-S computer code used to determine the pH in the sump water post-LOCA and the differences between it and ORIGEN-2/ARP. Please provide the input and output data of the program.”

DRAFT RESPONSE: In Enclosure VI of the LAR, Section 4.4.2.1 (page 4-105) it indicates that no computer codes were used in this analysis (referring to the containment sump pH analysis). This section specifically states:

“No computer codes were used in this analysis. To determine the pH in the CLB analysis, NaOH and H3BO3 molarities were first calculated and then used with Oak Ridge National Laboratory (ORNL) titration curve data to determine the pH of the spray and sump solutions during the injection and recirculation phases of ECCS operation.”

The information provided in Section 4.4.2.1 is similar to a V. C. Summer Nuclear Station letter submitted on June 15, 2009 (ADAMS Accession Number ML091680063) in response to a similar RAI question.

Steve Wideman
WCNOC Licensing
620-364-4037
Cell - 620-490-0449

From: Lyon, Fred [<mailto:Fred.Lyon@nrc.gov>]
Sent: Monday, December 16, 2013 2:46 PM
To: Wideman Steve G
Cc: Muilenburg William T
Subject: FW: Wolf Creek Generating Station - Request for Additional Information Re: Transition to Westinghouse Core Design and Safety Analysis (TAC No. MF2574)

From: nrc_mail_1-2 Resource [mailto:nrc_mail_1-2.Resource@nrc.gov]
Sent: Monday, December 16, 2013 10:46 AM
To: Lyon, Fred
Subject: Wolf Creek Generating Station - Request for Additional Information Re: Transition to Westinghouse Core Design and Safety Analysis (TAC No. MF2574)

Wolf Creek Generating Station - Request for Additional Information Re: Transition to Westinghouse Core Design and Safety Analysis (TAC No. MF2574)

ADAMS Accession No.: ML13345B335

The attached document is being sent to you per your request to receive electronic mailings, if you wish to be removed follow the instructions below. The document is publicly available and will be accessible via the public web site Electronic

Reading Room in the Agency Document Access and Management System (ADAMS), <http://www.nrc.gov/reading-rm/adams.html> , generally within six days. To access this document use the ADAMS number provided in this email.

Documents containing proprietary or safeguards information are not publicly available and will not be sent using the electronic mailing system.

You are currently subscribed to wolfcreek as: Fred.Lyon@nrc.gov .

To unsubscribe: Please go to the NRC's public website <http://www.nrc.gov/public-involve/listserver/plants-by-region.html>

Once at the site, type in your e-mail address in the space provided and check the box(es) that correspond to the list(s) you would like to unsubscribe from. Then click the Unsubscribe button.

or send an email to lyris@nrc.gov with the following information in the subject line
unsubscribe wolfcreek Fred.Lyon@nrc.gov

Hearing Identifier: NRR_PMDA
Email Number: 967

Mail Envelope Properties (Fred.Lyon@nrc.gov20131223093800)

Subject: FW: Wolf Creek Generating Station - Request for Additional Information Re: Transition to Westinghouse Core Design and Safety Analysis (TAC No. MF2574)
Sent Date: 12/23/2013 9:38:58 AM
Received Date: 12/23/2013 9:38:00 AM
From: Lyon, Fred

Created By: Fred.Lyon@nrc.gov

Recipients:
"Muilenburg William T (wimuile@WCNOC.com)" <wimuile@WCNOC.com>
Tracking Status: None
"Wideman Steve G (stwidem@WCNOC.com)" <stwidem@WCNOC.com>
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	5458	12/23/2013 9:38:00 AM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: