

Rulemaking1CEm Resource

From: RulemakingComments Resource
Sent: Thursday, December 26, 2013 9:50 AM
To: Rulemaking1CEm Resource
Subject: FW: NRC-2012-0246; Submission of Additional Comments by NYS OAG
Attachments: 2013 12 20 NYS Cover letter (NRC-2012-0246).pdf; 2013 12 20 NYSOAG Add'l Comments (FINAL).pdf; 2013 12 20 ISR Rpt No 13014-01-02 Review GEIS (NYS).pdf; 2013 03 14 RIC PowerPoint NYSOAG vfnl22813.pdf; 2013 08 20 NYS letter re Aqueous Release final.pdf; 2013 08 20 NYS Letter re Price Anderson final.pdf

**DOCKETED BY USNRC—OFFICE OF THE SECRETARY
SECY-067**

PR#: PR-51
FRN#: 78FR56775
NRC DOCKET#: NRC-2012-0246
SECY DOCKET DATE: 12/20/13
TITLE: Waste Confidence—Continued Storage of Spent Nuclear Fuel
COMMENT#: 00693

From: John J. Sipos [<mailto:John.Sipos@ag.ny.gov>]
Sent: Friday, December 20, 2013 7:10 PM
To: RulemakingComments Resource
Cc: Janice Dean; Teresa Manzi; Kathryn Liberatore
Subject: NRC-2012-0246; Submission of Additional Comments by NYS OAG

Enclosed please find comments, a report by ISR, a presentation made during the 2013 RIC, two additional supporting letters, and a cover letter.

Please inform me if you encounter difficulties opening the documents.

Thank you.

John Sipos
Assistant Attorney General
tel. 518-402-2251



Hearing Identifier: Secy_RuleMaking_comments_Public
Email Number: 719

Mail Envelope Properties (377CB97DD54F0F4FAAC7E9FD88BCA6D0014433C4A0F6)

Subject: FW: NRC-2012-0246; Submission of Additional Comments by NYS OAG
Sent Date: 12/26/2013 9:50:03 AM
Received Date: 12/26/2013 9:50:15 AM
From: RulemakingComments Resource

Created By: RulemakingComments.Resource@nrc.gov

Recipients:
"Rulemaking1CEm Resource" <Rulemaking1CEm.Resource@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	872	12/26/2013 9:50:15 AM
image001.gif	3435	
2013 12 20 NYS Cover letter (NRC-2012-0246).pdf		72893
2013 12 20 NYSOAG Add'l Comments (FINAL).pdf		2975685
2013 12 20 ISR Rpt No 13014-01-02 Review GEIS (NYS).pdf		1018031
2013 03 14 RIC PowerPoint NYSOAG vfnl22813.pdf		3069789
2013 08 20 NYS letter re Aqueous Release final.pdf		97588
2013 08 20 NYS Letter re Price Anderson final.pdf		373977

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:





STATE OF NEW YORK
OFFICE OF THE ATTORNEY GENERAL

ERIC T. SCHNEIDERMAN
ATTORNEY GENERAL

DIVISION OF SOCIAL JUSTICE
ENVIRONMENTAL PROTECTION BUREAU

December 20, 2013

The Honorable Annette L. Vietti-Cook
Secretary
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, Maryland 20852-2738

Re: Submission of Comments Concerning
Draft Waste Confidence Generic Environmental Impact Statement
and Proposed Rule
Docket No. NRC-2012-0246

Dear Secretary Vietti-Cook:

In connection with the referenced proceeding, please find additional comments submitted by the Office of the Attorney General of the State of New as well as a report by International Safety Research, Inc. (ISR), a presentation from the March 2013 Regulatory Information Conference, and two letters concerning aqueous releases and Price Anderson issues. The State respectfully requests that the Commission consider these submissions in the proceeding.

Thank you.

Respectfully submitted,

Signed (electronically) by

John J. Sipos
Assistant Attorney General

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of:

Consideration of Environmental Impacts of
Temporary Storage of Spent Fuel After
Cessation of Reactor Operations

RIN 3150-AJ20
NRC-2012-0246

ADDITIONAL COMMENTS SUBMITTED BY THE
ATTORNEY GENERAL OF THE STATE OF NEW YORK
ON THE NUCLEAR REGULATORY COMMISSION'S DRAFT WASTE CONFIDENCE
GENERIC ENVIRONMENTAL IMPACT STATEMENT AND PROPOSED RULE

Submitted: December 20, 2013

STATE OF NEW YORK
Office of the Attorney General
Eric T. Schneiderman
Attorney General
John J. Sipos
Janice A. Dean
Kathryn Liberatore
Laura Heslin
Assistant Attorneys General
The Capitol
Albany, New York 12224

TABLE OF CONTENTS

	Page
I. The Indian Point Site.....	1
Population	1
Drinking Water Resources.....	3
Topography and Meteorology	6
Improvements and Unique Sites within 50 miles	10
The Hudson River Ecosystem.....	11
Seismic Hazard	11
Need for Objective Site-Specific Analysis	14
Lack of Site-Specific Analysis of Severe Spent Fuel Pool Accident	14
Storage and Accumulation of Spent Nuclear Fuel at Indian Point	16
II. Need for Site-Specific and Site-Wide Severe Accident Review For the Indian Point Facilities	22
III. Generation of Spent Nuclear Fuel.....	24
IV. Toxicity and Longevity of Spent Nuclear Fuel	26
V. History of On-Site Storage of Spent Nuclear Fuel	27
VI. Environmental Hazards and Impacts of Spent Fuel Pools	31
A. Fires	31
B. Leaks.....	37

TABLE OF CONTENTS

	Page
VII. Significant New Information Regarding Spent Fuel Pools	41
A. Yucca Mountain Repository Project Formally Abandoned.....	43
B. External Events in Japan and Virginia	45
1. Fukushima Daiichi and Site-Wide Risk	45
2. North Anna, Virginia.....	58
VIII. Consideration of Site-Specific Alternatives	60
A. Thinning of Spent Fuel Pools and Use of Dry Cask Storage.....	62
B. Other Alternatives	69
C. Severe Accident Mitigation Alternatives Analyses And Spent Fuel Pools	70
IX. The Severe Accident Mitigation Alternatives Analyses Should Be Based on Site-Specific Data and Not Simply Replicate Inputs from Another Reactor.....	72
X. NRC Must Prepare a Meaningful Site-Specific Environmental Impact Statement Analyzing the Impacts of Sabotage and Terrorism at the Indian Point Facilities	74
XI. Conclusion	82

Note about Citations and References Contained in this Document

All citations and references mentioned in this document are hereby incorporated by reference. Should NRC Staff have difficulty obtaining any such citations and references, they are requested to contact the Office of the Attorney General for the State of New York for assistance.

The State of New York Office of the Attorney General submits the accompanying report by International Safety Research, Inc. (“ISR”) as well as these additional comments to the record in this rulemaking and environmental review proceeding.¹

Throughout this proceeding, New York has requested that NRC conduct a transparent, objective, and comprehensive site-specific severe accident mitigation alternatives analysis of spent fuel pool accidents at Indian Point – and conduct a site-wide analysis of severe accidents at Indian Point.

I. The Indian Point Site

Population. The Indian Point power reactors, spent fuel pools, and dry storage casks are 24 miles north of New York City, 35 miles from Times Square, and approximately 38 miles from Wall Street. The U.S. Census Bureau recognizes that New York City is the largest city in the Nation – with more than 8,000,000 residents.

The facilities are approximately 3 miles southwest of Peekskill, with a population of 22,441, 5 miles northeast of Haverstraw, with a population of 33,811, 16 miles southeast of Newburgh, with a population of 31,400, and 17 miles northwest of White Plains, with a population of 52,802, 23 miles northwest of Greenwich, Connecticut, 37 miles west of Bridgeport, Connecticut, and 37-39 miles north northeast of Jersey City and Newark, New Jersey.

¹ 78 Fed. Reg. 56621 (Sept. 13, 2013) (notice of release of proposed draft waste confidence generic environmental impact statement), 78 Fed. Reg. 56776 (Sept. 13, 2013) (notice of release of proposed regulation concerning waste confidence – continued storage of spent nuclear fuel), 78 Fed. Reg. 66858 (Nov. 2013) (extending time due to federal government shutdown).

With approximately 17 million people currently living within 50 miles of Indian Point, no other operating reactor site in the country comes close to Indian Point in terms of surrounding population.² NRC and FEMA confirm that substantially more people live within 10 and 50 miles of the Indian Point reactors, spent fuel pools, and waste storage facilities than at any other operating power reactor in the nation.

Typically, nuclear power plant sites and the surrounding area are flat-to-rolling countryside in wooded or agricultural areas. More than 50 percent of the sites have 80-km (50-mile) population densities of less than 200 persons per square mile, and over 80 percent have 80-km (50-mile) densities of less than 500 persons per square mile. The most notable exception is the Indian Point Station, located within 80 km (50 miles) of New York City, which has a projected 1990 population density within 80 km (50 miles) of almost 2000 persons per square mile.

NUREG-1437 (1996) at p. 2-2. Moreover, each day tens of thousands of additional people commute or travel into Indian Point's 50 mile radius.


In 1979, NRC's Director of State Programs said of the Indian Point site "I think it is insane to have a three-unit reactor on the Hudson River in Westchester County, 40 miles from Times Square, 20 miles from the Bronx." Robert Ryan, NRC Director of State Programs, *quoted in* STAFF REPORTS TO THE PRESIDENT'S COMMISSION ON THE ACCIDENT AT THREE MILE ISLAND (Oct. 1979), Report of the

² See NUREG-1437 (1996) at §2.2 & Table 2.1 (based on 1990 census); NUREG-1437, Rev. 1 (2013) at §3.1, Figure 3.1.1, Table 3.1.1 (based on 2000 census). Indian Point's current operator projects that the population living within 50 miles of the plant will grow to 19.2 million people by 2035. See Environmental Report for License Renewal of Indian Point Unit 2 and Unit 3 (2007) at 2-35 ("The total population (including transient populations) within a 50-mile radius of the site is projected to be 19,228,712 in 2035.").

Office of Chief Counsel on Emergency Preparedness, at p. 8.

Drinking Water Resources. The reactors and fuel pools are also 6 miles west of the New Croton Reservoir in Westchester County, which is part of the New York City reservoir system and provides drinking water to New York City residents. They are also in close proximity to other reservoirs in the New York metropolitan area. *See* Map: DISTANCE TO NEW YORK RESERVOIRS FROM INDIAN POINT SPENT FUEL POOLS AND REACTORS (below).

DISTANCE TO NEW YORK RESERVOIRS FROM INDIAN POINT SPENT FUEL POOLS AND REACTORS




To comply with NEPA, NRC's should expand its analysis to include the impact of severe spent fuel pool accidents on drinking water resources within NRC's designated 50-mile Emergency Planning Zone around the Indian Point facilities. NRC uses a computer code, known as MACCS2, to assist its analysis of severe accidents. The economic cost model of the MACCS2 code is intended to estimate the direct offsite costs from a severe nuclear accident. If other indirect costs were included such as medical expenses, adverse health effects, permanent income loss, costs of disposal of contaminated wastes, and economic impact of losing a resource—including the loss of drinking water and replacement for reservoirs during interdiction, the total economic cost would increase. *See, e.g.*, Transcript of Evidentiary Hearing, Indian Point License Renewal Proceeding (“Tr.”) 2278:7-8 (Bixler) (MACCS2 code “does not consider the migration through the ground water.”); Tr. 2284:6-10 (Bixler) (MACCS2 code “does not account any economic value to the loss of the water. I think what would probably happen in reality is that people would buy bottled water in that area, and consume that. . . . [but it] is not factored in.”); Tr. 2285:5-8 (Ghosh) (“[A]re we accounting for the economic impact of losing some resource? I just want to comment on that. Certainly, MACCS does not do that.”); Tr. 1975:9-20 (J. McDade/Bixler) (While an input parameter called per capita cost of long-term relocation (POPCST) does address unemployment for 20 weeks under Sample Problem A, it does not address permanent salary loss.).

To date, NRC's analysis has not included an acknowledgment and analysis of the cost to replace these drinking water resources that play a critical role in the

daily life of New York City's residents. Replacing radionuclide-contaminated drinking water resources for millions of City residents would likely represent a substantial cost.

Topography and Meteorology. The Indian Point facilities were constructed close to the river bank and are located at a relatively low point in the valley formed by the Hudson River. The hills of the Hudson River Valley in the vicinity of the Indian Point facilities are illustrated in the following two topographical presentations.

The first topographical map depicts the area within five miles of the facilities:



0.5 0.25 0 0.5 Miles


Topographic contours are in feet

Topographic Map from the National Geographic Society


Publisher: ESRI, Redlands, CA; <http://resources.esri.com/arcgisonline/services/>
(Prepared with ESRI GIS Software)




The following “hillshade” topographical map depicts the lower Hudson River Valley in the vicinity of the Indian Point site:



◆ Reactors



Hillshade from USGS 10 meter digital elevation model
(Prepared with ESRI GIS Software)



These river, hills, and topography tend to concentrate wind direction to the south (toward the New York City metropolitan area) or towards the north towards the U.S. Military Academy at West Point or Hudson River cities and towns. The following wind rose, prepared by Indian Point's owner, illustrates the dominant wind direction.




Figure 3: Plot of Weather for Years 1999 – 2002 from the site 10 meter tower showing wind direction (percent by direction).

Source: color version of figure available on ADAMS, ML093020492. During an evidentiary hearing concerning the application to renew Indian Point's two operating license, Entergy agreed that for the area surrounding Indian Point, the wind blows predominantly from the north to the south. Tr. 2294:1-20 (J. Wardwell/Lemay/O'Kula).

The following population rose depicts the relative population densities in the various sectors around Indian Point.




Figure 2.1 2035 projected total population by spatial element (dark red indicates highest population).

Source: Site Specific MACCS2 Input Data for Indian Point Energy Center, Rev. 1, (December 1, 2009), Enercon Services, Inc. Prepared for Entergy Nuclear Northeast, at 2-7. As noted, winds blow from the Indian Point facilities southward -- towards the New York City metropolitan area.

Improvements and Unique Sites within 50 miles. The communities within the 50-mile radius around Indian Point also contain some of the most densely-developed and expensive real estate in the country, critical natural resources, centers of national and international commerce, transportation arteries and hubs,

and historic sites. By way of example, Wall Street, the Nation's financial center, is 38 miles away. These unique sites are identified on the accompanying list. *See* LIST OF VARIOUS SITE SPECIFIC IMPROVEMENTS, INCLUDING LANDMARKS, PARKS, ARENAS, UNIVERSITIES, AND TRANSPORTATION FACILITIES WITHIN 50 MILES OF INDIAN POINT POWER REACTORS AND SPENT FUEL POOL FACILITIES. Many of the historic sites are on the national historic preservation list and are protected under the National Historic Preservation Act.³

The Hudson River Ecosystem. The Indian Point facilities are located on the eastern bank of the Hudson River (at river mile 43). The Native American name for the river, Mahicantuck, means "great waters in constant motion" or "river that flows two ways." This name highlights the fact that this waterway is more than a river -- it is a tidal estuary. The Hudson River is an important regional resource of significant aesthetic value in addition to providing transportation, recreation, and water supply. More than 200 species of fish are found in the Hudson and its tributaries. Bald eagles, herons, waterfowl, and other birds feed from the river's bounty. Tidal marshes, mudflats, and other significant habitats in and along the estuary support a diversity of life. Tidal freshwater wetlands near Indian Point support this life web. The Hudson River is one of the Nation's fourteen American Heritage Rivers.

Seismic Hazard. Indian Point is susceptible to earthquake damage since it

³ *See, e.g.*, Letter from Thomas Lyons, New York State Office of Parks, Recreation, and Historic Preservation, to David Wrona, NRC (Oct. 26, 2010) ML103060210 (as part of NEPA and SAMA review, discussing the Revolutionary War Stony Point Battlefield site, which has been designated a National Historical Landmark by the U.S. Department of the Interior, and stating that "the Stony Point Battlefield is an irreplaceable asset to the people of New York State and the Nation.").

was initially designed to withstand an earthquake and ground acceleration which are now deemed to be below the reasonably predictable earthquake and ground acceleration for the site and its environs. *See generally*, Declaration of Lynn R. Sykes, Ph.D., and Declaration of Leonardo Seeber and accompanying Exhibits, (Nov. 2007), available at ML073400205 (Volume I of II); Letter from Attorney General Schneiderman to NRC Commissioners, Seismic Risk at Indian Point Nuclear Generating Station, (March 18, 2011) ML110820058; *see also* Comments Concerning the Proposed Generic Communication “Draft NRC Generic Letter 2011-XX: Seismic Risk Evaluations for Operating Reactors,” Docket ID NRC-2011-0202, at 14-19 (Dec. 15, 2011) ML11354A231. In 2008, the Bulletin of the Seismological Society of America published a peer-reviewed article by Dr. Sykes, Mr. Seeber, and others, identifying a new seismic feature in the vicinity of Indian Point.

Observations and Tectonic Setting of Historic and Instrumentally Located Earthquakes in the Greater New York City–Philadelphia Area, BULLETIN OF THE SEISMOLOGICAL SOCIETY OF AMERICA, Vol. 98:1696-1719 (Aug. 2008). The article concluded:

Two nuclear power plants at Indian Point (near Peekskill in Fig. 2) are located closer to more people at any given distance than any other similar facilities in the United States. Entergy, their owner, recently applied for 20-yr extensions of their existing 40-yr licenses. Much new seismological information is available since their initial approvals in 1973 and 1975. Nevertheless, the U.S. Nuclear Regulatory Commission so far has not permitted any new information to be used or old information on which the original licenses were based to be contested in considering extensions of licenses. Indian Point is situated at the intersection of the two most striking linear features marking the seismicity (Fig. 3) and also in the midst of a large population that is at risk in case of an accident to the plants. This is clearly one of the least favorable sites in our study area from an earthquake hazard and risk perspective.

Id. at 1717.

There is substantial new evidence that there is earthquake risk that NRC did not take into consideration when approving operation licenses for existing reactors and spent fuel storage facilities. In 2004, United States Geological Survey (“USGS”) told NRC that earthquake hazards in the Central and Eastern United States (“CEUS”), the portion of the lower 48 states east of the Rocky Mountains, were higher than previously understood. In May 2005 NRC staff acknowledged that earthquake risk for reactors and spent fuel storage in CEUS may be greater than NRC assumed when it approved operating licenses for these facilities. *See, e.g.*, May 26, 2005 NRC Staff memorandum re: Identification of a Generic Seismic Issue (available at ML051450456). NRC staff’s response to the new USGS earthquake hazard information was to consider issuing a “generic letter” on the subject of “Implications of Updated Probabilistic Seismic Hazard Estimates in Central and Eastern United States.” June 9, 2005 NRC staff memorandum Generic Issue 199, “Implications of Updated Probabilistic Seismic Hazard Estimates in Central and Eastern United States” (available at ML051600272). This memorandum contained an estimate that “the initial screening technical analysis will be completed within three months of receipt of the necessary information from [NRC’s Office of Nuclear Reactor Regulation].” *Id.*

The summary of the February 6, 2008 NRC staff public meeting relates that a seismologist working on Generic Issue 199 stated that for some CEUS areas the current earthquake frequency estimates were several times larger than those used

in the 1980's, and that revised ground motion predictive equations generally produced higher estimates of uncertainty about the effect of earthquakes at these sites. February 8, 2008 NRC staff memorandum Subject: Summary of February 6, 2008, Category 2 Public Meeting with the Public and Industry to Discuss Generic Issue 199, "Implications of Updated Seismic Hazard Estimates in Central and Eastern United States on Existing Plants," p. 2 (available at ML080350189).⁴

Need for Objective Site-Specific Analysis. Given the combination of site-specific characteristics, the decontamination costs and resource replacement costs following a severe accident at Indian Point have the potential to be substantially larger than an accident at any other reactor in the country. Furthermore, in light of the site-specific characteristics and the considerable costs associated with a severe nuclear accident in the New York metropolitan area, mitigation alternatives are likely to be more cost effective at the Indian Point facilities

Lack of Site-Specific Analysis of Severe Spent Fuel Pool Accident. Given their regulatory history, the three power reactors and their spent fuel pools located at Indian Point were not subjected to a severe accident mitigation alternatives analysis when AEC and NRC issued the construction permits and operating licenses for those facilities. According to AEC and NRC documents, the Consolidated Edison Company ("ConEd") received the following construction

⁴ The summary also related that a representative of the Electric Power Research Institute ("EPRI"), a private organization funded by the electric power industry, stated that it had "calculated mean seismic spectra for the 28 sites used in [NRC Regulatory Guide] 1.165." *Id.* However, EPRI has prevented public review of information and has delayed NRC's reassessment of earthquake hazards. *See, e.g.*, February 1, 2008 Screening Analysis for GI-199, "Implications of Updated Probabilistic Seismic Hazard Estimates in Central and Eastern United States on Existing Plants," p. 2 (available at ML073400477) (EPRI unwilling to share a report with NRC contractor.).

permits and operation licenses on the following dates:

	CONSTRUCTION PERMIT ISSUED	OPERATING LICENSE ISSUED
IP Unit 1	May 4, 1956	March 26, 1962
IP Unit 2	October 14, 1966	September 28, 1973
IP Unit 3	August 13, 1969	December 12, 1975

Source: Federal Register and NRC Information Digest.⁵

When ConEd announced its selection of the Indian Point site back in March 1955 and filed an application for the necessary construction permit, the AEC did not have site selection regulations that addressed population or seismic issues.

To place this initial siting decision in perspective, ConEd selected, and AEC approved, Indian Point as the site for a power reactor before the Windscale - Sellafield (1957), Three Mile Island (1979), Chernobyl (1986), and multi-unit Fukushima (2011) events. The 1955 selection of Indian Point also came before the enactment of NEPA (1970), the promulgation of CEQ regulations (1978), the Third Circuit’s *Limerick* decision (1989), and NRC promulgation of the 10 C.F.R. § 51.53 regulation (1996) that collectively require an analysis of ways to mitigate the impacts of severe accidents at nuclear facilities. In addition, AEC approved the construction of the first reactor and spent fuel pool before Congress enacted in the Price Anderson Act (1957).

⁵ See 21 Fed. Reg. 3,085 (May 9, 1956); 31 Fed. Reg. 13,616-17 (Oct. 21, 1966); 34 Fed. Reg. 13,437 (Aug. 20, 1969); NUREG-1350, Volume 20, *2008 - 2009 Information Digest*, at 103, 113 (Aug. 2008).

NRC confirms that severe accidents and consequences were not taken into account when selecting and approving the Indian Point site. In its 1979 Siting Study Report, NRC stated:

The maximum credible accident concept was carried into Part 100 in which an analysis of the consequences of the accident was used as a test of suitability of a proposed site and plant design. In Part 100, the maximum credible accident is defined as "...a major accident, hypothesized for purposes of site analysis or postulated from considerations of possible accidental events, that would result in potential hazards not exceeded by those from any accident considered credible" [10 CFR §100.11(a), footnote 1]. Although more severe accidents (now generally referred to as Class 9 accidents) are conceivable, the consequences of such accidents were normally not analyzed for assessing the suitability of a proposed site and plant design.

NRC, Report of the Siting Policy Task force, NUREG-0625 (Aug. 1979) at p. 10, ML12187A284. Moreover, severe accidents to spent fuel pools were not considered by AEC or NRC at the initial licensing stages for Indian Point -- and were not analyzed in the Siting Study Report.

Storage and Accumulation of Spent Nuclear Fuel at Indian Point. When the federal government first licensed the operation of Indian Point Unit 2 and Indian Point Unit 3 it authorized each unit's single spent fuel pool to hold 241 spent fuel assemblies. NRC subsequently authorized the pools to hold five times (5x) the original limit. The following charts summarize how NRC has authorized increasing amounts of spent nuclear fuel to be stored in the spent fuel pools for Indian Point

Unit 2 and Unit 3:

Date	Fuel Assemblies
1973	264
1980	482
1985	980
1989	1,376

Date	Fuel Assemblies
1975	264
1978	840
1989	1,345

Indian Point currently has – and is expected continue to have – substantial amounts of radioactive spent nuclear fuel waste on site. During the May 8, 2012 site visit to the Indian Point facilities by the Atomic Safety and Licensing Board, Entergy representatives made the following statements about Entergy’s plans for spent nuclear fuel at Indian Point:

- (A) All of the spent fuel generated during since the start of commercial operation of Indian Point Unit 3 remains in the Indian Point Unit 3 spent fuel pool (as of the date of the May 2012 site visit);
- (B) Entergy has no current plans to construct an additional dry cask storage area (in addition to the existing dry cask storage area); and
- (C) At the end of operation under any 20-year extension of the current operating licenses, Entergy estimates that the existing dry cask storage area would be filled to capacity and that the Indian Point Unit 2 spent fuel pool and the Indian Point Unit 3 spent fuel pool would be filled to capacity as well.

⁶ Consolidated Edison, *Final Design Report for Reracking the Indian Point Unit No. 2 Spent Fuel Pool*, at 1, ML100200292 (May 1980); Consolidated Edison, *Supplemental Spent Fuel Safety Analysis*, at 3-1, ML100350310 (Nov. 1985); and Consolidated Edison, *Indian Point Unit 2 Spent Fuel Pool Increased Storage Capacity Licensing Report*, at 1-2, ML100200114 (June 1989).

⁷ USAEC, *Safety Evaluation Report by the Directorate of Licensing U.S. AEC In the Matter of Consolidated Edison Co. of New York, Inc. Indian Point Nuclear Generating Unit No. 3*, at 4-1, 9-2, ML072260465 (Sept. 21, 1973); USNRC, *Indian Point, Unit 3, Amendment 13, Authorizing Modifications to the Spent Fuel Pool, Increasing Capacity from 264 to 840 Fuel Assemblies*, attached to *Letter from A. Schwencer, NRC to New York State Power Authority*, ML003778668 (Mar. 22, 1978); and USNRC, *Indian Point, Unit 3, Amendment 90, Allowing for the Expansion of the Spent Fuel Pool Storage Capacity*, attached to *Letter from Joseph Neighbors, NRC to New York Power Authority*, ML003778816 (Oct. 12, 1989).

This means that under Entergy's plan the site's two operating spent fuel pools will continue the site's dense pool storage practices into the future.

All of these unique characteristics of the Indian Point site demonstrate why it is essential that a site-specific analysis of the potential environmental impacts from the storage of spent fuel at the Indian Point facilities and measures to mitigate those potential impacts must be addressed.

Once NRC recognizes the potential significant environmental impacts that spent fuel storage will have at Indian Point, there are a wide array of mitigation measures and alternatives that it is obligated to consider as part of the NEPA review. First, NRC is obligated to assure that:

the Commission has taken all practicable measures within its jurisdiction to avoid or minimize environmental harm from the alternative selected, and if not, to explain why those measures were not adopted.

10 C.F.R. § 51.103(a)(4). Second, where, as here no legally sufficient prior analysis of spent fuel pool severe accident mitigation alternatives has been completed, NRC is obligated to assure that such an analysis has occurred and that all reasonable severe accident scenarios and mitigation measures have been evaluated. On occasion NRC and its consultants have publicly recognized the much greater potential risk from events occurring in a spent fuel pool including criticality accidents and fire hazards. By way of example, the Sandia National Laboratories have recently acknowledged that reducing the volume of spent fuel in spent fuel pools would mitigate the risks posed by dense storage. *See, e.g., Investigations of Zirconium Fires During Spent Fuel Pool LOCAs* (Slideshow) (Feb. 7, 2012); *see also*

Responding to Fukushima-Daiichi (Speech) (Jan. 31, 2012); *Responding to Fukushima-Daiichi* (Slideshow) (Jan. 31, 2012); *On Site Spent Fuel Criticality Analyses*, NRR Action Plan (September 19, 2011) ML11251A210; Sandia National Laboratories, *Mitigation of Spent Fuel Pool Loss-of-Coolant Inventory Accidents and Extension of Reference Plant Analyses to Other Spent Fuel Pools* (Redacted) (November 2006); NUREG-1738, *Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants* (Feb. 2001); NRC Reactor Safety Team (RST), *Assessment of Fukushima Daiichi Units*, ML11216A018 (Mar. 26, 2011, 2100h) (discussing ejection of fuel and damage to Daiichi facilities).

There are a wide-range of alternatives and mitigation alternatives that should be considered to the current plan to continue to crowd more spent fuel into the spent fuel pools and to maintain their current configuration including suggestions from the National Academy of Sciences, *Safety and Security of Commercial Spent Nuclear Fuel Storage: Public Report*, The National Academies Press (2006), and by well-respected experts in nuclear power plant safety such as Robert Alvarez, et. al., *Reducing the Hazards from Stored Spent Power-Reactor Fuel in the United States*, Science and Global Security, Vol. 11:1-51. Among the many feasible and easily implemented measures that could significantly mitigate the environmental impacts of routine operation of spent fuel pools at Indian Point as well as significantly reduce the consequences of severe accidents are the immediate off-loading of all spent fuel that is at least 5 years old to dry cask storage, installation of safety grade spray systems in the spent fuel enclosures to ensure

replacement water in the event of loss of coolant accident, re-arrangement of the spent fuel in the pools to allow for better circulation in the event of loss of coolant, to mention only a few of the recommendations contained in the reports identified in the Attachments to this letter.

NRC Staff has already ordered that certain measures be taken at nuclear reactors in an attempt to address some of the environmental and safety problems associated with spent fuel storage. In its March 12, 2012 Status Report on Implementation of the Near-Term Task Force Recommendations Based on Insights from the Fukushima Dai-ichi Accident, NRC announced it had ordered that “strategies shall be developed to add multiple ways to maintain or restore core cooling, containment and spent fuel pool (SFP) cooling capabilities in order to improve the defense in depth of licensed nuclear power reactors” and “[l]icensees are ordered to install enhanced SFP instrumentation.” *Id.* at 2-3. These recently-announced, first steps underscore the fact that NRC has now recognized that spent fuel pools represent a potential source of significant adverse environmental impacts for which corrective actions are needed. However, NEPA requires analysis of a full range of site specific alternatives and mitigation measures. Such a full range of alternatives has not been developed or analyzed for Indian Point.

The State is aware of ongoing efforts by NRC to begin to address problems with the spent fuel storage, including the above-mentioned Orders regarding recommendations from the Fukushima Daiichi Near Term Task Force. It is not a satisfactory answer to the State’s concerns for NRC to indicate that those efforts

should be a substitute for consideration at this time in major federal rulemaking proceeding of the serious environmental damage that can be caused by the spent fuel pool use and alternatives to mitigate that damage.

As the United States Court of Appeals for the District of Columbia observed in a slightly different context:

By refusing to consider requirement of alterations until construction is completed, the Commission may effectively foreclose the environmental protection desired by Congress. It may also foreclose rigorous consideration of environmental factors at the eventual operating license proceedings. If “irreversible and irretrievable commitment[s] of resources” have already been made, the license hearing (and any public intervention therein) may become a hollow exercise.

Calvert Cliffs’ Coordinating Comm. v. Atomic Energy Comm’n, 449 F.2d 1109, 1128 (D.C. Cir. 1971); accord *NRDC v. United States NRC*, 539 F.2d 824 (2d Cir. 1976), vacated *sub nom. as moot*, *Allied-General Nuclear Servs. v. NRDC*, 434 U.S. 1030 (1978):

“Although an EIS may be supplemented, the critical agency decision must, of course, be made after the supplement has been circulated, considered and discussed in the light of the alternatives, not before. Otherwise the process becomes a useless ritual, defeating the purpose of NEPA, and rather making a mockery of it.” (*Natural Resources Defense Council, Inc. v. Callaway, supra*, 524 F.2d at 92.)

NRDC, 539 F.2d at 845.

As NRC seeks to fulfill its mandate under the National Environmental Policy Act and examine the site-specific environmental impacts associated with authorizing the operation of Indian Point facilities in the future, it should in a proactive way address the issue of how it deals with severe nuclear events – be they

releases from reactors or spent fuel pools – that lead to significant environmental impacts including, as in the case of Japan, land contamination and displacement, perhaps permanently, of people from their homes and their livelihoods and their communities.

II. Need for Site-Specific and Site-Wide Severe Accident Review for the Indian Point Facilities

Recent events should compel NRC to conduct a site specific analysis of spent fuel pool risks. Such events include: the U.S. government has withdrawn its application to create a spent nuclear fuel repository at Yucca Mountain; events in Japan and Virginia demonstrated that external events (such as earthquakes or flooding) can pose severe risks to spent nuclear fuel residing at nuclear plants; the Tennessee Valley Authority, a federal agency that operates commercial nuclear reactors, has announced plans to consider an alternative strategy to shift spent nuclear fuel from spent fuel pools to dry cask storage; and recently-released NRC and Sandia National Laboratories documents confirm the State's concern and that alternatives are readily available. These developments indicate that spent nuclear fuel will continue to be housed indefinitely in densely-packed spent fuel pools at individual nuclear reactor sites, that such storage entails substantial, yet differing, site-specific risks due to the potential for seismic activity and other external events, and also, that alternatives exist to mitigate these site-specific impacts.

Based on the experience it has gained in the Indian Point license renewal proceeding, the State of New York has concerns over the scope and adequacy of the required site-specific analyses of severe accidents at nuclear power plants, known as

severe accident mitigation alternatives analyses, or “SAMA” analyses. NRC conducts SAMA analyses pursuant to NEPA and as a result of the Third Circuit’s ruling in *Limerick Ecology Action, Inc. v. Nuclear Regulatory Commission*, 869 F.2d 719 (3d Cir. 1989). The SAMA analyses submitted with license renewal applications examine only severe accidents resulting in releases from the reactor core; they do not consider the site-specific impacts of spent fuel pool accidents. Because NRC Staff and reactor owners do not consider the environmental impacts of spent fuel pool accidents as part of their NEPA analysis when reviewing an application to renew an operating license, they do not consider alternatives to current spent fuel pool storage configurations. Moreover, NRC Staff and the industry steadfastly oppose any State or citizen request under NEPA to review the environmental impacts of spent fuel pool accidents or alternatives to current spent fuel pool practices. It does not appear that NRC Staff’s NEPA-based SAMA analyses take severe accidents resulting in a radiological release from the spent fuel pools into consideration at all. This is a significant gap in Staff’s NEPA analyses. To close that gap, the State requests that NRC perform a site-specific analysis of severe accidents to include both reactor core and spent fuel pool releases as well as the means and alternatives to mitigate the impacts of such accidents.

The State also wishes to bring to the NRC's attention a separate concern over the conduct of site-specific severe accident mitigation alternatives analyses. Separate and apart from the concern over dense storage of spent nuclear fuel in spent fuel pools, the State is also concerned that site-specific SAMA alternatives

have relied on inputs developed for Surry, a relatively rural reactor site, that are not appropriate for reactors whose emergency planning zones include more suburban or urban areas. The site-specific analysis of potential severe accidents must rely on site-specific data from the region around the specific reactor in question, and not replicate the data from the Surry site or a “sample problem” for a computer code.

III. Generation of Spent Nuclear Fuel

A nuclear reactor is powered by enriched uranium fuel. Fission (the splitting of atoms) generates heat, which produces steam that turns turbines to produce electricity. Over time, the ability of nuclear fuel to produce sufficient fission to generate commercial quantities of energy diminishes. After it has been used to generate power in a reactor core for approximately six years, plant operators remove the spent nuclear fuel and replace it with new nuclear fuel. The spent nuclear fuel removed from the reactor core is transferred to a swimming pool-like structure known as a spent fuel pool. Although it no longer produces sufficient fission to generate commercial amounts of energy, spent nuclear fuel continues to give off significant amounts of thermal energy (or heat) and radiation after the fuel is removed from the reactor.

Unlike the reactor core, spent fuel pools are located outside containment.




Diagram of Pressurized Water Reactor. Source: The Union of Concerned Scientists, *available at:*
http://www.ucsusa.org/nuclear_power/nuclear_power_technology/.




Diagram of Boiling Water Reactor. Source: Nuclear Regulatory Commission, available at: <http://www.nrc.gov/reading-rm/basic-ref/teachers/03.pdf> at 3-16 (captions added).

IV. Toxicity and Longevity of Spent Nuclear Fuel

The toxicity of high level spent nuclear fuel to humans is “greater than that of any hitherto familiar industrial poison.”⁸ “At massive levels, radiation exposure can cause sudden death.”⁹ Exposed spent nuclear fuel will deliver a lethal dose nearly instantly if it has cooled less than one year; within about one minute if it has cooled for 5 years; in about 2 minutes if it has cooled for 10 years; and in about 5

⁸ *Industrial Radioactive Waste Disposal*, Summary-Analysis of Hearings, Joint Committee on Atomic Energy, Congress of the United States, at 6 (Aug. 1959).

⁹ *Nuclear Energy Institute v. U.S. Environmental Protection Agency*, 373 F.3d 1251, 1258 (D.C. Cir. 2004)(internal citations omitted) (hereinafter *NEI v. EPA*).

minutes if it has cooled for 50 years. Spent fuel that has cooled for 100 years can still deliver a lethal dose after 25 minutes of exposure.¹⁰ Even “[a]t lower doses, radiation can have devastating health effects, including increased cancer risks and serious birth defects such as mental retardation, eye malformations, and small brain or head size.”¹¹ Although a few isotopes in spent nuclear fuel have short half-lives of only several hours or a few days, “[r]adioactive waste and its harmful consequences persist for time spans seemingly beyond human comprehension.”¹²

V. History of On-Site Storage of Spent Nuclear Fuel

During the first two decades of nuclear power production in the United States, the Atomic Energy Commission and the Nuclear Regulatory Commission assured host communities that spent nuclear fuel from commercial nuclear reactors would be promptly removed from the sites and sent to off-site facilities for reprocessing or disposal.¹³ Based upon the belief that spent nuclear fuel would be stored on-site only temporarily before it was transported off-site for reprocessing,

¹⁰ United States Department of Energy, Statement of Position of the United States Department of Energy, Proposed Rulemaking on the Storage and Disposal of Nuclear Waste (Waste Confidence Rulemaking), DOE/NE-0007, page II-56, Table II-4 (April 15, 1980); *see also id.*, pages II-8 – II-9, Table II-1; U.S. Department of Energy, Dose Ranges (rem) Chart (June 2010). Available at: <http://lowdose.energy.gov/pdf/DoseRanges.pdf>. The calculations set forth above are based on the surface dose rates in rem/hr from the DOE report and the lethal dose rate of approximately 800 rem from DOE’s Dose Ranges chart. The lethal dose of 800 rems means that 50% of the population exposed at that rate will die within 30 days even with medical treatment.

¹¹ *NEI v. EPA*, 373 F.3d at 1258.

¹² *Id.*

¹³ Government Accountability Office, Report to Congressional Requesters, *Nuclear Fuel Cycle Options* (GAO 12-70), at 2 (Oct. 2011); *see also* Statement of NRC Commissioner Victor Gilinsky, 48 Fed. Reg. 22730, 22733 (May 20, 1983) (“The current generation of nuclear power plants was licensed on the assumption that spent fuel would be retained on site for a brief period, prior to being sent away for reprocessing.”).

nuclear plants were built with relatively small spent fuel storage pools.¹⁴ Moreover, the public was informed that spent fuel would not be stored long-term at nuclear plant sites. The Atomic Energy Commission (“AEC”) told the public that the facilities’ radioactive waste would be transported away from the host communities to distant facilities such as West Valley, New York or Morris, Illinois, where the spent fuel would be reprocessed.¹⁵ For example, the Final Environmental Statement for Indian Point, Unit 2 stated that radioactive wastes generated at the plant would be released to the environment or shipped to a reprocessing facility in Illinois.¹⁶

However, in the mid-1970’s, problems developed at the West Valley and Morris reprocessing facilities,¹⁷ and the U.S. abandoned commercial reprocessing of

¹⁴ Blue Ribbon Commission on America’s Nuclear Future, Reactor and Fuel Cycle Technology Subcommittee, Draft Report to the Full Commission, at 10 (“*RAFCT Report*”) (June 2011); see also Blue Ribbon Commission on America’s Nuclear Future, Transportation and Storage Committee, Draft Report to the Full Commission, at 2 (“*Storage Committee Report*”) (May 31, 2011) (“These pools were not intended or designed for permanent storage; the assumption was that spent fuel assemblies would spend a few years immersed in the pools before being transferred out for reprocessing or final disposition.”).

¹⁵ See, e.g., *Vermont Yankee Nuclear Power Station Final Environmental Impact Statement*, U.S. Atomic Energy Commission, at 93-94, ML061880207 (July 1972) (irradiated fuel elements will be shipped after minimum 90-day cooling period); *Prairie Island Final Environmental Statement*, U.S. Atomic Energy Commission, at 192, ML081840311 (May 1973) (spent nuclear fuel elements will be shipped to Nuclear Fuel Services Preprocessing Plant at West Valley, NY); *Final Environmental Statement for Indian Point, Unit 2*, Volume I, U.S. Atomic Energy Commission, at 257, ML072390276 (Sept. 1972) (approximately 35 truckloads of irradiated fuel per year will be transported to Midwest Fuel Recovery Plant in Morris, IL); *Final Environmental Statement for Indian Point, Unit 3*, Volume I, U.S. Nuclear Regulatory Commission, NUREG-75/002, at 412, ML072390284 (Feb. 1975) (irradiated fuel could be transported to the Allied-Gulf Nuclear Services Plant in Barnwell, SC).

¹⁶ *Final Environmental Statement for Indian Point, Unit 2*, at IX-3 (PDF, 298). The report estimated that approximately 35 truckloads of irradiated fuel per year, from Units 1 and 2, would be transported from the plant to Midwest Fuel Recovery Plant in Morris, IL (p. V-87, PDF 258).

¹⁷ See generally 40 Fed. Reg. 42801 (Sept. 16, 1975) (discussing problems with West Valley and Morris reprocessing facilities).

spent nuclear fuel due to concerns over nuclear weapons proliferation and cost.¹⁸ In order to deal with the spent fuel accumulating at plants, NRC authorized re-racking of the spent fuel assemblies (also known as dense storage) in spent fuel pools so that they held much larger amounts of spent fuel than initially contemplated.¹⁹ While the original open-racks were designed to promote water circulation, the high-density racks eliminated many of the channels between the fuel assemblies so they could be packed closer together.²⁰ This means there is less water circulation to cool the assemblies (or air circulation in an event causing the loss of water in the pool).²¹

With reprocessing no longer a viable option and fuel pools quickly filling, reactor operators and the federal government attempted to locate and develop a single, common national radioactive waste repository. The federal government told the public and courts that the repository would be operational in 1985.²² Thereafter, the government represented that the common national repository would be available between 2007 and 2009 for Prairie Island and Vermont Yankee's spent fuel waste.²³ Those dates have also come and passed, and the revised date of 2025

¹⁸ *RAFCT Report* at 10. See also Statement by the President, 3 Pub. Papers 2763, 2767-68 (Oct. 28, 1976) (President Ford's announcement of moratorium); Statement by the President, 1 Pub. Papers 581, 587-83 (Apr. 7, 1977) (President Carter's announcement of moratorium).

¹⁹ See generally *Minnesota v. NRC*, 602 F.2d 412, 414 (D.C. Cir 1979) (describing requests by Vermont Yankee and Prairie Island to store 3 times as much spent fuel as originally envisioned).

²⁰ National Academy of Sciences, *Safety and Security of Commercial Spent Nuclear Fuel Storage: Public Report*, The National Academies Press, at 23 ("*NAS Report*") (2006).


²¹ *Id.*

²² *NRDC v. NRC*, 582 F.2d 166, 173 (2d Cir. 1978) (federal "goal is to have an operating high-level waste repository at the soonest possible time, namely 1985"). In 1980, the federal Department of Energy represented that a national repository "should be available for use in the 1997-2006 time period." DOE/NE-0007, at IV-4.

²³ *Minnesota*, 602 F.2d at 418.

was formally abandoned in a 2010 rulemaking proceeding.²⁴ As will be discussed below on page 43, the federal government recently abandoned its decades-long effort to create a national repository at Yucca Mountain in Nevada.

The current de facto national spent fuel storage strategy involves maximizing the amount of spent fuel that can be stored in reactor pools through use of high-density storage racks, and then moving the older fuel into on-site dry storage casks as needed to maintain enough free space in the pools for discharge of the full reactor core. As the chart below shows, the spent fuel pools at nuclear plants around the country are quickly reaching capacity.²⁵ NRC is aware that at some reactors, such as Indian Point Unit 3 located in New York, the spent fuel pools have already reached maximum capacity—even with dense storage.



Note: All operating nuclear power reactors are storing used fuel under NRC license in spent fuel pools. Some operating nuclear reactors are using dry cask storage. Information is based on loss of full-core reserve in the spent fuel pools.

Source: Energy Resources International and DOE/RW-0431 – Revision 1

²⁴ 75 Fed. Reg. 81040 (Dec. 23, 2010).

²⁵ The figure below is taken from NRC’s website, *available at*: <http://www.nrc.gov/waste/spent-fuel-storage/nuc-fuel-pool.html>.

VI. Environmental Hazards and Impacts of Spent Fuel Pools

Spent fuel pools have different designs and liners, and some are located at ground level while others are located above the ground. The design and placement of spent fuel racks, air circulation and convection mechanisms, type of reactor, and amount of heat generated by the fuel itself also differ from plant to plant. Unlike nuclear power reactors, which are located within containment shells, spent fuel pools are not protected by thick concrete domes,²⁶ making them susceptible to radiological release as a result of fires or leaks. Their susceptibility, however, is affected by the site-specific differences between the pools.²⁷

A. Fires

When fuel is removed from a nuclear reactor, it is extremely hot and continues to generate large amounts of energy. It must be submerged in cold water for five years so that it does not spontaneously ignite. The figures below, taken from a report prepared by Sandia National Laboratories,²⁸ show that spent fuel can generate close to 10 MW of energy when it is first removed from a reactor and placed in a spent fuel pool. To put this amount of energy in perspective, one megawatt of capacity produced by a conventional generator (such as a coal plant) will produce enough electricity to provide for the annual electric needs of 400 to 900 homes.²⁹ This considerable amount of residual or “decay” heat causes the



²⁶ *NAS Report* at 40.

²⁷ *Id.* at 8, 31, 40-43.

²⁸ Sandia National Laboratories, *Mitigation of Spent Fuel Pool Loss-of-Coolant Inventory Accidents and Extension of Reference Plant Analyses to Other Spent Fuel Pools*, at 54 (“2006 Sandia Report”) (Nov. 2006).

²⁹ Bob Bellemare, *What is a Megawatt?* (June 24, 2003). Available at:

temperature of the pool water to increase rapidly, and cooling water is required to constantly refresh the pool and replenish the water lost through evaporation so that the fuel assemblies do not overheat.



<http://www.utilipoint.com/2003/06/what-is-a-megawatt/>.

Assuming that a reactor has a 23-month refueling cycle, the scenario depicted by the above figures could take place ten times during a twenty year operating license authorized by a renewed reactor operating license. For sites, such as Indian Point, that have two operating power reactors, this scenario could occur approximately twenty times during the additional twenty year operating period.

In 2001, NRC issued a technical study called NUREG-1738 that examined the risk of spent fuel pool fire.³⁰ That study found that, if a pool lost enough water to uncover the spent fuel assemblies, the spent fuel could heat to the point where the fuel's zirconium cladding might catch fire.³¹ A zirconium fire could generate a radioactive plume causing thousands of deaths from cancer.³² Other studies submitted to NRC reached the same conclusion about the adverse consequences of a zirconium fire.³³ The graph below, taken from NUREG-1738, shows that for decay times of less than about 2 years for pressurized water reactors ("PWRs") and 1.5 years for boiling water reactors ("BWRs"), "it would take less than 10 hours for a zirconium fire to start or for significant fission product releases to begin once the fuel was fully uncovered and the fuel was cooled by an air flow of about two building volumes per hour. The figure also shows that after 4 years, PWR fuel could reach

³⁰ Nuclear Regulatory Commission, NUREG-1738, *Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants*, ("NUREG-1738") ML010430066 (Feb. 2001).

³¹ *Id.* at 2-1 to 2-3, A1A-1 to A1A-6. For an illustrated explanation of how a zirconium fire could occur, see The New York Times, Hazards of Storing Spent Fuel, (Mar. 18, 2011), available at: <http://www.nytimes.com/interactive/2011/03/12/world/asia/the-explosion-at-the-japanese-reactor.html?ref=asia>.

³² *Id.* at Appendix 4A, Attachment 1; *NAS Report* at 49-50.

³³ Robert Alvarez, et al., *Reducing the Hazards from Stored Spent Power-Reactor Fuel in the United States*. Science and Global Security, Vol. 11:1-51, at 7-11 ("*Reducing the Hazards*") (Jan. 22, 2003); Beyea, Lyman, von Hippel, *Damages from a Major Release of 137Cs into the Atmosphere of the United States*, Science and Global Security, Vol. 12:125-136 ("*Damages from a Major Release*") (Jan. 21, 2004).

the point of fission product release in about 24 hours.”³⁴




Figure 1A-1 Heatup time from 30 °C to 900 °C

NUREG-1738 also found that “[h]eat removal is very sensitive to” plant-specific factors, including “fuel assembly geometry” and “rack configuration,” and is “subject to unpredictable changes after an earthquake or cask drop that drains the pool.”³⁵ Following the release of NUREG-1738, NRC’s Director of Operations issued a memorandum acknowledging that “a zirconium fire event can have public health and safety consequences similar to a severe core damage accident with a large offsite release” and “that the possibility of a zirconium fire cannot be dismissed even many years after final reactor shutdown.”³⁶

A 2003 peer-reviewed article by Robert Alvarez, a Senior Scholar at Princeton University’s Institute for Policy Studies and a former Senior Policy Advisor to the

³⁴ NUREG-1738 at A1A-4.

³⁵ NUREG-1738 at x.

³⁶ Nuclear Regulatory Commission, SECY-01-0100, NRC Policy Issue (Notation Vote) Memorandum from William D. Travers, Executive Director for Operations to NRC Commissioners, *Policy Issue Related to Safeguards, Insurance, and Emergency Preparedness Regulations at Decommissioning Nuclear Power Plants Storing Fuel in Spent Fuel Pools (WITS 200000126)*, at 5, 2 (June 4, 2001).

U.S. Secretary of Energy, concluded that the dense packing of spent fuel in cooling pools does not provide a sufficient safety margin in the event of a pool breach and consequent water loss from an accident or terrorist attack.³⁷ In such cases, the fuel most recently placed in the pool could heat up enough to ignite its zirconium cladding, possibly resulting in the release of large amounts of radioactivity to the environment.³⁸ To reduce this risk, the Alvarez article recommended moving spent fuel that had cooled for five years to dry-cask storage.³⁹ The graph below, taken from the Alvarez article, shows that several days after being removed from the reactor, nuclear fuel is releasing 100 kilowatts of radioactive heat per metric ton of uranium (kWt/tU).⁴⁰




Figure 5: Decay heat as a function of time from 0.01 years (about 4 days) to 100 years for spent-fuel burnups of 33, 43, 53 and 63 MWd/kgU. The lowest burnup was typical for the 1970s. Current burnups are around 50 MWd/kgU (Source: authors³⁸).

³⁷ See *Reducing the Hazards from Stored Spent Power-Reactor Fuel in the United States*, Science and Global Security, Vol. 11:1-51 (“*Reducing the Hazards*”) (2003).

³⁸ *Id.*

³⁹ *Id.* at 27.

⁴⁰ *Id.* at 12.

Gordon Thompson of the Institute for Resource and Security Studies has also issued reports concluding that increased storage of spent fuel in dry casks would allow lower-density packing of spent fuel pools and decrease the risk of pool fires.⁴¹ But, as yet, only 22% of spent nuclear fuel is stored in dry casks.⁴² Other scientists and engineers have raised similar points.⁴³ NRC disagreed with *Reducing the Hazards* and criticized Alvarez and the Institute for Policy Studies for questioning NRC's and industry's reliance on densely packed spent fuel pools.

Concerned about the implications of the Alvarez article and NUREG-1738, the United States Congress directed NRC to seek independent technical advice from the National Academy of Sciences ("NAS") on the safety and security of spent fuel storage.⁴⁴ In response, NAS confirmed the potential for a pool fire that could result in the release of a substantial portion of a fuel pool's radioactive inventory.⁴⁵ The NAS report also agreed with NUREG-1738 that the risk of spent fuel pool fires cannot be determined on a generic basis: "[t]he potential vulnerabilities of spent fuel pools to terrorist attacks are plant-design specific. Therefore, specific vulnerabilities can be understood only by examining the characteristics of spent fuel

⁴¹ See, e.g., Gordon R. Thompson, *Environmental Impacts of Storing Spent Nuclear Fuel and High-Level Waste from Commercial Nuclear Reactors: A Critique of NRC's Waste Confidence Decision and Environmental Impact Determination*, at 49-50 (Feb. 6, 2009).

⁴² Nuclear Regulatory Commission, *Spent Fuel Storage in Pools and Dry Casks Key Points and Questions and Answers* (Apr. 29, 2011). Available at: <http://www.nrc.gov/waste/spent-fuel-storage/faqs.html>.

⁴³ See *Damages from a Major Release* (discussing accident costs at Indian Point and four other sites).

⁴⁴ U.S. Congress, Conference Report 108-357, *Making Appropriations for Energy and Water Development for the Fiscal Year Ending September 30, 2004, and for Other Purposes*, at 191 (Nov. 7, 2003).

⁴⁵ *NAS Report* at 1. NRC actions delayed the release of the public version of the report. *Agencies Fight Over Report on Sensitive Atomic Wastes*, New York Times (Mar. 30, 2005). The public version of the NAS Report was release on April 6, 2005.

storage at each plant.”⁴⁶ The NAS report also found that sabotage of spent fuel pools is possible and that under some conditions, a terrorist attack that partially or completely drained a spent fuel pool could lead to a zirconium cladding fire that would “propagate”—*i.e.*, spread from the spent fuel rod or assembly that initially caught fire to other assemblies—and cause the release of large quantities of radioactive materials to the environment.⁴⁷ Following the completion of the NAS Report, Congress directed NRC to develop site-specific mitigation models for different spent fuel sites.⁴⁸

B. Leaks

Although NRC has described spent fuel pools as “leak tight,” the experience has shown that description to be inaccurate. In 2005, Indian Point identified leakage of radionuclide-contaminated water from cracks in two different spent fuel pools and subsequently discovered tritium, strontium, and other radionuclides in groundwater underneath the site.⁴⁹ Strontium and tritium from Indian Point’s spent fuel pools have reached the Hudson River.⁵⁰

⁴⁶ *NAS Report* at 8.

⁴⁷ *Id.* at 38-39, 48.

⁴⁸ U.S. Congress, Conference Report 108-792, *Making Appropriations for Foreign Operations, Export Financing, and Related Programs for the Fiscal Year Ending September 30, 2005, and For Other Purposes*, at 982 (Nov. 20, 2004).

⁴⁹ Nuclear Regulatory Commission, NRC Talking Points Slide Entitled, “Tritium at Nuclear Power Plants in the United States, Slide 3: Background,” ML063260464 (Nov. 7, 2006); Nuclear Regulatory Commission Office of Nuclear Reactor Regulation, *Ground-Water Contamination Due to Undetected Leakage of Radioactive Water*, NRC Information Notice 2006-13, at 3-4 (“*Ground-Water Contamination*”) ML060540038 (July 10, 2006).

⁵⁰ *Ground-Water Contamination* at 3-4; Entergy, Indian Point License Renewal Application, Environmental Report at 5-4, ML071210530 (Apr. 23, 2007).

Existing radioactive leaks at Indian Point have already far exceeded national drinking water standards.⁵¹ All fresh groundwater in New York State is Class GA, the best use of which is as a source of potable water supply.⁵² Indian Point groundwater concentrations have exceeded national drinking water standards for tritium in six locations, sometimes by more than four times the tritium concentrations considered harmful to human health, and exceed national drinking water standards for Strontium-90 in ten locations, by almost five times in some locations.⁵³

While NRC has recently acknowledged tritium leaks, it has been reluctant to acknowledge leaks of strontium and other radionuclides. In November 2010, the State of New York sought to draw the Commission's attention to the fact that radionuclides in addition to tritium have leaked from reactors.⁵⁴ Moreover, the subsurface radiation plumes have exceeded EPA drinking water standards.⁵⁵ The concerns outlined in the State's 2010 letter further support treating groundwater contamination as a site-specific environmental impact.

In 2002, water from a spent fuel pool at Salem Nuclear Power Plant in New Jersey was discovered to have leaked into a narrow seismic gap between two buildings, and further investigation revealed tritium in the groundwater near one of

⁵¹ See GZA GeoEnvironmental, Inc., *Hydrogeologic Site Investigation Report, Indian Point Energy Center*, at 90, 126, ML080320540 ("GZA Report") (Jan. 7, 2008); see also 40 C.F.R. § 141.66 (establishing drinking water standard for tritium at 20,000 pCi per liter and strontium at 8 pCi per liter).

⁵² 6 N.Y.C.R.R. § 701.15.

⁵³ *GZA Report* at 125-26.

⁵⁴ State of New York Comment Letter on Groundwater Task Force Report, Docket ID NRC-2010-0302, 75 Fed. Reg. 57987 (Nov. 1, 2010) ML103080060.

⁵⁵ *Id.*

the buildings.⁵⁶ These leaks occurred during the reactors' initial licensing term, calling into question the structural integrity of spent fuel pools as many reactors approach the end of their initial terms and seek license renewals.

Radioactive water has also leaked from spent fuel pools at the Seabrook Nuclear Power Station in Seabrook, New Hampshire in 1999, at the Tennessee Valley Authority's Watts Bar Nuclear Generating Station in Spring City, Tennessee in 2002, and at Palo Verde Nuclear Generating Station, Unit 1 in Wintersburg, Arizona in 2005.⁵⁷

In 1997, groundwater samples taken by Brookhaven National Laboratories in Long Island, New York revealed concentrations of tritium at twice the allowable federal drinking-water standards.⁵⁸ Subsequent samples were found to contain thirty-two times the standard.⁵⁹ The tritium was leaking from the spent fuel pool serving the laboratory's nuclear reactor into the aquifer that provides the sole source of drinking water for nearby Suffolk County residents.⁶⁰ The Department of Energy's and laboratory's investigations concluded that the tritium had been leaking for as long as twelve years without the Department's or laboratory's

⁵⁶ Nuclear Regulatory Commission Office of Nuclear Reactor Regulation, *Spent Fuel Pool Leakage to Onsite Groundwater*, NRC Information Notice 2004-05 (Salem, New Jersey, Nuclear Generating Station), ML040580454 (Mar. 3, 2004).

⁵⁷ Nuclear Regulatory Commission, *Liquid Radioactive Release Lessons Learned Task Force Final Report*, at 9, 24, and 35, ("*Radioactive Release Lessons Learned*") ML062650312 (Sept. 1, 2006).

⁵⁸ General Accounting Office, Report to Congressional Requesters, Department of Energy, *Information on the Tritium Leak and Contractor Dismissal at the Brookhaven National Laboratory* (GAO/RCED-98-26), at 1-9 ("*Tritium Leak and Contractor Dismissal*") (Nov. 1997).

⁵⁹ *Id.* at 4.

⁶⁰ *Id.* at 7-9; 43 Fed. Reg. 26,611, 26,612 (June 21, 1978) (EPA designation of sole source aquifer).

knowledge.⁶¹ A subsequent federal investigation concluded that Brookhaven employees did not aggressively monitor its spent fuel pool for leaks—even postponing an agreed-upon monitoring-well system—so that years passed before tritium contamination was discovered in the aquifer near the spent fuel pool.⁶²

In 1986, in an “acute unmonitored release of large volumes of contaminated liquids to onsite ground surfaces and surface waters,” 124,000 gallons of water containing 0.20 curies of tritium and 0.373 curies of mixed fission products leaked from the spent fuel pool at the Edwin I. Hatch nuclear power plant in Baxley, Georgia to a nearby swamp and into the Altamaha River.⁶³ The plant’s owner did not calculate the maximum possible offsite doses, because no regulation required it to do so, but NRC found that the accident “demonstrated a lack of insistence on procedural adherence and attention to detail.” and levied a civil monetary penalty.⁶⁴

NRC acknowledged this Hatch leak in its 1990 waste confidence findings and also that on August 16, 1988 a seal on a fuel pool pump failed at the Turkey Point nuclear plant near Miami, Florida causing approximately 3,000 gallons of radioactive water to leak into a nearby storm sewer, contaminating the shoes and clothing of approximately 15 workers.⁶⁵

NRC recently acknowledged that “leaks can develop in [spent fuel pools] and go undetected for long periods of time absent appropriate monitoring, resulting in the contamination of onsite groundwater and the potential for undetected,

⁶¹ *Tritium Leak and Contractor Dismissal* at 9.

⁶² *Id.* at 9-12.

⁶³ *Radioactive Release Lessons Learned* at 5, 14; 55 Fed. Reg. 38474 (page 54) (Sept. 18, 1990).

⁶⁴ *Radioactive Release Lessons Learned* at 34.

⁶⁵ 55 Fed. Reg. 38474, (p. 54) (Sept. 18, 1990).

unevaluated releases of radioactivity to an unrestricted area.”⁶⁶ The NRC has also acknowledged that its current regulations do not require groundwater monitoring and that licensees typically initiate groundwater monitoring only in response to known leaks.⁶⁷ But NRC has not required plants to monitor for, assess, or remediate leaks, instead relying on voluntary initiatives undertaken by industry.⁶⁸

VII. Significant New Information Regarding Spent Fuel Pools

The past three years have seen several developments involving the storage of spent nuclear fuel that NRC should take into consideration in the Proposed Rule and the DGEIS. CEQ regulations, to which NRC gives deference, and NEPA caselaw recognize that over time new information may become available that should be factored into the decision-making process or used to update a previous EIS. Agencies must supplement a previously issued EIS when “[t]here are significant new circumstances or information relevant to environmental concerns and bearing on the proposed action or its impacts.”⁶⁹ Similarly, when new information comes to light over the course of a rulemaking, the federal agency should ensure that such information is taken into account in the rulemaking process and that any resulting NEPA-APA-AEA rulemaking does not impede consideration of such information in site-specific regulatory proceedings.

⁶⁶ *Ground-Water Contamination* at 5.

⁶⁷ *Id.* at 5-6.

⁶⁸ Nuclear Regulatory Commission, *Senior Management Review of Overall Regulatory Approach to Ground Water Protection*, SECY-11-0019 (Feb. 9, 2011); *Ground-Water Contamination* at 5-7.

⁶⁹ 40 C.F.R. § 1502.9(c). *See also Marsh v. Oregon Natural Resources Council*, 490 U.S. 360, 374 (1989) (“If there remains major Federal action to occur, and if the new information is sufficient to show that the remaining action will affect the quality of the human environment in a significant manner or to a significant extent not already considered, a supplemental EIS must be prepared” (internal citations omitted)).

As the colloquy during the January 11, 2012 Commissioners' meeting made clear, with respect to severe accidents, Staff's position is not that real world consequences and environmental impacts of such accidents would be insignificant, but rather that there is a low probability that precursor accidents will occur. Based on this supposed low probability, the Staff categorizes the environmental impacts from severe reactor accidents as "small."⁷¹ But NRC's characterization of severe accidents as "small" ignores the significant consequences that would ensue if a severe accident were to occur. The reports and photographs of the consequences of Fukushima's multi-reactor accidents depict impacts that were anything but "small." NRC's logic is simply no longer tenable in a NEPA review of the site-specific environmental impacts associated with issuing an operating license.

The destruction of four GE-designed reactors at Fukushima-Daiichi in March 2011 shows that severe accidents are neither improbable nor are the environmental impacts of severe accidents at power reactors or spent fuel pools "small." The consequences of those severe accidents, including the radiological contamination of portions of Fukushima Prefecture, show that the real world consequences of severe accidents are not "small." In light of the Fukushima accidents, recent regulatory actions and statements, and newly released documents, the State believes that NRC should consider the information contained herein to be significant and should pursue a site specific and site wide severe accident mitigation alternatives analysis for Indian Point.

⁷¹ *Id.* at 80-81.

A. Yucca Mountain Repository Project Formally Abandoned

In 2009, the federal government announced that the long awaited nuclear repository at Yucca Mountain, Nevada, was no longer a viable option.⁷³ Subsequently, in March 2010, the Department of Energy (“DOE”) submitted to NRC a request to withdraw its license application for the Yucca repository.⁷⁴ Although the NRC’s Atomic Safety and Licensing Board (“Board”) denied DOE’s request,⁷⁵ the decision was appealed and, after an evenly divided vote, the Commission ordered the Board to suspend its review by the end of fiscal year 2011, due to lack of funding for the upcoming fiscal year.⁷⁶ In its final report, the federal Blue Ribbon Commission noted:

The Obama Administration’s decision to halt work on a repository at Yucca Mountain in Nevada is but the latest indicator of a policy that has been troubled for decades and has now all but completely broken down. The approach laid out under the 1987 Amendments to the Nuclear Waste Policy Act (NWPA)—which tied the entire U.S. highlevel waste management program to the fate of the Yucca Mountain site—has not worked to produce a timely solution for dealing with the nation’s most hazardous radioactive materials. The United States has traveled nearly 25 years down the current path only to come to a point where continuing to rely on the same approach seems destined to bring further controversy, litigation, and protracted delay. . . . Put simply, this nation’s failure to

⁷³ Nuclear Regulatory Commission, Draft Report for Comment, *Background and Preliminary Assumptions For an Environmental Impact Statement—Long-Term Waste Confidence Update*, at 2, ML11340A141 (Dec. 2011).

⁷⁴ Dep’t of Energy Motion to Withdraw, *In re U.S. Dep’t of Energy (High-Level Waste Repository)*, Docket No. 63–001, ASLBP No. 09–892–HLW–CAB04 (United States Nuclear Regulatory Commission), ML100621397 (Mar. 3, 2010).

⁷⁵ HLW License Application Docket No. 63-001, Board Memorandum and Order (LBP-10-11), ML101800299, (June 29, 2010).

⁷⁶ HLW License Application Docket No. 63-001, Commission Memorandum and Order (CLI-11-07), ML11252A532 (Sept. 9, 2011). *See also* Memorandum from Catherine Haney, Director, Office of Material Safety and Safeguards, to Commission, *Update on the Yucca Mountain Program*, ML11180A265 (Sept. 1, 2011) (stating that the Yucca Mountain Program is on track to complete the closure of the Yucca Mountain licensing review by the end of Fiscal Year 2011).

come to grips with the nuclear waste issue has already proved damaging and costly and it will be more damaging and more costly the longer it continues⁷⁷

The State recognizes that the U.S. Court of Appeals for the D.C. Circuit recently directed NRC to resume its review of the application for a license to store nuclear waste at the Yucca Mountain site. *In re Aiken County*, 725 F.3d 255 (D.C.Cir 2013). According to NRC, approximately \$11 million of Congressionally-approved funds remains. *Id.*, at 267.

With little prospect of a central repository or disposal site for decades to come, spent nuclear fuel continues to accumulate at nuclear plants around the country. Currently, there is an inventory of approximately 69,000 metric tons of spent fuel from commercial nuclear plants, the majority of which is being stored in pools at those plants, and this inventory is growing at a rate of 2,000 to 2,400 metric tons per year.⁷⁸

The Blue Ribbon Commission concluded, “Simply put, it will take years to more than a decade to open one or more consolidated storage facilities and even longer to open one or more disposal facilities. This means that storage of substantial quantities of spent fuel at operating reactor sites can be expected to continue for some time.”⁸¹ The reality of the situation, demonstrated by these developments, is that the U.S. does not have a comprehensive policy for the removal

⁷⁷ Blue Ribbon Commission on America’s Nuclear Future, Report to the Secretary of Energy, at vi (“*Blue Ribbon Commission Report*”) (Jan. 2012).

⁷⁸ Blue Ribbon Commission on America’s Nuclear Future, Disposal Subcommittee, Draft Report to the Full Commission, at 2 (June 1, 2011). Even if the Yucca Mountain disposal site had been licensed and constructed, it could not hold more than 70,000 metric tons of waste.

⁸¹ *Blue Ribbon Commission Report* at 44.

and disposal of spent nuclear fuel from reactor sites (such as Indian Point), and is far from establishing one.

B. External Events in Japan and Virginia

The recent earthquakes in Japan and Virginia present significant new information that affirm the importance of site-specific evaluation of spent fuel pool risks.

1. Fukushima Daiichi and Site-Wide Risk

On March 11, 2011, the Japanese earthquake and tsunami led to the largest nuclear disaster since the Chernobyl accident in 1986.⁸³ A 100 square mile zone around the Fukushima Daiichi nuclear facility was evacuated, and, a year later, at least 80,000 people remain displaced from their homes.⁸⁴ The Japanese Environment Ministry plans to decontaminate only two-thirds of the evacuation zone, as radiation levels in the last third of the zone are too high to be brought down to safe levels with current technology.⁸⁵

In the weeks following the disaster, the U.S. Department of Energy and the National Nuclear Security Administration prepared maps depicting the ground


⁸³ The Fukushima nuclear disaster has been rated as a 7 on the International Atomic Energy Agency's ("IAEA") International Nuclear and Radiological Event Scale ("INES").⁸³ Level 7, the most serious level on the INES scale, constitutes a "major accident." It is described as "A major release of radioactive material with widespread health and environmental effects requiring implementation of planned and extended countermeasures." IAEA, Fukushima Nuclear Accident Update, (Apr. 12, 2011), *available at*:

<http://www.iaea.org/newscenter/news/2011/fukushima120411.html>.

⁸⁴ Hiroko Tabuchi, A Confused Nuclear Cleanup, New York Times (Feb. 10, 2012), *available at*: http://www.nytimes.com/2012/02/11/business/global/after-fukushima-disaster-a-confused-effort-at-cleanup.html?pagewanted=1&_r=1.

⁸⁵ Martin Fackler, Japan: Nuclear Contamination Cleanup Near Stricken Plant to Start in Spring, New York Times (Jan. 26, 2012), *available at*: http://www.nytimes.com/2012/01/27/world/asia/japan-nuclear-contamination-cleanup-near-stricken-plant-to-start-in-spring.html?_r=1

level dispersion of radionuclides in Fukushima Prefecture. While these maps show large areas of ground contamination, they do not depict the dispersion of radionuclides in the groundwater, rivers, or ocean.



The image on the left shows the ground level dose rate of cesium in Japan normalized to April 29, 2011. The image on the right shows the total cesium deposition normalized to the same date. Source: U.S. DOE and NNSA, Radiological Assessment of Effects From Fukushima Daiichi Nuclear Power Plant, (May 6, 2011).

Each of Fukushima Daiichi’s 6 reactor units has a spent fuel pool, in addition to one common larger pool shared by all 6 units.⁸⁶ The spent fuel cooling flow was lost for all units following the loss of power, and it was not restored when the

⁸⁶ Institute of Nuclear Power Operations, Special Report on the Nuclear Accident at the Fukushima Daiichi Nuclear Power Station, INPO 11-005, at 35, ML11347A454 (“INPO Report”) (Nov. 2011). It should be noted that the pools at each of Fukushima’s 6 units contain much less spent fuel than pools at typical U.S. plants. Nuclear Regulatory Commission, *Recommendations for Enhancing Reactor Safety in the 21st Century*, at 43, ML111861807 (“Near-Term Task Force Report”) (July 12, 2011).

emergency generators started.⁸⁷ In addition, workers were unable to monitor the spent fuel pools.⁸⁸ Spent fuel may also have been damaged by falling debris.⁹⁰

After a hydrogen explosion at Unit 4, operators feared that the water had boiled off of the fuel assemblies in Unit 4's pool because the entire core of the Unit 4 reactor had been off-loaded into the pool for maintenance three months earlier.⁹¹ The responders faced very challenging conditions at the plant, making it difficult to assess the status of the pool. Equipment was non-functional, parts of the plant were inaccessible, supplies of fresh water were interrupted, and there was high radiation, high temperature, smoke, steam, and debris.⁹² Fire engines, helicopters, and water cannons were all unable to add water to the spent fuel pool in the immediate aftermath of the earthquake and tsunami.⁹³ Finally, on March 18, concrete pumping trucks (with long articulated booms for transferring concrete) successfully added water to the pools. The Institute of Nuclear Power Operations ("INPO") notes, "The delay in refilling the SFPs may have contributed to increased radiation levels in the area around the spent fuel pools because less shielding was provided with the reduced water level."⁹⁴

⁸⁷ *Id.* at 12.

⁸⁸ *Near-Term Task Force Report* at 9.

⁹⁰ *Id.* at 37.

⁹¹ *Id.* at 36. The cause of the explosion has not yet been conclusively established; at present, NRC Staff is pursuing a hypothesis that the explosion was not caused by the spent fuel, but by hydrogen from Unit 3 that had entered Unit 4 through the ventilation system.

⁹² Gordon R. Thompson, *New and Significant Information From the Fukushima Daiichi Accident in the Context of Future Operation of the Pilgrim Nuclear Power Plant*, A Report for the Office of the Attorney General, Commonwealth of Massachusetts, at 18 ("*Thompson 2011 Report*") (June 1, 2011).

⁹³ *INPO Report* at 36.

⁹⁴ *Id.*

Several reports have discussed the significant new information generated by the Fukushima accident. On April 19, 2011, Dr. Arjun Makhijani of the Institute for Energy and Environmental Research submitted to NRC a declaration in support of an emergency petition to suspend all pending reactor licensing decisions pending investigation of the lessons learned from the Fukushima disaster.⁹⁵ Dr. Makhijani outlined the significant new information that has come out of the Fukushima accident including: the unanticipated compounding effects of simultaneous accidents at multiple co-located reactor units, including spent fuel pools; the unanticipated risks of spent fuel pool accidents, including explosions; the frequency of severe accidents and explosions; the inadequacy of safety systems to respond to long-duration accidents; and the health effects and costs of severe accidents.⁹⁶ Makhijani highlighted the unprecedented nature of the accident, noting, “In the entire history of nuclear power, there has not been another major accident (level 5 or above) that has involved multiple major sources of radioactivity—including multiple reactors and multiple spent fuel pools.”⁹⁷ He asserted that the information

⁹⁵ Declaration of Dr. Arjun Makhijani in Support of Emergency Petition to Suspend all Pending Reactor Licensing Decisions and Related Rulemaking Decisions Pending Investigation of Lessons Learned from Fukushima Daiichi, ML111091181 (Apr. 19, 2011).

⁹⁶ *Id.* at 5.

⁹⁷ *Id.* at 6. The Near-Term Task Force acknowledged that before the Fukushima accident, NRC had not anticipated an accident involving multiple units and spent fuel pools. In a May briefing one member stated, “Also, if you look at the way that we’ve analyzed accidents in the United States and the way that we deal with them, it really focused on a single unit being affected. Fukushima is a situation where multiple units were affected at the same time. So our EP [emergency preparedness] requirements focus on a single unit event . . . And if you’re dealing with a multiple unit event at the same time, you have considerations with regard to adequate staffing, how to triage, who makes the decisions on how to triage, and how you go about proceeding with what you need to do first.” Nuclear Regulatory Commission, Briefing on the Task Force Review of NRC Processes and Regulations Following the Events in Japan, Transcript of Proceedings, at 19-20, ML111360513 (May 12, 2011).

from the simultaneous system failures at Fukushima should be used by NRC to evaluate the safety and environmental implications of co-locating multiple reactors and spent fuel pools.

Similarly, in the relicensing proceeding for the Pilgrim nuclear power plant in Massachusetts, Dr. Gordon R. Thompson of the Institute for Resource and Security Studies submitted a report in June 2011 discussing the significant new information coming from Fukushima.⁹⁸ Thompson explained that the “Fukushima experience shows clearly that the operators’ capability to mitigate an accident . . . can be severely degraded in the accident environment.”⁹⁹ One example of this was the operators’ inability to add water to Unit 4’s spent fuel pool for several days following the hydrogen explosion.

In October 2011, the NRC Advisory Committee on Reactor Safeguards (“ACRS”) acknowledged that the Fukushima accident has provided new information regarding the hazards posed to spent fuel pools by falling debris.¹⁰⁰ It noted, “The Fukushima accident clearly demonstrates that hydrogen combustion events can cause significant structural damage. Such damage can also cause debris to fall into the spent fuel pools with subsequent potential ramifications not heretofore considered.”¹⁰¹ The ACRS found that the leaching of the debris may change the pool water chemistry, causing the aluminum racks to corrode and eventually degrading

⁹⁸ See *Thompson 2011 Report*.

⁹⁹ *Id.* at 20.

¹⁰⁰ Advisory Committee on Reactor Safeguards, Initial Review of: (1) the Near-Term Task Force Report on Fukushima and (2) Staff’s Recommended Actions to be Taken Without Delay, at 7 ML11284A136 (“*ACRS Review*”) (Oct. 13, 2011).

¹⁰¹ *Id.*

their integrity.¹⁰² It also noted, “These events at Fukushima have reminded us that spent fuel pools at nuclear power plants can be contributors to the overall risk posed by the plants.”¹⁰³

Various other organizations and individuals have pointed out the lessons to be learned from the Fukushima accident. Former NRC Commissioner Victor Gilinsky wrote in the *New York Times*: “[F]ederal regulators have yet to absorb the lessons from this crisis” and pointed out the dangers of a Fukushima-like accident at Indian Point.¹⁰⁵ Additionally, the Natural Resources Defense Council (“NRDC”) released a document warning, “An accident at one of Indian Point’s reactors on the scale of the recent catastrophe in Japan could cause a swath of land down to the George Washington Bridge to be uninhabitable for generations due to radiation contamination.”¹⁰⁶

Furthermore, the findings of the Near-Term Task Force support the argument that the Fukushima accident provides significant new information. “The Task Force concluded that the Fukushima Dai-ichi accident . . . provides new insights regarding low-likelihood, high-consequence events that warrant enhancements to defense-in-depth on the basis of redefining the level of protection that is regarded as adequate.”¹⁰⁷ In short, based on the information from the Fukushima accident, the Task Force found that NRC should create new regulations

¹⁰² *Id.* at 9.

¹⁰³ *Id.* at 10.

¹⁰⁵ Victor Gilinsky, *Indian Point: The Next Fukushima?*, *New York Times* (Dec. 16, 2011).

¹⁰⁶ Natural Resources Defense Council, *Nuclear Accident at Indian Point: Costs and Consequences*, (Oct. 2011), *available at*:

<http://www.nirs.org/reactorwatch/aging/nrdcaccidentip1011.pdf>

¹⁰⁷ *Near-Term Task Force Report* at viii.

to protect against occurrences that it previously characterized as having “small impacts” due to their low probability. Fukushima has shown that low probability, high consequence events do occur and therefore, they must be considered and measures must be taken to mitigate their potential consequences. In acknowledging this fact and suggesting measures to mitigate such dangers, the Task Force Report constitutes significant new information that must be considered in this proceeding.

The Fukushima accident and the recommendations of the Task Force also show that site-specific factors must be taken into consideration with regard to accidents involving spent fuel pools. The different characteristics of each pool affect the chances of a radionuclide release and the appropriate response to prevent a release. At Fukushima’s boiling water reactors, the spent fuel pools are located high up in the reactor buildings, making it difficult for water to be added in an emergency, “[h]owever, TEPCO’s approaches to adding water to pools revealed a lack of preparation for this contingency.”¹⁰⁸ Responding to the site-specific problems at Fukushima, “many of the actions recommended in the Task Force report have plant-specific features, and therefore require plant-specific regulatory attention.”¹⁰⁹ For example, the Task Force recommends that plants install “seismically qualified means to spray water into the spent fuel pools.”¹¹⁰ Such

¹⁰⁸ *Thompson 2011 Report* at 19. The boiling water reactor design was developed by the federal government’s Idaho National Laboratories and the General Electric Company in the 1950’s.

¹⁰⁹ Gordon R. Thompson, Declaration of Gordon R. Thompson Addressing New and Significant Information Provided by the NRC’s Near-Term Task Force Report on the Fukushima Accident, at 2, ML11223A283 (Aug. 11, 2011).

¹¹⁰ *Near-Term Task Force Report* at 46. This proposal is similar to a recommendation made by

means will vary due to site-specific factors such as the location of the spent fuel pool. Additionally, the ACRS noted:

The vulnerabilities of spent fuel pools under accident conditions and the need for measures to assure adequate coolant levels are design specific. . . . Staff should initiate a request for information for licensees to document details such as their current plant-specific spent fuel pool instrumentation, sources of spent fuel pool makeup and cooling, power supplies, contingencies and procedures for alternate makeup sources, etc. This information would better inform subsequent staff efforts and would help focus industry communications with respect to these issues.¹¹¹

The Fukushima disaster also highlighted the importance of safety-related systems for spent fuel pools. According to a Near-Term Task Force member,

Typically the spent fuel pool makeup and cooling systems in the United States are not safety-related systems. Loss of cooling in the spent fuel pool was expected to be a very slow-evolving, non-design basis accident situation. So the requirements for those systems are less stringent than they are for other systems addressing design basis accidents.¹¹²

For this reason, the Task Force recommendations include measures such as providing safety-related AC electrical power for pools and installing safety-related instrumentation to monitor the pools from the control room that can withstand design-basis natural phenomena. While the Commission ordered the installation of instruments to measure the level of pool water and relay that information to the control room, other measures to mitigate or minimize the impacts of severe pool accidents also exist. NRC should also acknowledge that NRC's Appendix R fire

the National Academy of Sciences back in 2006. *NAS Report* at 55.

¹¹¹ *ACRS Review* at 10.

¹¹² Comments of Jack Grobe Deputy Director of the Office of Nuclear Reactor Regulation, before Advisory Committee on Reactor Safe Guards, Fukushima Subcommittee, at 87, ML11229A243 (Aug. 16, 2011).

safety regulations (promulgated in the wake of the Brown Ferry fire) do not extend to spent fuel pool facilities.

The Blue Ribbon Commission recommended that the National Academy of Sciences (“NAS”) conduct its own separate assessment of the lessons learned from Fukushima and the implications of these lessons for the conclusions reached in earlier NAS studies on the safety and security of spent nuclear fuel.¹¹³ As part of this assessment, the Commission suggested that NAS conduct “an analysis of the advantages and disadvantages of moving spent fuel from densely packed pools to on-site dry cask storage to facilitate low-density packing in the pools.”¹¹⁴ However, the Near-Term Task Force report did not address this issue. When asked by Commissioner Ostendorff why this issue was not included, Task Force members replied that it was not clear what exactly happened to the spent fuel pools at Fukushima, that there was no “overwhelming evidence that the fuel would be safer outside of the pool than in it,” and that their recommendations enhance pool safety more than removing fuel would.¹¹⁵ However, Task Force members failed to acknowledge that dry cask storage has numerous safety advantages over pool storage¹¹⁶ and that some of the safety measures they recommended are necessary because of the dense-storage of fuel in U.S. spent fuel pools. In short, the recommendations deal with symptoms of the problem (e.g., the rapid heat up of

¹¹³ *Blue Ribbon Commission Report* at 44.

¹¹⁴ *Id.*

¹¹⁵ Nuclear Regulatory Commission, Briefing on the Task Force Review of NRC Processes and Regulations Following the Events in Japan, Transcript of Proceedings, at 36-37, ML112020051 (July 19, 2011).

¹¹⁶ *NAS Report* at 70.

densely packed spent fuel once water is removed from the pool) but do not offer alternatives or solutions to the problem itself. Even NRC Staff recognized that the transfer of spent fuel to dry cask storage has “a clear nexus to the Fukushima Daiichi event [and] may warrant regulatory action but [was] not included with the NTTF recommendations.”¹¹⁷

It also appears that the Commissioners were not informed that Sandia National Laboratories has recently acknowledged that reducing the volume of spent fuel in spent fuel pools would mitigate the risks posed by dense storage. On February 7 and 8, 2012, NRC Staff made publically available three documents discussing the safety of spent fuel pools. The first is a slideshow explaining the findings of a study conducted by Sandia National Laboratories, which investigated zirconium fires during spent fuel pool loss of coolant accidents (“LOCAs”).¹¹⁸ The study found that low density racking is the spent fuel configuration that is least vulnerable to zirconium fires.¹¹⁹


¹¹⁷ Nuclear Regulatory Commission, SECY-11-0317: Prioritization of Recommended Actions to be Taken in Response to Fukushima Lessons Learned, at 5, ML11269A204 (Oct. 3, 2011).

¹¹⁸ Samuel G. Durbin and Eric R. Lindgren of Sandia National Laboratories, Investigations of Zirconium Fires During Spent Fuel Pool LOCAs (Slideshow), ML120380359 (Feb. 7, 2012).

¹¹⁹ *Id.* at slide 15.



Spent Fuel Pool Configurations



15 K.C. Wagner and R.O. Gauntt, "Mitigation of Spent Fuel Pool Loss-of-Coolant Inventory Accidents and Extension of Reference Plant Analyses to Other Spent Fuel Pools, Sandia Letter Report," Nov. 2006



The disclosure of this study and its conclusion constitute significant new information because it is now clear that federal laboratories recognize that safer options are available for the storage of spent nuclear fuel. This recognition and the alternative of reducing the volume of waste stored in pools must be considered when NRC Staff examines the alternatives to the proposed federal action authorizing a 20-year extension of a facility's operating license. NRC should revise the Waste Confidence DGEIS and proposed rule and require the review of such alternatives

The next two recently released documents are a speech and slideshow presented by Michael Weber, NRC's Deputy Executive Director for Operations, at the U.S. Nuclear Infrastructure Council Meeting on January 31, 2012.¹²⁰ These documents discuss NRC's response to the Fukushima accident, focusing in particular on spent fuel pools. Director Weber acknowledged that the pools were not designed for the long-term storage of spent nuclear fuel, that zirconium fires can

¹²⁰ Michael Weber, Responding to Fukushima-Daiichi (Speech), ML12037A072 (*"Weber Speech"*) (Jan. 31, 2012); Michael Weber, Responding to Fukushima-Daiichi (Slideshow), ML120310267 (*"Weber Slideshow"*) (Jan. 31, 2012).

occur in pools, and that the consequences of a zirconium fire could be very large.¹²¹ Furthermore, he stated that since the fuel pools are located outside of the primary containment that houses the reactor, a release of radionuclides from the pool can reach the environment much more easily than a release from the reactor core.¹²² Director Weber further acknowledged that thinning the spent fuel pools would reduce the potential land contamination and economic impacts if a large release occurred.¹²³ He stated that due to the threat of zirconium fires, NRC is studying the benefits of removing spent fuel to achieve lower fuel density in the pools. Additionally, Mr. Weber disclosed that NRC Staff is currently conducting a Spent Fuel Pool Scoping Study to assess the impacts of thinning the pools.¹²⁴ This development reflects NRC's new understanding of the risks posed by spent fuel pools, due in large part to the events at Fukushima. The State believes this new understanding must be reflected in a revised EIS and rule.

In the wake of the Fukushima disaster, NRC is considering conducting site-specific reviews of the risks involved with spent fuel pools as part of a Level 3 Probabilistic Risk Assessment ("PRA"). In the policy position paper on options for PRA activities, NRC wrote, "To be complete, estimation of total site accident risk should also include an assessment of the risk from accidents involving other site

¹²¹ *Weber Speech* at 4-5.


¹²² *Id.* at 4.

¹²³ *Weber Slideshow* at slide 20.

¹²⁴ *Weber Speech* at 5.

radiological sources, to include spent nuclear fuel.”¹²⁵ The scope of the proposed PRA is depicted in the diagram below.¹²⁶

Option 3: Site Level 3 PRA



In a July 28, 2011 public meeting on PRA activities, Commissioner Apostolakis observed:

It seems to me that a major change in the way that we think about things . . . after Fukushima, is that we really have to talk about the site risk. We should start talking about site years rather than reactor years. So that is probably a major change.¹²⁷

During the same meeting, NRC Chairman Jaczko stated:

I think that there’s no question that the state of the art has improved significantly over the last two decades and that there are new issues that perhaps should be examined through the completion of Level 3 PRAs. As

¹²⁵ Nuclear Regulatory Commission, *Options for Proceeding with Future Level 3 Probabilistic Risk Assessment Activities*, SECY-11-0089, at 6, ML11090A042 (July 7, 2011).

¹²⁶ Figure taken from slides prepared by NRC Staff: Nuclear Regulatory Commission Office of Nuclear Regulatory Research, *Severe Accidents and Options for Proceeding with Level 3 PRA Activities*, ML11209B927 (July 28, 2011).

¹²⁷ *Id.* at 83. Also in that meeting, Stuart Lewis, Program Manager for Risk and Safety Management, Electric Power Research Institute, Inc., said, “[W]e have started to do some investigations that lead us to believe there is more that ought to be done in the area of understanding spent fuel pool risk . . . “ *Id.* at 26.

the staff notes in their paper, those include issues raised by the Fukushima accident, specifically the challenges posed by multi-unit events in the risks of radiological releases from spent fuel pools.¹²⁸


The State supports a comprehensive and realistic analysis of the risks posed by spent fuel pools and requests that such a review be brought into the site-specific NEPA review.

2. North Anna, Virginia

On August 23, 2011, a 5.8 magnitude earthquake occurred in Virginia with the epicenter located approximately 11 miles from the North Anna Power Station. The earthquake exceeded the spectral and peak ground accelerations that the plant was built to withstand and the plant temporarily lost power.¹²⁹ The tremor was felt in various northeast cities, including Washington and New York. While initial review by North Anna's owner concluded that there was no major damage to the reactors or spent fuel pools, the incident highlighted the fact that U.S. nuclear facilities are also subject to beyond-design-basis earthquakes. As indicated by the figures below, many nuclear reactors in the U.S. are located in areas with potentially dangerous seismic activity. The first figure is the U.S. Geological Survey National Seismic Hazard Map, updated in 2008, showing the earthquake ground motion (peak acceleration or PGA) for a 2% probability over 50 years. The second image, from NRC, shows the locations of nuclear reactors in the U.S.


¹²⁸ Nuclear Regulatory Commission, *Briefing on Severe Accidents and Options for Proceeding with Level 3 Probabilistic Risk Assessment Activities*, Transcript of Proceedings, at 3, ML112140574 (July 28, 2011).

¹²⁹ Nuclear Regulatory Commission, *NRC Technical Audit Report of North Anna Post-Seismic Fuel Inspections*, at 3, ML11305A239 (Oct. 27, 2011).



Source: U.S. Geological Survey, available at: <http://earthquake.usgs.gov/hazards/products/graphic2pct50.jpg>

U.S. Commercial Nuclear Power Reactors—Years of Operation



Source: U.S. Nuclear Regulatory Commission

Source: U.S. NRC, available at: <http://www.nrc.gov/reactors/operating/map-power-reactors.html>

On January 31, 2012, NRC, DOE, and EPRI released a new seismic study, revealing significantly higher earthquake risks in the central and eastern United States. According to NRC, “Calculations with the new model are expected to result in a higher likelihood of a given ground motion compared to calculations done using

previous models.”¹³⁰ Nuclear power plants will use the new model to re-evaluate their seismic risk. The State urges NRC to change the draft revised DGEIS and proposed rule to allow seismic risks to be taken into consideration by conducting a site-specific review of seismicity risks for spent fuel pools.

The State of New York submits that the Waste Confidence DGEIS and proposed rule are inconsistent with NEPA’s objective of forcing federal agencies to examine previously-held assumptions, confront the environmental consequences of their present decisions, and meaningfully weigh reasonable alternatives or conditions to the requested federal action before the federal agency takes action. Staff’s approach fails to take the NEPA-required “hard look” at the environmental consequences of from continued dense storage of spent nuclear fuel in spent fuel pools. No provision allowing site specific review is made in the DGEIS and the proposed rule. Given this absence, the DGEIS and the proposed rule should be revised to allow for such a site specific and site wide review.

VIII. Consideration of Site-Specific Alternatives

NEPA requires a federal agency to prepare “to the fullest extend possible” an environmental impact statement (“EIS”) regarding proposed “major Federal actions significantly affecting the quality of the human environment.”¹³³ An EIS must discuss, among other things, the adverse environmental impacts of the action and alternatives to the action.¹³⁴ “[O]ne important ingredient of an EIS is the

¹³⁰ Nuclear Regulatory Commission, Press Release: New Seismic Model Will Redefine Hazard Analysis at U.S. Nuclear Plants, No. 12-010 (Jan. 31, 2012).

¹³³ 42 U.S.C. § 4332(2)(C).

¹³⁴ *Id.*; 40 C.F.R. §§ 1502.2, 1502.14, 1507.2, 1508.9.

discussion of steps that can be taken to mitigate adverse environmental consequences.”¹³⁵

This directive that federal agencies meaningfully consider alternatives and mitigation measures to the proposed action is one of NEPA’s hallmarks.¹³⁶ The requirement that alternatives be studied, developed, and described both guides the substance of agency environmental decision making and provides evidence that the mandated decision making process has actually taken place.¹³⁷ NEPA is not intended to simply confirm or insulate previous agency decisions or assumptions. Rather, NEPA forces federal agencies with discretionary regulatory authority to confront and publicly evaluate the environmental impacts of proposed action, the alternatives to that action, and the means to mitigate or minimize the adverse impacts of the final agency action.¹³⁸

As discussed above (p.15), if the water in a spent fuel pool boils or drains away, the zirconium cladding that forms the spent fuel rods may melt or catch on fire, potentially causing a major release of radiation. NRC does not dispute that a spent fuel pool fire could have catastrophic environmental impacts. Indeed, it has acknowledged that “a zirconium fire event can have public health and safety consequences similar to a severe core damage accident with a large off-site

¹³⁵ *Robertson v. Methow Valley Citizens Council*, 490 U.S. 332, 351 (1989).

¹³⁶ 42 U.S.C. § 4332(2)(C),(E).

¹³⁷ *Calvert Cliffs’ Coordinating Committee, Inc. v. United States Atomic Energy Comm’n*, 449 F.2d 1109, 1114 (D.C. Cir. 1971).

¹³⁸ *Dep’t of Transportation v. Public Citizen*, 541 U.S. 752, 768-69 (2004).

release.”¹³⁹ Therefore, NRC must consider alternatives to the current storage scheme that reduce the risk of a zirconium fire. Moreover, these issues must be considered on a site-specific Category 2 basis, since plant-specific factors may make facilities more or less vulnerable to such fires, may require different mitigative measures, and may lead to different environmental impacts.¹⁴⁰ The State recommends that the following alternatives be considered in a site-specific review of a facility’s spent fuel pool.

A. Thinning of Spent Fuel Pools and Use of Dry Cask Storage

One alternative that should be considered is the thinning of spent fuel pools. Densely packed spent fuel heats up faster in the event of the loss of cooling water than more loosely packed fuel,¹⁴¹ giving workers and emergency crews less time to respond to prevent fire or other damage to the fuel assemblies.¹⁴²

¹³⁹ Nuclear Regulatory Commission, Policy Issues Related to Safeguards, Insurance, and Emergency Preparedness Regulations at Decommissioning Nuclear Power Plants Storing Fuel in Spent Fuel Pools (WITS 200000126), NRC SECY-01-0100, at 5 (June 4, 2001).

¹⁴⁰ This fact was recognized by Congress when it directed NRC to implement the recommendations of the 2006 NAS Report on spent nuclear fuel storage. In particular, Congress asked NRC to prepare site-specific models to mitigate the risks associated with spent fuel storage. U.S. Congress, Conference Report 108-792, *Making Appropriations for Foreign Operations, Export Financing, and Related Programs for the Fiscal Year Ending September 30, 2005, and For Other Purposes*, at 982 (Nov. 20, 2004). Former NRC Commissioner Victor Gilinsky also recommended that spent fuel storage be examined on a site-specific basis in his *Separate Views Regarding Proposed Amendments to 10 CFR Parts 50 and 51, Waste Confidence Proceeding*, 48 Fed. Reg. 22730 (May 20, 1983) (“While I agree that there is no obstacle in principle to extended on-site storage, I think it is clear that each power reactor site will have to be examined in detail.”).

¹⁴¹ Allan S. Benjamin et al., *Spent Fuel Heatup Following Loss of Water During Storage* (Sandia National Laboratory, NUREG/CR-0649, SAND77-1371) at 50 (“1979 Sandia Report”) (Mar. 1979) (“The high density holders . . . are the least well-suited to heat removal, as expected, particularly if the spent fuel is packed wall-to-wall so as to preclude a down-comer space at the edge of the pool.”).

¹⁴² See *2006 Sandia Report* at viii ([D]ispersed configurations [of spent fuel assemblies] provided additional time for mitigative actions before the release of fission products versus a non-dispersed configuration.); See also *NAS Report* at 103 (“[M]odifying the storage racks to provide




Figure: Effect of Storage Rack Configuration on Heatup of PWR Spent Fuel, Well-Ventilated Room. Source: 1979 Sandia Report at 51.

Alvarez et al. recommend moving away from the current “dense-pack” configurations and returning to open-rack configurations, for which the spent fuel pools were originally designed.¹⁴³ The figures below illustrate the different designs.¹⁴⁴

for closer spacing of the fuel assemblies. . . . can make it more difficult to cool the freshly discharged fuel if there is catastrophic loss of the fuel pool water.”).

¹⁴³ *Reducing the Hazards* at 23.

¹⁴⁴ First figure: *Reducing the Hazards* at 17. Second figure: *1979 Sandia Report* at 20.




Figure 7: Open and dense-pack PWR spent-fuel racks (Sources: Left: NUREG/CR-0649, SAND77-1371, 1979; right: authors).




Figure 3. Cross Sectional Dimensions of Spent Fuel Holders Shown in Fig. 2.

In the original design for pressurized-water reactor spent fuel pools, fuel assemblies were packed 53 cm apart, allowing the cooling water to channel between them.¹⁴⁵ In the densely packed design, fuel assemblies are only 23 cm apart (close to the 21.4 cm spacing in reactor cores),¹⁴⁶ allowing about five times as many

¹⁴⁵ *Reducing the Hazards* at 17.

¹⁴⁶ *Id.* at 16.

assemblies to be stored in the pool.¹⁴⁷ To keep these closely packed fuel rods sub-critical, they are placed in metal boxes containing neutron-absorbing boron.¹⁴⁸ In a loss of coolant accident, where pool water is lost, these boxes would prevent the horizontal circulation of cooling air.¹⁴⁹ A 1979 Sandia report¹⁵⁰ prepared for NRC found that with an open frame storage configuration in a well-ventilated facility, spent fuel in a drained storage pool would not overheat if it was cooled for five days before being transferred to the pool.¹⁵¹ Also, as mentioned above on pages 54-55, Sandia recently released the results of a study finding that low density racking is the spent fuel configuration that is least vulnerable to zirconium fires.¹⁵²

If there is not enough room in the pool to permit open frame storage—because too much fuel is unloaded from a reactor during a given five year period—Alvarez et al. recommend considering: “(1) an arrangement where one fifth of the fuel assemblies are removed in a pattern in which each of the remaining fuel assemblies has one side next to an empty space; (2) an arrangement where alternate rows of fuel assemblies are removed from the rack.”¹⁵³ The first suggestion is illustrated in the figure below.¹⁵⁴

¹⁴⁷ *NAS Report* at 43.

¹⁴⁸ *Id.*

¹⁴⁹ *Id.* at 17.

¹⁵⁰ *1979 Sandia Report*.

¹⁵¹ *Reducing the Hazards* at 23.

¹⁵² Samuel G. Durbin and Eric R. Lindgren of Sandia National Laboratories, Investigations of Zirconium Fires During Spent Fuel Pool LOCAs (Slideshow), ML120380359 (Feb. 7, 2012).

¹⁵³ *Id.*

¹⁵⁴ Figure is taken from: *Damages From a Major Release* at 133.




Figure 2: Removal of one fifth of the spent-fuel assemblies could result in every fuel assembly having one side exposed to an empty channel.

If this suggestion is found to be effective at allowing spent fuel in a drained pool to be convectively air cooled, it would reduce the amount of spent fuel that would need to be removed from pools in the U.S. in 2010 from 35,000 tons (under an open frame storage plan) to 9,000 tons.¹⁵⁵ However, Alvarez et al. recommend that all spent fuel be removed from pools and placed in dry cask storage after it has cooled for five years.

Similarly, the NAS report recommended that, space permitting, empty slots be arranged throughout the pool to promote natural air convection in the event that the pool is completely drained.¹⁵⁶ That report also found that spent fuel is less at risk from accident or attack in dry cask storage than in a fuel pool.¹⁵⁷ This is because the spent fuel stored in dry casks has been cooled for at least five years,

¹⁵⁵ *Id.*

¹⁵⁶ *NAS Report* at 55.

¹⁵⁷ *NAS Report* at 68.

and is therefore, not prone to zirconium cladding fires.¹⁵⁸ Moreover, the dry cask system divides the spent fuel between many different casks—each cask stores only 10 to 15 tons of fuel, as opposed to a pool, which stores hundreds of tons—so if an individual cask is compromised, there is less potential radiation to be released. Additionally, since dry cask storage relies on natural air circulation for cooling, a breach would not release contaminated water into the environment and emergency crews would not need to find an alternative source of water with which to fill them.

In the wake of the Fukushima nuclear disaster, nuclear plant operators are beginning to consider thinning spent fuel pools as a safety precaution. For example, in April 2011, the Tennessee Valley Authority issued a nuclear program update that said it was considering moving spent fuel out of pools and into dry cask storage.¹⁵⁹ Although TVA attended the January 11, 2012 public meeting, this initiative was not discussed.

Others have called for the removal of spent fuel that is more than five years old from storage pools. In March 2011, David Lochbaum, of the Union of Concerned Scientists, stated before the U.S. Senate Energy and Natural Resources Committee, “A better strategy would be to reduce the inventory of irradiated fuel in the pools to the minimum amount, which would be only the fuel discharged from the reactor

¹⁵⁸ *NAS Report* at 69.

¹⁵⁹ Tennessee Valley Authority, “Fact Sheet: Nuclear Program Update” (Apr. 14, 2011). Available at: http://www.tva.gov/news/releases/aprjun11/pdf/nuclear_program-update_fact_sheet.pdf. The Tennessee Valley Authority owns and operates various nuclear power reactors and is an agency of the United States.

core within the past five years.”¹⁶⁰ This, he said, would lower the risk of fire by decreasing the heat load of the pool, giving workers more time to respond in the event of the loss of cooling water. Also, if radiation was released, it would be significantly lower in a less densely packed pool. That same month at a meeting on Capital Hill, Energy Secretary Steven Chu recognized that the storage of spent nuclear fuel in dry casks is much safer than storage in pools.¹⁶¹ In May 2011, the Institute for Policy Studies released a report authored by Robert Alvarez, also recommending that all spent fuel that has been in pools for five years be removed and placed in dry storage.¹⁶² Additionally, in April 2011, U.S. Senator Diane Feinstein called upon the NRC Commissioners to enact regulatory policies that reduce the amount of spent fuel stored in pools.¹⁶³

In August 2011, Chairman Jaczko acknowledged the benefits of transferring spent fuel to dry cask and said the Commission should consider this alternative:

I also believe the Commission should consider in the long term if there should be new regulations to require licensees to move spent fuel to dry cask storage within a specific timeframe. This step, recognizing the inherent safety benefits of dry storage and combining that knowledge

¹⁶⁰ Statement by David Lochbaum, Director of Nuclear Safety Project, Before the U.S. Senate Energy and Natural Resources Committee, at 2 (March 29, 2011). *Available at:* http://www.ucsusa.org/assets/documents/nuclear_power/lochbaum-senate-energy-3-29-2011.pdf

¹⁶¹ Hearing on the Fiscal Year 2012: Department of Energy and Nuclear Regulatory Commission Budgets, House of Representatives, Subcommittee on Energy and Power joint with the Subcommittee on Environment and the Economy Committee on Energy and Commerce, at 77 (March 16, 2011). *Available at:* http://democrats.energycommerce.house.gov/sites/default/files/image_uploads/031611%20EP-EE%20Fiscal%20Year%202012%20DOE%20and%20NRC%20Budgets.pdf (Chu stated: “After you take the fuel rods out of the reactor, immediately you put them in a pool of water for a period of time where they are actually still dissipating a considerable amount of heat. But then after that, the next stage is that you can put them in dry cask storage, which is much safer.”).

¹⁶² Robert Alvarez, *Spent Nuclear Fuel Pools in the U.S.: Reducing the Deadly Risks of Storage*, at 21 (May 2011).

¹⁶³ Letter from Senator Feinstein to NRC Chairman Jaczko, ML11108A038 (April 8, 2011).

with the new ISFSI security regulations under development, may provide a safer and more secure disposition for spent fuel. I also believe that an NRC-developed pilot probabilistic risk assessment provides additional supporting evidence of the benefits of having more of the spent fuel held in dry storage.¹⁶⁴

B. Other Alternatives

While removing spent fuel and placing it in dry cask storage remains the safer alternative, there are other steps that can also contribute to reducing the risk of zirconium cladding fires in spent nuclear fuel pools. For example, the fuel assemblies in pools can be arranged in a checkerboard pattern so that newly discharged fuel is surrounded by older, cooler fuel. The cooler fuel will act as heat sink, absorbing the heat from the newer fuel.¹⁶⁵ Similarly, newly discharged fuel can be placed near the walls of the pool, which will also act as a heat sink. Water spray systems can be installed to cool fuel in the case of loss of pool coolant and pool walls can be reinforced to prevent their damage.¹⁶⁶ Also, limiting the frequency of full core offloads into pools and delaying the transfer of fuel into a pool after a reactor shutdown would reduce the heat-load in the pool.¹⁶⁷ What is possible at each facility will vary, and therefore, a site-specific evaluation must be conducted.

Although the recent Near-Term Task Force report does not call for the transfer of fuel to dry storage, Recommendation 7 of the report addresses some concerns about enhancing the safety of spent fuel pools. The Task Force

¹⁶⁴ Nuclear Regulatory Commission, Commission Voting Record: Near-Term Report and Recommendations for Agency Actions Following the Events in Japan, at PDF page 9, ML112310746 (Aug. 19, 2011).

¹⁶⁵ *NAS Report* at 54.

¹⁶⁶ *NAS Report* at 55.

¹⁶⁷ *NAS Report* at 55.

recommends that licensees be required to install or enhance equipment that will allow workers to better monitor spent fuel pools in emergencies, as well as improve the ability of workers to get water to the pools if necessary.¹⁶⁸ The State urges NRC to include such requirements for relicensing, in addition to requiring the thinning of spent fuel pools.¹⁶⁹

C. Severe Accident Mitigation Alternatives Analyses and Spent Fuel Pools

The destruction of the Fukushima facilities demonstrates that severe accidents can occur and can have significant, real world consequences.¹⁷⁰ The State calls on NRC to revise its approach to severe accident mitigation alternatives (or SAMA) analyses. Under 10 C.F.R. § 51.53(c)(3)(ii)(L), NRC must conduct a site-specific review of alternatives to mitigate a severe accident at a reactor that seeks to renew its operating license. NRC promulgated this regulation in 1996 in response to the court ruling in *Limerick Ecology Action, Inc. v. Nuclear Regulatory Commission*, 869 F.2d 719 (3d Cir. 1989). However, while NRC purports to examine alternatives to mitigate severe accidents that occur in the *reactor*, applicants and NRC do not review alternatives to mitigate severe accidents that occur in the *spent fuel pool* that is adjacent to the reactor but outside of the containment shell. In fact, the SAMA analyses only take into account releases from the reactor core. Releases

¹⁶⁸ *Near-Term Task Force Report* at 45-46.

¹⁶⁹ In the briefing on the proposed GEIS, held on January 11, 2012, Chairman Jaczko indicated that license renewal is an opportunity to get requirements implemented at nuclear facilities. *January 2012 GEIS Briefing Transcript* at 86. The State recommends that license renewal be made conditional upon the implementation of the requirements recommended by the Near-Term Task Force. This will ensure that the changes are implemented by licensees prior to license renewal.

¹⁷⁰ NRC Chairman Gregory Jaczko, *Looking to the Future*, S-12-002 (Feb. 9, 2012).

from spent fuel pools that would occur during a severe accident are not taken into consideration at all in the SAMA analyses. Thus, the communities and states that host power reactors do not receive a comprehensive review of all severe accidents at a licensed facility or the available means to mitigate the environmental effects of such severe accidents. It is important that radionuclide releases from spent fuel pools be considered as part of the SAMA analyses because the offsite cost risks of these releases can be higher than those from the reactor core.¹⁷¹

Today's reality is that large quantities of spent fuel are being stored at nuclear reactor sites. Indeed, under the dense storage regime in place today at Indian Point and other reactors, the spent fuel pool holds considerably more fuel assemblies than the reactor core. The NEPA review of severe accident mitigation alternatives should not exclude releases from these spent fuel pools or alternatives that could mitigate severe spent fuel pool accidents or releases. NRC Commissioners should revise current NRC NEPA policy and ensure that during this proceeding or during a license proceeding, a comprehensive and objective review of severe accidents takes place for the entirety of each facility that NRC licenses. Similarly, for sites that have more than one reactor and spent fuel pool, the SAMA review should not be limited to a severe accident at a single reactor or a single pool, but should examine the consequences of, and mitigation alternatives for, a severe accident that affects more than one reactor or pool at a NRC licensed site.

¹⁷¹ Gordon R. Thompson, Risk-Related Impacts from Continued Operation of the Indian Point Nuclear Power Plants, at 28 (Nov. 28, 2007).

IX. The Severe Accident Mitigation Alternatives Analyses Should be Based on Site-Specific Data and Not Simply Replicate Inputs from Another Reactor

In addition, the SAMA analyses must reflect the true, site-specific costs of an accident involving a spent fuel pool or resulting in a release from a spent fuel pool. As discussed in the accompanying report from ISR, in the context of SAMA analyses for severe nuclear reactor accidents, applicants have not been using site-specific data to calculate the economic costs. Instead, licensees have been relying on data from “Sample Problem A” to calculate the economic costs associated with a severe nuclear reactor accident in their SAMA analyses. Sample Problem A was one of fourteen sample problems provided with the MACCS2 code as an example for users to check whether the MACCS2 software was installed and operating properly. Sample Problem A is an example set of inputs that were developed for the Surry reactor site located in rural Virginia and was not meant to serve as default input values in the MACCS2 program.¹⁷² Yet NRC Staff, Entergy, and other applicants rely on Surry’s Sample Problem A in conducting SAMA analyses for other reactor sites, such as Indian Point, that differ markedly from Surry and its environs.

Each of the approximately 65 sites that host the 104 operating nuclear power reactors has a different profile and “context.”¹⁷³ NRC cannot credibly maintain that all U.S. reactor sites are the same or that an accident at one site will have the same

¹⁷² The “Sample Problem A” values were derived from the Surry facility and discussed in NUREG-1150, *Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants* (Dec. 1990).

¹⁷³ “Context is the geographic, biophysical, and social context in which the effects will occur. In the case of license renewal, the context is the environment surrounding the facility.” *Draft GEIS for License Renewal* at 1-5.

consequences as an accident at another site. Stated differently, the 50-mile emergency planning zone around the two operating Indian Point reactors in New York is materially different from the 50-mile emergency planning zone around the single Fort Calhoun reactor in Nebraska. The two Indian Point plants and single Calhoun plant are different with respect to: electrical output; spent fuel pool inventory; surrounding population; topography; prevailing wind; precipitation and snowfall; seismic hazards; tornado hazards; surrounding agricultural resources; and surrounding public drinking water/reservoirs—to name just a few material differences.

By using Sample Problem A inputs instead of inputs derived from site-specific data, applicants are failing to conduct the required site-specific SAMA analyses for nuclear reactor accidents in violation of NEPA, CEQ regulations, and NRC regulations. This error should not be carried into ongoing or future SAMA analyses of the reactor accidents, risks from a spent fuel pool accident, or radiological releases from a spent fuel pool. Any such SAMA analyses must rely on site-specific data from the plant at issue and its surrounding community and environment, not from Surry and its inputs in Sample Problem A.

Use of accurate, site-specific cost is especially important in light of a recent inter-agency dispute among federal agencies over which agency is responsible for ensuring the clean-up and decontamination of contaminated property and the funding source of such decontamination. A November 2010 article entitled *Agencies Struggle To Craft Offsite Cleanup Plan For Nuclear Power Accidents*, reported:

EPA, the Nuclear Regulatory Commission (NRC) and the Federal Emergency Management Agency (FEMA) are struggling to determine which agency—and with what money and legal authority—would oversee cleanup in the event of a large-scale accident at a nuclear power plant that disperses radiation off the reactor site and into the surrounding area.

The effort, which the agencies have not acknowledged publicly, was sparked when NRC recently informed the other agencies that it does not plan to take the lead in overseeing such a cleanup and that money in an industry-funded insurance account for nuclear accidents would likely not be available

[T]he NRC officials also indicated during the meetings that the industry-funded account established under the Price Anderson Act—which Congress passed in 1957 in an effort to limit the industry’s liability—would likely not be available to pay for such a cleanup.¹⁷⁴

Moreover, meaningful site-specific severe accident mitigation alternatives analyses should be conducted each time a facility seeks to extend its operating license. This is so because the population in the emergency planning zones, characteristics of the surrounding community, set of potential mitigation alternatives, and economic cost values may all experience significant change over the course of a 20-year operating license.

X. NRC Must Prepare a Meaningful Site-Specific Environmental Impact Statement Analyzing the Impacts of Sabotage at the Indian Point Facilities

On September 11, 2001, nineteen terrorists hijacked four jet airliners and crashed three of them into their intended targets. The impact of the fuel-laden planes caused explosions and large, long-lasting fires. Those explosions and fires destroyed a portion of the Pentagon in northern Virginia and caused the collapse of the World Trade Center towers and nearby buildings in New York City. *See Nat'l*

¹⁷⁴ Douglas P. Guarino, *Agencies Struggle To Craft Offsite Cleanup Plan For Nuclear Power Accidents*, Inside EPA (Nov. 10, 2010).

Comm'n on Terrorist Attacks Upon the U.S. ("9/11 Commission"), *The 9/11 Commission Report* (2004).

Minutes before hitting the World Trade Center, two of the hijacked planes flew near or over Indian Point. *See id.* at 32 (American Airlines Flight 11, United Airlines Flight 175). The wind direction at the time of the attacks was towards the southeast -- that is, from Indian Point towards New York City. *See id.* at 285.

The 9/11 Commission's report revealed that Khalid Sheikh Mohammad, the mastermind of the 9/11 attacks, originally planned to hijack additional aircraft to crash into targets on both coasts, including nuclear power plants. *The 9/11 Commission Report*, at 154. As late as July 2001, the terrorists were considering attacking a specific nuclear facility in New York, which one of the pilots "had seen during familiarization flights near New York." *Id.* at 245. This was likely Indian Point.

When Congress disbanded the Atomic Energy Commission and created the Nuclear Regulatory Commission in 1974, it charged the new agency with the responsibility to ensure the security of commercial nuclear power plants and nuclear material. Energy Reorganization Act of 1974, § 204, 42 U.S.C. § 5844 (Commission shall provide and maintain "safeguards against threats, thefts, and sabotage of such licensed facilities, and materials"). Congress added this responsibility in the wake of increasing sabotage and terrorism events in the early 1970s -- such as the 1972 attack at the Munich Olympics and hijackings of

commercial jets in the U.S. and abroad. To this end, within NRC there is an Office of Nuclear Security and Incident Response.

From time to time, the Nuclear Regulatory Commission has promulgated regulations identifying the threat which nuclear power plants must protect against. This is known as the "design basis threat" or "DBT" regulation. 10 C.F.R. § 73.1. The DBT describes the adversary force that operating power reactors must defend against. It is based on realistic assessments of the tactics, techniques, and procedures used by international and domestic terrorist groups and organizations. Over the past 35 years, as sabotage threats have evolved, the Nuclear Regulatory Commission has successively increased the security threat against which power plants must defend. *Compare* 42 Fed. Reg. 10836 (Feb. 24, 1977) *with* 59 Fed. Reg. 38889, 38891 (Aug. 1, 1994). In 1994, the Commission revised the DBT rule in response to an intrusion at a nuclear power plant, the 1993 vehicle bomb attack on the World Trade Center, and intelligence that showed "a conspiracy with ties to the Middle East extremists clearly demonstrated the capability and motivation to organize, plan, and successfully conduct a major vehicle bomb attack." 59 Fed. Reg. at 38891.

The most recent revision to the design basis threat regulation took place in 2007 following the September 11, 2001 attacks. 72 Fed. Reg. 12705 (Mar. 19, 2007); 42 U.S.C. § 2210e (Energy Policy Act of 2005 provision directing Commission to evaluate design basis threat rule). In that regulatory revision, NRC instructed nuclear power plants to defend against cyber-attacks, water-borne attacks, and

truck-based attacks. However, despite the September 11, 2001 airplane attacks on the Pentagon and the World Trade Center Towers, NRC did not require nuclear power plants to take defensive measures against airplane-based attacks. The United States Court of Appeals for the Ninth Circuit upheld NRC's decision not to include airplane-based attacks in the revised design basis threat rule. *Public Citizen v. NRC*, 573 F.3d 916 (9th Cir 2009). While the current DBT rule does not include airplane threats, “No one disputes that there is a credible threat of terrorists using commercial aircraft to attack nuclear power plants.” *Id.*, at 929 (Thomas, C.J., concurring in part and dissenting in part).

Also in response to September 11, NRC directed nuclear power plant designers to perform a rigorous assessment that could avoid or mitigate the effects of an aircraft impact. Specifically, in 2009, NRC promulgated a new regulation requiring applicants for new power reactors to assess the ability of their reactor designs to avoid or mitigate “the effects of the impact of a large, commercial aircraft.” 74 Fed. Reg. 28112 (June 12, 2009). That rule, however, only applies to *new* reactors; it does not apply to the *existing* fleet of 100 reactors currently operating. In the underlying rulemaking proceeding, New York opposed the exemption for existing plants and identified several concerns specific to the Indian Point facilities. *New York State’s Comments Concerning NRC Proposed Rulemaking to Amend 10 C.F.R. Part 52 to Require Certain Applicants to Consider Aircraft Impacts to Future Nuclear Power Plants*, (Dec. 17, 2007) ML073530552.

Following the September 11 airplane attacks, the NRC issued orders to nuclear power plants requiring them to be prepared to take measures to address the loss of control of areas of the facility following large explosions and fires such as those associated with an airplane crash. These measures, known as “B.5.b” mitigation measures (referring to the specific paragraph of the NRC order), were not intended to prevent the aircraft impact, but, rather, required plant operators to respond to such explosions and fires. The reference to “mitigative measures” apparently refers to a February 2002 directive, 67 Fed. Reg. 9792 (Mar. 4, 2002), requiring licensees to identify “mitigative strategies” to reduce the potential consequences of "the loss of areas of [a] plant due to explosions or fire," including those that an aircraft impact might create, that licensees could implement using already "existing or readily available resources." As the NRC's Executive Director made clear in testimony before Congress, the mitigation measures “*will be at the back end once the attack occurs.*” HOMELAND SECURITY: MONITORING NUCLEAR POWER PLANT SECURITY: HEARING BEFORE THE SUBCOMM. ON NAT'L SECURITY, EMERGING THREATS AND INT'L RELATIONS, HOUSE COMM. ON GOV'T REFORM, 108th Cong. 61 (2004) (statement of Luis Reyes, Executive Dir. of Operations, NRC). On occasion, NRC has made passing reference to undisclosed, unidentified, and undated site-specific studies that it conducted of a limited number of plants. 72 Fed. Reg. at 12710. NRC has not made such studies available to the Attorney General's Office.

In 2005, the National Academy of Sciences released a report from a study it conducted at the request of Congress, with the sponsorship of the NRC and the Department of Homeland Security, of the security risks posed by the storage of spent fuel at nuclear plant sites. *See Nat'l Acad. of Sciences, Safety and Security of Commercial Spent Nuclear Fuel Storage: Public Report* (2006). Based upon information provided by the NRC, the National Academy of Sciences judged that “attacks with civilian aircraft remain a credible threat.” *Id.* at 30. It noted that terrorists might choose to attack spent fuel pools because they are “less well protected structurally than reactor cores” and “typically contain inventories of medium- and long-lived radionuclides that are several times greater than those contained in individual reactor cores.” *Id.* at 36. The National Academy of Sciences concluded that the storage pools are susceptible to fire and radiological release from a wide range of conditions, including intentional attacks with large civilian aircraft. *Id.* at 49, 57.¹⁷⁵

The Federal Emergency Management Agency has taken actions signifying that it considers an aircraft attack on a nuclear power plant to be a credible threat. For instance, during a June 2004 exercise to assess emergency preparedness at Indian Point, the agency simulated a suicide attack by a large cargo jet. *Fed. Emergency Mgmt. Agency, Final Exercise Report: Indian Point Energy Center*, at

¹⁷⁵ A fully loaded Boeing 767 weighs nearly 400,000 pounds. *See* Boeing, Technical Characteristics-Boeing 767-200ER, at <http://www.boeing.com/commercial/767family/pf/pf200prod.html>. The A-380, Airbus's new superjumbo airliner, has a maximum takeoff weight of 1, 235, 000 pounds. *See* Airbus, Aircraft Families/A380Specifications, at <http://www.airbus.com/en/aircraftfamilies/a380/a380/specifications.html>. According to the NRC webpage, in May 2008 NRC Chairman Dale Klein attended a security drill at San Onofre Nuclear Generating Station involving a hijacked plane approaching the facility.

101-02 (Oct. 25, 2004). In that drill scenario, the plane missed the facilities and crashed into a parking lot.

As summarized in the NRC's *A Short History of Nuclear Regulation 1946-2009*, NUREG/BR-0175, Revision 2 (Oct. 2010) ML102980443, the September 11 airplane attacks revealed a weakness at U.S. commercial nuclear power plants, namely that the commercial U.S. nuclear facilities were not designed to withstand aircraft crashes and that the densely packed spent fuel pools were located outside of the concrete containment shell were potentially vulnerable to sabotage.

As the NRC was working on the protection of plants from a commando strike, it was also considering another problem that was equally difficult and even more ethereal—the effects of an airplane hitting a reactor building or spent fuel pool. Shortly after terrorists flew airplanes into the World Trade Center and the Pentagon on September 11, 2001, the NRC acknowledged that nuclear plant builders “did not specifically contemplate attacks by aircraft such as Boeing 757s and 767s, and nuclear plants were not designed to withstand such crashes.” The only operating plant designed to guard against the impact of a large airplane was TMI, located 3 miles from Harrisburg International Airport. It was designed to protect against a plane of about 200,000 pounds accidentally hitting the plant at a speed of 230 miles per hour; the planes that terrorists hijacked on September 11, 2001, were heavier and hit their targets at speeds of 350 to 537 miles per hour. Although the NRC pointed out that containment buildings were “extremely rugged structures,” it could not predict with certainty what the consequences would be “if a large airliner, fully loaded with jet fuel...crashed into a nuclear power plant.” The critical issue that industry and the NRC then faced was to assess the vulnerability of plants to an air attack that could produce a massive release of radiation.

NUREG/BR-0175, Rev. 2, at 86; *see also id.* at 87 (discussing spent fuel pools, which are located outside of the containment shell).

Consistent with its statutory responsibilities, the NRC has analyzed sabotage events in previous documents. For example, the 1996 GEIS for License Renewal Applications discussed the effects of sabotage – albeit in a pre-9/11 world. NUREG-1437, Vol. 1, at 5-18 (1996); *see, e.g.*, NUREG-0179, *Final Environmental Statement on the Transportation of Radioactive Materials by Air and Other Modes*, (Dec. 1977) (discussing potential sabotage impacts). In 1981, NRC published NUREG/CR-1345, *Nuclear Power Plant Design Concepts for Sabotage Protection*, Vols. 1 & 2 (Jan. 1981).

The Waste Confidence DGEIS contains a few brief generic phrases about the environmental impacts that could result from sabotage or terrorism. DGEIS §4-19 (4-84 -- 4-89). The document contains conclusory statements to the effect that “the environmental impact for a successful terrorist attack, if one occurs, could be significant and destabilizing.” DGEIS, at 4-84; 4-86 (consequences of sabotage could be “severe”). These statements and the remainder of § 4-19 provide no real descriptive analysis of the impacts beyond noting that the “damages could exceed \$ 70 billion” and lead to “192 early fatalities.” It is not clear how these passing observations would apply to the Indian Point facilities and the New York City metropolitan area. The document implies that the Severe Accident Mitigation Alternatives analysis prepared for *reactor* accidents “provide a means for mitigating the potential consequences of a terrorist attacks,” but that conclusory statement is

inconsistent with New York's experience with the SAMA process in the ongoing license renewal proceeding for Indian Point – and is plainly inapplicable to spent fuel pools. Equally important, § 4-19 does not identify, discuss, and evaluate alternatives and mitigation measures. Given these omissions, the DGEIS's discussion of the environmental impacts of sabotage events does not comply with NEPA. Moreover, in its current form, the DGEIS fails to account for cumulative impacts, segments review, and does not address site-specific issues relevant to Indian Point and the New York City metropolitan area.

XI. Conclusion

Spent nuclear fuel, one of the most dangerous and long-lasting substances known to humans, was never meant to be stored long-term and densely packed in pools at nuclear plants. When many of these facilities were built, AEC and NRC told the public that the spent fuel would be stored temporarily in pools only for a brief time before being promptly removed from the host communities. Contrary to those assurances, spent nuclear fuel has remained in densely packed spent fuel pools for decades. The events at the Fukushima nuclear facilities should serve as a lesson to reinforce what is already known—long-term storage of spent fuel in pools poses significant environmental risks and impacts. NEPA requires that NRC consider safer storage alternatives such as the thinning of spent fuel pools and the use of dry cask storage. These alternatives must be considered in a site-specific analysis that evaluates the unique features of each fuel pool and its surrounding environment. The State further urges NRC to ensure that the severe accident

mitigation alternatives analyses rely on site-specific cost estimates and are reanalyzed at each operating licensing milestone. Moreover, given the importance of these issues, the NRC should revise the GEIS and implementing regulations as requested by these comments and apply the GEIS, as revised, to all license renewal applications that are currently pending.

Dated: December 20, 2013
Albany, New York

*Signed electronically by
John J. Sipos*

Laura Heslin
Kathryn Liberatore
Janice Dean
John J. Sipos
Teresa Manzi

State of New York
Office of Attorney General

List of Various Site Specific Improvements,
Including Landmarks, Parks, Arenas, Universities, and Transportation Facilities
Within 50 Miles of Indian Point Power Reactors and Spent Fuel Facilities

National Historic Landmarks:

- Brooklyn Bridge
- Carnegie Hall
- Central Synagogue
- Central Park
- Cooper Union
- New York Stock Exchange
- Grand Central Terminal
- Guggenheim Museum
- Metropolitan Museum of Art
- New York Public Library
- New York Botanical Garden
- Governors Island
- New York City Hall
- Union Square
- St Patrick's Cathedral
- Trinity Church
- Stony Point Battlefield

National Parks:

- Statue of Liberty National Monument
- Saint Paul's Church National Historic Site
- Appalachian National Scenic Trail
- General Ulysses S. Grant National Memorial
- Home of Franklin D. Roosevelt National Historic Site
- Vanderbilt Mansion National Historic Site
- African Burial Ground National Monument
- Castle Clinton National Monument
- Governors Island National Monument
- Federal Hall National Memorial
- Hamilton Grange National Memorial
- Gateway National Recreation Area
- Sagamore Hill National Historic Site

Other

- One World Trade Center (under construction)
- Brooklyn Navy Yard
- Jacob K Javits Convention Center
- Flushing Meadows–Corona Park
- Lincoln Center for the Performing Arts
- Manhattan Municipal Building

Outdoor Sports Venues

- Yankee Stadium
- Citi Field
- USTA Billie Jean King National Tennis Center
- Icahn Stadium
- Aviator Arena
- Barclay's Center (under construction)
- Hamilton-Metz Field
- MCU Park
- Arnold and Marie Schwartz Athletic Center
- Aqueduct Racetrack
- Metropolitan Oval

Universities

- United States Military Academy (West Point)
- US Merchant Marine Academy
- Columbia University
- New York University
- Fordham University
- The Julliard School
- Culinary Institute of America
- St. John's University
- Yeshiva University
- Brooklyn Law School
- Brooklyn College
- CUNY (all campuses)
- Vassar College
- Pace University
- Pratt Institute
- Yeshiva University

Transportation

- South Ferry Terminal
 - Howland Hook Marine Terminal
 - Red Hook Container Terminal
 - Brooklyn Marine Terminal
 - New York Passenger Ship Terminal
 - Brooklyn Cruise Terminal
 - Newburgh-Beacon Bridge
 - Bear Mountain Bridge
 - Mid Hudson Bridge
 - Verrazanno Narrows Bridge
 - George Washington Bridge
 - Brooklyn Bridge
 - Manhattan Bridge
 - Williamsburg Bridge
 - Throgs Neck Bridge
 - Robert F. Kennedy Bridge
 - Queensboro Bridge
 - Bronx-Whitestone Bridge
 - Dutchess County Airport
 - Stewart Airport
 - Teterboro Airport
 - Laguardia Airport
 - JFK Airport
 - Westchester County Airport
 - Pennsylvania Station
 - World Trade Center PATH Station
 - Interstate I-95, I-287, I-87 (NYS Thruway), I-84, NYS Route 9, Taconic Parkway
- New York City Parks:**
- Randalls Island Park
 - Battery Park
 - Washington Square Park
 - Madison Park
 - Fort Tyron Park
 - The High Line

List of Various Site Specific Improvements,
Including Landmarks, Parks, Arenas, Universities, and Transportation Facilities
Within 50 Miles of Indian Point Power Reactors and Spent Fuel Facilities

- Highbridge Park
- The Cloisters
- Bronx Zoo
- Van Cortlandt Park
- Prospect Park
- Bryant Park
- Jacob Purdy House
- Fort Wadsworth
- Jamaica Bay Wildlife Refuge
- State Parks:**
- Bayswater Point
- Clay Pit Ponds
- East River
- Empire-Fulton Ferry
- Gantry Plaza
- Riverbank
- Roberto Clemente
- Clarence Fahnestock
- Fahnestock Winter Park
- Franklin D. Roosevelt
- Hudson Highlands
- James Baird
- Mills Norrie (Margaret Lewis Norrie)
- Ogden Mills & Ruth Livingston Mills
- Old Croton Aqueduct
- Rockefeller
- Walkway Over the Hudson (Poughkeepsie)
- Clinton House
- John Jay Homestead
- Philipse Manor Hall
- Staatsburgh State Historic Site
- Anthony Wayne Recreation Area
- Bear Mountain
- Beaver Pond Campgrounds
- Blauvelt
- Goosepond Mountain
- Harriman
- High Tor
- Highland Lakes
- Lake Sebago Beach
- Lake Tiorati Beach
- Lake Welch Beach
- Minnewaska Preserve
- Nyack Beach
- Rockland Lake
- Schunnemunk
- Silver Mine
- Sterling Forest
- Storm King
- Tallman Mountain
- Fort Montgomery
- Knox's Headquarters
- National Purple Heart Hall of Honor
- New Windsor Cantonment
- Stony Point Battlefield
- Washington's Headquarters
- Bethpage Golf Course
- Caumsett
- Planting Fields Arboretum
- Walt Whitman Birthplace

Prepared by Adam Solomon

REVIEW OF WASTE CONFIDENCE GENERIC ENVIRONMENTAL IMPACT STATEMENT

ISR Report 13014-01-02

20 December 2013

presented to

Office of the Attorney General - State of New York
120 Broadway, New York, NY 10271-0332

prepared by



DR. FRANÇOIS LEMAY

International Safety Research
38 Colonnade Road North
Ottawa, Ontario
Canada K2E 7J6



International Safety Research Inc.

TABLE OF CONTENTS

1. Introduction	1
1.1 Scope.....	1
1.2 Background.....	1
2. NRC Spent Fuel Pool Environmental Assessment	4
2.1 Scope of the DGEIS.....	4
2.2 Technical basis	5
2.3 Site Specificity.....	6
2.4 Acceptance Criteria.....	8
2.4.1 <i>Risk Criteria</i>	9
2.4.2 <i>Quantitative Health Objective</i>	9
2.4.3 <i>Site-Specific Analysis of Spent Fuel Pool Fire Costs</i>	10
3. Accident Assessment	12
3.1 Selection of accidents	12
3.1.1 <i>Event reports and accident precursors</i>	12
3.2 Source term	14
3.3 Event frequencies	14
3.3.1 <i>Initiating events</i>	14
3.3.2 <i>Summary</i>	16
3.4 Consequence assessment.....	16
3.4.1 <i>Atmospheric releases</i>	16
3.4.2 <i>Liquid releases</i>	18
3.4.3 <i>MACCS2 input parameters to determine offsite cost</i>	19
3.4.4 <i>NUREG-1150 cost of decontamination for non-farmland</i>	25
4. Relevance for Indian Point	28
4.1 Configuration of Spent Fuel Pool.....	28
4.2 Seismicity.....	28
4.3 MACCS2 Input Parameters.....	29
5. Conclusions	30
REFERENCES.....	31
Annex A – Average risk calculated over all reactor sites	33
Annex B – Cost of decontamination in urban environments.....	34

LIST OF FIGURES

Figure 1: Event report from Lacrosse Spent Fuel Pool	13
Figure 2: Population and wind rose for the Indian Point site. LEFT - Population by grid element (darker colors represent higher population) (ML13073A555 at p. 2-7), RIGHT – Wind rose for years 1999-2002 (ML12334A743).....	21
Figure 3: Comparison of population densities.....	22
Figure 4: Detailed surface analysis report (Tawil 1990, p. 4.33)	27

LIST OF TABLES

Table 1: Spent Fuel Pool Accident Probability and Consequences.....	17
Table 2: Summary of the population density sensitivity analysis (US-NRC 2013a).....	22
Table 3: Summary of site-specific MACCS2 input parameters relevant to Indian Point .	29

1. INTRODUCTION

1.1 Scope

The Office of the Attorney General of the State of New York requested that International Safety Research (ISR) perform a technical review of the US-NRC NUREG-2157, Waste Confidence Generic Environmental Impact Statement Draft Report for Comment (DGEIS), and supporting documents. US-NRC released the DGEIS for public comment in September 2013. In the DGEIS, US-NRC aims to analyze the environmental impacts of the continued storage of spent nuclear fuel beyond a reactor's licensed life for operation and prior to ultimate disposal.

In addition to the DGEIS, US-NRC released another document assessing the environmental impacts of continued fuel storage, entitled Consequence Study of a Beyond-Design-Basis Earthquake Affecting the Spent Fuel Pool for a U.S. Mark I Boiling Water Reactor (Spent Fuel Pool Consequence Study). On October 9, 2013, in SECY-13-0112 (ML13256A339), the US-NRC Staff provided the US-NRC Commissioners with the final Spent Fuel Pool Study, noting Staff's intention to make the report public and subsequently publish it as a NUREG. On November 12, 2013, the US-NRC issued COMSECY-13-0030 (ML13273A601), which incorporates results of the Spent Fuel Pool Consequence Study.

Although the DGEIS does not currently cite to the Spent Fuel Pool Consequence Study, the US-NRC has stated publicly that, if the study is finalized before the final GEIS is published, it will be added as a reference to the GEIS.¹ To date, the Spent Fuel Pool Consequence study has not yet been published as a NUREG.

This report will discuss all of these recent documents, and the storage of spent nuclear fuel in spent fuel pools. These recent US-NRC reports rely upon earlier reports, including NUREG-1738, a computer code (MACCS2), and various other documents.

The results of ISR's review of the aforementioned documents are recorded in this report. The review was limited to these documents, and did not include carrying out MACCS2 calculations, or proposing alternative studies or analyses for this type of risk assessment.

1.2 Background

This report concerns the storage of spent nuclear fuel in spent fuel pools, and NRC's assessment of the potential environmental impacts of continued storage of fuel at nuclear power plant sites, given the uncertainty surrounding a permanent repository.

¹ See, e.g., NRC, *Two Separate NRC Efforts Address Spent Fuel Safety*, <http://public-blog.nrc-gateway.gov/2013/06/24/two-separate-nrc-efforts-address-spent-fuel-safety/> (June 24, 2013) ("The draft GEIS [for the Waste Confidence rule] does not explicitly reference the pool study, though the waste confidence staff worked closely with the staff preparing the pool study while developing relevant chapters of the draft GEIS. If a final version of the [Spent Fuel Pool Consequence] study is published before the final waste confidence GEIS, the staff will incorporate a reference to it in the final GEIS.").

A nuclear power reactor's core contains zirconium-clad rods filled with enriched uranium pellets that fuel the atomic process. Over time, that fuel produces a less efficient nuclear reaction and must be replaced and removed from the reactor. Because spent-fuel rods generate several MW of heat and contain highly radioactive material, the rods are removed from the reactor and the containment area, transported through a transfer canal, and placed on racks in a pool adjacent to the reactor building to cool down. At operating U.S. PWR nuclear power plants, the pool is located outside of the containment structure that surrounds the reactor.

The US-NRC, and its predecessor the U.S. Atomic Energy Commission, have examined severe accidents at U.S. nuclear power plants. Earlier studies focused on potential reactor accidents, based on the assumption that spent nuclear fuel would be stored at an off-site, permanent repository and would only be temporarily stored on-site in spent fuel pools until a repository became available. As time went on without a permanent repository, spent nuclear fuel began to accumulate in spent fuel pools in quantities that exceeded the volume of fuel inside the reactor. A permanent repository has still not been developed.

The DGEIS is NRC's latest effort aimed at generically establishing that continued storage of spent nuclear fuel is safe in the absence of and uncertainty surrounding a permanent repository. The Spent Fuel Pool Consequence Study is NRC's effort to assess whether the expedited transfer of spent fuel to dry cask storage is warranted, given the reality of continued on-site storage. US-NRC's prior relevant risk assessments include assessments of spent fuel pool accident risk and reactor accident risk.

The following documents focus on spent fuel pool accidents:

- 1989 NUREG-1353, Regulatory Analysis for the Resolution of Generic Issue 82, Beyond Design Basis Accidents in Spent Fuel Pools (US-NRC 1989)
- 2001 NUREG-1738 Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants (US-NRC 2001)
- 2006 Wagner and Gauntt, redacted (Sandia 2006) and classified Sandia Studies discussed in the Denial of Petitions for Rulemaking PRM-51-10 and PRM-51-12, 73 Federal Register 46,204 (US-NRC 2008)

The following documents focus on reactor accidents:

- 1957 WASH-740, Theoretical Possibilities and Consequence of Major Accidents in Large Nuclear power Plants (BNL 1957)
- 1975 WASH-1400, also referred to as NUREG-75/014, Reactor Safety Study: An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants (US-NRC 1975)
- 1987 NUREG-1150, *Reactor Risk Reference Document (Draft for Comment)* - Main Report (Volume 1), Appendices A-I (Volume 2), and Appendices J-O (Volume 3) (US-NRC 1987)

- 1989 NUREG-1150, *Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants (Second Draft for Peer Review)* -Summary Report (Volume 1), Appendices (Volume 2) (US-NRC 1989a)
- 1990 NUREG-1150, *Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants* - Final Summary Report (Volume 1), Appendices A, B, and C (Volume 2), Appendices D and E (Volume 3) (US-NRC 1990)
- 1990 NUREG/CR-4551, J. L. Sprung, et al., *Evaluation of Severe Accident Risks: Quantification of major input parameters -MACCS Input*, Volume 2, Revision 1, Part 7 (Sandia 1990)
- 2012 NUREG/CR-7110, *State-of-the-Art Reactor Consequence Analyses (SOARCA) Project* (US-NRC 2012)

The MACCS2 code, which was publicly released in 1997, is a computer modeling tool developed by Sandia to evaluate impacts of severe accidents at nuclear power plants on the surrounding public. The MACCS2 code simulates the atmospheric release of radioactivity following a severe accident based on meteorological inputs, and calculates radiological health and economic impacts based on user-defined inputs. The MACCS2 code can model, among other things, economic costs of an accident. The latest of a series of computer modeling tools developed for this purpose, the MACCS2 code is an improved version of the MACCS code, which itself replaced the earlier CRAC2 code.

In many of the documents cited above, US-NRC utilized the MACCS2 code, and its predecessor codes, to assess the consequences of severe accidents at spent fuel pools and reactors. The MACCS2 code has also been utilized by applicants and NRC Staff as part of NRC's analysis in license renewal proceedings of site-specific severe accident mitigation alternatives for severe accidents affecting a specific reactor.² In running the MACCS2 code, US-NRC and applicants have chiefly relied upon an example set of economic cost inputs listed as "Sample Problem A" in the MACCS2 User Guide.³ The input parameters for Sample Problem A were taken from NUREG-1150, and incorporate site-specific data for the Surry site in rural Virginia.

² A small subset of 6 U.S. reactors examined severe accidents during their initial operating license application.

³ Sample Problem A is one of fourteen sample problems containing example sets of inputs included in the MACCS2 User Guide. US-NRC and applicants often adjust these input values for inflation using the Consumer Price Index.

2. NRC SPENT FUEL POOL ENVIRONMENTAL ASSESSMENT

2.1 Scope of the DGEIS

According to the DGEIS (p. iii), NRC's objective was:

- *“to examine the potential environmental impacts that could occur as a result of the continued storage of spent nuclear fuel (spent fuel) at at-reactor and away-from-reactor sites until a repository is available.*
- *establish generic impact determinations that would be applicable to a wide range of existing and potential future spent fuel storage sites.*
- *improve the efficiency of the NRC's licensing processes by*
 - *(1) providing an evaluation of the environmental impacts that may occur as a result of continuing to store spent fuel at at-reactor or away-from-reactor sites until a repository is available,*
 - *(2) identifying the types and assessing the magnitude of environmental impacts where generic findings can be established, and*
 - *(3) providing the regulatory basis for the NRC's proposed amendments to regulations”*

The NRC stated that it sought to address deficiencies identified by the U.S. Court of Appeals for the D.C. Circuit (US-NRC 2013, pp. 1-3):

“The Court identified three deficiencies in the NRC's environmental analysis:

- 1. Related to the Commission's conclusion that permanent disposal will be available 'when necessary,' the Court held that the Commission needed to evaluate the environmental effects of failing to secure permanent disposal, given the uncertainty about whether a repository would be built.*
- 2. Related to 60 years of continued storage, the Court concluded that the Commission had not adequately examined the risk of spent fuel pool leaks in a forward-looking fashion.*
- 3. Also related to continued storage, the Court concluded that the Commission had not adequately examined the consequences of potential spent fuel pool fires.”*

In the DGEIS, US-NRC includes an analysis of the environmental impacts of spent fuel pool leaks, spent fuel pool fires, and long term spent fuel storage on site. The DGEIS determines that a spent fuel pool fire is the bounding accident, i.e., that a spent fuel pool fire accident results in the highest potential consequences among the credible accidents analyzed in the DGEIS. US-NRC concludes that the risk of spent fuel pool fires is “small” for all plants. In summary, the DGEIS aimed to analyze the probability-weighted population doses and economic consequences of a spent fuel fire during the short-term storage timeframe, i.e., 60 years after a reactor license has expired.

The DGEIS also aims to address terrorist acts (US-NRC 2013, p. 4-84).

2.2 Technical basis

The DGEIS Appendix F relies extensively on previous studies of severe accident risks,⁴ factoring in the probability of occurrence as well as the potential consequences, to reach the conclusion that potential health and economic impacts from severe accidents in spent fuel pools are “small” (US-NRC 2013, p. 4-82). For spent fuel pool fires, NRC derives “a significant portion” of its analysis from its Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants, NUREG-1738 (US-NRC 2001), asserting that it is the most complete and consistent recent study regarding this topic.

NUREG-1738, prepared in connection with decommissioning rulemaking for permanently shutdown nuclear power plants, contains the results of the NRC’s evaluation of the potential accident risk in a spent fuel pool at decommissioning plants. See also SECY-01-0100, *Policy Issues Related to Safeguards, Insurance, and Emergency Preparedness Regulations at Decommissioning Nuclear Power Plants Storing Fuel in Spent Fuel Pools* (US-NRC 2001a). The NUREG-1738 study includes the results of MACCS2 calculations carried out for the spent fuel pool at the Surry site, which is surrounded by farmland in rural Virginia. For the economic costs of a spent fuel pool fire, NUREG-1738 quoted results obtained from the MACCS code for the Zion site in Illinois from NUREG-1353 (US-NRC 1989) and from NUREG/BR-0184 (US-NRC 1997). The analysis for the Zion site was chosen since consequence assessment results were available for both the reactor and the spent fuel pool; the same was not true for the Surry site.

NUREG-1738 was published before both the September 11 terrorist attacks and the severe accident at the Fukushima Dai-ichi nuclear power plants. Since the DGEIS relies on NUREG-1738 for the assessment of the consequences of a spent fuel pool fire, the quantitative analysis of consequences in the DGEIS does not include lessons learned from these two later events.

The DGEIS Appendix F qualitatively discusses NRC’s orders following the September 11 terrorist attacks and the “lessons learned” NRC is developing and implementing in response to accident at Fukushima Dai-ichi. NRC’s consideration of these safety enhancements is solely in the context of the probability that a spent fuel pool fire would occur. See DGEIS at F-12 (“These measures further reduce the probability of a spent fuel pool fire, and thus further increase the conservatism of NUREG–1738.”). The DGEIS, however, does not quantify the reduction in probability or clearly explain which post-September 11 or post-Fukushima measures generically reduce the probability. Nor does the DGEIS effectively identify, discuss, and evaluate other available mitigation measures to reduce or minimize the impacts of a severe spent fuel pool accident. For example, although the DGEIS relies upon NUREG/BR-0184’s calculation of the consequences of pool fire accidents, including protective measures such as the use of a spray system, post-Fukushima US-NRC Order EA-12-049 does not mandate the

⁴ The DGEIS Appendix F defines risk as the quantitative measure of the severity of the accident that accounts for the likelihood of the occurrence, i.e., risk is the probability-weighted consequence.

installation of fixed spray systems in spent fuel pools. Similarly, the DGEIS does not examine the alternative of reducing the volume of spent nuclear fuel (and hence the potential accident source term) in spent fuel pools, although this information is available in other documents (US-NRC 2013a).

In addition to NUREG-1738 and the other documents discussed above, the DGEIS relies on the technical assessment carried out in support of the Denial of Petitions for Rulemaking, 73 Fed. Reg. 46,204, (US-NRC 2008), which denied two states' petitions for rulemaking concerning the environmental impacts of the high-density storage of spent nuclear fuel in spent fuel pools. In DGEIS Appendix F, NRC references this document's discussion of measures that have been integrated since 2001 to reduce the probability of a spent fuel pool fire. 73 Fed. Reg. 46,204 relies on the Sandia letter report of Wagner and Gauntt (Sandia 2006) to conclude that post-2001 measures have reduced the likelihood that loss of water inventory in a spent fuel pool could lead to a spent fuel pool fire. The publicly-available version of this study has been heavily redacted and does not contain information necessary to quantify the reduction in risk.

A more recent analysis of the risk of spent fuel pool storage is contained in COMSECY-13-0030, *Staff evaluation and recommendation for Japan lessons-learned tier 3 issue on expedited transfer of spent fuel* (US-NRC 2013a), which incorporates the final version of *Consequence Study of a Beyond-Design-Basis Earthquake Affecting the Spent Fuel Pool for a U.S. Mark I Boiling Water Reactor*, SECY-13-0112, (US-NRC Oct. 9, 2013). As stated in Section 1.1 above, the DGEIS does not currently cite to the Spent Fuel Pool Consequence Study, but US-NRC stated its intention to include reference to the study in the final GEIS if it is published as a NUREG before the GEIS is finalized.

2.3 Site Specificity

The NRC states that the purpose of the DGEIS is to provide a regulatory basis for a proposed revision of the NRC's Waste Confidence rule. The DGEIS attempts to develop an environmental impact statement concerning the storage of spent nuclear fuel that would apply generically to all reactor and storage sites in the U.S. As discussed in Section 2.2 above, it does so by relying mostly on NUREG-1738, a generic study of the risks from spent fuel pools at decommissioning plants.

To quote the DGEIS (p. xxiv):

"The NRC considers the continued storage of spent fuel a generic activity that is similar for all commercial nuclear power plants and storage facilities."

Later, in the same document (p. 1-5), US-NRC explains its intent:

"The GEIS [...] if adopted, would provide a regulatory basis for the NRC's proposed amendment to 10 CFR 51.23."

"Further, the revision would state that because the impacts of continued storage have been generically assessed in this draft GEIS and codified in a Rule, NEPA analyses for future reactor and spent fuel storage facility licensing actions would not need to separately consider the environmental impacts of continued storage."

The authors of NUREG-1738 were very careful to spell out the limitations of their generic

approach for decommissioning plants. Subsequent documents like DGEIS and the Denial of Rulemaking Petitions in 73 Fed. Reg. 46,204 do not repeat these warnings. The following are examples of limitations that are identified in NUREG-1738.

Regarding the age of the fuel beyond which a spent fuel pool fire can be ruled out (US-NRC 2001, p. 2-1):

“...the revised analyses show that it is not feasible, without numerous constraints, to define a generic decay heat level (and therefore decay time) beyond which a zirconium fire is not physically possible. Heat removal is very sensitive to these constraints, and two of these constraints, fuel assembly geometry and spent fuel pool rack configuration, are plant specific.”

See also SECY-01-0100. Regarding the pool fire frequencies for all initiators (US-NRC 2001, p. 3.7):

“Plant-specific frequency estimates in some cases could be as much as an order of magnitude higher or lower because of the seismic hazard at the plant site.”

Regarding the possibility for air cooling following damage caused by severe weather (US-NRC 2001, p. 3-10):

“For loss of offsite power events caused by severe weather, the staff assumed a 90 percent partition for the high airflow case. This is based on a staff assumption that openings in the SFP building (e.g., doors and roof hatches) are large enough that, if forced circulation is lost, natural circulation cooling will provide at least two building volume of air per hour to the SFP. This assumption may need to be confirmed on a plant-specific basis.”

Regarding the low initiating event frequency⁵ for the loss of pool inventory (US-NRC 2001, p. 3-12):

“These assumptions may be nonconservative on a plant-specific basis depending on SFP configuration and commitments for configuration control.”

Regarding the likelihood of loss of cooling, loss of inventory, and loss of off-site power (US-NRC 2001, p. 3-12):

“Initiating event frequencies for loss of cooling, loss of inventory, and loss of offsite power are based on generic data. In addition, the probability of power recovery is also based on generic information. Site-specific differences will proportionately affect the risk from these initiating events.”

Regarding the assumption that leaks are self-limiting (US-NRC 2001, p. A2A-67):

“For the loss of inventory event tree, the assumption that the leak is self-limiting after a drop in level of 15 feet, may be a more significant assumption that, on a site specific basis may be non-conservative, and requires validation.”

⁵ Throughout this report, the terms probability and frequency are used. Frequency is simply probability, expressed on a per-year basis. Thus, the event frequency is the probability that an event will occur within one year.

In addition, NUREG-1738 relies on a series of Industry Decommissioning Commitments (IDC) and Staff Decommissioning Assumptions (SDA) that are spelled out and are assumed to apply generically to all plants (US-NRC 2001, p. 4-11 and 4-12). NUREG-1738 bases its analysis on the assumption that these commitments and assumptions are met. If they are not, the analysis carried out in NUREG-1738 may not be valid at a specific site.

By contrast, the authors of the DGEIS use less definite language (US-NRC 2013, p. F-8):

“In general, health impacts could be higher than the values reported in these studies if the amount of spent fuel involved in a fire (and, thus, the amount of radioactive material that could be released) was higher than assumed in these studies or the total population and population density were higher.”

Later, in the DGEIS (US-NRC 2013, p. F-7):

“As with health impacts, the economic impacts would vary for different facilities. For example, higher total population or population density could result in higher relocation costs, and land use (e.g., whether land is used as farmland or not) could also impact decontamination and condemnation costs.”

In summary, it seems that the US-NRC’s critique in the Denial of the Petition for Rulemaking of petitioners’ assertion that fuel will burn regardless of age, quoted below (US-NRC 2008), is equally applicable to the conclusions of the DGEIS:

“This conclusion, however, was in no sense a statement of certainty and was made in order to reach a conclusion on a generic basis, without relying on any plant-specific analyses.”

Likewise, US-NRC’s assessment of spent fuel pool fire risk in the DGEIS Appendix F and determination that such risk is “small” is in no sense a statement of certainty regarding the risk at any given plant.

2.4 Acceptance Criteria

In NUREG-1738, US-NRC adopted the US-NRC’s Policy Statement on Safety Goals for the Operation of Nuclear Power Plants. The Policy Statement expressed the Commission’s policy regarding the acceptable level of radiological risk from nuclear power plant operation as follows:

- *“Individual members of the public should be provided a level of protection from the consequences of nuclear power plant operation such that individuals bear no significant additional risk to life and health.”*
- *“Societal risks to life and health from nuclear power plant operation should be comparable to or less than the risks of generating electricity by viable competing technologies and should not be a significant addition to other societal risks.”*

The following sections describe the various criteria used by the US-NRC in its assessment of the risk from spent fuel pools in the DGEIS.

2.4.1 Risk Criteria

In section 3.7.3 of NUREG-1738, the US-NRC describes the Commission's Safety Goals that were used to derive risk acceptability criteria. The risk criteria for the spent fuel pool were derived from the existing severe reactor accident criteria. Both the spent fuel pool criteria and the severe reactor accident criteria are discussed here.

The US-NRC has created a pool performance guideline of 10^{-5} pool fire events per year, based on the need to meet quantitative health objectives with a severe spent fuel pool accident source term (US-NRC 2001, p. A4C-1). The logic behind this decision is that spent fuel pool fires have comparable health effect consequences to those of a severe reactor accident (US-NRC 2001, p. 4-4). Thus, the resulting pool performance guideline is compatible with the risk criteria guidelines for nuclear power plants.

The risk criteria guidelines for nuclear power plants are described in RG 1.174 and relate to core damage frequency and large early release frequency. Changes to the license are acceptable if they result in frequency changes smaller than one tenth of the baseline frequency. In the case of the spent fuel pool, US-NRC has adopted the large early release frequency as an acceptance criterion for spent fuel pool fires. If the baseline large early release frequency is below the 10^{-5} per year, then plant changes can be approved if they increase the large early release frequency by up to 10^{-6} per year.

2.4.2 Quantitative Health Objective

The following quantitative health objectives are used in determining achievement of the two safety goals set forth in the policy document discussed above in Section 2.2 (US-NRC 2001, p. A4C-2):

- *“The risk to an average individual in the vicinity of a nuclear power plant of prompt fatalities that might result from reactor accidents should not exceed one-tenth of 1 percent (0.1 percent) of the sum of prompt fatality risks resulting from other accidents to which members of the U.S. population are generally exposed.”*
- *“The risk to the population in the area near a nuclear power plant of cancer fatalities that might result from nuclear power plant operation should not exceed one-tenth of 1 percent (0.1 percent) of the sum of cancer fatality risks resulting from all other causes.”*

These objectives have been translated into two numerical objectives as follows:

- *“The individual risk of a prompt fatality from all ‘other accidents to which members of the U.S. population are generally exposed,’ such as fatal automobile accidents, is about 5×10^{-4} per year. One-tenth of one percent of this figure implies that the individual risk of prompt fatality from a reactor accident should be less than 5×10^{-7} per reactor year.”*
- *“The sum of cancer fatality risks resulting from all other causes for an individual is taken to be the cancer fatality rate in the U.S. which is about 1 in 500 or 2×10^{-3} per year. One tenth of 1 percent of this implies that the risk of cancer to the*

population in the area near a nuclear power plant because of its operation should be limited to 2×10^{-6} per reactor year.”

The numerical objectives above are compared to the early fatality risk to an average individual within 1.6 km (1 mi) and the latent cancer fatality risk to an average individual within 16 km (10 mi) of the plant.

When NRC established these criteria, it developed them to be applicable to all sites since individual prompt fatality risks are the same regardless of the population density surrounding a reactor. Although the policy statement mentions societal risks, the numerical objectives do not. The risk to society should be comprised of, at minimum, the latent health effects (i.e., the radiological impact to the population) and economic costs.

One possible quantitative objective for the radiological component of societal risk may be obtained by multiplying the objective for latent fatalities (2×10^{-6} latent fatalities per reactor year) by the nominal risk of latent fatalities (assumed to be 5% per person-Sv based on guidance from the International Commission on Radiological Protection (ICRP 2007)). This results in a numerical objective for collective dose of 4×10^{-5} person-Sv per reactor year, or 4×10^{-3} person-rem per reactor year.

If the DGEIS had adopted societal risk criteria, the analysis would have been dependent on the population density around the site, making it impossible to develop a generic approach that applies at all sites.

2.4.3 Site-Specific Analysis of Spent Fuel Pool Fire Costs

NUREG-1738 contains two cost analyses. In the first, US-NRC determines the cost of a spent fuel pool fire at the Zion site. The costs include both health costs and economic costs. Health costs refer to the collective radiation dose to members of the public, which is then converted to a dollar value. Economic costs include those costs associated with property decontamination or condemnation, and population relocation. The input parameters associated with these costs were the same as the offsite economic cost inputs proposed in NUREG-1150. To accomplish this, the authors of NUREG-1738 used the MACCS2 code to estimate economic costs associated with a severe nuclear reactor accident using inputs entered by the user. For Zion, NUREG-1738 used an 80-km (50 mi) average population density of 860 people per square mile from NUREG-1353 (US-NRC 1989).

The DGEIS adjusted the Zion costs from 1988 USD to 2010 USD using the Consumer Price Index. In NUREG-1353, the offsite health effect costs are based on \$1000 per person-rem, and account for more than 75% of the total economic cost. The cost of off-site property damage for the Zion site is a little over 5% of the total economic cost. It should be noted that the current US-NRC benchmark for health effect costs is \$2000 per person-rem; this is approximately equal to the 2013 USD-equivalent amount used in NUREG-1353, i.e., \$1000 per person rem adjusted to 2013 USD using the Consumer Price Index.

The other cost analysis used in NUREG-1738 is based on NUREG/BR-0184 (US-NRC 1997), which calculates cost using MACCS and the NUREG-1150 offsite economic cost inputs. In NUREG/BR-0184 the costs were expressed in 1983 USD. The DGEIS adjusted those costs to 2010 USD. The NUREG/BR-0184 analysis is based on the Zion

site like the NUREG-1353 analysis. Thus in NUREG/BR-0184 and NUREG-1353, the same population density is used.

With respect to site specific characteristics, it should be noted that as of 1990, the Indian Point site had 15.1 million people living within 50 miles of the site – more than twice the number that lived within 50 miles of the Zion site. (US-NRC 1996, p. 2-2 to 2-8 stating that Indian Point had “almost 2000 persons per square mile”). These population totals have increased since 1990. US-NRC reports that as of 2000, 16.8 million people lived within 50 miles of Indian Point (US-NRC 2013, p. 3-8), and that as of 2010 approximately 17 million people lived within 50 miles of Indian Point.⁶ To ISR’s knowledge, US-NRC has not disclosed or released the results of any site-specific MACCS2 analysis of a severe accident at the Indian Point spent fuel pools. Thus, it is not possible to compare the results of the Zion assessment to an Indian Point-specific assessment, and determine whether the differences are significant.

After reporting the results of NUREG-1738, NUREG/BR-0184, and NUREG-1353, the DGEIS attempts to benchmark the radiation dose consequences and the economic cost of a spent fuel pool accident against values for severe reactor accidents. Based on these results, the US-NRC concludes (US-NRC 2013, p. F-10):

“This analysis shows that the probability-weighted consequences for a spent fuel pool fire, as analyzed in NUREG–1738, are comparable to the probability-weighted consequences for severe power reactor accidents analyzed in the 1996 and 2013 License Renewal GEIS (NRC 1996, 2013).”

Based on this conclusion, it is reasonable to expect that US-NRC would implement similar requirements for severe reactor accidents and spent fuel pool accidents. This would include the conduct and documentation of a Severe Accident Mitigation Alternatives (SAMA) analysis that is based on a site-specific cost-benefit comparison of the costs of implementing mitigation alternatives with the benefits achieved by those mitigation alternatives. Furthermore, risk assessments and SAMA analyses for reactor and spent fuel pool accidents at the same site should not be conducted independently; an integrated, site-wide analysis is the way to quantitatively assess the risks posed by all operations conducted on a single site.

In conclusion, although US-NRC reports the similarities between spent fuel pool fires and reactor accidents, the DGEIS does not actually use this information. The DGEIS does not contain societal dose acceptance criteria or a SAMA analysis considering the costs and benefits of mitigation alternatives given the cost of a spent fuel pool fire.

⁶ The population within 50 miles of Indian Point is based on 2010 census data obtained from reference (US-NRC 2012b).

3. ACCIDENT ASSESSMENT

3.1 Selection of accidents

The DGEIS includes sections on spent fuel leaks, spent fuel pool fires, and terrorist acts. The DGEIS concludes that the consequences of these accidents are bounded by the consequences of a spent fuel pool fire and this is the only accident that is completely analyzed.

3.1.1 Event reports and accident precursors

In the DGEIS, US-NRC has relied upon a compilation of event reports such as NUREG-1275 Vol. 12 (US-NRC 1997a) to identify relevant spent fuel events. The DGEIS mentions that US-NRC staff also performs annual reviews of U.S. and international operating experience with spent fuel storage and handling (US-NRC 2013a), although this does not appear to be documented in an official document.

Section E.3 of the DGEIS discusses historical data on spent fuel pool leaks. It discusses the 13 sites where occurrences of spent fuel leaks that have been documented. However, the DGEIS does not include an exhaustive look at event reports and accident precursors that should inform the assessment of environmental risks from the spent fuel pools. Since the publication of NUREG-1275 in 1997, there have been many event reports that could inform the DGEIS, and that should be described in the DGEIS.

As an example, one of the assumptions included in the DGEIS is that pool drainage is not credible, based on the configuration of spent fuel pools.

NUREG-1738, p. 3-5 (and again on p. 3-11, p. 3-15):

“Plants do not have drain paths in their SFPs that could lower the pool level (by draining, suction, or pumping) more than 15 feet below the normal pool operating level, and licensees must initiate recovery using offsite sources.”

NUREG-1738, p. 3-6:

“IDC #6 Spent fuel pool seals that could cause leakage leading to fuel uncover in the event of seal failure shall be self-limiting to leakage or otherwise engineered so that drainage cannot occur.”

These assumptions may not be compatible with the configuration of some of the spent fuel pools, as the event report shown in Figure 1 shows.

While NUREG-1738 is clear that plants that do not pass the seismic checklist would not qualify for the exemptions on emergency preparedness (EP), indemnification or security, the DGEIS is far from clear on what would happen in a specific plant could not meet some of the conditions listed in NUREG-1738. Neither the DGEIS, nor NUREG-1738, lists exactly which plants meet the NUREG-1738 conditions and which plants do not.

3.2 Source term

With the exception of ruthenium and fuel fines, the DGEIS relies upon release fractions for all radionuclides (e.g., cesium-137 and iodine-131) from NUREG-1465, "Accident Source Terms for Light-Water Nuclear Power Plants". The DGEIS ages the source term for decay times of 60 days, 1 year, 2 years, 5 years and 10 years.

In NUREG-1738, US-NRC carried out a sensitivity analysis for ruthenium and fuel fines based on comments from the Advisory Committee on Reactor Safeguards (ACRS). In the DGEIS, US-NRC states that it now believes NUREG-1738's high ruthenium source term to be very conservative and that the low ruthenium release fractions are more representative of the consequences of a spent fuel pool fire (US-NRC 2013, p. F-5).

3.3 Event frequencies

3.3.1 Initiating events

Initiating events include (US-NRC 2001, p. 3-2, 3-3):

The staff identified nine initiating event categories to investigate as part of the quantitative assessment on SFP risk:

1. Loss of offsite power from plant centered and grid-related events
2. Loss of offsite power from events initiated by severe weather
3. Internal fire
4. Loss of pool cooling
5. Loss of coolant inventory
6. Seismic event
7. Cask drop
8. Aircraft impact (as an accident scenario)
9. Tornado missile

Criticality events are analyzed separately.

These initiating events are assumed to lead to a loss of cooling or a catastrophic failure of the spent fuel pool. In both cases, the resulting end-state is a spent fuel pool fire. US-NRC calculates a frequency for each of these events. The DGEIS then discusses frequency based on information presented in NUREG-1738 for the two most important initiating events: seismic events and heavy drop load events.

Seismic events

Two different seismic hazard estimates have been developed for U.S. reactor sites, one developed by Lawrence Livermore National Laboratories (LLNL) and one by the Electric Power Research Institute (EPRI). Using the site-specific LLNL seismic hazard estimates, the mean spent fuel pool failure probability for the sites analyzed by LLNL is about 2×10^{-6} per year and covers a range 6×10^{-7} per year to 1.5×10^{-5} per year (US-NRC 2001, p. 3-22). For the EPRI hazard estimates, the mean value of the pool failure frequency is about 2×10^{-7} per year and it covers the range 3×10^{-9} per year to 2×10^{-6} per

year (US-NRC 2001, p. 3-21). The plants that have the lowest and highest seismic risks are not identified in the analysis.

Based on the frequencies listed in Table 3.7-3 (US-NRC 2001, p. 3-35) the frequency of boil down events does not seem to consider loss of offsite power, and internal fire triggered by seismic events.

NUREG-1738 considers the risk contribution of earthquakes that damages pool support systems in the seismic risk of pool fire (US-NRC 2001, p. 3-9, A2B-3). The return frequency of the earthquakes is assumed to be 1 : 4000 years and a failure to obtain off-site resources in a timely manner is assumed to be 1×10^{-4} .

If loss of offsite power and internal fires triggered by seismic events were considered at the same earthquake return frequency as for the damage to pool support systems, the probability of these initiating events could increase.

The total probability of pool drainage from NUREG-1353 (2×10^{-6} events per year) is based on best estimates of the frequency of various event sequences, and is dominated by the seismic risk of structural failure (US-NRC 1989, p. 4-36). It should be noted that NUREG-1738 uses the average probabilities for the seismic events (p. 3-9) and acknowledges that site-specific values could be ten times higher or lower (p. 3-7). The DGEIS relies upon these average probabilities from NUREG-1738, reporting them in Table F-1 (US-NRC 2013, p. F-4). The DGEIS, however, does not include the caveat from NUREG-1738 that site-specific probabilities could vary by a factor of ten. Nor does the DGEIS provide examples of sites that would have higher or lower probabilities, or explain how or if the probabilities reported in NUREG-1738 conservatively bound the range of accident probabilities.

Heavy load drop events

For the cask drop event, NUREG-1738 bases the calculation of the probability of pool failure on Navy data and NUREG-0612 heavy loads evaluation (US-NRC 1980). For single failure-proof system, the frequency of catastrophic pool failure is 2×10^{-7} events per year. The frequency of catastrophic pool failure for non-single failure-proof system is 2.1×10^{-5} events per year, which exceeds the proposed pool performance guideline of 1×10^{-5} events per year. US-NRC believes that the frequency of pool failure can be reduced by performing a comprehensive and rigorous load drop analysis. For this reason, NUREG-1738 (Table 3.1, p. 3-9) and DGEIS quote the probability of cask drop as 2×10^{-7} events per year and ignores the calculation of the probability of cask drop for non-single failure-proof system. The US-NRC needs to show how the load drop analysis will change the human error rate calculation and reduce the frequency of cask drop events.

In addition, the calculation presented on page 3-17 of NUREG-1738 is unclear.

For the single-failure-proof handling system, the load drop frequency is $9.6 \times 10^{-6} \text{ y}^{-1}$ and the catastrophic failure is $2 \times 10^{-7} \text{ y}^{-1}$, for a ratio of $2.08 \times 10^{-2} = 0.13 \times 0.16$. This matches the description given in the text.

For non-single-failure-proof handling system the frequency of load drop is $3.4 \times 10^{-4} \text{ y}^{-1}$ and the mean value for the catastrophic failure rate is $2.1 \times 10^{-5} \text{ y}^{-1}$. The ratio is 6.2×10^{-2} catastrophic failure per transfer. How US-NRC arrived at this value is not clear.

3.3.2 Summary

According to the DGEIS, the dominant events for rapid drain down of a spent fuel pool are seismic events (5.8×10^{-7} to 2.4×10^{-6} events per year) and heavy load drop (2×10^{-7} events per year). However, the details of the analysis show that the seismic risk could be up to ten times higher at specific sites and the heavy load drop frequency is calculated to be higher than the pool performance guideline for non-single failure-proof system.

The DGEIS argues that the probabilities calculated in NUREG-1738 are conservative because post-September 11 and post-Fukushima measures have been and are being implemented at nuclear plants. As discussed above, the DGEIS does not specify what measures have been implemented at which plants. Because some of the measures are not mandatory or only apply to specific plants, any reduction in risk will differ on a plant-by-plant basis. The DGEIS does not quantify what the reduction in spent fuel pool fire risk would be, either in general or on a plant-by-plant basis.

3.4 Consequence assessment

The consequence assessment presented in Appendix F of the DGEIS and the Spent Fuel Pool Consequence Study (US-NRC 2013b) is based on CRAC2 calculations (1989), MACCS calculations (1997), and MACCS2 calculations (2001). The most detailed set of data comes from NUREG-1738 (US-NRC 2001) and is based on MACCS2 calculations.

The following subsections discuss the atmospheric and liquid releases assumed in the DGEIS and the Spent Fuel Pool Consequence Study for the purpose of calculating accident consequences. The following subsections also discuss the key MACCS2 input parameters used in the Consequence Study to determine the total offsite cost of a spent fuel pool accident.

3.4.1 Atmospheric releases

DGEIS Appendix F reports the results of previous US-NRC studies of consequences of atmospheric releases from one type of spent fuel pool accidents, spent fuel pool fires. These results are summarized in DGEIS Table F-1 (p. F-4), reproduced below in Table 1.

Table 1: Spent Fuel Pool Accident Probability and Consequences

Study	Accident frequency (per year)	Individual risk per event		Total person-Sv per event (50 mi)	Collective early fatality per event (10 mi)	Latent fatality (0 – 500 mi)	Total onsite and offsite economic (M\$ per event)
		Early fatality (1 mi)	Latent fatality (10 mi)				
NUREG-1738 (hi Ru)	5.8×10^{-7} – 2.4×10^{-6}	4.68×10^{-3} – 4.43×10^{-2}	6.39×10^{-2} – 8.49×10^{-2}	1.34×10^5 – 2.37×10^5	< 1 – 191	-	-
NUREG-1738 (lo Ru)		1.63×10^{-3} – 1.27×10^{-2}	1.29×10^{-2} – 1.88×10^{-2}	4.72×10^4 – 5.58×10^4	< 1 – 2	2.0×10^4 – 2.7×10^4	-
NUREG-1353	2×10^{-6}	-	-	2.6×10^5	-	-	5.57×10^4
NUREG/BR-0184	-	-	-	2.6×10^5	-	-	5.78×10^4

The only consequences the DGEIS compares to quantitative risk criteria (discussed in Sections 2.4.1 and 2.4.2 above) are the early and latent fatalities under the individual risk per event, listed in the third and fourth columns of Table 1.

The calculation of the societal risk quantities, including collective dose, collective early fatality, and latent fatality, as well as total economic costs is heavily dependent on the population density surrounding a particular site. The values in Table 1 were all calculated for the Zion site, using a population density of 860 people per square mile surrounding the site, as reported in US-NRC's 1996 GEIS for License Renewal. Zion's population density is not representative of some sites such as Indian Point, which had a population density of "almost 2000 persons per square mile," as reported in US-NRC's 1996 GEIS for License Renewal (US-NRC 1996, p. 2-2 to 2-8). Because Indian Point is surrounded by more than double the population density of Zion, the accident consequences would most certainly be significantly higher for Indian Point than the consequences reported for Zion in Table 1. The DGEIS does not discuss differences in population density among sites, or calculate the effect those differences would have on the consequence calculations.

Table F-2 (p. F-8) of the DGEIS presents a comparison of frequency-weighted consequences from severe reactor accidents and spent fuel pool fires. For spent fuel pool fires, Table F-2 multiplies the consequences presented in Table 1 by the average frequency for accident presented in Table 1, to produce frequency-weighted consequences. Multiplying the average values for the frequency and the consequences is acceptable if the probability distributions are un-correlated (see elaboration provided in Annex A). If the same plants that have a higher frequency of severe earthquakes also have the highest density of population around the site, the values calculated in Table F-2 of the DGEIS may under-represent the average risk.

US-NRC should calculate the correlation coefficient between the frequency of seismic events for the Zion site and the density of the population around the Zion site and use this correlation coefficient to correct the frequency-weighted probabilities presented in Table F-2 of the DGEIS. Alternatively, the US-NRC should calculate the collective dose-risk and the economic cost-risk for each site and re-calculate the average.

3.4.2 Liquid releases

One of the lessons learned from the Fukushima accident is that mitigation measures that stop the progression of a severe accident may have clear benefits in the short term, but may create longer term hazards from liquid or aqueous releases to the environment.

At Fukushima, the emergency workers pumped water into the damaged reactors. This water became contaminated on contact with the damaged fuel elements, and leaked out into the basement of the reactors.

The employees of TEPCO also pumped water into the spent fuel pools to compensate for evaporation and boil-off. In the days following the accident, the pumping was successful because the spent fuel pools remained intact, the spent fuel rods were not damaged, and the spent fuel pools did not leak contaminated water into the environment (TEPCO 2013). This event shows the importance of additional measures to cool the fuel since this is what averted further releases.

Within weeks after the accident, however, it became clear that the water pumped into the reactors was leaking into the Pacific Ocean. Within a month, TEPCO started to pump the contaminated water into tanks to store the contaminated water on-site, in an attempt to prevent more contaminated water from leaking into the ocean. Even with those storage tanks, some contaminated water still leaked into the ocean. According to TEPCO, as of 2013, the activity that flowed into the ocean was roughly estimated as 7×10^{11} to 1×10^{13} Bq (27 to 540 Ci) for strontium and 1×10^{12} to 2×10^{13} Bq (19 to 270 Ci) for cesium, respectively.

In addition to the water pumped into the reactors at Fukushima, ground water that would normally drain into the ocean is contaminated when it migrates through the reactor buildings. TEPCO had to build wells to intercept this ground water before it became contaminated. By October 2013, there were several hundred tanks holding some 340 000 tons of contaminated water. In 2013, more tanks are still added daily and TEPCO plans a total tank capacity of 800 000 tons by 2016. TEPCO is currently commissioning cesium removing equipment (SARRY – Toshiba, KURION – USA, and AREVA – France), plus a water treatment plant (Advanced Liquid Processing System) to decontaminate this water. The cost of managing the liquid releases has been very high. Japan has pledged \$475 million to build an ice wall and processing plant to stop radioactive water from contaminating the ocean (Wall Street Journal 2013).

Although two and a half years have passed since the Fukushima accident, radioactive water continues to flow into the ocean (New York Times 2013).

Thus, the unfolding experience at Fukushima shows that liquid or aqueous releases caused by a severe accident can have a significant environmental impact, resulting in health and economic consequences that should be addressed in the DGEIS's discussion of severe spent fuel pool accident impacts. If water is added to spent fuel pools at a sufficient rate early in the severe accident event, it may be possible to avoid damaging the spent fuel rods and minimize the amount of contaminated water leaking into the environment. On the other hand, if water is added after the onset of fuel damage, or after a spent fuel pool fire, the water leaking out of the spent fuel pool will be heavily contaminated. For the more severe events, where on-site infrastructure is damaged, it may take months before remediation measures such as construction of storage tanks,

pump and treat, diversion, or containment can be put in place. The DGEIS should contain a discussion of how aqueous releases can occur during a severe accident, and the potential consequences of aqueous releases during a severe accident, given the unfolding experience at Fukushima.

The MACCS2 code does not model “aqueous release pathways.” NRC Regulatory Information Conference (RIC) International Session - Post-Fukushima Research, NRC Office of Nuclear Regulatory Research (March 13, 2013) slide 7; see *also* Certified Minutes of the ACRS Reliability and PRA Subcommittee Meeting on Level 3 PRA on December 4, 2012 (ML13211A477). The DGEIS should acknowledge this limitation of the code, and discuss options for determining and mitigating the effects of aqueous releases.

Since hydrological and geological properties vary from site to site, as does the proximity of sites to bodies of water and the configuration of the reactor(s) and spent fuel pool(s), the consequences of contaminated water leaking into ground water and surface water should be assessed on a site-specific basis.

3.4.3 MACCS2 input parameters to determine offsite cost

The MELCOR Accident Consequence Code System 2, or MACCS2 code, is the computer model generally used in the U.S. for calculating the consequences of a severe accident. MACCS2 is a Gaussian plume model for calculation of radiological atmospheric dispersion and consequences, developed by Sandia National Laboratories. The MACCS2 code is the latest in a series of computer modeling tools developed to evaluate impacts of severe accidents at nuclear power plants on the surrounding public. MACCS2 was released in 1997 and developed as an improved version of the MACCS code, which itself replaced the earlier CRAC2 code.

The MACCS2 code simulates the atmospheric release of radioactivity, the direction, speed of travel, and dispersion (spread and dilution) of the plume based on meteorological inputs; and ultimately, MACCS2 calculates radiological health and economic impacts. It can model, among other things, the offsite population dose and the offsite economic costs of an accident.

The MACCS2 code evaluates several major factors which contribute to the costs of a severe nuclear accident. For example, MACCS2 evaluates release characteristics, weather pattern, population profile, clean-up costs, and other factors which affect the cost of a severe accident. MACCS2 is executed in three steps. The first module, ATMOS, calculates air and ground concentrations, plume size, and timing information for all plume segments as a function of downwind distance. The next module, EARLY, calculates the consequences due to exposure to radiation in the first seven days, which is the emergency phase of the accident. The last module, CHRONC, calculates the consequence of the long-term effects of radiation and computes the decontamination and economic impacts incurred due to the accident.

As discussed above, the DGEIS reports the quantitative consequence assessments performed in NUREG-1738 and references cited therein. NUREG-1738 relies upon the MACCS2 economic cost input parameters from NUREG-1150.

The Spent Fuel Pool Consequence Study (US-NRC 2013b) reports its own

consequence calculations based on MACCS2 runs US-NRC Staff performed in November 2012. The central purpose of the Consequence Study is to determine whether it is cost-beneficial to expedite the transfer of spent fuel from high-density spent fuel pools to dry storage casks by analyzing the probabilities and consequences of severe accidents originating from a spent fuel pool. The Consequence Study uses the Peach Bottom site as a reference case, so the frequencies and consequences reported in the study are for that site and the population density surrounding it.

The total offsite cost of a given spent fuel pool accident can be calculated by:

$$\text{Total offsite cost} = \text{cost equivalent of the offsite population dose} + \text{offsite economic cost}$$

The key MACCS2 input parameters that dictate the population dose and economic cost are discussed below. Where information exists, the corresponding values chosen in the Consequence Study are analyzed in terms of their origin and appropriateness as a site-independent value. Like NUREG-1738, which is reported in the DGEIS, the Consequence Study also used many MACCS2 economic cost input parameters from NUREG-1150.

NUREG-1150 reported economic cost inputs that were included in an example problem, Sample Problem A, in the MACCS2 User Guide. The NUREG-1150 authors chose five commercial nuclear plants of different design to estimate the risks of a severe accident. One of these, the Surry reactor, is a Westinghouse designed three-loop pressure water reactor in a large, dry containment building located near Williamsburg, Virginia. Thus, the NUREG-1150 values incorporate site-specific information for the Surry site. Neither the MACCS nor MACCS2 documentation suggests that the input values of the code sample problems be considered recommended or default values.

Population and meteorology

Two of the most important site-specific parameters in the MACCS2 input data are the population and meteorology. There is a direct correlation between these parameters and the offsite population dose and economic costs.

The offsite economic cost is calculated by multiplying the per capita parameters (e.g., VALWNF, CDNFRM, POPCST) by the population to which the mitigative action (e.g., condemnation, decontamination, interdiction respectively) is applied. Thus, in general, the total economic cost is directly proportional to the population.

The wind rose (i.e., probability of wind directions) of the site has a direct correlation to the probability of certain areas being contaminated in the event of a severe accident and thus requiring mitigative actions. In the Consequence Study, the reference plant Peach Bottom's wind rose was such that the predominant wind directions were towards lower population areas (US-NRC 2013b, Section A.2). By comparison, the predominant wind directions at the Indian Point site are to the North/North-Northwest and to the South; the latter would affect the New York City metropolitan area, one of the most populated areas in the U.S (see Figure 2 below, showing the highest population concentrations surrounding Indian Point and the wind rose).




Figure 2: Population and wind rose for the Indian Point site. LEFT - Population by grid element (darker colors represent higher population) (ML13073A555 at p. 2-7), RIGHT – Wind rose for years 1999-2002 (ML12334A743).

The impact of the wind rose at the reference plant Peach Bottom is acknowledged by the authors of the Consequence Study:

“Thus, if a release were to occur [at the reference plant Peach Bottom], it is more likely that a relatively small population would be affected than if the release occurred at a facility near a major city” (US-NRC 2013b, Section A.2).

As detailed in Section C.2.12 of COMSECY-13-0030, which adopts the Consequence Study, a sensitivity analysis was carried out as part of the Consequence Study to analyze the effect of population density on the offsite consequences. A summary of this analysis is shown in Table 2 below. The COMSECY contains the following warning regarding the Consequence Study’s results:

“...the results are not representative of any specific site because site specific meteorology for these sites is not used.” (US-NRC 2013a, p. 99)

Despite this disclaimer, the conclusion of the COMSECY’s sensitivity analysis is that population density is not a key parameter, i.e., US-NRC has decided that population density is not a variable that can significantly affect consequence calculation results (US-NRC 2013a, p. 21).

Because many plants are located in low population areas, Peach Bottom’s population may be representative of some plants. Given the combination of Indian Point’s population and predominate wind direction, the results of US-NRC’s Peach Bottom analysis are not applicable to Indian Point. As shown in Figure 3 below, the population density within 50 miles of the Indian Point site is far greater than even those considered in the Consequence Study’s sensitivity analysis.⁷ With the combination of higher population and a dominant wind direction toward the most populated areas, it is reasonable to expect that the consequences to the public surrounding Indian Point may

⁷ The population density within 50 miles of the Indian Point site is derived from the 2010 census data presented in reference (US-NRC 2012b).

be over 100% greater than the base case used in the Consequence Study. This increase is equally applicable for the calculation of economic costs, which does not appear to be included in the sensitivity analysis for population density.

There are several factors that must be considered alongside a significantly larger population, such as those who reside within 50 miles of the Indian Point reactor; building density is one such factor. With a larger building density than that of the reference site used in the Consequence Study, there are many more surfaces in urban environments that effectively deplete the amount of contamination in an airborne plume. This results in higher levels of contamination and thus greater radiological and economic costs (e.g., the cost of decontamination). Annex B provides a discussion of surface roughness as it relates to deposition velocity of radioactive particulate in urban environments.

Table 2: Summary of the population density sensitivity analysis (US-NRC 2013a)

Case	Statistical parameter	Representative site	Average 2010 population density within 50 miles	Net percent change in public health from the base case
High estimate	90 th percentile	Peach Bottom	722	25% - 28% increase
Mean estimate	Mean	Surry	303	No change
Median estimate	Median	Palisades	183	21% - 37% decrease
Low estimate	20 th percentile	Point Beach	102	67% - 73% decrease




Figure 3: Comparison of population densities

Offsite population dose

The majority of the MACCS2 input parameters related to the calculation of population dose are site-independent, and are based on guidance published in:

- NUREG/CR-7009: MACCS2 Best Practices as Applied in the State-of-the-Art Reactor Consequence Analyses Project (expected to be published in 2013)
- NUREG/CR-7161: Synthesis of Distributions Representing Important Non-Site-Specific Parameters in Off-site Consequence Analyses
- NUREG-1935: State-of-the-Art Reactor Consequence Analyses (SOARCA) research project
- NUREG/CR-6613: Code Manual for MACCS2 User's Guide
- NUREG-1150: Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants

The Consequence Study employed a factor of \$2,000/person-rem to convert the offsite collective dose to a monetary value. This factor was obtained from NUREG-1530: Reassessment of NRC's Dollar per Person-Rem Conversion Factor Policy. Due the uncertainty of this value, and based on recently updated ICRP risk coefficients, a sensitivity analysis that incorporates a values of \$4,000/person-rem is carried out in the Consequence Study (Section D.3.3.2).

Offsite economic cost

Aside from population and wind rose, the most sensitive MACCS2 input parameters in determining the total economic cost are listed below with the most sensitive parameter listed first. This list was the result of ISR's sensitivity analysis of all parameters used in the CHRONC (i.e. long-term phase) module of the MACCS2 code.

- 1) GWHLF – Long-term groundshine coefficients
- 2) DSCRLT – Long-term phase dose criterion (Sv)
- 3) VALWNF – Value of nonfarm wealth (\$/person)
- 4) TMPACT – Time action period ends (seconds)
- 5) DSRATE – Societal discount rate for property (/year)
- 6) FRNFIM – Nonfarm wealth improvements fraction
- 7) TGWHLF – Groundshine weathering half-lives (seconds)
- 8) DPRATE – Property depreciation rate (/year)
- 9) POPCST – Per capita cost of long-term relocation (\$/person)
- 10) CDNFRM – Nonfarm decontamination cost (\$/person)
- 11) TIMDEC – Decontamination times (for all decontamination levels) (seconds)

In the Consequence Study, US-NRC adopted the values for the groundshine parameters, GWHLF and TGWHLF, from the guidance it published. These groundshine parameters are radionuclide-specific, calculated from first physical principles and are not time or location-dependent.

The Consequence Study includes a sensitivity analysis of the habitability criterion, which is the combination of input parameters DSCRLT and TMPACT (US-NRC 2013b, Section D.3.2.2.8). The Consequence Study reports a range of possible values and the corresponding impact on the results.

The Consequence Study's value of nonfarm wealth (VALWNF) includes all public and private property not associated with farming that would be unusable if the region was rendered either temporarily or permanently uninhabitable. This value includes the cost of land, buildings, infrastructure, and the cost of any non-recoverable equipment or machinery (MACCS2 manual). The value chosen for the Consequence Study, which uses the Peach Bottom site as the reference case, is \$210,000/person (2012 USD). By its definition, this value is site-specific. As a comparison, in its submission for a licence renewal for Indian Point Units 2 and 3, the operator of the Indian Point reactors, Entergy, calculated VALWNF to be \$209,000/person (2004 USD) for the site. Entergy's value is approximately \$250,000/person in 2012 USD, which is 20% higher than the value used in the Consequence Study. As a further comparison, the corresponding value for VALWNF deemed appropriate in ISR Report 13014-01-01 is approximately \$284,000/person (2004 USD).⁸ In 2012 USD, this equates to \$345,000/person, which is 64% higher than the value used in the Consequence Study.

The Consequence Study based the parameters DSRATE, FRNFIM, and DPRATE on guidance published in WASH-1400 and NUREG/CR-4551. Given the limited range of these values (i.e., between 0 and 1), and the large uncertainty associated with them, the study's choice of these values is likely reasonable and appropriate.

The Consequence Study's per capita cost of long-term relocation (POPCST) takes into account both personal and corporate income losses, as well as moving expenses, for a transitional period. The value chosen for the Consequence Study is \$12,000/person (2012 USD). This value is site-specific. For example, in the state of New York, the average per capita income is approximately \$32,000 (2011 USD). Using an interdiction period of 140 days as recommended in NUREG/CR-4551, the total amount of lost wages is \$12,500/person (2012 USD). With the addition of corporate income losses and moving expenses, this amount for Indian Point is expected to be higher than the value used in the Consequence Study.

The cost and time for decontamination, CDNFRM and TIMDEC respectively, are entered for two levels of decontamination in the Consequence Study: light and heavy decontamination. Light decontamination generally refers to the removal of approximately one-half to two-thirds of the contamination; heavy decontamination generally refers to the removal of over 90% of the contamination, often using much more intensive and possibly destructive methods. The costs entered for each decontamination level are \$7,110/person and \$19,000/person respectively. These values are obtained from NUREG/CR-7009 and are deemed to be consistent with both NUREG-1150 and NUREG-1935 (US-NRC 2013b, Section 7.1.5). Section 3.4.4 provides an examination of the ultimately unsubstantiated analyses that led to the determination of CDNFRM in NUREG-1150.

In the Consequence Study, the decontamination time for both decontamination levels is entered as one year. The selection of one year differs from the decontamination times used in NUREG-1150 of 60 and 120 days for light and heavy decontamination, respectively. The Consequence Study does not explain why one year was selected instead of 60 and 120 days. In any event, decontamination time is also site-specific and the decontamination efforts required particularly for urban areas could increase the

⁸ Appropriate value for Indian Point derived from ISR Report 13014-01-01: Review of Indian Point Severe Accident Off Site Consequence Analysis (Dec. 21, 2011) (ML12334A761) as modified in Revisions to Tables in ISR Report 13014-01-01 (Jun. 28, 2012) (ML12340A648).

decontamination time beyond one year. Furthermore, the Consequence Study should have discussed and considered the unfolding experience of decontamination following the 2011 Fukushima accident. As of the date of this report (December 2013), the Fukushima decontamination has not been completed even though two and a half years have passed since the accident occurred. Indeed, it is expected to take several more years. Thus, it is questionable to use one year for the TIMDEC input for both light and heavy decontamination in the Spent Fuel Consequence Study MACCS2 analysis; the decision to use one year should be explained and substantiated.

3.4.4 NUREG-1150 cost of decontamination for non-farmland

Nonfarm Decontamination Cost (“CDNFRM”) is a MACCS2 input that defines the cost of decontaminating land that is not farmland. MACCS2 requires the user to input a CDNFRM value in dollars per person for each dose reduction factor specified by the user. NRC has used NUREG-1150 values, adjusted for inflation using the Consumer Price Index, as CDNFRM inputs.

NUREG-1150, however, contains a gaping hole—the source of the decontamination cost parameters in NUREG-1150, and thus the source of the decontamination cost parameters used in Sample Problem A, simply does not exist. Neither NUREG-1150 itself nor its companion, NUREG/CR-4551, explain how the Sample Problem A costs were obtained. NUREG/CR-4551 cites NUREG/CR-3673, as a reference for the Sample Problem A decontamination cost values, but NUREG/CR-3673 states only that:

“The cost estimates used in this study for various levels of decontamination effort in an area are taken from a detailed review of decontamination effectiveness and costs performed at Sandia National Laboratories (SNL) [Os84].”

“Os84” is listed as “Ostmeyer, R.M., and G.E. Runkle, An Assessment of Decontamination Costs and Effectiveness for Accident Radiological Releases, Albuquerque, N.M.: Sandia National Laboratories, *to be published*,” in NUREG/CR-3673’s references section. NUREG/CR-3673 at p. 8-8 (emphasis added). The Os84 document does not exist, at least in any available form. Os84 appears to have never been published, nor peer-reviewed.

Even if Os84 did still exist, the author of NUREG/CR-3673 (which cites to Os84) made it clear that these were tentative results:

“Little data exist which are directly applicable to the small particle sizes (0.1-10 μm) and soluble materials which are anticipated in releases from the LWR accidents. The cost and effectiveness estimates for decontamination contain large uncertainties, and results of future experimentation with decontamination techniques should be used to update models for decontamination.” (NUREG/CR-3673 at p. 4-15)

No one knows the origin of the NUREG-1150 decontamination cost values, other than a cryptic description that they were based upon “national average statistics.” NUREG/CR-3673 at p. 4-17. Public comments on a draft of NUREG-1150 state “Decontamination costs used in the calculations may be based on *decontamination of test sites in deserts* instead of agricultural, residential, and commercial property.” NUREG-1150 at D-32.

The comments received on a draft of NUREG-1150 suggest that its authors expected that site-specific estimates of decontamination costs would be developed. NUREG-1150 states:

“[PUBLIC] COMMENT: The models used in calculating the cost of a severe accident lack many factors that should be taken into account. Many of the assumptions are questionable and unfounded. The models have not been benchmarked. Some interpretations and conclusions that were made in draft NUREG-1150 are questionable. The cost estimates need to be more thoroughly documented to understand and evaluate the calculations.

[NRC] RESPONSE: The present version of NUREG-1150 provides a limited set of risk-reduction calculations, principally related to the potential benefits of accident management strategies in reducing core damage frequency. It does not assess the cost of these or other improvements. Such analyses are more properly considered in the context of specific regulatory action.

* * *

[PUBLIC] COMMENT: Decontamination costs used in the calculations may be based on decontamination of test sites in deserts instead of agricultural, residential, and commercial property.

[NRC] RESPONSE: The draft NUREG-1150 cost/benefit analyses reflected the conventional NRC methods for assessing costs and benefits. Because cost/benefit analyses are more properly considered in the context of specific regulatory activities, they are not provided in this version of NUREG-1150.”

These comments support the notion that reliance on Sample Problem A instead of developing site-specific inputs is unreasonable.

In the 1980s, NRC commissioned a site-specific case study to estimate the costs associated with a severe accident at Indian Point—Tawil 1990. NUREG/CR-5148, Chapter 5 (Tawil 1990). The results of Tawil 1990 show that NRC has actually conducted a site-specific analysis of the decontamination costs associated with a severe accident at Indian Point, without using NUREG-1150 values, and, therefore, without relying upon Sample Problem A.

Unlike the generic NUREG-1150 values that provide the MACCS2 code with two decontamination costs, one for land that’s farmland and land that’s not farmland, Tawil 1990 contains detailed analysis of land use and decontamination techniques to produce site-specific decontamination costs. The following table, Figure 4, lists Tawil 1990’s analysis of surface types *for a single grid element* that lies in Westchester County with a population of just over 1,000 and a “pre-accident real property value estimated at \$65 million” (*Id.* at 4.32). Tawil 1990 explains each column and each surface description in detail (*Id.* at 4.32 – 4.35). Tawil notes that “although this particular report applies to a grid element, a similar report can be generated for an exposure area” (*Id.* at 4.32).

DETAILED SURFACE RESULTS FOR GRID ELEMENT B, FOR PERIOD 30.

*** EXTERNAL PATHWAY ***

SURFACE	AREA (ha) 1/	EXPOSURE (Sv)	METH 2/ 3/	RESIDUAL (Sv)	AVG.COST (\$/ha)	TOT.COST (\$)	RATE (m**2/hr)
AGRICULTURAL FIELDS	5.91E+00	9.63E+00	Tx	5.39E-02	9.14E+04	5.40E+05	8.75E+02
ORCHARDS	2.90E-01	9.63E+00	TRx	9.24E-02	1.24E+05	3.60E+04	9.80E+01
VACANT LAND	3.42E+01	9.63E+00	TNx	5.39E-02	1.34E+05	4.59E+06	5.20E+01
WOODED LAND	2.54E+01	9.63E+00	T ~	8.67E+00	1.21E+04	3.07E+05	5.60E+03
ASPHALT STRTS/PRKNG	8.70E+00	9.63E+00	vCF	1.58E-01	2.11E+04	1.84E+05	4.30E+03
OTHER PAVED ASPHALT	5.88E-01	9.63E+00	vCF	1.58E-01	2.19E+04	1.29E+04	2.15E+03
CNCRETE STRTS/PRKNG	6.08E+00	9.63E+00	vCF	1.58E-01	2.11E+04	1.29E+05	4.30E+03
OTHER PAVED CNCRETE	2.35E+00	9.63E+00	VC #	1.85E-01	2.04E+04	4.79E+04	2.15E+03
LAWNS	5.03E+01	9.63E+00	R	1.93E-01	1.42E+05	7.13E+06	4.00E+01
RESERVOIRS	9.53E+00	9.63E+00	rxr	1.54E-01	9.38E+04	8.94E+05	6.56E+02
ROOFS	8.16E+01	9.63E+00	R	9.63E-02	4.71E+05	3.85E+07	2.40E+01
EXT. WOOD WALLS	1.17E+01	9.63E-01	W	1.44E-01	2.43E+03	2.84E+04	2.03E+02
EXT. BRICK WALLS	2.48E+00	9.63E-01	W	1.44E-01	2.43E+03	6.04E+03	2.03E+02
EXT. CONCRETE WALLS	1.54E+01	9.63E-01	W	1.06E-01	2.43E+03	3.75E+04	2.03E+02
INT'R WOOD/PL WALLS	3.69E+01	4.81E-01	V	2.41E-02	4.76E+03	1.76E+05	6.90E+01
INT'R CONCRETE WALLS	7.58E+00	4.81E-01	V	1.69E-01	4.76E+03	3.61E+04	6.90E+01
CARPETED FLOORS	7.22E+00	4.82E+00	VTR	2.60E-02	4.41E+05	3.19E+06	3.70E+00
LINOLEUM FLOORS	8.56E+00	4.82E+00	v	1.81E-01	9.52E+03	8.14E+04	6.90E+01
WOOD FLOORS	2.03E+00	4.82E+00	vF	1.73E-01	3.13E+04	6.35E+04	4.00E+01
CONCRETE FLOORS	1.17E+01	4.82E+00	vF	1.85E-01	3.13E+04	3.66E+05	4.00E+01
HARD-SURF FURNSHNGS	3.56E+03	4.82E+00	VR	1.44E-01	2.02E+04	7.21E+07	8.00E-03
SOFT-SURF FURNSHNGS	2.42E+03	4.82E+00	VR	6.50E-02	4.49E+03	1.09E+07	1.59E-01
ELECTRONIC EQUIP	3.97E+03	4.81E-01	V	1.69E-01	1.99E+02	7.90E+05	2.19E-01
PAPER PRODUCTS	3.78E+03	9.63E-01	k	1.93E-02	1.95E+03	7.35E+06	1.50E-01
AUTO EXTERIORS	8.91E+02	9.63E+00	TJJ	6.93E-02	4.82E+02	4.30E+05	2.50E-01
AUTO INTERIORS	8.91E+02	2.89E+00	Vz	8.67E-02	7.60E+02	6.77E+05	1.25E-01
AUTO TIRES, (PER 4)	8.91E+02	9.63E+00	R	9.63E-03	3.19E+02	2.84E+05	1.00E+00
AUTO ENG/DRV TRAIN	8.91E+02	9.63E+00	IEE	1.01E-01	2.56E+02	2.28E+05	1.00E+00

NOTES:
 1/ Area measures do not apply to autos and building contents; values are the number of automobiles and the number of building contents units.
 2/ --- = Decontamination not required /// = Unable to decontaminate surface
 3/ + = Method is required \ = Restricted operation is in effect
 Quick-Vac: # = in effect * = w/restricted operation ~ = w/required method

Figure 4: Detailed surface analysis report (Tawil 1990, p. 4.33)

Tawil 1990 supports a detailed, site-specific approach that takes into account the land use in great detail. For example, in urban areas—unlike the rural Virginia area used to create NUREG-1150—the cost of decontaminating the contents of a building can exceed the cost of decontaminating land and structures (Tawil 1990 Figure 4.3, at 4.26 - 4.28). Additionally, Tawil 1990 makes the point that decontaminating building contents is labor intensive and labor costs constitute a large portion of the cost of decontamination (Tawil 1990 at 2.8 - 2.71).

4. RELEVANCE FOR INDIAN POINT

This section discusses the relevance of the findings on the impact on the environment of spent fuel pool storage for the Indian Point site.

4.1 Configuration of Spent Fuel Pool

The DGEIS assumes that the generic spent fuel pool described in Section 2 of the DGEIS is representative of most spent fuel pools. The US-NRC has adopted as its reference spent fuel pool, one that has 700 MTU storage capacity that reaches its licensed dense storage capacity limit in about 35 years into licensed life for operation of a reactor.

The total capacity of the spent fuel pools at Indian Point Unit 2 and Unit 3 is 1374 and 1375 fuel assemblies. Using 0.45 MTU per assembly, this is equivalent to about 620 MTU per pool, which is comparable to the reference spent fuel pool.

Since 2004, IP-2 has a single failure proof spent fuel pool gantry crane (Entergy 2004), therefore the analysis for the probability of a cask drop event contained in NUREG-1738 is directly applicable. A similar upgrade to the IP-3 cask handling crane was evaluated and found to be not feasible, therefore the spent fuel from the IP-3 spent fuel pool is transferred to the IP-2 spent fuel pool before being loaded into casks (NRC 2012a).

The DGEIS uses the risk assessment from NUREG-1738, which relies on a series of Industry Decommissioning Commitments (IDC) and Staff Decommissioning Assumptions (SDA) that are spelled out and are assumed to apply generically to all plants (US-NRC 2001, p. 4-11 and 4-12).

Since Indian Point Unit 2 and 3 have not been decommissioned, it is not known which of these assumptions are actually met in the operating plants. The consequences of not meeting these assumptions should be spelled out in the DGEIS.

4.2 Seismicity

The DGEIS uses an average site seismicity corresponding to a frequency of exceeding 1.2 g of 2×10^{-7} per year to 2×10^{-6} per year. The actual frequency of exceeding 1.2 g at the Indian Point site is not quoted in the DGEIS or NUREG-1738; although the data shown in Figure 10 of COMSECY-2013-0030 (p.81) suggests that this frequency is greater than 2×10^{-6} per year. The recent US-NRC GI-199 report (US-NRC 2010, p. B-7) reports the safe shutdown earthquake, $SSE_{PGA} = 0.15$ g for the Indian Point site, and the high confidence of a low probability of failure, $HCLPF_{PGA} = 0.3$ g for IP-2 and 0.15 g for IP-3. The safe shutdown earthquake is the largest earthquake that must be considered in the design. The high confidence of a low probability of failure earthquake takes into account the fragility of the plant.

Chapter 9 of the IP2 and IP3 Final Safety Analysis Reports (FSARs) indicates that the SFP structures are classified as Seismic Category I. The IP2 FSAR is specific regarding the design criteria, and indicates that the IP2 SFP was designed in accordance with the provisions of American Concrete Institute (ACI)-318, "Building Code Requirements for

Reinforced Concrete" (see Section 9.5.2.1.4 of the IP2 FSAR). The 1989 license amendment issued for IP3 SFP re-rack indicates that the design criteria used to evaluate the SFP structure are based on the provisions in ACI 349-80, "Code Requirements for Nuclear Safety-Related Concrete Structures."

Based the classification of these structures indicated above, they are required to be designed against bounding loading combinations which include loads due to a safe shutdown earthquake. As such, the structural analyses are performed to ensure that the SFPs will remain functional during and after a safe shutdown earthquake (Boska 2011).

4.3 MACCS2 Input Parameters

Section 3.4.3 of this report discusses the importance of various MACCS2 input parameters in determining the offsite population dose cost and offsite economic cost following a severe accident at a spent fuel pool. The following table summarizes those input parameters and values used in the Consequence Study that are site-specific to the Peach Bottom reference plant and compares them to appropriate values for Indian Point.

Table 3: Summary of site-specific MACCS2 input parameters relevant to Indian Point

Parameter	Value used in the Consequence Study reference site	Minimum appropriate value for the Indian Point site	Minimum Ratio (Indian Point/reference site)	Applicable to the population dose cost	Applicable to the economic cost
Population within a 50-mile radius	5.7 million	17 million	3.0	Yes	Yes
Predominant wind direction	Towards lesser populated areas	Towards heavily populated areas	N/A	Yes	Yes
Value of nonfarm wealth (2012 USD)	\$210,000/person	\$345,000/person*	1.6	No	Yes
Relocation costs (2012 USD)	\$12,000/person	\$12,500/person*	1.04	No	Yes
Cost of decontamination (DF=3,15) (2012 USD)	\$7,110/person \$19,000/person	\$17,630/person* \$83,500/person*	2.5 4.4	No	Yes
Time of decontamination (DF=3,15)	1 year (DF=3) 1 year (DF=15)	1 year (DF=3)* 2 years (DF=15)*	1 2	No	Yes

* The ISR Report and updated tables submitted in the context of the Indian Point relicensing proceeding provided a suggested range of appropriate values for each of these parameters. For the sake of simplicity, and for illustrative purposes in this DGEIS proceeding, only the minimum value is represented here in Table 3. Values were CPI-adjusted to 2012 USD. The reader is directed to ISR Report 13014-01-01: Review of Indian Point Severe Accident Off Site Consequence Analysis (Dec. 21, 2011) (ML12334A761) as modified in Revisions to Tables in ISR Report 13014-01-01 (Jun. 28, 2012) (ML12340A648) for a complete discussion of site-specific input parameters for Indian Point, which also include higher input values.

Furthermore, the DGEIS uses the population density around the Zion plant, 860 people per square mile, while the population density surrounding Indian Point is over 2100 people per square mile.

5. CONCLUSIONS

Based upon ISR's review of the DGEIS and supporting documents, US-NRC should address the following comments before finalizing the DGEIS:

1. Ensure that the conclusions of the DGEIS are based on actual practices and conditions at spent fuel pools at various sites around the U.S. Explicitly list and describe those sites that have spent fuel pools that do not meet an assumption or condition included in the DGEIS or documents relied upon by the DGEIS. The DGEIS should either employ conservative bounding or direct site-specific review for certain plants like Indian Point.
2. Develop a quantitative health risk acceptance criteria compatible with the Commission's Policy Statement regarding societal risk (in addition to the criteria for individual risk).
3. Analyze alternatives to mitigate the potential severe accident impacts. This should be done in a site-wide manner that integrates all hazards and corresponding risks that exist on the site (i.e., all reactor units and spent fuel pools are assessed in a single risk assessment). The DGEIS should either employ conservative bounding or direct site-specific review for certain plants like Indian Point.
4. Document explicitly how the assessment of event frequencies includes the contribution of seismic events to loss of offsite power and internal fire.
5. Show how the load drop analysis required for non-single failure proof cranes changes the human error rate calculation from 2.1×10^{-5} per year to 2×10^{-7} per year for cask drop events.
6. Revise the calculation of the societal risk-dose and the economic risk-cost to account for the possible correlation between the seismic risk and the population density.
7. Include an analysis of the impact of new monitoring, and post-accident response measures put in place for intentional, malevolent actions since 9/11 and the Fukushima event, listing which plants have implemented which measures and quantify how those measures affect risk.
8. Include an assessment of the environmental consequences and cost of liquid releases during a spent fuel pool accident, with specific reference to and discussion of the unfolding events at Fukushima.
9. Revise the MACCS2 consequence assessment to be conservative and bounding or make it site-specific and compatible with the current practices for severe accident mitigation alternative analyses for reactors. Include a re-assessment of the time and cost of decontamination for severe accidents, which are higher for areas with higher population densities.

REFERENCES

- [1] BNL 1957, Theoretical Possibilities and Consequence of Major Accidents in Large Nuclear power Plants, WASH-740.
- [2] Boska 2011, Email John Boska to John Kauffman, sent on Thursday, March 31, 2011 8:56 AM, ML11238A095).
- [3] Entergy 2004. Indian Point Unit 2, Fuel Storage Building Single-Failure-Proof Gantry Crane, June 16, 2004.
- [4] ICRP 2007, The 2007 Recommendations of the International Commission on Radiological Protection, ICRP 103.
- [5] New York Times 2013, *Memo From Japan With a Plant's Tainted Water Still Flowing, No End to Environmental Fears*, Martin Fackler & Hiroko Tabuchi, October 24, 2013.
- [6] Sandia 2006, Wagner K. C. and Gauntt R.O., Mitigation of Spent Fuel Pool Loss-of-Coolant Inventory Accidents And Extension of Reference Plant Analyses to Other Spent Fuel Pools, Sandia Letter Report, Revision 2 Completed November 2006 (ML090490559) (redacted by US-NRC).
- [7] Sandia 1990, J. L. Sprung, et al., Evaluation of Severe Accident Risks: Quantification of major input parameters -MACCS Input, Volume 2, Revision 1, Part 7, NUREG/CR-4551.
- [8] TEPCO 2013, online repository of information relating to remediation efforts following the Fukushima accident, <http://www.tepco.co.jp>.
- [9] US NRC 2013, Waste Confidence Generic Environmental Impact Statement, Draft Report for Comment, NUREG-2157, September 2013.
- [10] US-NRC 2013a, Staff Evaluation and Recommendation for Japan Lessons-Learned Tier 3 Issue on Expedited Transfer of Spent Fuel, COMSECY-13-0030, November 12, 2013.
- [11] US-NRC 2013b, Consequence Study of a Beyond-Design-Basis Earthquake Affecting the Spent Fuel Pool for a U.S. Mark I Boiling Water Reactor, Draft Report, June 2013.
- [12] US-NRC 2012, State-of-the-Art Reactor Consequence Analyses (SOARCA) Project, NUREG/CR-7110.
- [13] US-NRC 2012a, Transfer of Spent Fuel from Indian Point Unit 3 Spent Fuel Pool to Indian Point Unit 2 Spent Fuel Pool, Amendment of Technical Specifications, Finding of No Significant Impact, 77 Federal Register 414,554 (Friday, July 13, 2012).
- [14] US-NRC 2012b, Excel Spreadsheet, 2010 census v entergy estimate.xlsx (provided by Brian Harris to New York State Office of the Attorney General via email on April 12, 2012).
- [15] US-NRC 2010, Generic Issue 199 (GI-199), Implications of Updated Probabilistic

Seismic Hazard Estimates in Central And Eastern United States on Existing Plants Safety/Risk Assessment, August 2010.

- [16] US-NRC 2008, Classified Sandia Studies discussed in the Denial of Petitions for Rulemaking PRM-51-10 and PRM-51-12, 73 Federal Register 46,204.
- [17] US-NRC 2001, Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants, NUREG-1738, February 2001.
- [18] US-NRC 2001a, Policy Issues Related to Safeguards, Insurance, and Emergency Preparedness Regulations at Decommissioning Nuclear power Plants Storing Fuel in Spent Fuel Pools, SECY-01-0100.
- [19] US-NRC 1997, Regulatory Analysis Technical Evaluation Handbook, NUREG/BR-0184.
- [20] US-NRC 1997a, Operating Experience Feedback Reports, NUREG-1275.
- [21] US-NRC 1996, Generic Environmental Impact Statement for License Renewal of Nuclear Plants, NUREG-1437.
- [22] US-NRC 1990, Severe Accident Risks: An Assessment for Five Us. Nuclear Power Plants - Final Summary Report (Volume 1), Appendices A, B, and C (Volume 2), Appendices D and E (Volume 3), NUREG-1150.
- [23] US-NRC 1989, Regulatory Analysis for the Resolution of Generic Issue 82, "Beyond Design Basis Accidents in Spent Fuel Pools". U.S. Nuclear Regulatory. NUREG-1353, April 1989.
- [24] US-NRC 1989a, Severe Accident Risks: An Assessment for Five Us. Nuclear Power Plants (Second Draft for Peer Review) - Summary Report (Volume 1), Appendices (Volume 2), NUREG-1150.
- [25] US-NRC 1987, Reactor Risk Reference Document (Draft for Comment) - Main Report (Volume 1), Appendices A-I (Volume 2), and Appendices J-O (Volume 3), NUREG-1150.
- [26] US-NRC 1980, Control of Heavy Loads at Nuclear Power Plants, Resolution of Generic Technical Activity A-36, NUREG-0612, July 1980.
- [27] US-NRC 1975, Reactor Safety Study: An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants, WASH-1400.
- [28] Wall Street Journal 2013, Japan Unveils Strategy to Deal With Fukushima Daiichi Water Leaks Projects to Cost Around \$475 Million Include a Wall of Ice, Second Processing Plant to Filter Radioactive Particles, Mari Iwata & Toko Sekiguchi, September 3, 2013.

ANNEX A – AVERAGE RISK CALCULATED OVER ALL REACTOR SITES

When multiplying the average values of two probability distributions, such as the frequency F_i and the consequence C_i , the correct product is given by Equation A.1 since the covariance of F and C is the difference between the mean product and the product of the means:

$$\bar{R} = \bar{F} \times \bar{C} + Cov(F, C) \quad (\text{Equation A.1})$$

where:

$$\bar{F} = \frac{1}{N} \sum_{i=1}^N F_i \text{ is the average over all reactor sites of the frequency of an event}$$

$$\bar{C} = \frac{1}{N} \sum_{i=1}^N C_i \text{ is the average over all reactor sites of the consequences of an event}$$

$$Cov(F, C) = \frac{1}{N} \sum_{i=1}^N (F_i - \bar{F})(C_i - \bar{C}) \text{ is the covariance over all reactor sites}$$

Table A.1 below illustrates how neglecting the covariance term can bias the results. First, assume that two different reactor sites, A and B, have frequency and consequences that are perfectly correlated. This means that site A has a low frequency and low consequences and site B has a high frequency and high consequences. If the average frequency of these two sites and average consequences of these two sites are used to calculate the average risk (last row in Table A.1 below), the value obtained is $0.5 \times 50 = 25$. This is the method used by US-NRC in the DGEIS, but it is wrong.

If the risk for each site is calculated separately, and then the average over all sites is calculated from the separately calculated risk for each site, the resulting value is $(0 + 100) / 2 = 50$. This is the correct way to calculate the average risk. It is possible to obtain the correct answer from the average values if Equation A.1, which includes a covariance term, is used. The result is $0.5 \times 50 + 25 = 50$.

Table A.1: Frequency, consequences and risks for two reactor sites

Site	Frequency (Ry ⁻¹)	Consequences	Risk (consequence Ry ⁻¹)
A	0	0	0
B	1	100	100
Average	0.5	50	25 / 50

ANNEX B – COST OF DECONTAMINATION IN URBAN ENVIRONMENTS

The contamination left behind after an airborne release is function of the deposition velocity " v_d ", a parameter that describes the ratio of the activity on the ground to the activity in the air.

In reality, the deposition velocity varies with the ground cover. The activity removed from the cloud and deposited on the ground is larger when the drag from large objects is bigger and when more surfaces can capture the contamination in the air. This is captured by the dependence of the deposition velocity with ground-roughness length z_0 .

To quote NUREG/CR-2300 v2, p 9-29:

"For particles, v_d depends on a variety of parameters: the chemical properties of the material being deposited, the size and shape of the particles, the surface-roughness length z_0 , the nature of the vegetation, the atmospheric stability category, and so on. As a result, a survey of published data on the value of v_d produces figures varying between 0.0001 and 20 cm/sec (Hosker, 1974). Since this remains an area of great uncertainty, it is discussed in some depth in Appendix D, where it is shown that, for particulate matter emitted in the aftermath of a reactor accident, it is reasonable to expect v_d to be in the range 0.1 to 10 cm/sec. Hence, the value of 1 cm/sec chosen for use in the Reactor Safety Study seems as good as any other."

Later in NUREG/CR-2300 v2, p.D-15, the effect of ground-roughness length is described.

"Figure D-6 gives a typical example of Sehmel's theoretical predictions for v_d as a function of d for various roughness lengths and particle densities. These predictions are based on correlations derived from wind-tunnel data for the surface mass-transfer resistance for depositing particles. Also shown are some examples of the effect of density. This figure clearly shows that, for particle diameters of 1 to 10 μm , the dry-deposition velocity is a sensitive function of z_0 ."




Figure D-6. Effect of the meteorological roughness length z_0 and particle density ρ_p on deposition velocity. From Sehmel (1980).

The section on dry deposition velocity ends with the following remark (NUREG/CR 2300 v2, p.D-17):

“In conclusion, for the consequence models that use a single deposition velocity for particulate matter released during a reactor accident, it is reasonable to assume that v_d is in the range 0.1 to 1 cm/sec. Over rough or heavily vegetated surfaces, deposition velocities of up to 10 cm/sec may be appropriate.”

An urban environment qualifies as a rough surface. The following table is taken from the MACCS2 Guide, page A-20.

Table A-4. Surface Roughness Lengths for Characteristic Surface Types
(See Jow (1990) – Volume 2. MELCOR Accident Consequence Code System (MACCS), Model Description, NUREG/CR-4691, SAND86-1562, Sandia National Laboratories, Albuquerque, NM (1990))

Surface Type	Surface Roughness Length z_0 (cm)	Roughness Factor (Eqn. 10)	Scaling Factor for Dilution Factor
Tall Grass, Cropland	10 – 15	1.27 – 1.38	0.79 – 0.72
Countryside	30	1.58	0.63

Surface Type	Surface Roughness Length z_0 (cm)	Roughness Factor (Eqn. 10)	Scaling Factor for Dilution Factor
Suburban	100	2.02	0.50
Forests	20 – 200	1.46 – 2.32	0.68 – 0.43
Urban	100 - 300	2.02 – 2.51	0.50 – 0.40

The table shows that the surface roughness length is highest for an urban environment and more contamination will be removed from the cloud and deposited on surfaces than for other types of ground cover.

There are two methods that have been used by atmospheric dispersion codes to address this fact.

The first method consists of allowing the deposition velocity to vary with the ground-roughness. This is the method that has been implemented in the European Union consequence assessment code COSYMA [Haserman and Jones 1995]. When the consequences are calculated for an urban environment, the deposition velocity can be increased locally by a factor 10 - 100 to account for the increased removal rate from the cloud due to the larger ground-roughness length (see Figure D-6). When this method is used, the activity removed from the cloud must be distributed on all the surfaces of the buildings, which means that the actual contamination on each surface is lower than the nominal value per square meter calculated by COSYMA. This distribution of the contamination ensures that mass is conserved (there is no more contamination on surfaces than what was removed from the cloud).

The second method consists of using a single average deposition velocity that does not vary with ground-roughness. This is the method implemented in the MACCS2 code. In most calculations, the deposition velocity is set to $V_{DEPOS}=0.01$ m/s (1 cm/s). So, in a farmland area with *low surface roughness*, MACCS2 will overestimate the amount of contamination removed from the cloud and deposited on the ground. On the other hand, in an urban area with *high surface roughness*, MACCS2 will underestimate the amount of contamination removed from the cloud and deposited on the ground. Since MACCS2 uses a single average deposition velocity value for the whole 50 mile area around the reactor, the actual contamination removed from the cloud and available to contaminate all the surfaces in an urban area is actually higher than the nominal value per square meter calculated by the MACCS2 code.

In this context, it is inappropriate to claim that conservation of mass dictates that the nominal ground contamination value must be distributed on all surfaces of a building. If the ground contamination value calculated by MACCS2 was distributed among all surfaces of a building, the procedure would underestimate the true contamination on the surfaces of the building. On the contrary, it is appropriate to directly use the value calculated by MACCS2 on all surfaces of the building since the value calculated by MACCS2 does not account for, and underestimates the enhanced deposition in an urban environment.

References

Haserman, I., and Jones, J.A. 1995. *Cosyma User Guide*, Version 95/1. Forschungszentrum Karlsruhe GmbH. National Radiological Protection Board. EUR 13045. KfK 4331 B.

PRA PROCEDURES GUIDE, A Guide to the Performance of Probabilistic Risk Assessments for Nuclear Power Plants, Final Report, Vol. 1 - Chapters 1-8, Vol. 2 - Chapters 9-13 and Appendices A-G, NUREG/CR-2300, 1983.

MACCS2 Computer Code Application Guidance for Documented Safety Analysis, DOE-EH-4.2.1.4-MACCS2-Code Guidance, June 2004.

**Insights to the Future of High Level
Waste Management:**

**A State's Perspective on
the Storage of Spent Nuclear Fuel,
the Waste Confidence Process &
Site-Specific Impacts and
Mitigation Alternatives**

March 14, 2013
NRC Regulatory Information Conference
Rockville, MD

John J. Sipos
Assistant Attorney General
State of New York



High Density Spent Fuel Pools


- Site-Specific Impacts
- Site-Specific Alternatives & Mitigation Measures

March 14, 2013



Option 3: Site Level 3 PRA

Scope



Source: Figure taken from slides prepared by NRC Staff: Nuclear Regulatory Commission Office of Nuclear Regulatory Research, *Severe Accidents and Options for Proceeding with Level 3 PRA Activities*, ML11209B927 (July 28, 2011).



Consideration of Other Site Radiological Sources

To be complete, estimation of total site accident risk should also include an assessment of the risk from accidents involving other site radiological sources, to include spent nuclear fuel.

Source: Nuclear Regulatory Commission, Options for Proceeding with Future Level 3 Probabilistic Risk Assessment Activities, SECY-11-0089, at 6, ML11090A042 (July 7, 2011).

and site-specific mitigation measures
and alternatives

March 14, 2013



Fukushima Daiichi Summary Display

Priority	Unit	STATUS AS OF 06:00 EDT (19:00 Local) - 03/16/2011
4	1	Core Status - Severe core damage (based on the amount of hydrogen generated). Radiation has been released. Possible RCS breach. (GE) Sea water injection to RPV.
		Containment - Primary apparently intact. Secondary Containment destroyed.
		Spent Fuel Pool - No information on SFP status.
3	2	Core Status - Severe core damage likely. Radiation release has occurred. Possible RCS breach (GE). Sea water injection to RPV.
		Containment - Primary apparently intact. Secondary Containment lost.
		Spent Fuel Pool - No information on SFP status. Some reports attribute smoke/steam coming from the SFP.
2	3	Core Status - Severe core damaged (based on the amount of hydrogen generated). Radiation has been released. Possible RCS breach. (GE). Sea water injection to RPV.
		Containment - Primary apparently intact. Secondary Containment destroyed.
		Spent Fuel Pool - May be in the same condition as Unit 4 SFP below. (Monninger)
1	4	Core off-loaded to Spent Fuel Pool. Secondary Containment destroyed. Walls of SFP have collapsed. No SFP cooling is possible at this time. TEPCO requests recommendations. (Monninger)
5	5	Shutdown since January 3, 2011. Core loaded in RPV. RPV/SFP levels lower than normal and decreasing. Unit 6 D/G providing make-up water to Unit 5. (IAEA).
6	6	Shutdown since August 14, 2010. Core loaded in RPV. RPV/SFP levels lower than normal. Unit 6 D/G providing make-up water to Unit 5. (IAEA).

Source: NRC ADAMS Accession No. ML12080A196 (frame 259 of 782) (placed on public ADAMS on March 23, 2012) (highlight added).

March 14, 2013




Site-Specific Impacts Related to On-Site
Storage of Spent Nuclear Fuel at the
Indian Point Facilities, Westchester
County, NY

- 24 miles from New York City
- 6 miles from New York City reservoir

March 14, 2013






Topographic contours are in feet

Topographic Map from the National Geographic Society


Publisher: ESRI, Redlands, CA; <http://resources.esri.com/arcgisonline/serve/ce/>
 (Prepared with ESRI GIS Software)



March 14, 2013




◆ Reactors



Hillshade from USGS 10 meter digital elevation model
(Prepared with ESRI GIS Software)



March 14, 2013



March 14, 2013



During the May 8, 2012 site visit to the Indian Point facilities by the Atomic Safety and Licensing Board, Entergy representatives made the following statements about Entergy's plans for spent nuclear fuel at Indian Point:

- (A) All of the spent fuel generated during since the start of commercial operation of Indian Point Unit 3 remains in the Indian Point Unit 3 spent fuel pool (as of the date of the site visit);
- (B) Entergy has no current plans to construct an additional dry cask storage area (in addition to the existing dry cask storage area); and
- (C) At the end of operation under any 20-year extension of the current operating licenses, Entergy estimates that the existing dry cask storage area would be filled to capacity and that the Indian Point Unit 2 spent fuel pool and the Indian Point Unit 3 spent fuel pool would be filled to capacity as well.

Source: State of New York, Riverkeeper, Inc., and Hudson River Sloop Clearwater's Joint Contention NYS-39/RK-EC-9/CW-EC-10 Concerning the On-Site Storage of Nuclear Waste at Indian Point, ¶ 32 (Jul. 8, 2012) ML12190A002.

March 14, 2013



Transparent, Objective, Thorough Review of Site-Specific

- Alternatives
- Mitigation

Accident Mitigation Alternatives

Severe Accident Mitigation Alternatives

March 14, 2013



John J. Sipos
Office of the Attorney General
State of New York
The Capitol
Albany, NY 12224
(518) 402-2251

March 14, 2013





STATE OF NEW YORK
OFFICE OF THE ATTORNEY GENERAL

ERIC T. SCHNEIDERMAN
ATTORNEY GENERAL

DIVISION OF SOCIAL JUSTICE
ENVIRONMENTAL PROTECTION BUREAU

August 20, 2013

Via Electronic Mail

Sherwin E. Turk, Esq.
Office of the General Counsel
U.S. Nuclear Regulatory Commission
One White Flint North, Mail Stop: O-15 D21
11555 Rockville Pike
Rockville, MD 20852-2738

Re: Aqueous Releases Following Severe Accidents at Indian Point Facilities

Dear Sherwin:


We write to request additional information regarding NRC's examination of potential aqueous releases following a severe accident, both for the Indian Point facilities and on an agency-wide basis. As we discussed on our conference call yesterday, the severe accident mitigation alternatives ("SAMA") analysis for Indian Point does not consider aqueous releases. Significant new information shows that, in light of the ongoing aqueous releases at Fukushima, aqueous releases should be considered in both the analysis of the impacts associated with a severe accident at Indian Point and the SAMA analysis for Indian Point.

On April 27, 2013, the State submitted supplemental comments on the draft supplement to the December 2010 Final Supplemental Environmental Impact Statement ("FSEIS").¹ The State's April 2013 supplemental comments identified and discussed new and significant information. The State requested that NRC Staff examine the new and significant information in

¹ The State had previously submitted comments on March 28, 2012 and August 20, 2012.

the supplement to the environmental impact statement.

The State's April 2013 comments cited a presentation by the Director of NRC's Research Office from NRC's March 2013 Regulatory Information Conference. Based on that presentation, it is clear that the MACCS2 computer code used to examine severe accidents lacks the ability to analyze the impacts to water resources and the environment resulting from aqueous radiological releases accompanying such an accident. International Session - Post-Fukushima Research, Brian Sheron, Director, NRC Office of Nuclear Regulatory Research (March 13, 2013).² In slide 7 of that presentation (reproduced below), NRC notes (1) aqueous releases occurred during Fukushima accident, and (2) current models do not address aqueous release pathways.



- Aqueous release occurred during Fukushima accident
- Current models do not address aqueous release pathways
- RES is starting a program to assess:
 - Containment failure modes that could lead to aqueous releases
 - Source term modeling for aqueous pathways
 - Transport of contaminated water and its radiological consequences: surface water bodies, groundwater
- Expected outcome: whether potential aqueous releases warrant further mitigating action.

The term “current models,” as used in the slide, would include computer codes such as MACCS2, which Entergy and NRC Staff used to analyze severe reactor accidents in connection with the applications for renewed operating licenses for the Indian Point facilities.

In addition to the March 2013 presentation, the State's April 2013 comments also included recent reports regarding continuing radiological aqueous releases at the Fukushima site

² The document is available at <https://ric.nrc-gateway.gov/m/Docs/Abstracts/sheronb-rev1-hv-w15.pdf>.

– two years after the start of the severe accidents that damaged four of the Dai-ichi nuclear facilities. The State’s comments explained that, although these releases had not been reflected yet in publically-available NRC documents, according to news articles, the receptacles holding radiation contaminated fluids at the Fukushima site have leaked and have released radiological material to the environment. *See, e.g., Damaged Nuclear Plant in Japan Leaks Toxic Water*, Martin Fackler, New York Times (April 6, 2013); *Japan Nuclear Plant Finds New Leaks*, Mari Iwata, Wall Street Journal (April 7, 2013); *Nuclear Plant in Japan Has Leak in Other Tank*, Hiroko Tabuchi, New York Times (April 9, 2013); *Fukushima Nuclear Plant is Still Unstable, Japanese Official Says*, Hiroko Tabuchi, New York Times (April 10, 2013).

More recently, on August 1, 2013, NRC made the transcript of a December 2012 Advisory Committee on Reactor Safeguards (“ACRS”) subcommittee meeting publicly available. July 30, 2013 Memorandum to ACRS Members regarding Certified Minutes of the ACRS Reliability and PRA Subcommittee Meeting on Level 3 PRA on December 4, 2012 (ML13211A477) (“ACRS Transcript”). At that meeting Alan Kuritzky from NRC’s Office of Research, Division of Risk Analysis, explained

Aqueous transport and dispersion of radioactive materials, this is something very big given the Fukushima event, but something we simply are not going to address in our study, but the Agency as a whole is looking into it.

ACRS Transcript at 43:17-21.

An article appearing in today’s New York Times further underscores the importance of the issue. *Fukushima Plant Has 300-Ton Water Leak*, Associated Press, New York Times (Web Edition) (August 20, 2013) (“The operator of Japan’s tsunami-crippled nuclear power plant said Tuesday that about 300 tons (300,000 liters, 80,000 gallons) of highly radioactive water have leaked from one of the hundreds of storage tanks there — its worst leak yet from such a

vessel.”).

Aqueous releases following a severe accident would be of particular concern at Indian Point, which sits on the Hudson River. Aqueous releases have the potential to contaminate the Hudson River’s waters, riverbanks, riverbed and sediment, adjacent freshwater tidal wetlands, and fish and other aquatic organisms and impacts to the environment and human health could exceed the impacts flowing from the aqueous releases into the Pacific Ocean at Fukushima. The unique, site-specific conditions at Indian Point warrant an analysis of the aqueous release issue in the context of the SAMA analysis.

NRC’s acknowledgement of the continuing aqueous releases at Fukushima and the importance of analyzing aqueous release pathways in the context of severe accidents constitutes new and significant information. Under 10 C.F.R. § 51.92(a)(2), NRC Staff is obligated to “prepare a supplement to a final environmental impact statement . . . if . . . [t]here are new and significant circumstances or information relevant to environmental concerns and bearing on the proposed action or its impacts.” *See also* 40 C.F.R. § 1502.9(c)(1)(ii); *Marsh v. Oregon Natural Res. Council*, 490 U.S. 360, 370-78 (1989) (even after initial approval of an environmental impact statement (“EIS”), an agency must continue to evaluate the environmental consequences of the project and supplement the EIS as necessary).

The information is new because the presentation was made publically available after NRC Staff issued its FSEIS in December 2010. It is significant because an analysis of aqueous releases would lead to an increase in severe accident costs, which could lead to the consideration of mitigation measures designed specifically to address aqueous releases or render additional mitigation measures cost-beneficial in the SAMA analysis. NRC Staff’s failure to identify and analyze the impacts and costs associated with aqueous release following a severe accident and

the alternatives to mitigate such impacts in the FSEIS supplement is not consistent with the National Environmental Policy Act.

We appreciate your cooperation and look forward to receiving a description of NRC's analysis of aqueous releases in the wake of the Fukushima accidents. Please also indicate whether NRC plans to supplement the FSEIS for the renewal of the operating licenses for the Indian Point facilities to include a site-specific analysis of the impacts of aqueous releases flowing from a severe accident and the means to mitigate such impacts. Based on our conversation yesterday, we trust that you will forward this letter and our request to the appropriate individuals including Brian W. Sheron, Director, Office of Nuclear Regulatory Research and John Lubinski, Director, Division of License Renewal.

Sincerely,

s/

John J. Sipos
Kathryn Liberatore
Assistant Attorneys General
(518) 402-2251

cc: Paul Bessette, Esq., counsel for Entergy
Robert D. Snook, Assistant Attorney General, State of Connecticut
Phillip Musegaas, Esq., counsel for Riverkeeper
Manna Jo Greene, Clearwater



STATE OF NEW YORK
OFFICE OF THE ATTORNEY GENERAL

ERIC T. SCHNEIDERMAN
ATTORNEY GENERAL

DIVISION OF SOCIAL JUSTICE
ENVIRONMENTAL PROTECTION BUREAU

August 20, 2013

Via Electronic Mail

Sherwin E. Turk, Esq.
Office of the General Counsel
U.S. Nuclear Regulatory Commission
One White Flint North, Mail Stop: O-15 D21
11555 Rockville Pike
Rockville, MD 20852-2738

Re: Oversight and Funding of Offsite Decontamination
Following a Severe Accident at the Indian Point Facilities

Dear Sherwin:

The State writes to request additional information regarding NRC's oversight and funding of offsite decontamination in the event of a severe accident at Indian Point. As we discussed on our conference call yesterday, it is not clear which federal agency is responsible for decontaminating the area surrounding Indian Point or whether the Price Anderson Act covers such decontamination costs.

On March 20, 2012, NRC Staff announced that it was going to supplement its examination of the environmental impacts of the issuance of proposed operating licenses for the Indian Point Unit 2 and Indian Point Unit 3 facilities in the December 2010 Final Supplemental Environmental Impact Statement ("FSEIS"). 77 Fed. Reg. 16278 (Mar. 20, 2012). On March 28, 2012, the State sent a letter to NRC Staff regarding the proposed scope of the FSEIS supplement. *See* March 28, 2012 letter from J. Sipos to S. Turk (NRC), ML12090A609. In its


scoping comments, the State urged NRC Staff to address, in a proactive way, the issue of how it deals with severe nuclear events that lead to significant environmental impacts including land contamination. *Id.* at 13. In Attachment I to the State’s letter, the State raised the issue of funding for decontamination costs, noting that—according to documents prepared by staff at the U.S. Environmental Protection Agency (“EPA”)—the NRC recently informed the EPA and the Federal Emergency Management Agency (“FEMA”) that the industry-funded account established under the Price Anderson Act would likely not be available to pay for offsite decontamination in the event of a severe accident at a nuclear plant. *Id.*, Attachment I at 59 (discussing Douglas P. Guarino, *Agencies Struggle To Craft Offsite Cleanup Plan For Nuclear Power Accidents*, Inside EPA (Nov. 10, 2010), and attached emails disclosed pursuant to Freedom of Information Act (“FOIA”) Request).

On June 26, 2012, NRC Staff informed the public that the draft FSEIS supplement was available for public comment, however, the draft did not address the State’s scoping comments. *See* Notice of Availability of Draft Supplement to Final Plant Specific Supplement 38 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Regarding Indian Point Nuclear Generating Unit Nos. 2 and 3, June 26, 2012, ML12178A660; Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Supplement 38 Regarding Indian Point Nuclear Generating Unit Nos. 2 and 3, Draft Report for Comment, June 2012, ML12174A244.

On August 20, 2012, the State submitted comments on the draft FSEIS supplement to the NRC, identifying and discussing the issue of funding for environmental restoration following a major radiological release at Indian Point. *See* Comments by the New York State Office of the Attorney General on the Draft Supplement to Supplement 38 to the Generic Environmental

Impact Statement For License Renewal of Nuclear Plants, Regarding Indian Point Nuclear Generating Unit Nos. 2 and 3, Draft Report for Comment Dated June 26, 2012 (“State Comments”) at 4, Aug. 20, 2012, ML12235A409.

The State’s comments cited a presentation by NRC Commissioner William D. Magwood, IV at the Health Physics Society Mid-Year Meeting on February 6, 2012. *See* Commissioner Magwood, Nuclear Issues in the Post Fukushima World - Presentation at the Health Physics Society Mid-Year Meeting (“Magwood Presentation”), Feb. 6, 2012, *available at*: <http://www.nrc.gov/about-nrc/organization/commission/comm-william-magwood/testimony-speeches.html>. In the presentation, Commissioner Magwood noted that “[t]here is no regulatory framework for environmental restoration following a major radiological release.” *Id.* at slide 15 (reproduced below).



Based on this information, the State commented that “it [is] not clear that NRC has the desire, capability, or financial resources to respond to a serve accident at Indian Point and ensure the thorough decontamination of the New York metropolitan area including, but not limited to,

its water resources—and drinking water resources—in the wake of such an accident.” State Comments at 4.

In response to the State’s comments, NRC Staff stated that “NRC has technical leadership for the Federal government’s response to the event,” but it also listed eight other federal agencies “who may respond to an event at an NRC-licensed facility, or involving NRC-licensed material.” Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Supplement 38 Regarding Indian Point Nuclear Generating Unit Nos. 2 and 3 Final Report, Supplemental Report and Comment Responses (“June 2013 FSEIS Supplement”) at A-32, June 2013, ML13162A616. Staff’s response did not address Commissioner Magwood’s statement regarding the lack of a regulatory framework for environmental restoration following a major radiological release. Nor did Staff explain which agency is responsible for decontaminating the New York metropolitan area following a severe accident at Indian Point, or which agency’s decontamination standards will apply to a cleanup.

Staff noted that “[c]osts associated with nuclear incidents are governed by the Price-Anderson Nuclear Industries Indemnity Act” and that “[t]he main purpose of the Act is to provide prompt and orderly compensation to the public who may incur damages from a nuclear incident, no matter who might be liable.” *Id.* Staff added that there is a combined level of protection under the Price Anderson Act of \$12 billion, and if a nuclear accident involves damages in excess of this amount, the Act “includes a provision that obligates Congress to take appropriate action to provide compensation for public liability claims.” *Id.* at A-33. However, while Staff’s response explains how the public will be compensated for damages incurred as a result of an accident, such as hotel stays, lost wages and property replacement costs, it does not

explain how *decontamination* costs will be funded in the event of a severe accident at the Indian Point reactors or spent fuel pools.

Given the unique characteristics of Indian Point, the State believes it is especially important that the public have access to this information. The Indian Point reactors are located 24 miles north of New York City. More than 17 million people live within 50 miles of Indian Point, a total that is projected to grow to over 20 million by 2035. According to the Atomic Energy Commission, the NRC, and FEMA, more people live within 10 and 50 miles of the Indian Point reactors than at any other operating power reactor in the nation. The communities within the 50-mile radius around Indian Point also contain some of the most densely-developed and expensive real estate in the country, critical natural resources, centers of national and international commerce, transportation arteries and hubs, and historic sites. Thus, the decontamination costs of a severe accident at Indian Point have the potential to be larger than an accident at any other reactor in the country.

Documents disclosed by the NRC and other federal agencies indicate that there are conflicting responsibilities of multiple federal agencies for offsite restoration after a nuclear incident and that NRC may not lead cleanup oversight in the event that an accident at a nuclear power plant dispersed radioactive contamination off the reactor site and into the surrounding area. See Douglas P. Guarino, *Agencies Struggle To Craft Offsite Cleanup Plan For Nuclear Power Accidents*, Inside EPA (Nov. 10, 2010), and attached emails disclosed pursuant to FOIA Request (reproduced in part below).

**NRC-FEMA-EPA White Paper:
Potential Authorities and/or Funding Sources for Off-site Cleanup Following a
Nuclear Power Plant Incident**

Background:

- The Environmental Protection Agency (EPA), the Nuclear Regulatory Commission (NRC), and the Federal Emergency Management Agency (FEMA) began a series of quarterly meetings in 2009 to discuss unresolved concerns regarding off-site environmental cleanup following a nuclear power plant incident. Deleted: an
- ~~NRC recently indicated to FEMA that they would not be taking the lead for off-site environmental cleanup after a nuclear power plant incident. NRC suggested EPA would be the appropriate agency to lead such efforts.~~ Formatted: Bullets and Numbering
- ~~NRC also indicated the Price Anderson Act would be unable to pay for environmental cleanup after a nuclear power plant incident, only for compensation for damages incurred (e.g., hotel stays, replacement costs for property and personnel items, lost wages, etc).~~ Deleted: the
- ~~FEMA convened a workgroup to discuss the following issues related to nuclear power plant incidents: potential Agency roles (e.g., who would lead cleanup efforts); cleanup authorities; and fund sources.~~
- Evaluation of language from the *Price-Anderson Act*, the *Stafford Act*, and EPA's previous policies and expectation that the *CERCLA (Comprehensive Environmental Response, Compensation, and Liability Act)* would generally not be used for response actions to address releases from NRC-licensed sites including nuclear power plants, may indicate a potential gap in authority to perform or oversee and fund off-site cleanup following a nuclear power plant incident, depending on the circumstances of the incident and the subsequent declarations of the federal government.
- The Report to Congress from the Presidential Commission on Catastrophic Nuclear Accidents (See Attachment D)¹: outlines a number of concerns regarding nuclear power plant incidents. The report covers the sourcing of funds under a "Major Disaster," a "Catastrophe," and how to prepare and respond to a "catastrophic disaster."
 - Current plans do not cover "long-duration accidents that have impacts over large land areas"
 - The authority of the Court to award damages does not extend to executive branch powers.
- The following are questions and concerns are unresolved:

¹ "Report to the Congress from the Presidential Commission on Catastrophic Nuclear Accident." State of Nevada, n.d. Web. 1 Jul 2010.

- Under what authority will off-site cleanup following a nuclear power plant be conducted?
- What is the funding source for off-site cleanup following a nuclear power plant incident?

Objective:

- Provide current understanding on potential authorities and sources of funding for off-site cleanup following a nuclear power plant incident.

These documents also indicate that money set aside by the Price Anderson Act would not be available to fund decontamination. *Id.* If there is no regulatory framework or source of funding in place to decontaminate the New York metropolitan area in the event of a severe accident at Indian Point, that fact should be disclosed by NRC Staff to the public.

Therefore, in light of Commissioner Magwood's statements and NRC's statements to EPA, the State requests that the U.S. Nuclear Regulatory Commission answer the following questions:

1. Which federal agency is responsible for decontaminating radiation released offsite by a severe accident at the Indian Point reactors and spent fuel pools?
2. Would the Price Anderson Act fund decontamination in the event that that an accident at Indian Point caused radioactive contamination to be dispersed off the reactor site and into the surrounding area?

We appreciate your cooperation and look forward to receiving additional information regarding NRC's oversight and funding of offsite decontamination in the event of a severe accident at Indian Point. Based on our conversation yesterday, we trust that you will forward this letter and our request to the appropriate individuals, including James Wiggins, Director, Office of Nuclear Security and Incident Response, and Robert Lewis, Director, Division of Preparedness and Response, Office of Nuclear Security and Incident Response.

Sincerely,

s/

John J. Sipos
Laura Heslin
Assistant Attorneys General
(518) 402-2251

cc: Paul Bessette, Esq., Counsel for Entergy
Robert D. Snook, Assistant Attorney General, State of Connecticut
Phillip Musegaas, Esq., Counsel for Riverkeeper
Manna Jo Greene, Clearwater