

MANUAL HARD COPY DISTRIBUTION  
DOCUMENT TRANSMITTAL 2013-54823

---

USER INFORMATION:

GERLACH\*ROSEY M            EEMPL#:028401    CA#: 0363

Address: NUCSA2

Phone#: 254-3194

TRANSMITTAL INFORMATION:

TO:        GERLACH\*ROSEY M            12/11/2013

LOCATION:    USNRC

FROM:    NUCLEAR RECORDS DOCUMENT CONTROL CENTER (NUCSA-2)

THE FOLLOWING CHANGES HAVE OCCURRED TO THE HARDCOPY OR ELECTRONIC MANUAL ASSIGNED TO YOU. HARDCOPY USERS MUST ENSURE THE DOCUMENTS PROVIDED MATCH THE INFORMATION ON THIS TRANSMITTAL. WHEN REPLACING THIS MATERIAL IN YOUR HARDCOPY MANUAL, ENSURE THE UPDATE DOCUMENT ID IS THE SAME DOCUMENT ID YOU'RE REMOVING FROM YOUR MANUAL. TOOLS FROM THE HUMAN PERFORMANCE TOOL BAG SHOULD BE UTILIZED TO ELIMINATE THE CHANCE OF ERRORS.

ATTENTION: "REPLACE" directions do not affect the Table of Contents, Therefore no TOC will be issued with the updated material.

TSB1 - TECHNICAL SPECIFICATION BASES UNIT 1 MANUAL

REMOVE MANUAL TABLE OF CONTENTS    DATE: 10/24/2013

ADD        MANUAL TABLE OF CONTENTS    DATE: 12/10/2013

CATEGORY: DOCUMENTS    TYPE: TSB1

A001  
HRR

ID: TEXT 3.6.4.1  
REMOVE: REV:8

ADD: REV: 9

CATEGORY: DOCUMENTS TYPE: TSB1  
ID: TEXT LOES  
ADD: REV: 112

REMOVE: REV:111

ANY DISCREPANCIES WITH THE MATERIAL PROVIDED, CONTACT DCS @ X3107 OR X3136 FOR ASSISTANCE. UPDATES FOR HARDCOPY MANUALS WILL BE DISTRIBUTED WITHIN 3 DAYS IN ACCORDANCE WITH DEPARTMENT PROCEDURES. PLEASE MAKE ALL CHANGES AND ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX UPON COMPLETION OF UPDATES. FOR ELECTRONIC MANUAL USERS, ELECTRONICALLY REVIEW THE APPROPRIATE DOCUMENTS AND ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX.

# SSES MANUAL

Manual Name: TSB1

Manual Title: TECHNICAL SPECIFICATION BASES UNIT 1 MANUAL

# CONTROLLED

## Table Of Contents

Issue Date: 12/10/2013

<u>Procedure Name</u>	<u>Rev</u>	<u>Issue Date</u>	<u>Change ID</u>	<u>Change Number</u>
TEXT LOES	112	12/10/2013		
<b>Title:</b> LIST OF EFFECTIVE SECTIONS				
TEXT TOC	22	03/28/2013		
<b>Title:</b> TABLE OF CONTENTS				
TEXT 2.1.1	5	05/06/2009		
<b>Title:</b> SAFETY LIMITS (SLS) REACTOR CORE SLS				
TEXT 2.1.2	1	10/04/2007		
<b>Title:</b> SAFETY LIMITS (SLS) REACTOR COOLANT SYSTEM (RCS) PRESSURE S				
TEXT 3.0	3	08/20/2009		
<b>Title:</b> LIMITING CONDITION FOR OPERATION (LCO) APPLICABILITY				
TEXT 3.1.1	1	04/18/2006		
<b>Title:</b> REACTIVITY CONTROL SYSTEMS SHUTDOWN MARGIN (SDM)				
TEXT 3.1.2	0	11/15/2002		
<b>Title:</b> REACTIVITY CONTROL SYSTEMS REACTIVITY ANOMALIES				
TEXT 3.1.3	2	01/19/2009		
<b>Title:</b> REACTIVITY CONTROL SYSTEMS CONTROL ROD OPERABILITY				
TEXT 3.1.4	4	01/30/2009		
<b>Title:</b> REACTIVITY CONTROL SYSTEMS CONTROL ROD SCRAM TIMES				
TEXT 3.1.5	1	07/06/2005		
<b>Title:</b> REACTIVITY CONTROL SYSTEMS CONTROL ROD SCRAM ACCUMULATORS				
TEXT 3.1.6	2	04/18/2006		
<b>Title:</b> REACTIVITY CONTROL SYSTEMS ROD PATTERN CONTROL				

# SSES MANUAL

**Manual Name:** TSB1

**Manual Title:** TECHNICAL SPECIFICATION BASES UNIT 1 MANUAL

TEXT 3.1.7 3 04/23/2008  
**Title:** REACTIVITY CONTROL SYSTEMS STANDBY LIQUID CONTROL (SLC) SYSTEM

TEXT 3.1.8 3 05/06/2009  
**Title:** REACTIVITY CONTROL SYSTEMS SCRAM DISCHARGE VOLUME (SDV) VENT AND DRAIN VALVES

TEXT 3.2.1 2 04/23/2008  
**Title:** POWER DISTRIBUTION LIMITS AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)

TEXT 3.2.2 3 05/06/2009  
**Title:** POWER DISTRIBUTION LIMITS MINIMUM CRITICAL POWER RATIO (MCPR)

TEXT 3.2.3 2 04/23/2008  
**Title:** POWER DISTRIBUTION LIMITS LINEAR HEAT GENERATION RATE (LHGR)

TEXT 3.3.1.1 5 07/23/2013  
**Title:** INSTRUMENTATION REACTOR PROTECTION SYSTEM (RPS) INSTRUMENTATION

TEXT 3.3.1.2 2 01/19/2009  
**Title:** INSTRUMENTATION SOURCE RANGE MONITOR (SRM) INSTRUMENTATION

TEXT 3.3.2.1 3 04/23/2008  
**Title:** INSTRUMENTATION CONTROL ROD BLOCK INSTRUMENTATION

TEXT 3.3.2.2 2 04/05/2010  
**Title:** INSTRUMENTATION FEEDWATER MAIN TURBINE HIGH WATER LEVEL TRIP INSTRUMENTATION

TEXT 3.3.3.1 9 02/28/2013  
**Title:** INSTRUMENTATION POST ACCIDENT MONITORING (PAM) INSTRUMENTATION

TEXT 3.3.3.2 1 04/18/2005  
**Title:** INSTRUMENTATION REMOTE SHUTDOWN SYSTEM

TEXT 3.3.4.1 1 04/23/2008  
**Title:** INSTRUMENTATION END OF CYCLE RECIRCULATION PUMP TRIP (EOC-RPT) INSTRUMENTATION

# SSES MANUAL

**Manual Name:** TSB1

**Manual Title:** TECHNICAL SPECIFICATION BASES UNIT 1 MANUAL

TEXT 3.3.4.2	0	11/15/2002
<b>Title:</b> INSTRUMENTATION ANTICIPATED TRANSIENT WITHOUT SCRAM RECIRCULATION PUMP TRIP (ATWS-RPT) INSTRUMENTATION		
TEXT 3.3.5.1	3	08/20/2009
<b>Title:</b> INSTRUMENTATION EMERGENCY CORE COOLING SYSTEM (ECCS) INSTRUMENTATION		
TEXT 3.3.5.2	0	11/15/2002
<b>Title:</b> INSTRUMENTATION REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM INSTRUMENTATION		
TEXT 3.3.6.1	5	07/23/2013
<b>Title:</b> INSTRUMENTATION PRIMARY CONTAINMENT ISOLATION INSTRUMENTATION		
TEXT 3.3.6.2	4	09/01/2010
<b>Title:</b> INSTRUMENTATION SECONDARY CONTAINMENT ISOLATION INSTRUMENTATION		
TEXT 3.3.7.1	2	10/27/2008
<b>Title:</b> INSTRUMENTATION CONTROL ROOM EMERGENCY OUTSIDE AIR SUPPLY (CREOAS) SYSTEM INSTRUMENTATION		
TEXT 3.3.8.1	2	12/17/2007
<b>Title:</b> INSTRUMENTATION LOSS OF POWER (LOP) INSTRUMENTATION		
TEXT 3.3.8.2	0	11/15/2002
<b>Title:</b> INSTRUMENTATION REACTOR PROTECTION SYSTEM (RPS) ELECTRIC POWER MONITORING		
TEXT 3.4.1	4	04/27/2010
<b>Title:</b> REACTOR COOLANT SYSTEM (RCS) RECIRCULATION LOOPS OPERATING		
TEXT 3.4.2	3	10/23/2013
<b>Title:</b> REACTOR COOLANT SYSTEM (RCS) JET PUMPS		
TEXT 3.4.3	3	01/13/2012
<b>Title:</b> REACTOR COOLANT SYSTEM RCS SAFETY RELIEF VALVES S/RVS		
TEXT 3.4.4	0	11/15/2002
<b>Title:</b> REACTOR COOLANT SYSTEM (RCS) RCS OPERATIONAL LEAKAGE		

# SSES MANUAL

**Manual Name:** TSB1

**Manual Title:** TECHNICAL SPECIFICATION BASES UNIT 1 MANUAL

TEXT 3.4.5	1	01/16/2006	<b>Title:</b> REACTOR COOLANT SYSTEM (RCS) RCS PRESSURE ISOLATION VALVE (PIV) LEAKAGE
TEXT 3.4.6	3	01/25/2011	<b>Title:</b> REACTOR COOLANT SYSTEM (RCS) RCS LEAKAGE DETECTION INSTRUMENTATION
TEXT 3.4.7	2	10/04/2007	<b>Title:</b> REACTOR COOLANT SYSTEM (RCS) RCS SPECIFIC ACTIVITY
TEXT 3.4.8	2	03/28/2013	<b>Title:</b> REACTOR COOLANT SYSTEM (RCS) RESIDUAL HEAT REMOVAL (RHR) SHUTDOWN COOLING SYSTEM - HOT SHUTDOWN
TEXT 3.4.9	1	03/28/2013	<b>Title:</b> REACTOR COOLANT SYSTEM (RCS) RESIDUAL HEAT REMOVAL (RHR) SHUTDOWN COOLING SYSTEM - COLD SHUTDOWN
TEXT 3.4.10	3	04/23/2008	<b>Title:</b> REACTOR COOLANT SYSTEM (RCS) RCS PRESSURE AND TEMPERATURE (P/T) LIMITS
TEXT 3.4.11	0	11/15/2002	<b>Title:</b> REACTOR COOLANT SYSTEM (RCS) REACTOR STEAM DOME PRESSURE
TEXT 3.5.1	2	01/16/2006	<b>Title:</b> EMERGENCY CORE COOLING SYSTEMS (ECCS) AND REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM ECCS - OPERATING
TEXT 3.5.2	0	11/15/2002	<b>Title:</b> EMERGENCY CORE COOLING SYSTEMS (ECCS) AND REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM ECCS - SHUTDOWN
TEXT 3.5.3	2	07/09/2010	<b>Title:</b> EMERGENCY CORE COOLING SYSTEMS (ECCS) AND REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM RCIC SYSTEM
TEXT 3.6.1.1	4	11/09/2011	<b>Title:</b> PRIMARY CONTAINMENT
TEXT 3.6.1.2	1	04/23/2008	<b>Title:</b> CONTAINMENT SYSTEMS PRIMARY CONTAINMENT AIR LOCK

## SSES MANUAL

**Manual Name:** TSB1

**Manual Title:** TECHNICAL SPECIFICATION BASES UNIT 1 MANUAL

TEXT 3.6.1.3	10	05/23/2012	<b>Title:</b> CONTAINMENT SYSTEMS PRIMARY CONTAINMENT ISOLATION VALVES (PCIVS)
TEXT 3.6.1.4	1	04/23/2008	<b>Title:</b> CONTAINMENT SYSTEMS CONTAINMENT PRESSURE
TEXT 3.6.1.5	1	10/05/2005	<b>Title:</b> CONTAINMENT SYSTEMS DRYWELL AIR TEMPERATURE
TEXT 3.6.1.6	0	11/15/2002	<b>Title:</b> CONTAINMENT SYSTEMS SUPPRESSION CHAMBER-TO-DRYWELL VACUUM BREAKERS
TEXT 3.6.2.1	2	04/23/2008	<b>Title:</b> CONTAINMENT SYSTEMS SUPPRESSION POOL AVERAGE TEMPERATURE
TEXT 3.6.2.2	0	11/15/2002	<b>Title:</b> CONTAINMENT SYSTEMS SUPPRESSION POOL WATER LEVEL
TEXT 3.6.2.3	1	01/16/2006	<b>Title:</b> CONTAINMENT SYSTEMS RESIDUAL HEAT REMOVAL (RHR) SUPPRESSION POOL COOLING
TEXT 3.6.2.4	0	11/15/2002	<b>Title:</b> CONTAINMENT SYSTEMS RESIDUAL HEAT REMOVAL (RHR) SUPPRESSION POOL SPRAY
TEXT 3.6.3.1	2	06/13/2006	<b>Title:</b> CONTAINMENT SYSTEMS PRIMARY CONTAINMENT HYDROGEN RECOMBINERS
TEXT 3.6.3.2	1	04/18/2005	<b>Title:</b> CONTAINMENT SYSTEMS DRYWELL AIR FLOW SYSTEM
TEXT 3.6.3.3	1	02/28/2013	<b>Title:</b> CONTAINMENT SYSTEMS PRIMARY CONTAINMENT OXYGEN CONCENTRATION
TEXT 3.6.4.1	9	12/10/2013	<b>Title:</b> CONTAINMENT SYSTEMS SECONDARY CONTAINMENT

# SSSES MANUAL

**Manual Name:** TSB1

**Manual Title:** TECHNICAL SPECIFICATION BASES UNIT 1 MANUAL

TEXT 3.6.4.2	8	03/28/2013	<b>Title:</b> CONTAINMENT SYSTEMS SECONDARY CONTAINMENT ISOLATION VALVES (SCIVS)
TEXT 3.6.4.3	4	09/21/2006	<b>Title:</b> CONTAINMENT SYSTEMS STANDBY GAS TREATMENT (SGT) SYSTEM
TEXT 3.7.1	4	04/05/2010	<b>Title:</b> PLANT SYSTEMS RESIDUAL HEAT REMOVAL SERVICE WATER (RHRSW) SYSTEM AND THE ULTIMATE HEAT SINK (UHS)
TEXT 3.7.2	2	02/11/2009	<b>Title:</b> PLANT SYSTEMS EMERGENCY SERVICE WATER (ESW) SYSTEM
TEXT 3.7.3	1	01/08/2010	<b>Title:</b> PLANT SYSTEMS CONTROL ROOM EMERGENCY OUTSIDE AIR SUPPLY (CREOAS) SYSTEM
TEXT 3.7.4	0	11/15/2002	<b>Title:</b> PLANT SYSTEMS CONTROL ROOM FLOOR COOLING SYSTEM
TEXT 3.7.5	1	10/04/2007	<b>Title:</b> PLANT SYSTEMS MAIN CONDENSER OFFGAS
TEXT 3.7.6	2	04/23/2008	<b>Title:</b> PLANT SYSTEMS MAIN TURBINE BYPASS SYSTEM
TEXT 3.7.7	1	10/04/2007	<b>Title:</b> PLANT SYSTEMS SPENT FUEL STORAGE POOL WATER LEVEL
TEXT 3.7.8	0	04/23/2008	<b>Title:</b> PLANT SYSTEMS
TEXT 3.8.1	6	05/06/2009	<b>Title:</b> ELECTRICAL POWER SYSTEMS AC SOURCES - OPERATING
TEXT 3.8.2	0	11/15/2002	<b>Title:</b> ELECTRICAL POWER SYSTEMS AC SOURCES - SHUTDOWN



## SSES MANUAL

**Manual Name:** TSB1

**Manual Title:** TECHNICAL SPECIFICATION BASES UNIT 1 MANUAL

TEXT 3.8.3	4	10/23/2013	<b>Title:</b> ELECTRICAL POWER SYSTEMS DIESEL FUEL OIL, LUBE OIL, AND STARTING AIR
TEXT 3.8.4	3	01/19/2009	<b>Title:</b> ELECTRICAL POWER SYSTEMS DC SOURCES - OPERATING
TEXT 3.8.5	1	12/14/2006	<b>Title:</b> ELECTRICAL POWER SYSTEMS DC SOURCES - SHUTDOWN
TEXT 3.8.6	1	12/14/2006	<b>Title:</b> ELECTRICAL POWER SYSTEMS BATTERY CELL PARAMETERS
TEXT 3.8.7	1	10/05/2005	<b>Title:</b> ELECTRICAL POWER SYSTEMS DISTRIBUTION SYSTEMS - OPERATING
TEXT 3.8.8	0	11/15/2002	<b>Title:</b> ELECTRICAL POWER SYSTEMS DISTRIBUTION SYSTEMS - SHUTDOWN
TEXT 3.9.1	0	11/15/2002	<b>Title:</b> REFUELING OPERATIONS REFUELING EQUIPMENT INTERLOCKS
TEXT 3.9.2	1	09/01/2010	<b>Title:</b> REFUELING OPERATIONS REFUEL POSITION ONE-ROD-OUT INTERLOCK
TEXT 3.9.3	0	11/15/2002	<b>Title:</b> REFUELING OPERATIONS CONTROL ROD POSITION
TEXT 3.9.4	0	11/15/2002	<b>Title:</b> REFUELING OPERATIONS CONTROL ROD POSITION INDICATION
TEXT 3.9.5	0	11/15/2002	<b>Title:</b> REFUELING OPERATIONS CONTROL ROD OPERABILITY - REFUELING
TEXT 3.9.6	1	10/04/2007	<b>Title:</b> REFUELING OPERATIONS REACTOR PRESSURE VESSEL (RPV) WATER LEVEL

## SSES MANUAL

**Manual Name:** TSB1

**Manual Title:** TECHNICAL SPECIFICATION BASES UNIT 1 MANUAL

TEXT 3.9.7	0	11/15/2002	<b>Title:</b> REFUELING OPERATIONS RESIDUAL HEAT REMOVAL (RHR) - HIGH WATER LEVEL
TEXT 3.9.8	0	11/15/2002	<b>Title:</b> REFUELING OPERATIONS RESIDUAL HEAT REMOVAL (RHR) - LOW WATER LEVEL
TEXT 3.10.1	1	01/23/2008	<b>Title:</b> SPECIAL OPERATIONS INSERVICE LEAK AND HYDROSTATIC TESTING OPERATION
TEXT 3.10.2	0	11/15/2002	<b>Title:</b> SPECIAL OPERATIONS REACTOR MODE SWITCH INTERLOCK TESTING
TEXT 3.10.3	0	11/15/2002	<b>Title:</b> SPECIAL OPERATIONS SINGLE CONTROL ROD WITHDRAWAL - HOT SHUTDOWN
TEXT 3.10.4	0	11/15/2002	<b>Title:</b> SPECIAL OPERATIONS SINGLE CONTROL ROD WITHDRAWAL - COLD SHUTDOWN
TEXT 3.10.5	0	11/15/2002	<b>Title:</b> SPECIAL OPERATIONS SINGLE CONTROL ROD DRIVE (CRD) REMOVAL - REFUELING
TEXT 3.10.6	0	11/15/2002	<b>Title:</b> SPECIAL OPERATIONS MULTIPLE CONTROL ROD WITHDRAWAL - REFUELING
TEXT 3.10.7	1	04/18/2006	<b>Title:</b> SPECIAL OPERATIONS CONTROL ROD TESTING - OPERATING
TEXT 3.10.8	1	04/12/2006	<b>Title:</b> SPECIAL OPERATIONS SHUTDOWN MARGIN (SDM) TEST - REFUELING

SUSQUEHANNA STEAM ELECTRIC STATION  
**LIST OF EFFECTIVE SECTIONS (TECHNICAL SPECIFICATIONS BASES)**

<u>Section</u>	<u>Title</u>	<u>Revision</u>
TOC	Table of Contents	22
B 2.0	SAFETY LIMITS BASES	
	Page B 2.0-1	0
	Page TS / B 2.0-2	3
	Page TS / B 2.0-3	5
	Page TS / B 2.0-4	3
	Page TS / B 2.0-5	5
	Page TS / B 2.0-6	1
	Pages TS / B 2.0-7 through TS / B 2.0-9	1
B 3.0	LCO AND SR APPLICABILITY BASES	
	Page TS / B 3.0-1	1
	Pages TS / B 3.0-2 through TS / B 3.0-4	0
	Pages TS / B 3.0-5 through TS / B 3.0-7	1
	Page TS / B 3.0-8	3
	Pages TS / B 3.0-9 through TS / B 3.0-11	2
	Page TS / B 3.0-11a	0
	Page TS / B 3.0-12	1
	Pages TS / B 3.0-13 through TS / B 3.0-15	2
	Pages TS / B 3.0-16 and TS / B 3.0-17	0
B 3.1	REACTIVITY CONTROL BASES	
	Pages B 3.1-1 through B 3.1-4	0
	Page TS / B 3.1-5	1
	Pages TS / B 3.1-6 and TS / B 3.1-7	2
	Pages B 3.1-8 through B 3.1-13	0
	Page TS / B 3.1-14	1
	Page B 3.1-15	0
	Page TS / B 3.1-16	1
	Pages B 3.1-17 through B 3.1-19	0
	Pages TS / B 3.1-20 and TS / B 3.1-21	1
	Page TS / B 3.1-22	0
	Page TS / B 3.1-23	1
	Page TS / B 3.1-24	0
	Pages TS / B 3.1-25 through TS / B 3.1-27	1
	Page TS / B 3.1-28	2
	Page TS / B 3.1-29	1
	Pages B 3.1-30 through B 3.1-33	0
	Pages TS / B 3.3-34 through TS / B 3.3-36	1
	Pages TS / B 3.1-37 and TS / B 3.1-38	2
	Pages TS / B 3.1-39 and TS / B 3.1-40	2
	Page TS / B 3.1-40a	0
	Pages TS / B 3.1-41 and TS / B 3.1-42	2

SUSQUEHANNA STEAM ELECTRIC STATION  
**LIST OF EFFECTIVE SECTIONS** (TECHNICAL SPECIFICATIONS BASES)

<u>Section</u>	<u>Title</u>	<u>Revision</u>
	Page TS / B 3.1.43	1
	Page TS / B 3.1-44	0
	Page TS / B 3.1-45	3
	Pages TS / B 3.1-46 through TS / B 3.1-49	1
	Page TS / B 3.1-50	0
	Page TS / B 3.1-51	3
<b>B 3.2</b>	<b>POWER DISTRIBUTION LIMITS BASES</b>	
	Page TS / B 3.2-1	2
	Pages TS / B 3.2-2 and TS / B 3.2-3	3
	Pages TS / B 3.2-4 and TS / B 3.2-5	2
	Page TS / B 3.2-6	3
	Page B 3.2-7	1
	Pages TS / B 3.2-8 and TS / B 3.2-9	3
	Page TS / B 3.2.10	2
	Page TS / B 3.2-11	3
	Page TS / B 3.2-12	1
	Page TS / B 3.2-13	2
<b>B 3.3</b>	<b>INSTRUMENTATION</b>	
	Pages TS / B 3.3-1 through TS / B 3.3-4	1
	Page TS / B 3.3-5	2
	Page TS / B 3.3-6	1
	Page TS / B 3.3-7	3
	Page TS / B 3.3-7a	1
	Page TS / B 3.3-8	5
	Pages TS / B 3.3-9 through TS / B 3.3-12	3
	Pages TS / B 3.3-12a	1
	Pages TS / B 3.3-12b and TS / B 3.3-12c	0
	Page TS / B 3.3-13	1
	Page TS / B 3.3-14	3
	Pages TS / B 3.3-15 and TS / B 3.3-16	1
	Pages TS / B 3.3-17 and TS / B 3.3-18	4
	Page TS / B 3.3-19	1
	Pages TS / B 3.3-20 through TS / B 3.3-22	2
	Page TS / B 3.3-22a	0
	Pages TS / B 3.3-23 and TS / B 3.3-24	2
	Pages TS / B 3.3-24a and TS / B 3.3-24b	0
	Page TS / B 3.3-25	3
	Page TS / B 3.3-26	2
	Page TS / B 3.3-27	1
	Pages TS / B 3.3-28 through TS / B 3.3-30	3
	Page TS / B 3.3-30a	0

SUSQUEHANNA STEAM ELECTRIC STATION  
**LIST OF EFFECTIVE SECTIONS** (TECHNICAL SPECIFICATIONS BASES)

<u>Section</u>	<u>Title</u>	<u>Revision</u>
	Page TS / B 3.3-31	4
	Page TS / B 3.3-32	5
	Pages TS / B 3.3-32a	0
	Page TS / B 3.3-32b	1
	Page TS / B 3.3-33	5
	Page TS / B 3.3-33a	0
	Page TS / B 3.3-34	1
	Pages TS / B 3.3-35 and TS / B 3.3-36	2
	Pages TS / B 3.3-37 and TS / B 3.3-38	1
	Page TS / B 3.3-39	2
	Pages TS / B 3.3-40 through TS / B 3.3-43	1
	Page TS / B 3.3-44	4
	Pages TS / B 3.3-44a and TS / B 3.3-44b	0
	Page TS / B 3.3-45	3
	Pages TS / B 3.3-45a and TS / B 3.3-45b	0
	Page TS / B 3.3-46	3
	Pages TS / B 3.3-47	2
	Pages TS / B 3.3-48 through TS / B 3.3-51	3
	Pages TS / B 3.3-52 and TS / B 3.3-53	2
	Page TS / B 3.3-53a	0
	Page TS / B 3.3-54	4
	Page TS / B 3.3-55	2
	Pages TS / B 3.3-56 and TS / B 3.3-57	1
	Page TS / B 3.3-58	0
	Page TS / B 3.3-59	1
	Page TS / B 3.3-60	0
	Page TS / B 3.3-61	1
	Pages TS / B 3.3-62 and TS / B 3.3-63	0
	Pages TS / B 3.3-64 and TS / B 3.3-65	2
	Page TS / B 3.3-66	4
	Page TS / B 3.3-67	3
	Page TS / B 3.3-68	4
	Page TS / B 3.3-69	5
	Pages TS / B 3.3-70	4
	Page TS / B 3.3-71	3
	Pages TS / B 3.3-72 and TS / B 3.3-73	2
	Page TS / B 3.3-74	3
	Page TS / B 3.3-75	2
	Page TS / B 3.3-75a	6
	Page TS / B 3.3-75b	7
	Page TS / B 3.3-75c	6

SUSQUEHANNA STEAM ELECTRIC STATION  
**LIST OF EFFECTIVE SECTIONS (TECHNICAL SPECIFICATIONS BASES)**

<u>Section</u>	<u>Title</u>	<u>Revision</u>
	Pages B 3.3-76 through 3.3-77	0
	Page TS / B 3.3-78	1
	Pages B 3.3-79 through B 3.3-81	0
	Page B 3.3-82	1
	Page B 3.3-83	0
	Pages B 3.3-84 and B 3.3-85	1
	Page B 3.3-86	0
	Page B 3.3-87	1
	Page B 3.3-88	0
	Page B 3.3-89	1
	Page TS / B 3.3-90	1
	Page B 3.3-91	0
	Pages TS / B 3.3-92 through TS / B 3.3-100	1
	Pages TS / B 3.3-101 through TS / B 3.3-103	0
	Page TS / B 3.3-104	2
	Pages TS / B 3.3-105 and TS / B 3.3-106	0
	Page TS / B 3.3-107	1
	Page TS / B 3.3-108	0
	Page TS / B 3.3-109	1
	Pages TS / B 3.3-110 and TS / B 3.3-111	0
	Pages TS / B 3.3-112 and TS / B 3.3-112a	1
	Pages TS / B 3.3-113 through TS / B 3.3-115	1
	Page TS / B 3.3-116	3
	Page TS / B 3.3-117	1
	Pages TS / B 3.3-118 through TS / B 3.3-122	0
	Pages TS / B 3.3-123 and TS / B 3.3-124	1
	Page TS / B 3.3-124a	0
	Page TS / B 3.3-125	0
	Pages TS / B 3.3-126 and TS / B 3.3-127	1
	Pages TS / B 3.3-128 through TS / B 3.3-130	0
	Page TS / B 3.3-131	1
	Pages TS / B 3.3-132 through TS / B 3.3-134	0
	Pages B 3.3-135 through B 3.3-137	0
	Page TS / B 3.3-138	1
	Pages B 3.3-139 through B 3.3-149	0
	Pages TS / B 3.3-150 and TS / B 3.3-151	1
	Pages TS / B 3.3-152 through TS / B 3.3-154	2
	Page TS / B 3.3-155	1
	Pages TS / B 3.3-156 through TS / B 3.3-158	2
	Pages TS / B 3.3-159 through TS / B 3.3-162	1
	Page TS / B 3.3-163	2
	Page TS / B 3.3-164	1
	Pages TS / B 3.3-165 through TS / B 3.3-167	2

SUSQUEHANNA STEAM ELECTRIC STATION  
**LIST OF EFFECTIVE SECTIONS (TECHNICAL SPECIFICATIONS BASES)**

<u>Section</u>	<u>Title</u>	<u>Revision</u>
	Pages TS / B 3.3-168 and TS / B 3.3-169	1
	Page TS / B 3.3-170	2
	Pages TS / B 3.3-171 through TS / B 3.3-177	1
	Pages TS / B 3.3-178 through TS / B 3.3-179a	2
	Pages TS / B 3.3-179b and TS / B 3.3-179c	0
	Page TS / B 3.3-180	1
	Page TS / B 3.3-181	3
	Page TS / B 3.3-182	1
	Page TS / B 3.3-183	2
	Page TS / B 3.3-184	1
	Page TS / B 3.3-185	4
	Page TS / B 3.3-186	1
	Pages TS / B 3.3-187 and TS / B 3.3-188	2
	Pages TS / B 3.3-189 through TS / B 3.3-191	1
	Page TS / B 3.3-192	0
	Page TS / B 3.3-193	1
	Pages TS / B 3.3-194 and TS / B 3.3-195	0
	Page TS / B 3.3-196	2
	Pages TS / B 3.3-197 through TS / B 3.3-204	0
	Page TS / B 3.3-205	1
	Pages B 3.3-206 through B 3.3-209	0
	Page TS / B 3.3-210	1
	Pages B 3.3-211 through B 3.3-219	0
<b>B 3.4</b>	<b>REACTOR COOLANT SYSTEM BASES</b>	
	Pages B 3.4-1 and B 3.4-2	0
	Pages TS / B 3.4-3 and Page TS / B 3.4-4	4
	Page TS / B 3.4-5	3
	Pages TS / B 3.4-6 through TS / B 3.4-9	2
	Page TS / B 3.4-10	1
	Pages TS / 3.4-11 and TS / B 3.4-12	0
	Page TS / B 3.4-13	2
	Page TS / B 3.4-14	1
	Page TS / B 3.4-15	2
	Pages TS / B 3.4-16 and TS / B 3.4-17	4
	Page TS / B 3.4-18	2
	Pages B 3.4-19 through B 3.4-27	0
	Pages TS / B 3.4-28 through TS / B 3.4-30	1
	Page TS / B 3.4-31	0
	Pages TS / B 3.4-32 and TS / B 3.4-33	1
	Page TS / B 3.4-34	0
	Pages TS / B 3.4-35 and TS / B 3.4-36	1
	Page TS / B 3.4-37	2
	Page TS / B 3.4-38	1

SUSQUEHANNA STEAM ELECTRIC STATION  
**LIST OF EFFECTIVE SECTIONS (TECHNICAL SPECIFICATIONS BASES)**

<u>Section</u>	<u>Title</u>	<u>Revision</u>
	Pages B 3.4-39 and B 3.4-40	0
	Page TS / B 3.4-41	2
	Pages TS / B 3.4-42 through TS / B 3.4-45	0
	Page TS / B 3.4-46	1
	Pages TS B 3.4-47 and TS / B 3.4-48	0
	Page TS / B 3.4-49	3
	Page TS / B 3.4-50	1
	Page TS / B 3.4-51	3
	Page TS / B 3.4-52	2
	Page TS / B 3.4-53	1
	Pages TS / B 3.4-54 through TS / B 3.4-56	2
	Page TS / B 3.4-57	3
	Pages TS / B 3.4-58 through TS / B 3.4-60	1
<b>B 3.5</b>	<b>ECCS AND RCIC BASES</b>	
	Pages B 3.5-1 and B 3.5-2	0
	Page TS / B 3.5-3	2
	Page TS / B 3.5-4	1
	Page TS / B 3.5-5	2
	Page TS / B 3.5-6	1
	Pages B 3.5-7 through B 3.5-10	0
	Page TS / B 3.5-11	1
	Page TS / B 3.5-12	0
	Page TS / B 3.5-13	1
	Pages TS / B 3.5-14 and TS / B 3.5-15	0
	Pages TS / B 3.5-16 through TS / B 3.5-18	1
	Pages B 3.5-19 through B 3.5-24	0
	Page TS / B 3.5-25 through TS / B 3.5-27	1
	Page TS / B 3.5-28	0
	Page TS / B 3.5-29	1
	Pages TS / B 3.5-30 and TS / B 3.5-31	0
<b>B 3.6</b>	<b>CONTAINMENT SYSTEMS BASES</b>	
	Page TS / B 3.6-1	2
	Page TS / B 3.6-1a	3
	Page TS / B 3.6-2	4
	Page TS / B 3.6-3	3
	Page TS / B 3.6-4	4
	Pages TS / B 3.6-5 and TS / B 3.6-6	3
	Page TS / B 3.6-6a	2
	Page TS / B 3.6-6b	3
	Page TS / B 3.6-6c	0
	Page B 3.6-7	0



SUSQUEHANNA STEAM ELECTRIC STATION  
**LIST OF EFFECTIVE SECTIONS (TECHNICAL SPECIFICATIONS BASES)**

<u>Section</u>	<u>Title</u>	<u>Revision</u>
	Page B 3.6-8	1
	Pages B 3.6-9 through B 3.6-14	0
	Page TS / B 3.6-15	3
	Page TS / B 3.6-15a	0
	Page TS / B 3.6-15b	2
	Pages TS / B 3.6-16 and TS / B 3.6-17	2
	Page TS / B 3.6-17a	1
	Pages TS / B 3.6-18 and TS / B 3.6-19	0
	Page TS / B 3.6-20	1
	Page TS / B 3.6-21	2
	Page TS / B 3.6-22	1
	Page TS / B 3.6-22a	0
	Page TS / B 3.6-23	1
	Pages TS / B 3.6-24 and TS / B 3.6-25	0
	Pages TS / B 3.6-26 and TS / B 3.6-27	2
	Page TS / B 3.6-28	7
	Page TS / B 3.6-29	2
	Page TS / B 3.6-30	1
	Page TS / B 3.6-31	3
	Pages TS / B 3.6-32 and TS / B 3.6-33	1
	Pages TS / B 3.6-34 and TS / B 3.6-35	0
	Page TS / B 3.6-36	1
	Page TS / B 3.6-37	0
	Page TS / B 3.6-38	3
	Page TS / B 3.6-39	2
	Page TS / B 3.6-40	6
	Page TS / B 3.6-40a	0
	Page B 3.6-41	1
	Pages B 3.6-42 and B 3.6-43	3
	Pages TS / B 3.6-44 and TS / B 3.6-45	1
	Page TS / B 3.6-46	2
	Pages TS / B 3.6-47 through TS / B 3.6-51	1
	Page TS / B 3.6-52	2
	Pages TS / B 3.6-53 through TS / B 3.6-56	0
	Page TS / B 3.6-57	1
	Page TS / 3.6-58	2
	Pages B 3.6-59 through B 3.6-63	0
	Pages TS / B 3.6-64 and TS / B 3.6-65	1
	Pages B 3.6-66 through B 3.6-69	0
	Pages TS / B 3.6-70 through TS / B 3.6-72	1
	Page TS / B 3.6-73	2
	Pages TS / B 3.6-74 and TS / B 3.6-75	1
	Pages B 3.6-76 and B 3.6-77	0

SUSQUEHANNA STEAM ELECTRIC STATION  
**LIST OF EFFECTIVE SECTIONS (TECHNICAL SPECIFICATIONS BASES)**

<u>Section</u>	<u>Title</u>	<u>Revision</u>
	Page TS / B 3.6-78	1
	Pages B 3.6-79 and B 3.3.6-80	0
	Page TS / B 3.6-81	1
	Pages TS / B 3.6-82 and TS / B 3.6-83	0
	Page TS / B 3.6-84	4
	Page TS / B 3.6-85	2
	Page TS / B 3.6-86	4
	Pages TS / B 3.6-87 through TS / B 3.6-88a	2
	Page TS / B 3.6-89	5
	Page TS / B 3.6-90	3
	Page TS / B 3.6-90a	0
	Pages TS / B 3.6-91 and TS / B 3.6-92	3
	Page TS / B 3.6-93	2
	Pages TS / B 3.6-94 through TS / B 3.6-96	1
	Page TS / B 3.6-97	2
	Page TS / B 3.6-98	1
	Page TS / B 3.6-99	2
	Pages TS / B 3.6-100 and TS / B 3.6-100a	5
	Page TS / B 3.6-100b	3
	Pages TS / B 3.6-101 and TS / B 3.6-102	1
	Pages TS / B 3.6-103 and TS / B 3.6-104	2
	Page TS / B 3.6-105	3
	Page TS / B 3.6-106	2
	Page TS / B 3.6-107	3
B 3.7	PLANT SYSTEMS BASES	
	Pages TS / B 3.7-1	3
	Page TS / B 3.7-2	4
	Pages TS / B 3.7-3 through TS / B 3.7-5	3
	Page TS / B 3.7-5a	1
	Page TS / B 3.7-6	3
	Page TS / B 3.7-6a	2
	Page TS / B 3.7-6b	1
	Page TS / B 3.7-6c	2
	Page TS / B 3.7-7	3
	Page TS / B 3.7-8	2
	Pages TS / B 3.7-9 through TS / B 3.7-11	1
	Pages TS / B 3.7-12 and TS / B 3.7-13	2
	Pages TS / B 3.7-14 through TS / B 3.7-18	3
	Page TS / B 3.7-18a	1
	Pages TS / B 3.7-18b through TS / B 3.7-18e	0
	Pages TS / B 3.7-19 through TS / B 3.7-23	1
	Page TS / B 3.7-24	1

SUSQUEHANNA STEAM ELECTRIC STATION  
**LIST OF EFFECTIVE SECTIONS (TECHNICAL SPECIFICATIONS BASES)**

<u>Section</u>	<u>Title</u>	<u>Revision</u>
	Pages TS / B 3.7-25 and TS / B 3.7-26	0
	Pages TS / B 3.7-27 through TS / B 3.7-29	5
	Page TS / B 3.7-30	2
	Page TS / B 3.7-31	1
	Page TS / B 3.7-32	0
	Page TS / B 3.7-33	1
	Pages TS / B 3.7-34 through TS / B 3.7-37	0
<b>B 3.8</b>	<b>ELECTRICAL POWER SYSTEMS BASES</b>	
	Page TS / B 3.8-1	3
	Pages TS / B 3.8-2 and TS / B 3.8-3	2
	Page TS / B 3.8-4	3
	Pages TS / B 3.8-4a and TS / B 3.8-4b	0
	Page TS / B 3.8-5	5
	Page TS / B 3.8-6	3
	Pages TS / B 3.8-7 through TS/B 3.8-8	2
	Page TS / B 3.8-9	4
	Page TS / B 3.8-10	3
	Pages TS / B 3.8-11 and TS / B 3.8-17	2
	Page TS / B 3.8-18	3
	Pages TS / B 3.8-19 through TS / B 3.8-21	2
	Pages TS / B 3.8-22 and TS / B 3.8-23	3
	Pages TS / B 3.8-24 through TS / B 3.8-37	2
	Pages B 3.8-38 through B 3.8-44	0
	Page TS / B 3.8-45	3
	Pages TS / B 3.8-46 through TS / B 3.8-48	0
	Pages TS / B 3.8-49 and TS / B 3.8-50	3
	Page TS / B 3.8-51	1
	Page TS / B 3.8-52	0
	Page TS / B 3.8-53	1
	Pages TS / B 3.8-54 through TS / B 3.8-57	2
	Pages TS / B 3.8-58 through TS / B 3.8-61	3
	Pages TS / B 3.8-62 and TS / B 3.8-63	5
	Page TS / B 3.8-64	4
	Page TS / B 3.8-65	5
	Pages TS / B 3.8-66 through TS / B 3.8-77	1
	Pages TS / B 3.8-77A through TS / B 3.8-77C	0
	Pages B 3.8-78 through B 3.8-80	0
	Page TS / B 3.8-81	1
	Pages B 3.8-82 through B 3.8-90	0

SUSQUEHANNA STEAM ELECTRIC STATION  
**LIST OF EFFECTIVE SECTIONS (TECHNICAL SPECIFICATIONS BASES)**

<u>Section</u>	<u>Title</u>	<u>Revision</u>
B 3.9	REFUELING OPERATIONS BASES	
	Pages TS / B 3.9-1 and TS / B 3.9-1a	1
	Pages TS / B 3.9-2 through TS / B 3.9-5	1
	Pages TS / B 3.9-6 through TS / B 3.9-8	0
	Pages B 3.9-9 through B 3.9-18	0
	Pages TS / B 3.9-19 through TS / B 3.9-21	1
	Pages B 3.9-22 through B 3.9-30	0
B 3.10	SPECIAL OPERATIONS BASES	
	Page TS / B 3.10-1	2
	Pages TS / B 3.10-2 through TS / B 3.10-5	1
	Pages B 3.10-6 through B 3.10-31	0
	Page TS / B 3.10-32	2
	Page B 3.10-33	0
	Page TS / B 3.10-34	1
	Pages B 3.10-35 and B 3.10-36	0
	Page TS / B 3.10-37	1
	Page TS / B 3.10-38	2

TSB1 Text LOES.doc  
11/22/2013

## B 3.6 CONTAINMENT SYSTEMS

### B 3.6.4.1 Secondary Containment

#### BASES

---

**BACKGROUND** The secondary containment structure completely encloses the primary containment structure such that a dual-containment design is utilized to limit the spread of radioactivity to the environment to within limits. The function of the secondary containment is to contain, dilute, and hold up fission products that may leak from primary containment into secondary containment following a Design Basis Accident (DBA). In conjunction with operation of the Standby Gas Treatment (SGT) System and closure of certain valves whose lines penetrate the secondary containment, the secondary containment is designed to reduce the activity level of the fission products prior to release to the environment and to isolate and contain fission products that are released during certain operations that take place inside primary containment, when primary containment is not required to be OPERABLE, or that take place outside primary containment (Ref. 1).

The secondary containment is a structure that completely encloses the primary containment and reactor coolant pressure boundary components. This structure forms a control volume that serves to hold up and dilute the fission products. It is possible for the pressure in the control volume to rise relative to the environmental pressure (e.g., due to pump and motor heat load additions).

The secondary containment boundary consists of the reactor building structure and associated removable walls and panels, hatches, doors, dampers, sealed penetrations and valves. Certain plant piping systems (e.g., Service Water, RHR Service Water, Emergency Service Water, Feedwater, etc.) penetrate the secondary containment boundary. The intact piping within secondary containment provides a passive barrier which maintains secondary containment requirements. Breaches of these piping systems within secondary containment will be controlled to maintain secondary containment requirements. The secondary containment is divided into Zone I, Zone II and Zone III, each of which must be OPERABLE depending on plant status and the alignment of the secondary containment boundary. Specifically, the Unit 1 secondary containment boundary can be modified to exclude Zone II. Similarly, the Unit 2 secondary containment boundary can be modified to exclude Zone I. Secondary containment may consist of only Zone III when in MODE 4 or 5 during CORE ALTERATIONS, or during handling of irradiated fuel within the Zone III secondary containment boundary.

(continued)

---

BASES

---

**BACKGROUND**  
(continued)      To prevent ground level exfiltration while allowing the secondary containment to be designed as a conventional structure, the secondary containment requires support systems to maintain the control volume pressure at less than the external pressure. Requirements for the safety related systems are specified separately in LCO 3.6.4.2, "Secondary Containment Isolation Valves (SCIVs)," and LCO 3.6.4.3, "Standby Gas Treatment (SGT) System." When one or more zones are excluded from secondary containment, the specific requirements for support systems will also change (e.g., required secondary containment isolation valves).

---

**APPLICABLE SAFETY ANALYSES**      There are two principal accidents for which credit is taken for secondary containment OPERABILITY. These are a loss of coolant accident (LOCA) (Ref. 2) and a fuel handling accident inside secondary containment (Ref. 3). The secondary containment performs no active function in response to either of these limiting events; however, its leak tightness is required to ensure that the release of radioactive materials from the primary containment is restricted to those leakage paths and associated leakage rates assumed in the accident analysis and that fission products entrapped within the secondary containment structure will be treated by the SGT System prior to discharge to the environment.

Secondary containment satisfies Criterion 3 of the NRC Policy Statement (Ref. 4).

---

**LCO**      An OPERABLE secondary containment provides a control volume into which fission products that bypass or leak from primary containment, or are released from the reactor coolant pressure boundary components located in secondary containment, can be diluted and processed prior to release to the environment. For the secondary containment to be considered OPERABLE, it must have adequate leak tightness to ensure that the required vacuum can be established and maintained. The leak tightness of secondary containment must also ensure that the release of radioactive materials to the environment is restricted to those leakage paths and associated leakage rates assumed in the accident analysis. For example, secondary containment bypass leakage must be restricted to the leakage rate required by LCO 3.6.1.3. The secondary containment boundary required to be OPERABLE is dependent on the operating status of both units, as well as the configuration of walls, doors, hatches, SCIVs, and available flow paths to the SGT System.

(continued)

---

BASES (continued)

---

**APPLICABILITY** In MODES 1, 2, and 3, a LOCA could lead to a fission product release to primary containment that leaks to secondary containment. Therefore, secondary containment OPERABILITY is required during the same operating conditions that require primary containment OPERABILITY.

In MODES 4 and 5, the probability and consequences of the LOCA are reduced due to the pressure and temperature limitations in these MODES. Therefore, maintaining secondary containment OPERABLE is not required in MODE 4 or 5 to ensure a control volume, except for other situations for which significant releases of radioactive material can be postulated, such as during operations with a potential for draining the reactor vessel (OPDRVs), during CORE ALTERATIONS, or during movement of irradiated fuel assemblies in the secondary containment.

---

**ACTIONS**

A.1

If secondary containment is inoperable, it must be restored to OPERABLE status within 4 hours. The 4 hour Completion Time provides a period of time to correct the problem that is commensurate with the importance of maintaining secondary containment during MODES 1, 2, and 3. This time period also ensures that the probability of an accident (requiring secondary containment OPERABILITY) occurring during periods where secondary containment is inoperable is minimal.

A temporary (one-time) Completion Time is connected to the Completion Time Requirements above (4 hours) with an "OR" connector. The Temporary Completion Time is 48 hours and applies to the replacement of the Reactor Building Recirculating Fan Damper Motors. The Temporary Completion Time of 48 hours may only be used once, and expires on December 31, 2005.

B.1 and B.2

If secondary containment cannot be restored to OPERABLE status within the required Completion Time, the plant must be brought to a MODE in which the LCO does not apply. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours and to MODE 4 within 36 hours. The allowed Completion Times are reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

(continued)

BASES

---

ACTIONS  
(continued)

C.1, C.2, and C.3

Movement of irradiated fuel assemblies in the secondary containment, CORE ALTERATIONS, and OPDRVs can be postulated to cause fission product release to the secondary containment. In such cases, the secondary containment is the only barrier to release of fission products to the environment. CORE ALTERATIONS and movement of irradiated fuel assemblies must be immediately suspended if the secondary containment is inoperable.

Suspension of these activities shall not preclude completing an action that involves moving a component to a safe position. Also, action must be immediately initiated to suspend OPDRVs to minimize the probability of a vessel draindown and subsequent potential for fission product release. Actions must continue until OPDRVs are suspended.

Required Action C.1 has been modified by a Note stating that LCO 3.0.3 is not applicable. If moving irradiated fuel assemblies while in MODE 4 or 5, LCO 3.0.3 would not specify any action. If moving irradiated fuel assemblies while in MODE 1, 2, or 3, the fuel movement is independent of reactor operations. Therefore, in either case, inability to suspend movement of irradiated fuel assemblies would not be a sufficient reason to require a reactor shutdown.

---

SURVEILLANCE  
REQUIREMENTS

SR 3.6.4.1.1

This SR ensures that the secondary containment boundary is sufficiently leak tight to preclude exfiltration under expected wind conditions. Expected wind conditions are defined as sustained wind speeds of less than or equal to 16 mph at the 60m meteorological tower or less than or equal to 11 mph at the 10m meteorological tower if the 60m tower wind speed is not available. Changes in indicated reactor building differential pressure observed during periods of short-term wind speed gusts above these sustained speeds do not by themselves impact secondary containment integrity. However, if secondary containment integrity is known to be compromised, the LCO must be entered regardless of wind speed.

(continued)



BASES

---

SURVEILLANCE REQUIREMENTS SR 3.6.4.1.1 (continued)

The 24 hour Frequency of this SR was developed based on operating experience related to secondary containment vacuum variations during the applicable MODES and the low probability of a DBA occurring between surveillances.

Furthermore, the 24 hour Frequency is considered adequate in view of other indications available in the control room, including alarms, to alert the operator to an abnormal secondary containment vacuum condition.

SR 3.6.4.1.2 and SR 3.6.4.1.3

Verifying that secondary containment equipment hatches, removable walls and one access door in each access opening required to be closed are closed ensures that the infiltration of outside air of such a magnitude as to prevent maintaining the desired negative pressure does not occur.

Verifying that all such openings are closed also provides adequate assurance that exfiltration from the secondary containment will not occur. In this application, the term "sealed" has no connotation of leak tightness.

An access opening typically contains one inner and one outer door. Maintaining secondary containment OPERABILITY requires verifying one door in each access opening to secondary containment zones is closed. In some cases (e.g., railroad bay), secondary containment access openings are shared such that a secondary containment barrier may have multiple inner or multiple outer doors. The intent is to maintain the secondary containment barrier intact, which is achieved by maintaining the inner or outer portion of the barrier closed at all times. However, all secondary containment access doors are normally kept closed, except when the access opening is being used for entry and exit or when maintenance is being performed on an access opening.

When the railroad bay door (No. 101) is closed; all Zone I and III hatches, removable walls, dampers, and one door in each access opening connected to the railroad access bay are closed; or, only Zone I removable walls and/or doors are open to the railroad access shaft; or, only Zone III hatches and/or dampers are open to the railroad access shaft. When the railroad bay door (No. 101) is open; all Zone I and III hatches, removable walls, dampers, and one door in each access opening connected to the railroad access bay are closed. The truck bay hatch is closed and the truck bay door (No. 102) is closed unless Zone II is isolated from Zones I and III.

(continued)

**BASES**

---

**SURVEILLANCE REQUIREMENTS** SR 3.6.4.1.2 and SR 3.6.4.1.3 (continued)

When an access opening between required secondary containment zones is being used for exit and entry, then at least one door (where two doors are provided) must remain closed. The access openings between secondary containment zones which are not provided with two doors are administratively controlled to maintain secondary containment integrity during exit and entry. This Surveillance is modified by a Note that allows access openings with a single door (i.e., no airlock) within the secondary containment boundary (i.e., between required secondary containment zones) to be opened for entry and exit. Opening of an access door for entry and exit allows sufficient administrative control by individual personnel making the entries and exits to assure the secondary containment function is not degraded. When one of the zones is not a zone required for secondary containment OPERABILITY, the Note allowance would not apply.

The 31 day Frequency for these SRs has been shown to be adequate, based on operating experience, and is considered adequate in view of the other indications of door and hatch status that are available to the operator.

---

(continued)

BASES

**SURVEILLANCE REQUIREMENTS** SR 3.6.4.1.4 and SR 3.6.4.1.5

(continued)

The SGT System exhausts the secondary containment atmosphere to the environment through appropriate treatment equipment. To ensure that all fission products are treated, SR 3.6.4.1.4 verifies that the SGT System will rapidly establish and maintain a pressure in the secondary containment that is less than the pressure external to the secondary containment boundary. This is confirmed by demonstrating that one SGT subsystem will draw down the secondary containment to  $\geq 0.25$  inches of vacuum water gauge in less than or equal to the maximum time allowed. This cannot be accomplished if the secondary containment boundary is not intact. SR 3.6.4.1.5 demonstrates that one SGT subsystem can maintain  $\geq 0.25$  inches of vacuum water gauge for at least 1 hour at less than or equal to the maximum flow rate permitted for the secondary containment configuration that is operable. The 1 hour test period allows secondary containment to be in thermal equilibrium at steady state conditions. As noted, both SR 3.6.4.1.4 and SR 3.6.4.1.5 acceptance limits are dependent upon the secondary containment configuration when testing is being performed. The acceptance criteria for the SRs based on secondary containment configuration is defined as follows:

SECONDARY CONTAINMENT TEST CONFIGURATION	MAXIMUM DRAWDOWN TIME(SEC) (SR 3.6.4.1.4 ACCEPTANCE CRITERIA)	MAXIMUM FLOW RATE (CFM) (SR 3.6.4.1.5 ACCEPTANCE CRITERIA)
Group 1		
Zones I, II and III (Unit 1 Railroad Bay aligned to Secondary Containment).	$\leq 300$ Seconds (Zones I, II, and III)	$\leq 4000$ CFM (From Zones I, II, and III)
Zones I and III (Unit 1 Railroad Bay aligned to Secondary Containment).	$\leq 300$ Seconds (Zones I and III)	$\leq 2885$ CFM (From Zones I and III)
Group 2		
Zones I, II and III (Unit 1 Railroad Bay not aligned to Secondary Containment).	$\leq 300$ Seconds (Zones I, II, and III)	$\leq 3910$ CFM (From Zones I, II, and III)
Zones I and III (Unit 1 Railroad Bay not aligned to Secondary Containment).	$\leq 300$ Seconds (Zones I and III)	$\leq 2800$ CFM (From Zones I and III)

Only one of the above listed configurations needs to be tested to confirm secondary containment OPERABILITY.

(continued)

BASES

---

SURVEILLANCE REQUIREMENTS SR 3.6.4.1.4 and SR 3.6.4.1.5 (continued)

A Note also modifies the Frequency for each SR. This Note identifies that each configuration is to be tested every 60 months. Testing each configuration every 60 months assures that the most limiting configuration is tested every 60 months. The 60 month Frequency is acceptable because operating experience has shown that these components usually pass the Surveillance and all active components are tested more frequently. Therefore, these tests are used to ensure secondary containment boundary integrity.

The Unit 1 Railroad Bay can be aligned as a No Zone (isolated from secondary containment) or as part of secondary containment (Zone I or III). Drawdown testing of the secondary containment shall be performed with the Unit 1 Railroad Bay aligned in the most limiting configuration. More specifically, secondary containment drawdown testing will be performed with the Unit 1 Railroad Bay aligned as a No Zone with the Railroad Bay door open or as part of secondary containment. The specific alignment will be selected based on the alignment that provides the least amount of inleakage and drawdown time margin (on a percentage basis) to the acceptance criteria. This could result in one alignment (e.g., No Zone with the Railroad Bay door open) being limiting for one criterion (e.g., drawdown time) and the other alignment (e.g., Railroad Bay aligned to secondary containment) being limiting for the other criterion (e.g., inleakage). It also could result in one alignment being limiting for both criteria.

Note that aligning the Railroad Bay to either Zone I or III is acceptable since either zone is part of secondary containment. It is preferred to align the Railroad Bay to Zone III for testing since Zone III is included in all possible secondary containment isolation alignments. The most limiting Unit 1 Railroad Bay alignment shall be established each Surveillance period (60 month). Subsequent drawdown testing during the same Surveillance period only requires testing of the Unit 1 Railroad Bay in the most limiting configuration. For example, Zone I, II, and III Surveillance testing is performed with the Unit 1 Railroad Bay aligned both as a No Zone with the Railroad Bay door open and as Zone III. If the Surveillance testing determined the most limiting configuration occurs with the Unit 1 Railroad Bay aligned as Zone III, then subsequent Zone I and III drawdown testing during the same Surveillance period only needs to be performed with the Unit 1 Railroad Bay aligned as Zone III.

(continued)

---

BASES

---

SURVEILLANCE REQUIREMENTS SR 3.6.4.1.4 and SR 3.6.4.1.5 (continued)

Since these SRs are secondary containment tests, they need not be performed with each SGT subsystem. The SGT subsystems are tested on a STAGGERED TEST BASIS, however, to ensure that in addition to the requirements of LCO 3.6.4.3, either SGT subsystem will perform SR 3.6.4.1.4 and SR 3.6.4.1.5. Operating experience has shown these components usually pass the Surveillance when performed at the 24 month Frequency. Therefore, the Frequency was concluded to be acceptable from a reliability standpoint.

---

- REFERENCES
1. FSAR, Section 6.2.3.
  2. FSAR, Section 15.6.
  3. FSAR, Section 15.7.4.
  4. Final Policy Statement on Technical Specifications Improvements, July 22, 1993 (58 FR 39132).
-