

**JOB PERFORMANCE MEASURE**

Job Position <b>SRO</b>	No. JP-OP-802-4101-443	Revision 0
Activate ECOS in accordance with EP-290	Duration 15 minutes	Page 1

Examinee: \_\_\_\_\_ SRO

Evaluator: \_\_\_\_\_

JPM Type:                    **Normal** / Alternate Path / Time Critical                    Start Time \_\_\_\_\_  
 Evaluation Method:        **Perform** / Walkthrough / Discuss                                Stop Time \_\_\_\_\_  
 Location:                     Plant / Simulator / **Classroom**    Total Time: \_\_\_\_\_

<b>PERFORMANCE EVALUATION SUMMARY</b>											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
* 1.											
* 2.											
* 3.											
* 4.											
* 5.											
* 6.											
* 7.											
* 8.											

<b>OPERATOR FUNDAMENTALS OBSERVATION</b>				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Activate ECOS in accordance with EP-290	No.: JP-OP-802-4101-443 Revision: 0 Page 2
--	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Activate ECOS in accordance with EP-290	No.: JP-OP-802-4101-443 Revision: 0 Page 3
--	--

**JPM Information**

**System:**

N/A

**Task:**

73999 - Activate the Emergency Call Out System (ECOS)

**References:** Required (R) / Available (A)

EP-290, Emergency Notifications (R)

**Tools and Equipment Required:**

Unplugged Telephone

**Initial Conditions:**

- You are the Work Control Supervisor.
- It is back shift on a Saturday night.
- A Site Area Emergency has been declared and you have reported to the Main Control Room as requested by the Shift Manager.
- Initial notifications to County, State, and Ontario Province have been completed.

**Initiating Cue(s):**

Activate ECOS using a phone in accordance with Enclosure E, of EP-290, Emergency Notifications.

**Terminating Cue(s):**

ECOS is activated.

**Task Standard:**

ECOS is activated using a phone in accordance with EP-290, Enclosure E.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

N/A

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** Generic  
**K/A STATEMENT:**  
2.4.43 – Knowledge of emergency communication systems and techniques. .... 3.2 / 3.8

**Maintenance Rule Safety Classification:**

No

**Maintenance Rule Risk Significant? (Yes or No)**

No

JOB PERFORMANCE MEASURE

JPM Title Activate ECOS in accordance with EP-290	No.: JP-OP-802-4101-443 Revision: 0 Page 4
--	--

PERFORMANCE EVALUATION

Start Time \_\_\_\_\_

ELEMENT	STANDARD
<b>NOTE: An unplugged telephone available for examinee's use will allow more effective simulation of ECOS activation by SM phone.</b>	
<b>CUE: Provide the examinee with the Cue Sheet. If necessary, provide the examinee with a current copy of EP-290.</b>	
* 1. [3.1.1] Have ready the applicable <i>Scenario ID Number</i> from Table 1-1 for the corresponding classification.	* 1. Determines correct <i>Scenario ID Number</i> from Table 1-1 is <b>3</b> .
* 2. [3.1.2] Call the Remote Scenario Activation phone number (800) 380-0407 or (615) 844-5611.	* 2. Dials (800) 380-0407 or (615) 844-5611.
<b>CUE: After the phone number has been dialed, state "Welcome, enter your User ID Number followed by the # sign."</b>	
* 3. [3.1.3] At the prompt for User ID, enter <b>65235</b> , then press #.	* 3. Enters <b>65235</b> , followed by #.
<b>CUE: After the User ID and # have been entered, state "Enter your Security PIN number, followed by the # sign."</b>	
<b>CUE: If asked, the Security PIN number is 12345.</b>	
* 4. [3.1.4] At the prompt for Security PIN, enter the confidential PIN number, then press #.	* 4. Enters <b>12345</b> , followed by #.
<b>CUE: After the Security PIN and # have been entered, state "Enter the Scenario ID Number followed by the # sign."</b>	
* 5. [3.1.5] At the prompt for Scenario ID, enter the associated Scenario ID from Table 1-1, and then press #.	* 5. Enters <b>3</b> , followed by #.
<b>NOTE: The system will go through a list of options from the program menu.</b>	
<b>CUE: After the Scenario ID and # have been entered, state "Listen to the following Options then press the appropriate number on the phone key pad:</b> <b>Press 1</b> - to listen to the current scenario message [pre-recorded messages designed for Fermi 2 ERO] - or - <b>Press 2</b> - to re-record the scenario message. The system will give instructions on how to record and verify your message. - or - <b>Press 3</b> - to start the scenario. When you hear the response, "The scenario is building", exit the program by pressing #. - or - <b>Press 4</b> - to return to the main menu."	
* 6. [3.1.6] Press the appropriate number on the phone key pad.	* 6. Presses <b>3</b> .
<b>CUE: After the number 3 has been entered, state "The Scenario is building."</b>	
* 7. [3.1.6] When the system reports that the scenario is building exit the program by pressing the # sign.	* 7. Presses #, and hangs up the phone.

JOB PERFORMANCE MEASURE

JPM Title Activate ECOS in accordance with EP-290	No.: JP-OP-802-4101-443 Revision: 0 Page 5
--	--

ELEMENT	STANDARD
<b>NOTE:</b> ECOS is programmed to immediately call [734] 586-5235 at the Shift Manager's desk for "emergency" or "test" activations.	
<b>CUE:</b> After the phone has been hung up, state <b>"The phone is ringing."</b> When the applicant answers the phone, states <b>"Enter the last 5 digits of your SAP Employee Number."</b>	
* 8. [4.2] Answer the call, and when prompted for the last five digits of your SAP Employee Number, enter <b>1111</b> , then press <b>#</b> .	* 8. Enters <b>1111</b> , followed by <b>#</b> .
<b>CUE:</b> After 1111 and # have been entered, state <b>"ECOS is activated."</b>	
<b>CUE:</b> End JPM when ECOS is activated.	

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* **Critical Step**

JOB PERFORMANCE MEASURE

JPM Title Activate ECOS in accordance with EP-290	No.: JP-OP-802-4101-443 Revision: 0 Page 6
--	--

**Evaluator Notes:**

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

**Generic Notes and Cues:**

None

**System Specific Notes and Cues:**

None

**Task Performance and Cues:**

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

**Critical Steps:**

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Activate ECOS in accordance with EP-290	No.: JP-OP-802-4101-443 Revision: 0 Page 7
--	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Activate ECOS in accordance with EP-290	No.: JP-OP-802-4101-443 Revision: 0 Page 8
--	--

**Simulator Setup**

**IC#:**

N/A

**Malfunctions:**

Number	Title	Value	Delay	Ramp
N/A				

**Remote Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Override Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Special Instructions:**

N/A

**Cue Sheet: (JP-OP-802-4101-443)**

**Initial Conditions:**

- You are the Work Control Supervisor.
- It is back shift on a Saturday night.
- A Site Area Emergency has been declared and you have reported to the Main Control Room as requested by the Shift Manager.
- Initial notifications to County, State, and Ontario Province have been completed.

**Initiating Cue(s):**

Activate ECOS using a phone in accordance with Enclosure E, of EP-290, Emergency Notifications.

**JOB PERFORMANCE MEASURE**

Job Position SRO / RO	No. JP-OP-315-0107-002	Revision 1
JPM Title Transfer Feedwater Control from Long Cycle Cleanup to Startup Level Control	Duration 15 minutes	Page 1

Examinee: \_\_\_\_\_ SRO / RO

Evaluator: \_\_\_\_\_

JPM Type:                   **Normal** / Alternate Path / Time Critical                   Start Time \_\_\_\_\_

Evaluation Method:       **Perform** / Walkthrough / Discuss                   Stop Time \_\_\_\_\_

Location:                   Plant / **Simulator** / Classroom                   Total Time: \_\_\_\_\_

<b>PERFORMANCE EVALUATION SUMMARY</b>											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
1.				*11.							
2.				*12.							
3.				13.							
4.											
5.											
* 6.											
* 7.											
* 8.											
9.											
10.											

<b>OPERATOR FUNDAMENTALS OBSERVATION</b>				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Transfer Feedwater Control from Long Cycle Cleanup to Startup Level Control	No.: JP-OP-315-0107-002 Revision: 1 Page 2
---	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Transfer Feedwater Control from Long Cycle Cleanup to Startup Level Control	No.: JP-OP-315-0107-002 Revision: 1 Page 3
---	--

**JPM Information**

**System:**

N2100 – Reactor Feedwater System

**Task:**

62073 - Transfer from long cycle cleanup to startup level control

**References:** Required (R) / Available (A)

23.107, Reactor Feedwater and Condensate (R)

**Tools and Equipment Required:**

None

**Initial Conditions:**

- You are the Control Room NSO.
- Plant startup is in progress. The reactor is just critical. Pressurization is to begin.
- Feedwater is in Long Cycle Cleanup mode. Chemistry has reported Condensate and Feedwater chemistry is within the administrative limits.

**Initiating Cue(s):**

The CRS directs you to transfer Feedwater Control from Long Cycle Cleanup to Startup Level Control per 23.107.

**Terminating Cue(s):**

Feedwater is in Startup Level Control.

**Task Standard:**

Feedwater Control is transferred from Long Cycle Cleanup to Startup Level Control per 23.107.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

SF-2 – Reactor Water Inventory Control

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** 259001 – Reactor Feedwater System

**K/A STATEMENT:**

A4 Ability to manually operate and/or monitor in the control room:  
A4.05 Reactor Water Level ..... 4.0 / 3.9

**Maintenance Rule Safety Classification:**

N2100-06

**Maintenance Rule Risk Significant? (Yes or No)**

No

JOB PERFORMANCE MEASURE

JPM Title Transfer Feedwater Control from Long Cycle Cleanup to Startup Level Control	No.: JP-OP-315-0107-002 Revision: 1 Page 4
---	--

PERFORMANCE EVALUATION

Start Time \_\_\_\_\_

ELEMENT		STANDARD	
<b>NOTE:</b>			
<b>CUE: Provide examinee with Cue Sheet.</b>			
1.	[5.1.2.2] Place or verify, RPV Startup LCV Mode Switch in START. If C32-K816, FW & RR Flat Panel Display, is available, verify DCS logic is in START.	1.	RPV Startup LCV Mode Switch is verified in START. DCS logic is verified in START.
2.	[5.1.2.3.a] Verify Feedwater Logic white POST SCRAM light is OFF.	2.	Feedwater Logic white POST SCRAM light is verified OFF.
3.	[5.1.2.3.b] Verify Reactor Water Level Set Down white POST SCRAM light is OFF.	3.	Reactor Water Level Set Down white POST SCRAM light is verified OFF.
4.	[5.1.2.4] Place or verify C32-R620, N21-F403 RPV Startup LCV Controller, in MANUAL.	4.	C32-R620, N21-F403 RPV Startup LCV Controller, is placed in MANUAL.
5.	[5.1.2.5] Place or verify, Level Control Mode switch in 1 ELEM. If C32-K816, FW & RR Flat Panel Display, is available, verify DCS logic is in 1 ELEMENT.	5.	Level Control Mode switch is placed in 1 ELEM. DCS logic is verified in 1 ELEMENT.
<b>NOTE: This step is performed while verifying that N20-F404 throttles. If N20-F404 fails to throttle, N2000-F618 must be manually throttled to maintain proper flow.</b>			
* 6.	[5.1.2.6] Adjust output of C32-R620, N21-F403 RPV Startup LCV Controller, to 0% (COP H11-P603), while maintaining Condensate flow rate at approximately 9000 gpm, as indicated on N20-R815, Cond To Cond F/D's Flow Recorder.	* 6.	Output of C32-R620, N21-F403 RPV Startup LCV Controller, is adjusted to 0% while maintaining Condensate flow rate at approximately 9000 gpm.
* 7.	[5.1.2.7] Close N2100-F604, Fw Htr 6N Cond Rtrn to Cndr Vlv, and N2100-F605, Fw Htr 6S Cond Rtrn to Cndr Vlv.	* 7.	N2100-F604 and N2100-F605 are closed.
* 8.	[5.1.2.8] Open N2100-F601, Fw Htr 6N Outlet Iso Valve, and N2100-F602, Fw Htr 6S Outlet Iso Valve.	* 8.	N2100-F601 and N2100-F602 are opened.
<b>CUE: Report as NO that disconnect switch MCC 72A-4A Position 4A, is in OFF for N2100-F604.</b>			
9.	[5.1.2.9] Place disconnect switch MCC 72A-4A, Position 4A, in OFF for N2100-F604, Fw Htr 6N Cond Rtrn to Cndr Vlv.	9.	Directs NO to place disconnect switch MCC 72A-4A, Position 4A, in OFF for N2100-F604.
<b>CUE: Report as NO that disconnect switch MCC 72R-2A Position 3C, is in OFF for N2100-F605.</b>			
10.	[5.1.2.10] Place disconnect switch MCC 72R-2A, Position 3C, in OFF for N2100-F605, Fw Htr 6S Cond Rtrn to Cndr Vlv.	10.	Directs NO to place disconnect switch MCC 72R-2A, Position 3C, in OFF for N2100-F605.

JOB PERFORMANCE MEASURE

JPM Title Transfer Feedwater Control from Long Cycle Cleanup to Startup Level Control	No.: JP-OP-315-0107-002 Revision: 1 Page 5
---	--

ELEMENT		STANDARD	
<b>NOTE: This step is performed while verifying that N20-F404 throttles. If N20-F404 fails to throttle, N2000-F618 must be manually throttled to maintain proper flow.</b>			
*11.	[5.1.2.11] Slowly adjust output of C32-R620, N21-F403 RPV Startup LCV Controller, to open N21-F403, RPV Startup LCV, until RPV water level starts to rise, while maintaining Condensate flow rate at approximately 9000 gpm.	*11.	Output of C32-R620, N21-F403 RPV Startup LCV Controller, is adjusted until RPV water level starts to rise while maintaining Condensate flow rate at approximately 9000 gpm.
*12.	[5.1.2.12] <b>WHEN</b> desired RPV water level is reached (Level 4 to Level 7), place C32-R620, N21-F403 RPV Startup LCV Controller, in AUTO.	*12.	C32-R620, N21-F403 RPV Startup LCV Controller, is placed in AUTO when desired RPV level is reached.
13.	[5.1.2.13] Adjust RPV water level setpoint to maintain desired Reactor Water Level (Level 4 to Level 7).	13.	RPV water level setpoint is adjusted to maintain desired Reactor Water Level.
<b>CUE: End JPM when Feedwater is in Startup Level Control.</b>			

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* **Critical Step**

## JOB PERFORMANCE MEASURE

JPM Title Transfer Feedwater Control from Long Cycle Cleanup to Startup Level Control	No.: JP-OP-315-0107-002 Revision: 1 Page 6
---	--

### Evaluator Notes:

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

### Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

### System Specific Notes and Cues:

None

### Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

### Critical Steps:

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Transfer Feedwater Control from Long Cycle Cleanup to Startup Level Control	No.: JP-OP-315-0107-002 Revision: 1 Page 7
---	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Transfer Feedwater Control from Long Cycle Cleanup to Startup Level Control	No.: JP-OP-315-0107-002 Revision: 1 Page 8
---	--

**Simulator Setup**

**IC#:**

IC-05

**Malfunctions:**

Number	Title	Value	Delay	Ramp
--------	-------	-------	-------	------

**Remote Functions:**

Number	Title	Value	Delay	Ramp
--------	-------	-------	-------	------

**Override Functions:**

Number	Title	Value	Delay	Ramp
--------	-------	-------	-------	------

**Special Instructions:**

1. Initialize the simulator to IC-05, and place in RUN.
2. If necessary, insert control rods to stabilize power.
3. **Verify Long Cycle Cleanup is established.**
4. **Establish RWCU blowdown flow of about 60 gpm.**

**Cue Sheet: (JP-OP-315-0107-002)**

**Initial Conditions:**

- You are the Control Room NSO.
- Plant startup is in progress. The reactor is just critical. Pressurization is to begin.
- Feedwater is in Long Cycle Cleanup mode. Chemistry has reported Condensate and Feedwater chemistry is within the administrative limits.

**Initiating Cue(s):**

The CRS directs you to transfer Feedwater Control from Long Cycle Cleanup to Startup Level Control per 23.107.

JOB PERFORMANCE MEASURE

Job Position SRO / RO	No. JP-OP-315-0110-407	Revision 0
JPM Title Conduct Control Rod Drive Coupling Integrity Test with Coupling Failure	Duration 15 minutes	Page 1

Examinee: \_\_\_\_\_ SRO / RO

Evaluator: \_\_\_\_\_

JPM Type: Normal / **Alternate Path** / Time Critical Start Time \_\_\_\_\_

Evaluation Method: **Perform** / Walkthrough / Discuss Stop Time \_\_\_\_\_

Location: Plant / **Simulator** / Classroom Total Time: \_\_\_\_\_

PERFORMANCE EVALUATION SUMMARY											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
* 1.				*11.							
* 2.				12.							
3.				13.							
4.				*14.							
5.											
6.											
7.											
* 8.											
* 9.											
*10.											

OPERATOR FUNDAMENTALS OBSERVATION				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS** \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

**JOB PERFORMANCE MEASURE**

<p>JPM Title Conduct Control Rod Drive Coupling Integrity Test with Coupling Failure</p>	<p align="right">No.: JP-OP-315-0110-407 Revision: 0 Page 2</p>
--	---

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses “stop when unsure” if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Conduct Control Rod Drive Coupling Integrity Test with Coupling Failure	No.: JP-OP-315-0110-407 Revision: 0 Page 3
---	--

**JPM Information**

**System:**

C1102 – Control Drive and Drive Mechanism

**Task:**

74311 - Perform actions for Control Rod re-coupling not successful OR Control Rod cannot be verified coupled

**References:** Required (R) / Available (A)

AOP 20.106.02 (R)  
SOP 23.623 (R)  
ARPs 3D76 & 3D80 (A)

**Tools and Equipment Required:**

Marked up 23.623, Attachment 2

**Initial Conditions:**

- A plant startup is in progress.
- Reactor power level is ~55%.
- You are the P603 operator.

**Initiating Cue(s):**

The CRS directs you to continue the reactor startup with rods on Post-LPSP Control Rod Pull Sheet A-9/2, RWM-Step 49, from control rod 14-47. I will act as your Verifier.

**Terminating Cue(s):**

Control Rod 14-47 is disarmed in accordance with 20.106.02.

**Task Standard:**

CRD Coupling Integrity Test is performed in accordance with 23.623. Control Rod 14-47 is disarmed in accordance with 20.106.02.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function/Category:**

1 – Reactivity Control  
11 – Abnormal Plant Evolutions

**K/A Reference:**

**K/A SYSTEM:** 201003 - Control Rod and Drive Mechanism

**K/A STATEMENT:**

A2 Ability to (a) predict the impacts of the following on the CONTROL ROD AND DRIVE MECHANISM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: (CFR: 41.5 / 45.6)

A2.02 Uncoupled rod . . . . . 3.7 / 3.8

**Maintenance Rule Safety Classification:**

B1100-07

**Maintenance Rule Risk Significant? (Yes or No)**

No

JOB PERFORMANCE MEASURE

JPM Title Conduct Control Rod Drive Coupling Integrity Test with Coupling Failure	No.: JP-OP-315-0110-407 Revision: 0 Page 4
---	--

**PERFORMANCE EVALUATION**

Start Time \_\_\_\_\_

ELEMENT	STANDARD
<b>CUE: Provide examinee with Cue Sheet, Rod Pull Sheet, and marked up 23.623, Attachment 2.</b>	
<b>NOTE: Rod can be continuously withdrawn using Override vs. notching out.</b>	
* 1. Turn on Rod Select Power.	* 1. Informs CRS, then turns on Rod Select Power.
* 2. Begin withdrawing Control Rod 14-47 from Position 18 to 48 by notching rod, or continuously withdrawing iaw 23.623.	* 2. Rod Movement Control taken to OUT NOTCH. When the settle function is complete, this step is repeated until the rod is at Position 48.  OR Rod Out Notch Override taken to OVERRD and Rod Movement Control taken to OUT NOTCH.
<b>NOTE: When rod 14-47 reaches Position 48, the Four-Rod Display indicates blank, annunciators 3D76 and 3D80 alarm, and the rod's DRIFT light indicates on the Full Core Display.</b>	
<b>Alternate Path Begins Here</b>	
3. Respond to 3D76 alarm. Inform CRS of rod overtravel past Position 48.	3. CRS is informed of overtravel.
4. [IR 1.] Verify Control Rod overtravel at 4-Rod Display by checking that no position number is indicated in window and Full Out light on the Full Core Display is out.	4. 4-Rod Display and Full Core Display is checked for selected rod.
5. [IR 2.] Verify 3D80, CONTROL ROD DRIFT, is received.	5. 3D80, CONTROL ROD DRIFT, is verified to be in alarm.
<b>CUE: The CRS will direct the performance of AOP 20.106.02, Condition C.</b>	
6. [IR 3.] Recommend CRS enters 20.106.02.	6. Recommends entering 20.106.02.
<b>CUE: If asked, the CRS will contact the SNE to evaluate the rod pattern.</b>	
7. [C.1] Direct the Station Nuclear Engineer to evaluate the effect on Control Rod Pattern.	7. Station Nuclear Engineer contacted.
* 8. [C.2.a] Insert CRD in notch mode until nuclear instrumentation indicates Control Rod is being inserted.	* 8. Uncoupled rod is inserted one notch at a time until nuclear instrumentation indicates Control Rod is being inserted.
<b>NOTE: The operator MAY elect to reset the rod drift per 3D80 SA 2. At some point after the overtravel condition is resolved; however this is not a critical task.</b>	
<b>CUE: The SM and SNE give permission to withdraw control rod.</b>	
* 9. [C.2.b] Obtain permission from the SM and SNE to withdraw Control Rod.	* 9. Requests permission from the SM and SNE to withdraw Control Rod.

JOB PERFORMANCE MEASURE

JPM Title Conduct Control Rod Drive Coupling Integrity Test with Coupling Failure	No.: JP-OP-315-0110-407 Revision: 0 Page 5
---	--

ELEMENT	STANDARD
*10. [C.2.c] Fully withdraw Control Rod in notch mode while observing nuclear instrumentation response.	*10. Rod Movement Control taken to OUT NOTCH. When the settle function is complete, this step is repeated until the rod is at Position 48.
<b>NOTE: The following steps are directed by 20.106.02, step C.2.d, and performed per 23.623.</b>	
*11. [6.1.2.2.a] Attempt to withdraw Control Rod from Position 48 by notching rod.	*11. Rod Movement Control taken to OUT NOTCH.
12. [6.1.2.2.b] Verify Control Rod is coupled as follows: 1) Rod settling back to Position 48. 2) Annunciator 3D76, CONTROL ROD OVERTRAVEL, does not alarm.	12. Identifies rod does not settle back to Position 48 and 3D76 alarms. The selected control rod is <b>NOT</b> coupled.
<b>CUE: The CRS acknowledges the report, then directs the performance of AOP 20.106.02, Conditions E.2 and E.3.</b>	
13. Inform CRS that control rod 14-47 re-coupling is not successful.	13. CRS is informed that control rod 14-47 re-coupling is not successful.
*14. [E.2] Fully insert Control Rod.	*14. Control Rod 14-47 is fully inserted.
<b>CUE: Notify Examinee that time compression may be used for activities performed outside of the Control Room. Report that amphenols are disconnected, or C11-F103 and C11-F105 are closed, whichever has been directed.</b>	
15. [E.3] Disarm affected HCU by one of the following methods: - Disconnect amphenols to directional control valves. OR - Close C11-F103, then C11-F105	15. NO directed to disarm HCU 14-47 by one of the following methods: - Disconnect amphenols to directional control valves. OR - Close C11-F103, then C11-F105
<b>CUE: End the JPM when Control Rod 14-47 is disarmed in accordance with 20.106.02.</b>	

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* **Critical Steps**

## JOB PERFORMANCE MEASURE

JPM Title Conduct Control Rod Drive Coupling Integrity Test with Coupling Failure	No.: JP-OP-315-0110-407 Revision: 0 Page 6
---	--

### Evaluator Notes:

Provide the examinee the pull sheets for the next control rod to be withdrawn to position 48 (LPSP Pull Sheet A-9/2, RWM-Step: 49, marked with rods pulling from 18 to 48) and 23.623 Attachment 2 marked up with current rod pattern.

This JPM can be performed at low power (startup) or at higher power (control rod pattern adjustment). If this JPM is being performed at low power, provide normal pull sheets; if being performed at high power provide rod pattern adjustment sheets.

The examiner will act as the SNE to verify the correct control rod is selected for movement.

The trainee may jump directly to 20.106.02 vs. reviewing ARP 3D76 or 3D80.

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

### Generic Notes and Cues:

None

### System Specific Notes and Cues:

None

### Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

### Critical Steps:

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Conduct Control Rod Drive Coupling Integrity Test with Coupling Failure	No.: JP-OP-315-0110-407 Revision: 0 Page 7
---	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

Reference:

---

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

Reference

---

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Conduct Control Rod Drive Coupling Integrity Test with Coupling Failure	No.: JP-OP-315-0110-407 Revision: 0 Page 8
---	--

**Simulator Setup**

**IC#:**

IC-15

**Malfunctions:**

<b>Number</b>	<b>Title</b>	<b>Value</b>	<b>Delay</b>	<b>Ramp</b>
C11MF0233	CONTROL ROD 14-47 UNCOUPLED	ACTIVE	0	0

**Remote Functions:**

<b>Number</b>	<b>Title</b>	<b>Value</b>	<b>Delay</b>	<b>Ramp</b>
C11RF0398	Re-Initialize NUMAC RWM	RESET	0	0

**Override Functions:**

<b>Number</b>	<b>Title</b>	<b>Value</b>	<b>Delay</b>	<b>Ramp</b>
None				

**Special Instructions:**

1. Initialize the simulator to IC-15 (or the selected IC), and place the simulator in RUN.
3. Open and Execute Lesson JP0110-407.Isn, or set the malfunctions as indicated above.

**Cue Sheet: (JP-OP-315-0110-407)**

**Initial Conditions:**

- A plant startup is in progress.
- Reactor power level is ~55%.
- You are the P603 operator.

**Initiating Cue(s):**

The CRS directs you to continue the reactor startup with rods on Post-LPSP Control Rod Pull Sheet A-9/2, RWM-Step 49, from control rod 14-47. I will act as your Verifier.

**JOB PERFORMANCE MEASURE**

Job Position SRO / RO	No. JP-OP-315-0262-003	Revision 1
JPM Title Transfer UPS from Normal to Alternate Power using Static Transfer Switch (Alt Path)	Duration 10 minutes	Page 1

Examinee: \_\_\_\_\_ SRO / RO

Evaluator: \_\_\_\_\_

JPM Type:                    Normal / **Alternate Path** / Time Critical                    Start Time \_\_\_\_\_

Evaluation Method:       Perform / **Walkthrough** / Discuss                                    Stop Time \_\_\_\_\_

Location:                    **Plant** / Simulator / Classroom    Total Time: \_\_\_\_\_

<b>PERFORMANCE EVALUATION SUMMARY</b>											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
* 1.				*11.				21.			
2.				12.							
3.				13.							
4.				*14.							
* 5.				15.							
6.				16.							
7.				*17.							
8.				*18.							
9.				19.							
10.				20.							

<b>OPERATOR FUNDAMENTALS OBSERVATION</b>				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Transfer UPS from Normal to Alternate Power using Static Transfer Switch (Alt Path)	No.: JP-OP-315-0262-003 Revision: 1 Page 2
---	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Transfer UPS from Normal to Alternate Power using Static Transfer Switch (Alt Path)	No.: JP-OP-315-0262-003 Revision: 1 Page 3
--	--

**JPM Information**

**System:**

R3100 - Uninterruptible Power Supply

**Task:**

78271 - Transfer Uninterruptible Power Supply from Normal to Alternate Power using Static Transfer Switch

**References:** Required (R) / Available (A)

23.308.01, Uninterruptible Power Supply (UPS) System (R)

**Tools and Equipment Required:**

None

**Initial Conditions:**

You are the extra operator on shift.

**Initiating Cue(s):**

The Control Room NSO directs you to shift UPS A (B) Power Supply from Normal to Alternate using the Static Transfer Switch.

**Terminating Cue(s):**

UPS A(B) has been transferred back to the normal power supply using the Static Transfer Switch.

**Task Standard:**

UPS is in service aligned to the Normal Power Supply in accordance with 23.308.01.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

SF-6 Electrical

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** 262002 - Uninterruptable Power Supply (A.C./D.C.)

**K/A STATEMENT:**

A2. Ability to (a) predict the impacts of UPS bus under voltage; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences

A2.01 Under Voltage ..... 2.6 / 2.8

**Maintenance Rule Safety Classification:**

R3100-05

**Maintenance Rule Risk Significant? (Yes or No)**

No

JOB PERFORMANCE MEASURE

JPM Title Transfer UPS from Normal to Alternate Power using Static Transfer Switch (Alt Path)	No.: JP-OP-315-0262-003 Revision: 1 Page 4
---	--

PERFORMANCE EVALUATION

Start Time \_\_\_\_\_

ELEMENT		STANDARD	
<b>CUE: Provide Examinee with Cue Sheet.</b>			
<b>CUE: Return Mode switch is in MAN.</b>			
* 1.	[5.1.2.1] Place Return Mode switch in MAN (Mimic Bus).	* 1.	Places Return Mode switch in MAN.
<b>CUE: Sync Switch is in ON.</b>			
2.	[5.1.2.2] Verify Sync Switch is in ON.	2.	Verifies Sync Switch is in ON.
<b>CUE: Retransfer Blocked light is ON.</b>			
3.	[5.1.2.3] Verify amber Retransfer Blocked light is ON.	3.	Verifies amber Retransfer Blocked light is ON.
<b>CUE: Sync Monitor light is OFF.</b>			
4.	[5.1.2.4] Verify clear Sync Monitor light is OFF (Mimic Bus).	4.	Verifies clear Sync Monitor light is OFF.
<b>CUE: Test switch is in ALT LINE.</b>			
* 5.	[5.1.2.5] Place Test switch to ALT LINE (Mimic Bus).	* 5.	Places Test switch to ALT LINE.
<b>CUE: Alternate Line light is ON.</b>			
6.	[5.1.2.6] Verify amber Alternate Line light is ON (Mimic Bus).	6.	Verifies amber Alternate Line light is ON.
<b>CUE: Inverter light is OFF.</b>			
7.	[5.1.2.7] Verify red Inverter light is OFF (Mimic Bus).	7.	Verifies red Inverter light is OFF.
<b>Alternate Path Begins Here</b>			
<b>CUE: Control Room reports the UPS UNIT A/B TROUBLE alarm (3D22) has been received and requests local status of UPS Unit A(B).</b>			
<b>CUE: When examinee requests UPS Unit status, report that amber REGULATOR FAILURE light is ON, and the Static Transfer Switch Output voltage (UPS Regulator Output AC VOLTAGE) is reading 100 VAC.</b>			
<b>CUE: If examinee turns around to look at the B(A) UPS panel, report all indications on that panel are normal.</b>			
<b>NOTE: Examinee should recognize failure of Alternate Regulator Output. This requires UPS to be transferred back to Normal.</b>			
<b>CUE: As Control Room, acknowledge status report. If not recommended by examinee, direct UPS transferred back to NORMAL (per 3D22).</b>			
8.	Determine status of UPS Unit A(B).	8.	Reports UPS Unit status to Control Room.
<b>CUE: Alternate Line light is ON.</b>			
9.	[5.2.2.1] Verify amber Alternate Line light is ON (Mimic Bus).	9.	Verifies amber Alternate Line light is ON.
<b>CUE: Return Mode switch is in MAN.</b>			
10.	[5.2.2.2] Verify or place Return Mode switch in MAN (Mimic Bus).	10.	Verifies Return Mode switch in MAN.

JOB PERFORMANCE MEASURE

JPM Title Transfer UPS from Normal to Alternate Power using Static Transfer Switch (Alt Path)	No.: JP-OP-315-0262-003 Revision: 1 Page 5
--	--

ELEMENT		STANDARD	
<b>CUE: Test switch is in CENTER. ( It may have been placed in CENTER in step 5.1.2.7)</b>			
*11.	[5.2.2.3] Verify or place Test switch in CENTER (Mimic Bus).	*11.	Places Test switch in CENTER.
<b>CUE: Sync Switch is in ON</b>			
12.	[5.2.2.4] Verify Sync Switch is in ON.	12.	Verifies Sync Switch is in ON.
<b>CUE: Sync Monitor light is OFF.</b>			
13.	[5.2.2.5] Verify clear Sync Monitor light is OFF (Mimic Bus).	13.	Verifies clear Sync Monitor light is OFF.
<b>CUE: Reset pushbutton is depressed.</b>			
*14.	[5.2.2.6] Depress Reset pushbutton (Mimic Bus).	*14.	Depresses Reset pushbutton.
<b>CUE: Red Inverter light is ON.</b>			
15.	[5.2.2.7] Verify red Inverter light is ON (Mimic Bus).	15.	Verifies red Inverter light is ON.
<b>CUE: Alternate Line light is OFF.</b>			
16.	[5.2.2.8] Verify amber Alternate Line light is OFF (Mimic Bus).	16.	Verifies amber Alternate Line light is OFF.
<b>CUE: Return Mode switch is in AUTO.</b>			
*17.	[5.2.2.9] Place Return Mode switch in AUTO (Mimic Bus).	*17.	Places Return Mode switch in AUTO.
<b>CUE: Alarm Latch Reset pushbutton is depressed.</b>			
*18.	[5.2.2.10] Depress Alarm Latch Reset pushbutton (Mimic Bus).	*18.	Depresses Alarm Latch Reset pushbutton.
<b>CUE: Retransfer Blocked light is OFF.</b>			
19.	[5.2.2.11] Verify amber Retransfer Blocked light is OFF.	19.	Verifies amber Retransfer Blocked light is OFF.
<b>CUE: Summary Alarm light is OFF.</b>			
20.	[5.2.2.12] Verify amber Summary Alarm light is OFF (Mimic Bus).	20.	Verifies amber Summary Alarm light is OFF.
<b>CUE: The CRS acknowledges the report.</b>			
21.	Inform the Control Room that UPS A (B) has been transferred back to the normal power supply using the Static Transfer Switch.	21.	Informs the Control Room that UPS A (B) is aligned to the normal power supply.
<b>CUE: End JPM when UPS A(B) has been transferred back to the normal power supply using the Static Transfer Switch.</b>			

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* Critical Step

## JOB PERFORMANCE MEASURE

JPM Title Transfer UPS from Normal to Alternate Power using Static Transfer Switch (Alt Path)	No.: JP-OP-315-0262-003 Revision: 1 Page 6
---	--

### Evaluator Notes:

Start this JPM at the UPS. This JPM can be performed on either UPS.

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

### Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Ex.: Pump start: "Switch has been rotated to the start position, red light is lit, green light is out, amperage initially pegs out high, and is now indicating   X   amps."

Pump stop: "Switch has been rotated to the stop position, green light is lit, red light is out, amperage indicates 0 amps."

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

Manual valves are checked in the closed direction (MOP02 and MOP05). Valve stem position may aid in valve position determination, but cannot be used as Independent Verification (MOP02).

Ex.: Verify valve closed: "Valve handwheel indicates no valve movement in the clockwise direction."

Verify valve open: "Valve handwheel has been rotated slightly in the clockwise direction and returned to the original positions."

Closing a valve: "Valve handwheel has been rotated in the fully clockwise direction until no additional valve movement. Valve stem is down."

Opening a valve: "Valve handwheel has been rotated in the fully counterclockwise direction until no additional valve movement, valve stem is out."

Controllers have an Auto light that is GREEN when selected and AMBER (YELLOW) when Manual is selected. When in Manual, the open and closed pushbuttons control the parameter to be changed by adjusting position or speed. When the deviation meter is nulled, then the process can be shifted to Auto to allow the desired setpoint to control the process.

### System Specific Notes and Cues:

None

### Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

### Critical Steps:

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Transfer UPS from Normal to Alternate Power using Static Transfer Switch (Alt Path)	No.: JP-OP-315-0262-003 Revision: 1 Page 7
---	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Transfer UPS from Normal to Alternate Power using Static Transfer Switch (Alt Path)	No.: JP-OP-315-0262-003 Revision: 1 Page 8
---	--

**Simulator Setup**

**IC#:**

N/A

**Malfunctions:**

Number	Title	Value	Delay	Ramp
N/A				

**Remote Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Override Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Special Instructions:**

N/A

**Cue Sheet: (JP-OP-315-0262-003)**

**Initial Conditions:**

You are the extra operator on shift.

**Initiating Cue(s):**

The Control Room NSO directs you to shift UPS A (B) Power Supply from Normal to Alternate using the Static Transfer Switch.

**JOB PERFORMANCE MEASURE**

Job Position SRO / RO	No. JP-OP-802-3006-321	Revision 3
JPM Title Defeat RBCCW/EECW to Drywell Isolations	Duration 25 minutes	Page 1

Examinee: \_\_\_\_\_ SRO / RO

Evaluator: \_\_\_\_\_

JPM Type:                    **Normal** / Alternate Path / Time Critical                    Start Time \_\_\_\_\_  
 Evaluation Method:       Perform / **Walkthrough** / Discuss                                    Stop Time \_\_\_\_\_  
 Location:                    **Plant** / Simulator / Classroom    Total Time: \_\_\_\_\_

<b>PERFORMANCE EVALUATION SUMMARY</b>											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
* 1.											
* 2.											
* 3.											

<b>OPERATOR FUNDAMENTALS OBSERVATION</b>				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Defeat RBCCW/EECW to Drywell Isolations	No.: JP-OP-802-3006-321 Revision: 3 Page 2
--	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Defeat RBCCW/EECW to Drywell Isolations	No.: JP-OP-802-3006-321 Revision: 3 Page 3
--	--

**JPM Information**

**System:**

P4400 - EECW / RBCCW

**Task:**

51995 - Defeat RBCCW/EECW Cooling Water to Drywell Isolations

**References:** Required (R) / Available (A)

29.ESP.23, Defeat of RBCCW/EECW to Drywell (R)  
ODE-14, Attachment 9, Energized Equipment Work Permit (A)

**Tools and Equipment Required:**

None

**Initial Conditions:**

- You are the Control Room NSO.
- EOP flowcharts direct defeat of RBCCW/EECW Isolations.

**Initiating Cue(s):**

The CRS directs you to defeat RBCCW/EECW Isolations per 29.ESP.23.

**Terminating Cue(s):**

RBCCW/EECW Isolation is defeated per 29.ESP.23.

**Task Standard:**

RBCCW/EECW Isolation is defeated per 29.ESP.23.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

SF-8 Plant Service Systems

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** 295024 - High Drywell Pressure  
**K/A STATEMENT:**  
EA1. Ability to operate and/or monitor the following as they apply to HIGH DRYWELL PRESSURE:  
EA 1.07PCIS/NSSSS..... 3.8 / 3.9

**Maintenance Rule Safety Classification:**

P4400-01

**Maintenance Rule Risk Significant? (Yes or No)**

Yes

JOB PERFORMANCE MEASURE

JPM Title Defeat RBCCW/EECW to Drywell Isolations	No.: JP-OP-802-3006-321 Revision: 3 Page 4
--	--

**PERFORMANCE EVALUATION**

Start Time \_\_\_\_\_

ELEMENT		STANDARD	
<b>NOTE: Cues are indicated on the line above (just prior to) the step for which they are/may be required.</b>			
<b>CUE: Provide examinee with Cue Sheet. After SM EOP Locker is opened, provide examinee with copy of 29.ESP.23 and ODE-14, Attachment 9.</b>			
* 1.	[1.1] Retrieve EOP Defeat Package from SM EOP Locker.	* 1.	EOP Defeat Package retrieved from SM EOP Locker.
<b>NOTE: While working in the Relay Room panels, all conductive jewelry should be removed, and safety glasses and 100% cotton long sleeves should be worn.</b>			
<b>CUE: The Lead at Terminal B-171 is lifted.</b>			
* 2.	[2.1] At RR H11-P857, lift lead at Terminal B-171 (Division 1).	* 2.	Lead at Terminal B-171 lifted.
<b>CUE: The Lead at Terminal E-191 is lifted.</b>			
* 3.	[2.2] At RR H11-P870, lift lead at Terminal E-191 (Division 2).	* 3.	Lead at Terminal E-191 lifted.
<b>CUE: End JPM when RBCCW/EECW Isolation is defeated per 29.ESP.23.</b>			

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* Critical Step

## JOB PERFORMANCE MEASURE

JPM Title Defeat RBCCW/EECW to Drywell Isolations	No.: JP-OP-802-3006-321 Revision: 3 Page 5
--	--

### Evaluator Notes:

Ensure SM informed of JPM walkthrough in relay room and cabinet doors opened for walkthrough of this task.

**Stop** the JPM if, at any time, this JPM interferes with plant operation.

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

### Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Ex.: Pump start: "Switch has been rotated to the start position, red light is lit, green light is out, amperage initially pegs out high, and is now indicating  X  amps."

Pump stop: "Switch has been rotated to the stop position, green light is lit, red light is out, amperage indicates 0 amps."

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

Manual valves are checked in the closed direction (MOP02 and MOP05). Valve stem position may aid in valve position determination, but cannot be used as Independent Verification (MOP02).

Ex.: Verify valve closed: "Valve handwheel indicates no valve movement in the clockwise direction."

Verify valve open: "Valve handwheel has been rotated slightly in the clockwise direction and returned to the original positions."

Closing a valve: "Valve handwheel has been rotated in the fully clockwise direction until no additional valve movement. Valve stem is down."

Opening a valve: "Valve handwheel has been rotated in the fully counterclockwise direction until no additional valve movement, valve stem is out."

Controllers have an Auto light that is GREEN when selected and AMBER (YELLOW) when Manual is selected. When in Manual, the open and closed pushbuttons control the parameter to be changed by adjusting position or speed. When the deviation meter is nulled, then the process can be shifted to Auto to allow the desired setpoint to control the process.

### System Specific Notes and Cues:

ESP Defeats are installed either by installing a jumper, lifting leads, or removing a plug-in relay or fuse.

#### Installing Jumpers:

- Ensure the operator goes to the SM and obtains the key to the EOP cabinet.
- Upon unlocking the cabinet, the operator finds the correct package and ensures the proper equipment is in the package.
- Per the attached drawing, locate the panel and verify the panel opened is correct and the operator has opened the correct side door.
- Within the panel, locate the proper terminal strip and verify that the proper terminal number is selected.
- Using proper safety techniques, a jumper is landed on each terminal ensuring that no other terminal is touched or cabinet ground is touched with the free end.
- Repeat until all jumpers are installed per the package.
- For some cabinets, the terminals are separated load to source side of the terminal point by a Knife Switch. In these cabinets the direction of the ESP has the knife switch screw unlocked and opened prior to installing the defeat. This will be spelled out and then the same rules as above apply.

## JOB PERFORMANCE MEASURE

JPM Title Defeat RBCCW/EECW to Drywell Isolations	No.: JP-OP-802-3006-321 Revision: 3 Page 6
--	--

- When both ends are safely landed on all jumpers per the package in the proper location, the operator calls the control room and informs them that the defeat is installed.

### **Lifting Leads:**

- Ensure the operator goes to the SM and obtains the key to the EOP cabinet.
- Upon unlocking the cabinet, the operator finds the correct package and ensures the proper equipment is in the package.
- Per the attached drawing, locate the panel and verify the panel opened is correct and the operator has opened the correct side door.
- Within the panel, locate the proper terminal strip and verify that the proper terminal number is selected.
- Using the proper safety techniques, remove the locking screw and remove the wire from the terminal point keeping it from making contact with the other cabinet wiring or cabinet sides.
- Tape the wire electrical end or install the boot provided.
- For some terminal points, more than one wire will be terminated at the proper point. For these, the instruction will read " Lift and separate leads". This means remove the leads safely and place each into boots or tape separately.
- For some cabinets, the terminals are separated load to source side of the terminal point by a Knife Switch. In these cabinets the direction of the ESP has the knife switch screw unlocked and opened prior to installing the defeat. This will be spelled out and then the same rules as above apply.
- When all leads are removed per the package in the proper location, the operator calls the control room and informs them that the defeat is complete.

### **Remove Plug-in Relay or Fuse:**

- Ensure the operator goes to the SM and obtains the key to the EOP cabinet.
- Upon unlocking the cabinet, the operator finds the correct package and ensures the proper equipment is in the package.
- Per the attached drawing, locate the panel and verify the panel opened is correct and the operator has opened the correct side door.
- Locate the plug-in relay or fuse and verify the defeat package to the relay, or fuse in question, labels.
- Plug-in relays have seismic clips which need to be removed first and then grasped on either side and pulled straight back out of the cabinet.
- Fuses need to be grasped by fuse pullers and pulled out evenly and in one motion. There is a fuse identifier mylar cover on some fuses which needs to be removed to reach the fuse.
- The one exception is the Main Turbine Bypass Dump System fuses which set in the H11P632 cabinet in a fuse block. FS59 & FS60 are contained in a block that can be pulled out much like the plug-in relay without the seismic clip.
- When all steps are complete, contact the control room and announce that the defeat is completed.

### **Task Performance and Cues:**

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

### **Critical Steps:**

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Defeat RBCCW/EECW to Drywell Isolations	No.: JP-OP-802-3006-321 Revision: 3 Page 7
--	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

Reference:

---

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

Reference

---

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Defeat RBCCW/EECW to Drywell Isolations	No.: JP-OP-802-3006-321 Revision: 3 Page 8
--	--

**Simulator Setup**

**IC#:**

N/A

**Malfunctions:**

Number	Title	Value	Delay	Ramp
N/A				

**Remote Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Override Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Special Instructions:**

N/A

**Cue Sheet: (JP-OP-802-3006-321)**

**Initial Conditions:**

- You are the CRNSO.
- EOP flowcharts direct defeat of RBCCW/EECW Isolations.

**Initiating Cue(s):**

The CRS directs you to defeat RBCCW/EECW Isolations per 29.ESP.23.

**JOB PERFORMANCE MEASURE**

Job Position SRO / RO / NO	No. JP-OP-315-0150-003	Revision 0
JPM Title Place RHRSW Radiation Monitor Sample Pump in Service	Duration 10 minutes	Page 1

Examinee: \_\_\_\_\_ SRO / RO / NO

Evaluator: \_\_\_\_\_

JPM Type:                    **Normal** / Alternate Path / Time Critical                    Start Time \_\_\_\_\_

Evaluation Method:       Perform / **Walkthrough** / Discuss    Stop Time \_\_\_\_\_

Location:                    **Plant** / Simulator / Classroom    Total Time: \_\_\_\_\_

<b>PERFORMANCE EVALUATION SUMMARY</b>											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
* 1.											
* 2.											
* 3.											
* 4.											
5.											
* 6.											

<b>OPERATOR FUNDAMENTALS OBSERVATION</b>				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**        \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Place RHRSW Radiation Monitor Sample Pump in Service	No.: JP-OP-315-0150-003 Revision: 0 Page 2
---	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Place RHRSW Radiation Monitor Sample Pump in Service	No.: JP-OP-315-0150-003 Revision: 0 Page 3
---	--

**JPM Information**

**System:**

D1100 – Process Liquid Radiation Monitoring System

**Task:**

62977 - Perform Residual Heat Removal Service Water Radiation Monitor D11-K801A (B) Operational Checkout

**References:** Required (R) / Available (A)

23.626, Process Liquid Radiation Monitoring System (R)

**Tools and Equipment Required:**

None

**Initial Conditions:**

- You are the Reactor Building Rounds Operator.
- The Control Room has just placed RHR Div 1 (2) in Torus Cooling.

**Initiating Cue(s):**

- The CRNSO directs you to place Division 1 (2) RHRSW Radiation Monitor Sample Pump in service per 23.626, Process Liquid Radiation Monitoring System, section 7.0.
- All prerequisites have been met.

**Terminating Cue(s):**

The RHRSW Radiation Monitor Sample Pump has been started.

**Task Standard:**

The RHRSW Radiation Monitor has been vented and the Sample Pump has been started in accordance with 23.626, Process Liquid Radiation Monitoring System, section 7.0.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

7 – Instrumentation  
9 – Radioactivity Release

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** 272000 - Radiation Monitoring System  
**K/A STATEMENT:**  
A1. Ability to predict and/or monitor changes in parameters associated with operating the RADIATION MONITORING SYSTEM including: (CFR: 41.5 / 45.5)  
A1.01 Lights, alarms, and indications associated with normal operations -----3.2/3.2

**Maintenance Rule Safety Classification:**

D1100-01

**Maintenance Rule Risk Significant? (Yes or No)**

Yes

JOB PERFORMANCE MEASURE

JPM Title Place RHRSW Radiation Monitor Sample Pump in Service	No.: JP-OP-315-0150-003 Revision: 0 Page 4
---	--

PERFORMANCE EVALUATION

Start Time \_\_\_\_\_

ELEMENT		STANDARD	
<b>NOTE: Provide examinee with Cue Sheet.</b>			
<b>CUE: After the examinee demonstrates/explains how he would obtain a controlled copy of the procedure, hand the examinee a copy of SOP 23.626, Section 7.0.</b>			
<b>CUE: D1100-F056A (F056B), RHRSW Div I (II) Radiation Monitor Vent Valve is Open. A few seconds later, report that a steady stream of water is flowing from vent line.</b>			
* 1.	[7.2.1] Open D1100-F056A (F056B), RHRSW Div I (II) Radiation Monitor Vent Valve, on Local Rack D11-P291 (P292).	* 1.	Opens D1100-F056A (F056B), RHRSW Div I (II) Radiation Monitor Vent Valve.
<b>CUE: D1100-F056A (F056B), RHRSW Div I (II) Radiation Monitor Vent Valve is Closed.</b>			
* 2.	[7.2.2] Close D1100-F056A (F056B), RHRSW Div I (II) Radiation Monitor Vent Valve, when a steady stream of water flows from vent line.	* 2.	Closes D1100-F056A (F056B) when a steady stream of water flows from vent line.
<b>CUE: D1100-F054A (F054B), RHRSW Div I (II) Radiation Monitor Vent Valve is Open. A few seconds later, report that a steady stream of water is flowing from vent line.</b>			
* 3.	[7.2.3] Open D1100-F054A (F054B), RHRSW Div I (II) Radiation Monitor Vent Valve, on Local Rack D11-P291 (P292).	* 3.	Opens D1100-F054A (F054B), RHRSW Div I (II) Radiation Monitor Vent Valve.
<b>CUE: D1100-F054A (F054B), RHRSW Div I (II) Radiation Monitor Vent Valve is Closed.</b>			
* 4.	[7.2.4] Close D1100-F054A (F054B), RHRSW Div I (II) Radiation Monitor Vent Valve, when a steady stream of water flows from vent line.	* 4.	Closes D1100-F054A (F054B) when a steady stream of water flows from vent line.
<b>CUE: Communication is established with the CRNSO. Acknowledge report that Sample Pump is to be started.</b>			
5.	[7.2.5] Establish communication with Control Room.	5.	Establishes communication with Control Room.
<b>CUE: The RHRSW Radiation Monitor Sample Pump control switch is in HAND. Report that the sample pump is running.</b>			
* 6.	[7.2.6] Locally at Rack D11-P291 (P292), start RHRSW Radiation Monitor Sample Pump by placing control switch in HAND.	* 6.	Places RHRSW Radiation Monitor Sample Pump control switch in HAND.
<b>CUE: Terminate the JPM when the RHRSW Radiation Monitor Sample Pump is started (control switch placed in HAND).</b>			

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* Critical Step

## JOB PERFORMANCE MEASURE

JPM Title Place RHRSW Radiation Monitor Sample Pump in Service	No.: JP-OP-315-0150-003 Revision: 0 Page 5
---	--

### Evaluator Notes:

Start this JPM from the Control Room.

Do not allow the examinee to operate any plant equipment.

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

### Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Ex.: Pump start: "Switch has been rotated to the start position, red light is lit, green light is out, amperage initially pegs out high, and is now indicating   X   amps."

Pump stop: "Switch has been rotated to the stop position, green light is lit, red light is out, amperage indicates 0 amps."

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

Manual valves are checked in the closed direction (MOP02 and MOP05). Valve stem position may aid in valve position determination, but cannot be used as Independent Verification (MOP02).

Ex.: Verify valve closed: "Valve handwheel indicates no valve movement in the clockwise direction."

Verify valve open: "Valve handwheel has been rotated slightly in the clockwise direction and returned to the original positions."

Closing a valve: "Valve handwheel has been rotated in the fully clockwise direction until no additional valve movement. Valve stem is down."

Opening a valve: "Valve handwheel has been rotated in the fully counterclockwise direction until no additional valve movement, valve stem is out."

Controllers have an Auto light that is GREEN when selected and AMBER (YELLOW) when Manual is selected. When in Manual, the open and closed pushbuttons control the parameter to be changed by adjusting position or speed. When the deviation meter is nulled, then the process can be shifted to Auto to allow the desired setpoint to control the process.

### System Specific Notes and Cues:

None

### Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

### Critical Steps:

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Place RHRSW Radiation Monitor Sample Pump in Service	No.: JP-OP-315-0150-003 Revision: 0 Page 6
---	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Place RHRSW Radiation Monitor Sample Pump in Service	No.: JP-OP-315-0150-003 Revision: 0 Page 7
---	--

**Simulator Setup**

**IC#:**

N/A

**Malfunctions:**

Number	Title	Value	Delay	Ramp
N/A				

**Remote Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Override Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Special Instructions:**

N/A

**Cue Sheet: (JP-OP-315-0150-003)**

**Initial Conditions:**

- You are the Reactor Building Rounds Operator.
- The Control Room has just placed RHR Div 1 (2) in Torus Cooling.

**Initiating Cue(s):**

- The CRNSO directs you to place Division 1 (2) RHRSW Radiation Monitor Sample Pump in service per 23.626, Process Liquid Radiation Monitoring System, section 7.0.
- All prerequisites have been met.

**JOB PERFORMANCE MEASURE**

Job Position SRO / RO	No. JP-OP-802-2001-211	Revision 5
JPM Title Control Reactor Pressure from the Remote Shutdown Panel (Alt Path)	Duration 20 minutes	Page 1

Examinee: \_\_\_\_\_ SRO / RO

Evaluator: \_\_\_\_\_

JPM Type:                    Normal / **Alternate Path** / Time Critical                    Start Time \_\_\_\_\_

Evaluation Method:        **Perform** / Walkthrough / Discuss                                    Stop Time \_\_\_\_\_

Location:                    Plant / **Simulator** / Classroom    Total Time: \_\_\_\_\_

<b>PERFORMANCE EVALUATION SUMMARY</b>											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
* 1.											
* 2.											
* 3.											
* 4.											
* 5.											
* 6.											
7.											

<b>OPERATOR FUNDAMENTALS OBSERVATION</b>				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Control Reactor Pressure from the Remote Shutdown Panel (Alt Path)	No.: JP-OP-802-2001-211 Revision: 5 Page 2
--	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

## JOB PERFORMANCE MEASURE

JPM Title Control Reactor Pressure from the Remote Shutdown Panel (Alt Path)	No.: JP-OP-802-2001-211 Revision: 5 Page 3
--	--

### JPM Information

**System:**

B2104 – Safety and Relief Valves

**Task:**

73750 - Control reactor pressure at the remote shutdown panel using SRVs.

**References:** Required (R) / Available (A)

AOP 20.000.19, Shutdown from Outside the Control Room (R)

**Tools and Equipment Required:**

None

**Initial Conditions:**

- You are the Control Room NSO.
- The control room is being evacuated due to toxic fumes making the control room uninhabitable.
- The East (A) CRD Pump control switch is in the RUN position in the main control room. Division 1 RHR is in its normal standby lineup.
- A Group 1 isolation has occurred.

**Initiating Cue(s):**

- The CRS directs you to control reactor pressure and level in accordance with AOP 20.000.19, Shutdown from Outside the Control Room.
- All prerequisites are complete.
- Conditions A through D have been completed, and you are to begin at Condition E.
- You are to inform the CRS when reactor pressure and level are being controlled.
- You may allow pressure to rise slightly above 1093 psig to allow Low-Low Set SRVs to arm and operate.

**Terminating Cue(s):**

Reactor level and pressure are being controlled in accordance with AOP 20.000.19.

**Task Standard:**

Reactor pressure and reactor water level are maintained within allowable limits from the Remote Shutdown Panel in accordance with 20.000.19 Shutdown from Outside the Control Room.

JOB PERFORMANCE MEASURE

JPM Title Control Reactor Pressure from the Remote Shutdown Panel (Alt Path)	No.: JP-OP-802-2001-211 Revision: 5 Page 4
--	--

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

3 – Reactor Pressure Control

**K/A Reference:** (from NUREG 1123)

K/A SYSTEM: 295016 – Control Room Abandonment  
K/A STATEMENT:  
AA1 Ability to operate and/or monitor the following as they apply to CONTROL ROOM  
ABANDONMENT : (CFR: 41.7 / 45.6)  
AA1.08 Reactor Pressure .....4.0 / 4.0

**Maintenance Rule Safety Classification:**

B2104-03

**Maintenance Rule Risk Significant? (Yes or No)**

Yes

JOB PERFORMANCE MEASURE

JPM Title Control Reactor Pressure from the Remote Shutdown Panel (Alt Path)	No.: JP-OP-802-2001-211 Revision: 5 Page 5
--	--

PERFORMANCE EVALUATION

Start Time \_\_\_\_\_

ELEMENT	STANDARD
<b>CUE: Provide the examinee the Cue Sheet.</b>	
* 1. [E.1] Position CMC switches to match those of the Main Control Room.	* 1. Places the East (A) CRD Pump CMC SWITCH in Run.
* 2. [E.2] Place the following transfer switches to ON: a. C3500-M130, Div. 2 DC Transfer Switch b. C3500-M131, BOP Transfer Switch c. C3500-M134, Swing Bus Transfer Switch d. C3500-M132, Div. I DC Transfer Switch e. C3500-M133, Div. I AC Transfer Switch	* 2. Rotates each switch clockwise about 45 degrees to the ON position.
* 3. [E.3] Place the RCIC Rm High Temp Isolation Defeat (Logic A) in BYPASS	* 3. Rotates the switch clockwise to the BYPASS position.
* 4. [E.4] Place the RCIC Rm High Temp Isolation Defeat (Logic B) in BYPASS.	* 4. Rotates the switch clockwise to the BYPASS position
<p><b>NOTE: The candidate may decide to control pressure first if level initially appears normal. If so, the candidate will return to this step later.</b></p> <p><b>The first equipment selected to control water level will fail, and the candidate will be forced to use the other. The candidate may send an operator to investigate the failure.</b></p>	
* 5. [E.5] Maintain Reactor Water Level between 174 and 214 inches using one of the following: a. RCIC b. CRD	* 5. Depresses and holds RCIC INITIATE pushbutton on the RSD Panel until flow is indicated on C35-R006, RCIC Pump Discharge Flow Indicator, or Operates the CRD pumps as necessary to control water level.
<b>Alternate Path Begins Here</b>	
<p><b>NOTE: Low-Low Set has failed. When the examinee recognizes the failure, he will be forced to manually use SRV A or B (first SRV selected fails to open) to control reactor pressure.</b></p>	
* 6. [E.6] Maintain Reactor Pressure between 900 and 1050 psig by using B2104-F013A and/or B2104-F013B.	* 6. Allows pressure to rise to observe SRV A operate in Low-Low Set, then determines that Low-Low Set has failed.  Operates SRV A and/or B using the open and closed pushbuttons to control reactor pressure.
<b>CUE: IF asked, inform the examinee that Torus cooling is not required to be placed in service per SM instructions.</b>	
7. Once pressure and level are being controlled, inform CRS.	7. Examinee informs CRS that pressure and level are being controlled.
<b>CUE: End JPM when reactor level and pressure is within the proper bands in accordance with AOP 20.000.19.</b>	

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* Critical Step

## JOB PERFORMANCE MEASURE

JPM Title Control Reactor Pressure from the Remote Shutdown Panel (Alt Path)	No.: JP-OP-802-2001-211 Revision: 5 Page 6
--	--

### Evaluator Notes:

The Remote Shutdown Panel in the Simulator will be used to perform this JPM.

The first equipment selected to control water level (RCIC/CRD) will fail. The second one will operate properly.

The first SRV selected for pressure control (A/B) will also fail. The second one will work properly.

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

### Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

Controllers have an Auto light that is GREEN when selected and AMBER (YELLOW) when Manual is selected. When in Manual, the open and closed pushbuttons control the parameter to be changed by adjusting position or speed. When the deviation meter is nulled, then the process can be shifted to Auto to allow the desired setpoint to control the process.

### System Specific Notes and Cues:

None

### Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

### Critical Steps:

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Control Reactor Pressure from the Remote Shutdown Panel (Alt Path)	No.: JP-OP-802-2001-211 Revision: 5 Page 7
--	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Control Reactor Pressure from the Remote Shutdown Panel (Alt Path)	No.: JP-OP-802-2001-211 Revision: 5 Page 8
--	--

**Simulator Setup**

**IC#:**

IC-20, or any full power IC.

**Malfunctions:**

Number	Title	Value	Delay	Ramp
B21MF0102	Spurious Main Steam Isolation	ACTIVE	0	0
B21MF0023	Main Steam SRV Failure B2100-F013A	100	4	0
B21MF0023	Main Steam SRV Failure B2100-F013A <i>cd='H_P601_C006_1 LT 855'</i>	0	0	0
B21MF0023	Main Steam SRV Failure B2100-F013A <i>cd='P100_C017_1 EQ 1 and B21MF0024 EQ 0'</i>	CLEAR	0	0
B21MF0024	Main Steam SRV Failure B2100-F013B	0	0	0
B21MF0024	Main Steam SRV Failure B2100-F013B <i>cd='P100_C015_1 EQ 1 and B21MF0023 EQ 0'</i>	CLEAR	0	0
B21MF0029	Main Steam SRV Failure B2100-F013G	0	0	0
C11MF1119	CRD Hydraulic Pump B Trip	ACTIVE	0	0
C11MF1119	CRD Hydraulic Pump B Trip <i>cd='P100_C049_1 EQ 1 and E51RF0040 EQ 0'</i>	CLEAR	0	0
E51MF0013	RCIC Turbine Trip <i>cd='P100_C049_1 EQ 1 and E51RF0040 EQ 0'</i>	ACTIVE	0	0

**Remote Functions:**

Number	Title	Value	Delay	Ramp
E51RF0040	E5100-F045 RCIC Steam Supply	0	0	0
E51RF0040	E5100-F045 RCIC Steam Supply <i>cd='P100_C004_2 EQ 1 and C11MF1119 EQ 2'</i>	CLEAR	0	0

**Override Functions:**

Number	Title	Value	Delay	Ramp
P603_A048_1	Reactor Mode Shutdown Handle Pos.	1	1	0
P804_A061_2	Turbine Trip Armed Pos	1	2	0
P804_A061_3	Turbine Trip Trip Switch	1	3	0
P601_B220_1	Low Low Set Div 2 Reset Switch <i>cd='H_P601_C006_1 LT 855'</i>	1	1	0
P601_B217_1	Low Low Set Div 1 Reset Switch <i>cd='H_P601_C006_1 LT 855'</i>	1	1	0
P601_B220_1	Low Low Set Div 2 Reset Switch <i>cd='H_P601_C006_1 LT 855'</i>	-1	2	0
P601_B217_1	Low Low Set Div 1 Reset Switch <i>cd='H_P601_C006_1 LT 855'</i>	-1	2	0

**Special Instructions:**

1. Initialize simulator to desired IC.
2. Place simulator in **RUN**.
3. Open and execute Lesson **JP2001-211**.lsn.
4. When lesson has completed execution (SRV A closed and plant stable), place simulator in **FREEZE**.
5. When ready to start the JPM, place the simulator in **RUN**.

**NOTE:** Do not snap an IC from this setup to use later. The conditional steps for failed equipment are not saved in the IC and will not work during subsequent JPM performances.

**Cue Sheet: (JP-OP-802-2001-211)**

**Initial Conditions:**

- You are the Control Room NSO.
- The plant is beginning the process of being shutdown from outside the control room due to toxic fumes making the control room uninhabitable.
- The “East” or “A” CRD Pump control switch is in the RUN position in the main control room. Division 1 RHR is in its normal standby lineup.
- A Group 1 Isolation has occurred.

**Initiating Cue(s):**

- The CRS directs you to control reactor pressure and level IAW AOP 20.000.19, Shutdown from Outside the Control Room.
- All prerequisites are complete.
- AOP 20.000.19, Conditions A through D have been completed, and you are to begin at E.
- You are to inform the CRS when reactor pressure and level are being controlled.
- You may allow pressure to rise slightly above 1093 psig to allow Low-Low Set SRVs to arm and operate.

**JOB PERFORMANCE MEASURE**

Job Position SRO / RO	No. JP-OP-802-4101-421	Revision 2
JPM Title Verify Offsite Electrical Lineup	Duration 10 minutes	Page 1

Examinee: \_\_\_\_\_ SRO / RO

Evaluator: \_\_\_\_\_

JPM Type:                    **Normal** / Alternate Path / Time Critical                    Start Time \_\_\_\_\_

Evaluation Method:        **Perform** / Walkthrough / Discuss                                    Stop Time \_\_\_\_\_

Location:                     Plant / **Simulator** / Classroom    Total Time: \_\_\_\_\_

PERFORMANCE EVALUATION SUMMARY											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
* 1.				*11.							
* 2.				*12.							
* 3.				*13.							
* 4.				14.							
* 5.				15.							
* 6.											
* 7.											
* 8.											
* 9.											
*10.											

OPERATOR FUNDAMENTALS OBSERVATION				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Verify Offsite Electrical Lineup	No.: JP-OP-802-4101-421 Revision: 2 Page 2
---	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Verify Offsite Electrical Lineup	No.: JP-OP-802-4101-421 Revision: 2 Page 3
---	--

**JPM Information**

**System:**

S2000/S4000 – 120/345KV Switchyards

**Task:**

57520 - Perform Control Room - Mode 1, 2, 3 Surveillances

**References:** Required (R) / Available (A)

24.000.01, Situational Surveillances/LCO Action Tracking, Attachment 28b (R)

**Tools and Equipment Required:**

Marked up 24.000.01, Attachments 28a & 28b

**Initial Conditions:**

- You are the CRNSO.
- The current time is 0500.
- EDG-11 was declared INOP at 0455.
- The CRS has entered LCO 3.8.1 Action A.

**Initiating Cue(s):**

The CRS directs you to perform 24.000.01, Attachment 28b.

**Terminating Cue(s):**

24.000.01 Attachment 28b is completed.

**Task Standard:**

24.000.01, Attachment 28b, is completed correctly.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

N/A

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** GENERIC  
**K/A STATEMENT:**  
2.1.29 Knowledge of how to conduct system lineups, such as valves, breakers, switches, etc.  
(CFR 41.10 / 45.1 / 45.12)..... 4.1 / 4.0

**Maintenance Rule Safety Classification:**

N/A

**Maintenance Rule Risk Significant? (Yes or No)**

N/A

JOB PERFORMANCE MEASURE

JPM Title Verify Offsite Electrical Lineup	No.: JP-OP-802-4101-421 Revision: 2 Page 4
---	--

PERFORMANCE EVALUATION

Start Time \_\_\_\_\_

ELEMENT		STANDARD	
<b>CUE: Provide examinee with Cue Sheet and marked up 24.000.01 Attachments 28a &amp; 28b.</b>			
* 1.	[1.1.1] Record Bus 101 voltage.	* 1.	Records 120V Bus 101 voltage.
* 2.	[1.1.2] Verify indicated voltage is approximately 120 VAC.	* 2.	Records initials verifying voltage is ~120 VAC.
* 3.	[1.1.3] If indicated bus voltage is <116 VAC, notify the SM, otherwise NA.	* 3.	Records NA in the initials block.
<b>CUE: If asked, inform examinee that Breaker GD was opened mid-shift at ITC's request.</b>			
* 4.	[1.1.4] Verify one the following lineups is met: <ul style="list-style-type: none"> <li>For Shoal Line supplying, Breaker GD is CLOSED.</li> <li>For Radka Line supplying, Breaker GK and GH are CLOSED.</li> <li>For Swan Creek Line Supplying, Breakers GM and GH are CLOSED.</li> </ul>	* 4.	Checks off the following boxes, and initials that at least one of the lineups is correct: <ul style="list-style-type: none"> <li>For Radka Line supplying, Breaker GK and GH are CLOSED.</li> <li>For Swan Creek Line Supplying, Breakers GM and GH are CLOSED.</li> </ul>
* 5.	[1.1.5] Verify the following breakers are CLOSED: <ul style="list-style-type: none"> <li>TRANS 1 DEC POS A BKR CONTROL</li> <li>SS TRANS 64 PRI POS D BKR CONTROL</li> <li>Bus 64B-B6</li> <li>64B-C6</li> </ul>	* 5.	Checks off each box and initials that breakers are CLOSED.
* 6.	[1.2] For Bus 102 supplying SST 64, perform the following:	* 6.	This section is NA, therefore examinee records NA on steps 1.2.1 through 1.2.5.
* 7.	[1.3] Verify at least one of the two conditions is met: <ul style="list-style-type: none"> <li>Steps 1.1.2, 1.1.4, and Step 1.1.5 were completed satisfactorily.</li> </ul> <p style="text-align: center;">or</p> <ul style="list-style-type: none"> <li>Steps 1.2.2, 1.2.4, and Step 1.2.5 were completed satisfactorily.</li> </ul>	* 7.	Places a check mark next to step 1.3.1 and initials the Acceptance Criteria.
* 8.	[1.4.1] Record Bus 301 voltage.	* 8.	Records 120V Bus 301 voltage.
* 9.	[1.4.2] Verify indicated voltage is approximately 120 VAC.	* 9.	Records initials verifying voltage is ~120 VAC.
*10.	[1.4.3] If indicated bus voltage is <118.1 VAC, notify the SM, otherwise NA	*10.	Records NA in the initials block.

JOB PERFORMANCE MEASURE

JPM Title Verify Offsite Electrical Lineup	No.: JP-OP-802-4101-421 Revision: 2 Page 5
---	--

ELEMENT	STANDARD
*11. [1.4.4] Verify one the following lineups is met: <ul style="list-style-type: none"> <li>• For BRTN 2 Line supplying, Breaker DF is CLOSED.</li> <li>• For BRTN 2 Line supplying, Breakers DM, CM, and CF are CLOSED with Main Generator off line.</li> <li>• For BRTN 3 Line, Breaker BM is CLOSED</li> <li>• For BRTN 3 Line, Breakers BT, CM and CF are CLOSED with Main Generator off line.</li> </ul>	*11. Checks off the following boxes, and initials that at least one of the lineups is correct: <ul style="list-style-type: none"> <li>• For BRTN 2 Line supplying, Breaker DF is CLOSED.</li> <li>• For BRTN 3 Line, Breaker BM is CLOSED</li> </ul>
*12. [1.4.5] Breakers 65E-E6 and 65F-F6 are closed.	*12. Initials that Breakers 65E-E6 and 65F-F6 are closed.
*13. [1.5] Verify Step 1.4.2 <b>and</b> Step 1.4.4 <b>and</b> 1.4.5 were completed satisfactorily.	*13. Records initials the Acceptance Criteria block.
14. [1.6] Sign for completed and record Name, Initials and Signature	14. Records date and time of completion, and records Name, Initials and Signature.
15. Document on Attachment 28a that Action 2 was performed by recording Date, Time, Initials and ID number.	15. Records Date and Time performed, Initials and enters ID number on Attachment 28a, Action 2.
<b>CUE: Terminate JPM when 24.000.01, Attachment 28b, is completed.</b>	

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

**\* Critical Step**

## JOB PERFORMANCE MEASURE

JPM Title  
Verify Offsite Electrical Lineup

No.: JP-OP-802-4101-421  
Revision: 2  
Page 6

### Evaluator Notes:

This JPM can be performed in the Simulator or the Control Room.

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

### Generic Notes and Cues:

None

### System Specific Notes and Cues:

None

### Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

### Critical Steps:

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Verify Offsite Electrical Lineup	No.: JP-OP-802-4101-421 Revision: 2 Page 7
---	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Verify Offsite Electrical Lineup	No.: JP-OP-802-4101-421 Revision: 2 Page 8
---	--

**Simulator Setup**

**IC#:**

IC-20 or any full power IC.

**Malfunctions:**

Number	Title	Value	Delay	Ramp
N/A				

**Remote Functions:**

Number	Title	Value	Delay	Ramp
R30RF0009	EDG 11 Control Mode Switch	MPO	0	0

**Override Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Special Instructions:**

1. Initialize to desired IC, and place the simulator in **RUN**.
2. Open Shoal Line Breaker GD.
3. Insert the remote function listed above.
4. Silence and acknowledge all alarms, and place the simulator in **FREEZE**.

**Cue Sheet: (JP-OP-802-4101-421)**

**Initial Conditions:**

- You are the CRNSO.
- The current time is 0500.
- EDG-11 was declared INOP at 0455.
- The CRS has entered LCO 3.8.1 Action A.

**Initiating Cue(s):**

The CRS directs you to perform 24.000.01, Attachment 28b.

**JOB PERFORMANCE MEASURE**

Job Position SRO / RO	No. JP-OP-802-3006-401	Revision 0
JPM Title Perform Torus Water Average Temperature Calculation	Duration 10 minutes	Page 1

Examinee: \_\_\_\_\_ SRO / RO

Evaluator: \_\_\_\_\_

JPM Type:                    **Normal** / Alternate Path / Time Critical                    Start Time \_\_\_\_\_

Evaluation Method:       **Perform** / Walkthrough / Discuss                    Stop Time \_\_\_\_\_

Location:                    Plant / Simulator / **Classroom**                    Total Time: \_\_\_\_\_

<b>PERFORMANCE EVALUATION SUMMARY</b>											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
* 1.											
* 2.											
* 3.											
* 4.											

<b>OPERATOR FUNDAMENTALS OBSERVATION</b>				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Perform Torus Water Average Temperature Calculation	No.: JP-OP-802-3006-401 Revision: 0 Page 2
--	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Perform Torus Water Average Temperature Calculation	No.: JP-OP-802-3006-401 Revision: 0 Page 3
--	--

**JPM Information**

**System:**

T5000 – Primary Containment Monitoring System

**Task:**

52016 - Calculate Torus Water Average Temperature

**References:** Required (R) / Available (A)

29.ESP.01, Supplemental Information, Section 15, Torus Water Temperature Calculation (R)

**Tools and Equipment Required:**

Calculator

**Initial Conditions:**

- You are an extra person on shift.
- Primary Containment Control EOP has been entered due to Drywell Temperature of 147°F.

**Initiating Cue(s):**

The CRS directs you to calculate Torus Water Average Temperature in accordance with 29.ESP.01.

**Terminating Cue(s):**

Torus Water temperature has been determined by calculation.

**Task Standard:**

Perform Torus Water Average Temperature Calculation in accordance with 29.ESP.01, Section 15.0.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function/Category:**

10 - Emergency Plant Evolutions

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** 295026 - Suppression Pool High Water Temperature  
**K/A STATEMENT:**  
EA2. Ability to determine and/or interpret the following as they apply to Suppression Pool High Water Temperature:  
EA2.01 Suppression Pool Water temperature .....4.1 / 4.2

**Maintenance Rule Safety Classification:**

N/A

**Maintenance Rule Risk Significant? (Yes or No)**

N/A

JOB PERFORMANCE MEASURE

JPM Title Perform Torus Water Average Temperature Calculation	No.: JP-OP-802-3006-401 Revision: 0 Page 4
--	--

**PERFORMANCE EVALUATION**

Start Time \_\_\_\_\_

ELEMENT	STANDARD
<b>CUE: Provide examinee with Cue Sheet.</b>  <b>After the examinee demonstrates/explains how he would obtain a controlled copy of the procedure, hand the examinee a copy of 29.ESP.01.</b>  <b>Controlled procedure copies are located in the Tagging Center. Other procedures are located in remote locations.</b>  <b>Procedures may be obtained and/or verified current electronically using Automated Record Management System (ARMS). "Current" status is coded "AFC".</b>	
<b>CUE: If asked, Torus water level indicates 0 inches.</b>	
* 1. [15.0 CAUTION] Determine if Torus water level is less than -11 inches.	* 1. Determines Torus water level.
<b>CUE: If asked, report that no SRV has actuated in the past 48 hours.</b>	
* 2. [15.0 NOTE (1/2)] Determine if an SRV has actuated.	* 2. Determines that an SRV has NOT actuated.
<b>CUE: When asked for the instrument point readings, provide the examinee with the Data Sheet.</b>	
* 3. Determine T23-R800, Torus Water Temperature Recorder, instrument point readings.	* 3. T23-R800 instrument point readings determined.
* 4. Calculate Average Torus Water Temperature.	* 4. Calculates Average Torus Water Temperature. <b>(93.4°F)</b>
<b>CUE: End JPM when Torus Water temperature has been determined by calculation.</b>	

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* **Critical Step**

JOB PERFORMANCE MEASURE

JPM Title Perform Torus Water Average Temperature Calculation	No.: JP-OP-802-3006-401 Revision: 0 Page 5
--	--

**Evaluator Notes:**

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

**Generic Notes and Cues:**

None

**System Specific Notes and Cues:**

None

**Task Performance and Cues:**

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

**Critical Steps:**

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Perform Torus Water Average Temperature Calculation	No.: JP-OP-802-3006-401 Revision: 0 Page 6
--	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Perform Torus Water Average Temperature Calculation	No.: JP-OP-802-3006-401 Revision: 0 Page 7
--	--

**Simulator Setup**

**IC#:**

N/A

**Malfunctions:**

Number	Title	Value	Delay	Ramp
N/A				

**Remote Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Override Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Special Instructions:**

N/A

JOB PERFORMANCE MEASURE

**Data Sheet: (JP-OP-802-3006-401)**

**T23-R800, Torus Water Temperature Recorder,  
Instrument Point Readings**

**Pt. 1 = 96°F**

**Pt. 5 = 90°F**

**Pt. 2 = 98°F**

**Pt. 6 = 88°F**

**Pt. 3 = 91°F**

**Pt. 7 = INOP**

**Pt. 4 = 89°F**

**Pt. 8 = 97°F**

**Cue Sheet: (JP-OP-802-3006-401)**

**Initial Conditions:**

- You are an extra person on shift.
- Primary Containment Control EOP has been entered due to Drywell temperature of 147°F.

**Initiating Cue(s):**

The CRS directs you to calculate Torus Water Average Temperature in accordance with 29.ESP.01.

**JOB PERFORMANCE MEASURE**

Job Position SRO / RO / NO	No. JP-OP-802-4101-441	Revision 1
JPM Title Identify the Isolation Boundaries for a Clearance to Replace a Pump Impeller	Duration 20 minutes	Page 1

Examinee: \_\_\_\_\_ SRO / RO / NO

Evaluator: \_\_\_\_\_

JPM Type:                    **Normal** / Alternate Path / Time Critical                    Start Time \_\_\_\_\_

Evaluation Method:       **Perform** / Walkthrough / Discuss                               Stop Time \_\_\_\_\_

Location:                    Plant / Simulator / **Classroom**     Total Time: \_\_\_\_\_

<b>PERFORMANCE EVALUATION SUMMARY</b>											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
1.											
* 2.											
3.											
* 4.											
* 5.											
* 6.											
* 7.											

<b>OPERATOR FUNDAMENTALS OBSERVATION</b>				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**        \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Identify the Isolation Boundaries for a Clearance to Replace a Pump Impeller	No.: JP-OP-802-4101-441 Revision: 1 Page 2
---	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Identify the Isolation Boundaries for a Clearance to Replace a Pump Impeller	No.: JP-OP-802-4101-441 Revision: 1 Page 3
---	--

**JPM Information**

**System:**

N/A

**Task:**

20993 Perform Protective tagging as the Shift Foreman (Determines the limits of protection necessary and proper tag locations required to protect all aspects of the work).

**References:** Required (R) / Available (A)

MOP12, Tagging and Protective Barrier System (R)  
23.120, Stator Water Cooling (A)  
M-5717-4, Generator Stator Winding Cooling System Functional Operating Sketch (A)  
I-2341-24 Schematic Diagram, Stator Coolant Pump East & West (A)

**Tools and Equipment Required:**

Mechanical Piping Diagram, Electrical Diagram

**Initial Conditions:**

- You are the Control Room NSO.
- A tagout has been requested to permit replacement of the East Stator Water Cooling Pump impeller.
- The E-Tagging system is not available.

**Initiating Cue(s):**

In preparation for initiating a Safety Tagging Record (STR) to replace the impeller on the East Stator Water Cooling Pump, determine the limits of protection necessary and proper tag locations required to protect all aspects of the work order.

**Terminating Cue(s):**

The applicant provides the component isolation boundaries.

**Task Standard:**

The component isolation boundaries are identified per MOP12.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

N/A

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** Generic/Equipment Control  
**K/A STATEMENT:** 2.2.13 Knowledge of tagging and clearance procedures (4.1/4.3)

**Maintenance Rule Safety Classification:**

N/A

**Maintenance Rule Risk Significant? (Yes or No)**

N/A

JOB PERFORMANCE MEASURE

JPM Title Identify the Isolation Boundaries for a Clearance to Replace a Pump Impeller	No.: JP-OP-802-4101-441 Revision: 1 Page 4
---	--

PERFORMANCE EVALUATION

Start Time \_\_\_\_\_

ELEMENT	STANDARD
<p><b>CUE:</b> Provide the applicant with a blank Safety Tagging Record to document his findings. If requested, provide copy of MOP12 and/or ODE-19.</p> <p><b>NOTE:</b> The applicant is not being graded on completion of the form, only that the required boundaries and tag locations are identified.</p> <p><b>NOTE:</b> If hard copies of the mechanical/electrical drawings are unavailable, a Fermi computer may be used to access the drawings (M-5717-4 or I-2341-24) as needed.</p>	
1. Using the associated electrical drawing, identify the electrical isolation boundary.	1. Identifies the Power Supply Breaker as the electrical isolation boundary.
*2. Identify the proper tag location for each component identified in the previous step.	* 2. Identifies <b>Bus 72A Pos 4C</b> , N3033C047 East Stator Water Cooling Pump breaker should be in the <b>disconnect</b> position and RED TAGGED.
3. Using the associated mechanical drawing, identify the mechanical isolation boundaries.	3. Identifies the following mechanical isolation boundaries: <ul style="list-style-type: none"> <li>• Suction Valve, <b>N3033-F089A</b></li> <li>• Discharge Valve, <b>N3033-F070A</b></li> <li>• Vent Valve, <b>N3033-F907A</b></li> <li>• Drain Valve, <b>N3033-F067A</b></li> </ul>
*4. Identify the required position of the Suction Valve.	*4. Identifies the Suction Valve N3033-F089A should be <b>Closed</b> and RED TAGGED.
*5. Identify the required position of the Discharge Valve.	*5. Identifies the Discharge Valve N3033-F070A should be <b>Closed</b> and RED TAGGED.
*6. Identify the required position of the Drain Valve.	*6. Identifies the Drain Valve N3033-F067A should be <b>Open</b> and RED TAGGED.
*7. Identify the required position of the Vent Valve.	*7. Identifies the Vent Valve N3033-F907A should be <b>Open</b> and RED TAGGED.
<p><b>CUE:</b> The JPM may be terminated when the applicant provides the component isolation boundaries.</p>	

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* **Critical Step**

JOB PERFORMANCE MEASURE

JPM Title Identify the Isolation Boundaries for a Clearance to Replace a Pump Impeller	No.: JP-OP-802-4101-441 Revision: 1 Page 5
--	--

**Evaluator Notes:**

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

**Generic Notes and Cues:**

None

**System Specific Notes and Cues:**

None

**Task Performance and Cues:**

The Elements of this JPM are step by step in accordance with the procedure. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

**Critical Steps:**

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Identify the Isolation Boundaries for a Clearance to Replace a Pump Impeller	No.: JP-OP-802-4101-441 Revision: 1 Page 6
--	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

Reference:

---

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

Reference

---

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Identify the Isolation Boundaries for a Clearance to Replace a Pump Impeller	No.: JP-OP-802-4101-441 Revision: 1 Page 7
--	--

**Simulator Setup**

**IC#:**

**Malfunctions:**

Number	Title	Value	Delay	Ramp
--------	-------	-------	-------	------

**Remote Functions:**

Number	Title	Value	Delay	Ramp
--------	-------	-------	-------	------

**Override Functions:**

Number	Title	Value	Delay	Ramp
--------	-------	-------	-------	------

**Special Instructions:**

**Cue Sheet: (JP-OP-802-4101-441)**

**Initial Conditions:**

- You are the CRNSO.
- A tag out has been requested to permit replacement of the East Stator Water Cooling Pump impeller.
- The E-Tagging system is not available

**Initiating Cue(s):**

In preparation for initiating a Safety Tagging Record (STR) to replace the impeller on the East Stator Water Cooling Pump, determine the limits of protection necessary and proper tag locations required to protect all aspects of the work order.

**JOB PERFORMANCE MEASURE**

Job Position SRO / RO	No. JP-OP-315-0139-005	Revision 1
JPM Title Manually Isolate HPCI System (Alt Path)	Duration 10 minutes	Page 1

Examinee: \_\_\_\_\_ SRO / RO

Evaluator: \_\_\_\_\_

JPM Type:                    Normal / **Alternate Path** / Time Critical                    Start Time \_\_\_\_\_

Evaluation Method:        **Perform** / Walkthrough / Discuss                    Stop Time \_\_\_\_\_

Location:                    Plant / **Simulator** / Classroom                    Total Time: \_\_\_\_\_

PERFORMANCE EVALUATION SUMMARY											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
1.				*11.							
2.				*12.							
* 3.				*13.							
* 4.				14.							
* 5.				15.							
* 6.				16.							
7.				17.							
* 8.				18.							
* 9.				*19.							
*10.											

OPERATOR FUNDAMENTALS OBSERVATION				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Manually Isolate HPCI System (Alt Path)	No.: JP-OP-315-0139-005 Revision: 1 Page 2
--	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Manually Isolate HPCI System (Alt Path)	No.: JP-OP-315-0139-005 Revision: 1 Page 3
--	--

**JPM Information**

**System:**

E4100 - High Pressure Coolant Injection System

**Task:**

63658 - Start HPCI in the Test Mode

**References:** Required (R) / Available (A)

23.202, High Pressure Coolant Injection System (R)

**Tools and Equipment Required:**

None

**Initial Conditions:**

- You are the Control Room NSO.
- HPCI is to be run in the Test Mode.
- RHR Division 1 is in Torus Cooling.
- Division 1 SGTS is in operation.
- All other prerequisites have been met.

**Initiating Cue(s):**

The CRS directs you to start HPCI in the Test Mode in accordance with 23.202, Section 6.1.

**Terminating Cue(s):**

HPCI System is manually isolated.

**Task Standard:**

HPCI System is shutdown and isolated in accordance with ARP 2D49 and/or 2D53.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

SF-5 Containment Integrity

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** 295032 - High Secondary Containment Area Temperature  
**K/A STATEMENT:**  
EA1. Ability to operate and/or monitor the following as they apply to HIGH SECONDARY CONTAINMENT AREA TEMPERATURE: (CFR: 41.7 / 45.6)  
EA1.05 Affected systems so as to isolate damaged portions ..... 3.7 / 3.9

**Maintenance Rule Safety Classification:**

E4100-06

**Maintenance Rule Risk Significant? (Yes or No)**

No

JOB PERFORMANCE MEASURE

JPM Title Manually Isolate HPCI System (Alt Path)	No.: JP-OP-315-0139-005 Revision: 1 Page 4
--	--

PERFORMANCE EVALUATION

Start Time \_\_\_\_\_

ELEMENT		STANDARD	
<b>CUE: Provide examinee with Cue Sheet.</b>			
1.	[6.1.2.1] Verify or place E41-K820, Test Iso/PCV E41-F011 Ctrlr, in AUTO.	1.	E41-K820 is verified in AUTO.
2.	[6.1.2.2.a] On E41-K820, depress D button until S comes ON.	2.	S is verified ON.
* 3.	[6.1.2.2.a.1)] Turn the pulser knob to set the valve position open setpoint to approximately 56.5% on the digital display.	* 3.	Pulser knob is turned until ~56.5 is read on the digital display.
* 4.	[6.1.2.2.b] On E41-K820, depress D button until Y comes ON.	* 4.	D button is depressed until Y comes ON.
* 5.	[6.1.2.2.b.1)] If Reactor Pressure is >150 psig, turn the pulser knob to set the discharge pressure setpoint to 250 psi on the digital display.	* 5.	Pulser knob is turned until 250 is read on the digital display.
* 6.	[6.1.2.3] Place E4100-M001, HPCI Test Line Iso/PCV E41-F011 Selector Switch, in OPER.	* 6.	E4100-M001 is placed in OPER.
7.	[6.1.2.4] Verify E41-F011, HPCI/RCIC Test Iso/PCV, closed.	7.	E41-F011 is verified closed.
* 8.	[6.1.2.5] Open E4150-F008, HPCI Test Line Iso Vlv.	* 8.	E4150-F008 is opened.
* 9.	[6.1.2.6] Open T4600-F406, HPCI to SGTS Iso Vlv.	* 9.	T4600-F406 is opened.
*10.	[6.1.2.7] Place E4101-C003, HPCI Baro Cndr Vacuum Pump CMC switch, in RUN, and verify pump starts.	*10.	HPCI Baro Cndr Vacuum Pump CMC switch is placed in RUN, and pump is verified to start.
*11.	[6.1.2.8] Open E4150-F003, HPCI Stm Sply Oybdr Iso Vlv.	*11.	E4150-F003 is opened.
*12.	[6.1.2.9] Open E4150-F059, HPCI Oil Clr Clg Water Iso Vlv.	*12.	E4150-F059 is opened.
*13.	[6.1.2.10] Simultaneously: <ul style="list-style-type: none"> <li>Place E4101-C005, HPCI Turbine Aux Oil Pump, in RUN, and verify pump starts, AND</li> <li>Open E4150-F001, HPCI Turb Stm Sply Iso Vlv.</li> </ul>	*13.	Simultaneously: <ul style="list-style-type: none"> <li>HPCI Turbine Aux Oil Pump is placed in RUN, and pump start verified, AND</li> <li>E4150-F001 is opened.</li> </ul>
14.	[6.1.2.11] Verify HPCI Pump and Turbine starts and speed increases.	14.	HPCI Pump and Turbine start and speed increase is verified.

JOB PERFORMANCE MEASURE

JPM Title Manually Isolate HPCI System (Alt Path)	No.: JP-OP-315-0139-005 Revision: 1 Page 5
--	--

ELEMENT	STANDARD
<b>Alternate Path begins when HPCI Turbine speed reaches 3000 rpm.</b>	
<b>CUE: As CRS, acknowledge alarm report.</b>	
15. Respond to annunciators 1D70, Steam Leak Detection Diff Temp High, and 1D66, Steam Leak Detection Ambient Temp High.	15. Announces the alarms to the CRS, and references the appropriate ARPs.
<b>CUE: If examinee requests H11-P614 information, report that alarmed module is for HPCI Equipment Room, and temperature is reading 155°F.</b>	
16. [1D66/1D70] Direct an operator to RR H11-P614, NSSS Temperature Recording and Leak Detection Cabinet, to determine alarmed module and temperature.	16. Directs operator to RR H11-P614, NSSS Temperature Recording and Leak Detection Cabinet, to determine alarmed module and temperature.
<b>CUE: As CRS, acknowledge alarm report.</b>	
17. Respond to annunciators 2D49, HPCI Logic A Isolation Trip Signal Initiated, and 2D53, HPCI Logic B Isolation Trip Signal Initiated.	17. Announces the alarms to the CRS, and references the appropriate ARPs.
<b>CUE: If examinee reports the isolation failure and requests direction, direct examinee to manually isolate the HPCI System.</b>	
18. [2D49/2D53] Verify HPCI Turbine has tripped and is isolated.	18. Verifies HPCI Turbine has tripped and recognizes system has <b>NOT</b> isolated.
<b>NOTE: Closing either E41-F002 or E41-F003 will effectively isolate the HPCI System.</b>	
*19. [2D49/2D53] Manually close E41-F002, HPCI Steam Supply Inboard Isolation Valve, and/or E41-F003, HPCI Steam Supply Outboard Isolation Valve.	*19. Manually closes E41-F002, HPCI Steam Supply Inboard Isolation Valve, and/or E41-F003, HPCI Steam Supply Outboard Isolation Valve.
<b>CUE: End JPM when the HPCI System is manually isolated.</b>	

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* **Critical Step**

## JOB PERFORMANCE MEASURE

JPM Title Manually Isolate HPCI System (Alt Path)	No.: JP-OP-315-0139-005 Revision: 1 Page 6
--	--

### Evaluator Notes:

This is an Alternate Path JPM. The steam supply line will break as speed increases, and the system will fail to automatically isolate.

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

### Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

Controllers have an Auto light that is GREEN when selected and AMBER (YELLOW) when Manual is selected. When in Manual, the open and closed pushbuttons control the parameter to be changed by adjusting position or speed. When the deviation meter is nulled, then the process can be shifted to Auto to allow the desired setpoint to control the process.

### System Specific Notes and Cues:

None

### Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

### Critical Steps:

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Manually Isolate HPCI System (Alt Path)	No.: JP-OP-315-0139-005 Revision: 1 Page 7
--	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Manually Isolate HPCI System (Alt Path)	No.: JP-OP-315-0139-005 Revision: 1 Page 8
--	--

**Simulator Setup**

**IC#:**

IC-20

**Malfunctions:**

Number	Title	Value	Delay	Ramp
E41MF0007	HPCI Steam Line Break <b>[NOTE 1]</b> <i>cd=' H_P602_A137_1 GT 3000'</i>	20	0	0

**Remote Functions:**

Number	Title	Value	Delay	Ramp
EOPRF0022	E41-F002 Isolation Defeat for RPV Venting <b>[NOTE 2]</b> <i>cd=' P602_A117_3 EQ 1'</i>	DEFEAT	0	0
EOPRF0023	E41-F003 Isolation Defeat for RPV Venting <b>[NOTE 2]</b> <i>cd=' P602_A117_3 EQ 1'</i>	DEFEAT	0	0

**Override Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**NOTE 1:** Conditional on HPCI Turbine speed >3000 rpm (H\_P602\_A137\_1 GT 3000).

**NOTE 2:** Conditional on HPCI Turbine Aux Oil Pump in RUN (P602\_A117\_3 EQ 1).

**Special Instructions:**

1. Initialize the simulator to **IC-20** and place in **RUN**.
2. Start SGTS T4600-C003, Div. 1 SGTS Exhaust Fan.
3. Start Div. 1 RHRSW:
  - a. Throttle open E4150-F068A for 5 seconds.
  - b. Start one RHRSW Pump.
  - c. Throttle open E4150-F068A to ~6000 gpm.
  - d. Start the second RHRSW Pump.
  - e. Fully open E4150-F068A.
4. Start Div. 1 RHR in Torus Cooling:
  - a. Open E1150-F028B, Div. 2 Torus Isolation Vlv.
  - b. Start one Div. 1 RHR Pump.
  - c. Throttle open E1150-F024B, Div. 2 Torus Cooling Vlv, to ~10,000 gpm.
5. Pump down Torus using TWMS to -1 inches.
6. Open and execute lesson **JP0139-005**.Isn.
7. Trigger First Step.

**Cue Sheet: (JP-OP-315-0139-005)**

**Initial Conditions:**

- You are the Control Room NSO.
- HPCI is to be run in the Test Mode.
- RHR Division 1 is in Torus Cooling.
- Division 1 SGTS is in operation.
- All other prerequisites have been met.

**Initiating Cue(s):**

The CRS directs you to start HPCI in the Test Mode in accordance with 23.202, Section 6.1.

**JOB PERFORMANCE MEASURE**

Job Position SRO / RO	No. JP-ER-831-0001-402	Revision 3
JPM Title Request Emergency Offsite Services	Duration 20 minutes	Page 1

Examinee: \_\_\_\_\_ SRO / RO

Evaluator: \_\_\_\_\_

JPM Type:                    **Normal** / Alternate Path / Time Critical                    Start Time \_\_\_\_\_

Evaluation Method:        **Perform** / Walkthrough / Discuss                                    Stop Time \_\_\_\_\_

Location:                     Plant / Simulator / **Classroom**    Total Time: \_\_\_\_\_

<b>PERFORMANCE EVALUATION SUMMARY</b>											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
1.											
* 2.											
* 3.											
4.											
* 5.											
* 6.											
7.											
* 8.											
* 9.											

<b>OPERATOR FUNDAMENTALS OBSERVATION</b>				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Request Emergency Offsite Services	No.: JP-ER-831-0001-402 Revision: 3 Page 2
---	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

## JOB PERFORMANCE MEASURE

JPM Title  
Request Emergency Offsite Services

No.: JP-ER-831-0001-402  
Revision: 3  
Page 3

### JPM Information

**System:**

N/A

**Task:**

74001 - Request offsite ambulance/paramedic, fire, or hospital support

**References:** Required (R) / Available (A)

EP-290, Emergency Notifications (R)  
EP-29004, Ambulance/ Paramedic Support Request Form (A)  
EP-29005, Hospital Support Request Form (A)  
EP-29006, Secondary Alarm Station Report (A)

**Tools and Equipment Required:**

None

**Initial Conditions:**

- You are an extra operator in the Control Room when a major steam leak occurs.
- The steam leak has just been isolated when the control room receives a report that 3 personnel have received life-threatening burns from the steam leak.
- The personnel are in the North Heater Drain Pump Room where radiation levels are not excessive.
- The area surrounding the location of the seriously burned personnel is contaminated.

**Initiating Cue(s):**

- The SM directs you to obtain ambulance and paramedic assistance.
- Inform the SM when the requests for assistance have been made and arrangements for entry of the responding personnel have been completed.

**Terminating Cue(s):**

Offsite assistance has been requested, the hospital has been informed and site entry has been expedited for responding personnel.

**Task Standard:**

Offsite Assistance has been requested from Frenchtown Fire Department, Ambulance and Paramedics per EP 290.

JOB PERFORMANCE MEASURE

JPM Title Request Emergency Offsite Services	No.: JP-ER-831-0001-402 Revision: 3 Page 4
---	--

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

N/A

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** Generic  
**K/A STATEMENT:**  
2.4.43 Knowledge of emergency communications systems and techniques..... 3.2 / 3.8

**Maintenance Rule Safety Classification:**

N/A

**Maintenance Rule Risk Significant? (Yes or No)**

N/A

JOB PERFORMANCE MEASURE

JPM Title Request Emergency Offsite Services	No.: JP-ER-831-0001-402 Revision: 3 Page 5
---	--

PERFORMANCE EVALUATION

Start Time \_\_\_\_\_

ELEMENT	STANDARD
<b>CUE: Provide examinee with Cue Sheet. If asked, provide examinee with a copy of EP-290004.</b>	
<b>CUE: If requested, SM informs examinee that paramedics should be aware that area around injured personnel as well as personnel themselves might be contaminated. Area radiation levels are not a significant risk.</b>	
1. Obtain EP-2900004, Ambulance/ Paramedic Support Request Form, and complete appropriate sections.	1. Obtains and completes EP-290004 as follows: <ul style="list-style-type: none"> <li>• Checks block for Rescue Squad and ambulance</li> <li>• Fills in Name, Title, and Telephone Number</li> <li>• 3 injured personnel</li> <li>• Seriously Burned</li> <li>• 3 potentially contaminated</li> <li>• Transport to Mercy Memorial</li> </ul>
<b>CUE: As Central Dispatch, acknowledge the information provided.</b>	
* 2. Call 734-241-2727 (for urgent medical assistance) to request paramedic and ambulance.	* 2. Calls number, states "This is (name, title, telephone number) calling from Fermi 2. There are injured personnel onsite and your assistance is required immediately." Provides other information previously filled in on form.
<b>CUE: As Central Dispatch, respond that contact name is Robert James.</b>	
* 3. Request contact name from Central Dispatch, and enter date and time.	* 3. Requests contact name from Central Dispatch, and notes it on form along with current date and time.
<b>NOTE: EP-290006 may be completed <u>before</u> EP-290005.</b>	
<b>CUE: If requested, provide examinee with a copy of EP-290005.</b>	
4. Obtain EP-290005 and complete the form.	4. Obtains EP-290005 and completes the form with the previously collected information.
* 5. Call 734-240-8477 or 734-240-8488 (Mercy Memorial Hospital) asking for the Charge Nurse and provide the collected information.	* 5. Calls Mercy Memorial, states "This is (name, title, telephone number) calling from Fermi 2. There are injured personnel onsite and the ambulance service has been contacted to transport the victims to you." Provides the other information required, including number of injured personnel (3). States "You are requested to implement your radiological emergency response plan."

JOB PERFORMANCE MEASURE

JPM Title Request Emergency Offsite Services	No.: JP-ER-831-0001-402 Revision: 3 Page 6
---	--

ELEMENT	STANDARD
<b>CUE: As Charge Nurse, respond that contact name is Samuel Smith.</b>	
* 6. Request contact name from Charge Nurse, and enter date and time.	* 6. Requests contact name from Charge Nurse, and notes it on form along with current date and time.
<b>CUE: If requested, provide examinee with a copy of EP-290006. If asked, SM reports that injured personnel are in the North Heater Bay.</b>	
7. Obtain EP-290006 and complete the form.	7. Obtains EP-290006 and completes the form with the required information: <ul style="list-style-type: none"> <li>• Checks that Fire/Paramedics, Ambulance, and Hospital contacted.</li> <li>• 2 vehicles reporting onsite</li> <li>• 4 personnel reporting onsite</li> <li>• Checks Fermi Drive gate to be used</li> <li>• Injured personnel are in the North Heater Bay</li> </ul>
* 8. Use Control Room-Security direct line to SAS (Secondary Alarm Station) or call 6-5215, and report required information.	* 8. Contacts Secondary Alarm Station and reports: <ul style="list-style-type: none"> <li>• Fire/Paramedics, Ambulance, and Hospital contacted.</li> <li>• 2 vehicles reporting</li> <li>• 4 personnel responding</li> <li>• Access is through Fermi Drive gate</li> <li>• Injured personnel are in the North Heater Drain Pump Room (Turbine Building)</li> </ul>
<b>CUE: As Security Supervisor, respond that contact name is Joseph Ruger.</b>	
* 9. Request contact name from SAS, and enter date and time.	* 9. Requests contact name from SAS, and notes it on form along with current date and time.
<b>CUE: Terminate JPM when SM is notified that offsite assistance has been requested, the hospital informed, and site entry expedited for responding personnel.</b>	

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* Critical Step

## JOB PERFORMANCE MEASURE

JPM Title  
Request Emergency Offsite Services

No.: JP-ER-831-0001-402  
Revision: 3  
Page 7

### Evaluator Notes:

This JPM may be started at the CRS Desk in the Simulator.

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

### Generic Notes and Cues:

None

### System Specific Notes and Cues:

None

### Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

### Critical Steps:

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Request Emergency Offsite Services	No.: JP-ER-831-0001-402 Revision: 3 Page 8
---	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Request Emergency Offsite Services	No.: JP-ER-831-0001-402 Revision: 3 Page 9
---	--

**Simulator Setup**

**IC#:**

N/A

**Malfunctions:**

Number	Title	Value	Delay	Ramp
N/A				

**Remote Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Override Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Special Instructions:**

N/A

**Cue Sheet: (JP-ER-831-0001-402)**

**Initial Conditions:**

- You are an extra operator in the Control Room when a major steam leak occurs.
- The steam leak has just been isolated when the control room receives a report that 3 personnel have received life-threatening burns from the steam leak.
- The personnel are in the North Heater Drain Pump Room where radiation levels are not excessive.
- The area surrounding the location of the seriously burned personnel is contaminated.

**Initiating Cue(s):**

- The SM directs you to obtain ambulance and paramedic assistance.
- Inform the SM when the requests for assistance have been made and arrangements for entry of the responding personnel have been completed.

**JOB PERFORMANCE MEASURE**

Job Position SRO / RO	No. JP-OP-315-0158-402	Revision 3
JPM Title Loss 64C and EDG 12 Fails to Start	Duration 15 minutes	Page 1

Examinee: \_\_\_\_\_ SRO / RO

Evaluator: \_\_\_\_\_

JPM Type:                    **Normal** / Alternate Path / Time Critical                    Start Time \_\_\_\_\_

Evaluation Method:        **Perform** / Walkthrough / Discuss                                    Stop Time \_\_\_\_\_

Location:                     Plant / **Simulator** / Classroom    Total Time: \_\_\_\_\_

<b>PERFORMANCE EVALUATION SUMMARY</b>											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
* 1.											
* 2.											
* 3.											
4.											
* 5.											

<b>OPERATOR FUNDAMENTALS OBSERVATION</b>				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
<b>Operator Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>	<b>Comment Number</b>
<b>Monitoring</b>				
<b>Control</b>				
<b>Conservatism</b>				
<b>Teamwork</b>				
<b>Knowledge</b>				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Loss 64C and EDG 12 Fails to Start	No.: JP-OP-315-0158-402 Revision: 3 Page 2
---	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Loss 64C and EDG 12 Fails to Start	No.: JP-OP-315-0158-402 Revision: 3 Page 3
---	--

**JPM Information**

**System:**

R1400 - 4160/480V ESF Electrical Distribution

**Task:**

74965 - Restore North RR MG.  
64234 - Manually initiate a start of SGTS  
64864 - Shift Divisions of CCHVAC

**References:** Required (R) / Available (A)

20.300.64C, Loss of Bus 64C (R)  
20.300.72C, Loss of Bus 72C (R)

**Tools and Equipment Required:**

None

**Initial Conditions:**

- You are the 3<sup>rd</sup> NSO.
- Reactor Power is at 100%.
- Plant conditions are stable as you see them.

**Initiating Cue(s):**

The CRS has directed you to perform an electrical walkdown.

**Terminating Cue(s):**

AOP 20.300.72C, "Loss of Bus 72C", Subsequent Actions, Conditions B.1, C.1 & H are complete.

**Task Standard:**

The electrical walkdown will determine that 4160V Bus 64C has tripped and EDG 12 failed to start due to a bus fault. Actions are taken in response to the loss of 480V Bus 72C in accordance with steps B.1, C.1 and H of 20.300.72C, Loss of Bus 72C.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

SF-6 - Electrical

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** 262001 - AC Electrical Distribution  
**K/A STATEMENT:**  
A2. Ability to (a) predict the impacts of the following on the A.C. ELECTRICAL DISTRIBUTION; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: (CFR: 41.5 / 45.6)  
A2.04 Types of loads that, if de-energized, would degrade or hinder plant operation..... 3.8/4.2

**Maintenance Rule Safety Classification:**

R1400-01

**Maintenance Rule Risk Significant? (Yes or No)**

Yes

JOB PERFORMANCE MEASURE

JPM Title Loss 64C and EDG 12 Fails to Start	No.: JP-OP-315-0158-402 Revision: 3 Page 4
---	--

**PERFORMANCE EVALUATION**

Start Time \_\_\_\_\_

ELEMENT	STANDARD
<b>NOTE: Examinee will announce actions which change plant conditions/alarms with "Crew Update."</b>	
<b>CUE: When Bus 64C lockout is reported, acknowledge the report as CRS. Announce entry into 20.300.72C, Loss of Bus 72C. Direct the examinee to perform Conditions B.1, C.1 and H of AOP 20.300.72C. If asked, other control room operators will be performing other AOP steps.</b>	
*1. Perform an electrical walkdown.	*1. Determines that Bus 64C tripped, breakers B6 and B8 are open indicating a bus fault, and the EDG did not start.
*2. [B.1] Place RR MG North Cooling Fan in OFF/RESET, then in RUN.	*2. RR MG North Cooling Fan CMC switch placed in OFF/RESET, then in RUN.
*3. [C.1] Start Div 2 SGTS.	*3. Div 2 SGTS Exhaust Fan CMC switch placed in RUN.
4. [H.1] Place Div 1 CCHVAC Mode Select Switch in ALL STOP.	4. Div 1 CCHVAC Mode Select Switch placed in ALL STOP.
*5. [H.2] Place Div 2 CCHVAC Mode Select Switch in ALL AUTO.	*5. Div 2 CCHVAC Mode Select Switch placed in ALL AUTO.
<b>CUE: End JPM when AOP 20.300.72C, steps B.1, C.1, and H are completed.</b>	

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* Critical Step

## JOB PERFORMANCE MEASURE

JPM Title  
Loss 64C and EDG 12 Fails to Start

No.: JP-OP-315-0158-402  
Revision: 3  
Page 5

### Evaluator Notes:

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

### Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

Controllers have an Auto light that is GREEN when selected and AMBER (YELLOW) when Manual is selected. When in Manual, the open and closed pushbuttons control the parameter to be changed by adjusting position or speed. When the deviation meter is nulled, then the process can be shifted to Auto to allow the desired setpoint to control the process.

### System Specific Notes and Cues:

None

### Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

### Critical Steps:

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Loss 64C and EDG 12 Fails to Start	No.: JP-OP-315-0158-402 Revision: 3 Page 6
---	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Loss 64C and EDG 12 Fails to Start	No.: JP-OP-315-0158-402 Revision: 3 Page 7
---	--

**Simulator Setup**

**IC#:**

IC-20 or any full power IC.

**Malfunctions:**

Number	Title	Value	Delay	Ramp
R11MF0012	4160V Bus Trip 64C	ACTIVE	0	0

**Remote Functions:**

Number	Title	Value	Delay	Ramp
None				

**Override Functions:**

Number	Title	Value	Delay	Ramp
None				

**Special Instructions:**

1. Initialize simulator to selected IC.
2. Place simulator in RUN.
3. Open and execute lesson **JP0158-402**.lsn

**Cue Sheet: (JP-OP-315-0158-402)**

**Initial Conditions:**

- You are the 3<sup>rd</sup> NSO.
- Reactor Power is at 100%.
- Plant conditions are stable as you see them.

**Initiating Cue(s):**

The CRS has directed you to perform an electrical walkdown.

**JOB PERFORMANCE MEASURE**

Job Position SRO / RO	No. JP-OP-802-2104-212	Revision 4
JPM Title Respond to Multiple Control Rod Drifts and RPS Failure	Duration 3 minutes	Page 1

Examinee: \_\_\_\_\_ SRO / RO

Evaluator: \_\_\_\_\_

JPM Type:                    Normal / **Alternate Path** / Time Critical                    Start Time \_\_\_\_\_

Evaluation Method:        **Perform** / Walkthrough / Discuss                                    Stop Time \_\_\_\_\_

Location:                     Plant / **Simulator** / Classroom    Total Time: \_\_\_\_\_

PERFORMANCE EVALUATION SUMMARY											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
1.											
2.											
*3.											
4.											
*5.											

OPERATOR FUNDAMENTALS OBSERVATION				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Respond to Multiple Control Rod Drifts and RPS Failure	No.: JP-OP-802-2104-212 Revision: 4 Page 2
---	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

## JOB PERFORMANCE MEASURE

JPM Title  
Respond to Multiple Control Rod Drifts and RPS Failure

No.: JP-OP-802-2104-212  
Revision: 4  
Page 3

### JPM Information

**System:**

C1100 – Control Rod Drive Hydraulic System

**Task:**

75357 - Perform Immediate Actions for Control Rod Drift

**References:** Required (R) / Available (A)

3D80, Control Rod Drift (R)  
20.106.07, Control Rod Drift (A)  
23.106, Control Rod Drive Hydraulic System (A)  
ODE-10, Emergency Operating Procedure Expectations (A)

**Tools and Equipment Required:**

None

**Initial Conditions:**

- You are the P603 Operator.
- Plant conditions are as you see them.

**Initiating Cue(s):**

- Respond to conditions in accordance with plant procedures.
- Another operator will address plant alarms **not** associated with this task.

**Terminating Cue(s):**

Mode Switch is in SHUTDOWN, RPS has actuated using Manual Scram pushbuttons and all rods are fully inserted.

**Task Standard:**

Examinee places Mode Switch in Shutdown due to multiple rod drifts. Then he identifies failure of Mode Switch and depresses Manual Scram Pushbuttons resulting in a full scram.

JOB PERFORMANCE MEASURE

JPM Title Respond to Multiple Control Rod Drifts and RPS Failure	No.: JP-OP-802-2104-212 Revision: 4 Page 4
---	--

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function/Category:**

7 – Instrumentation 11- Abnormal Plant Evolutions
--

**K/A Reference:** (from NUREG 1123)

<b>K/A SYSTEM:</b> 212000 - Reactor Protection System <b>K/A STATEMENT:</b> A2. Ability to (a) predict the impacts of the following on the REACTOR PROTECTION SYSTEM ; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: A2.16 Changing mode switch position.....4.0 / 4.1
--

**Maintenance Rule Safety Classification:**

C7100-02
----------

**Maintenance Rule Risk Significant? (Yes or No)**

Yes
-----

JOB PERFORMANCE MEASURE

JPM Title Respond to Multiple Control Rod Drifts and RPS Failure	No.: JP-OP-802-2104-212 Revision: 4 Page 5
---	--

**PERFORMANCE EVALUATION**

Start Time \_\_\_\_\_

ELEMENT		STANDARD	
<b>CUE: Provide Examinee with CUE SHEET. After examinee states he is ready, inform him he has control, then cue the console operator to trigger the rod drifts.</b>			
<b>CUE: As CRS, acknowledge alarm report.</b>			
1.	Respond to alarm 3D80, CONTROL ROD DRIFT.	1.	Calls out alarm and reviews ARP.
<b>CUE: As CRS, acknowledge report. Announce entry into AOP 20.106.07, Control Rod Drift.</b>			
<b>NOTE: Actions for single control rod drift need not be completed in their entirety before initiation of multiple rod drifts.</b>			
2.	[1.] Verify Rod Drift as follows: <ul style="list-style-type: none"> <li>• Red Rod Drift light ON at Full Core Display.</li> <li>• Rod moving out or into core.</li> <li>• Nuclear Instrumentation for power changes caused by moving Control Rods.</li> </ul>	2.	Using Full Core Display, identifies drifting rod 10-15.  If rod 10-15 is SELECTED, rod is drifting IN.  Reports drifting rod to CRS.
<b>CUE: As CRS, acknowledge report. If examinee asks for direction, direct him to perform the required procedural actions.</b>			
* 3.	Examinee observes and identifies multiple control rods drifting.	* 3.	Examinee identifies and reports multiple control rods are drifting.
<b>Alternate Path Begins Here (RPS Failure)</b>			
4.	[IA.1] Place Reactor Mode Switch in SHUTDOWN.	4.	Immediate actions to place the mode switch in SHUTDOWN are carried out without direction when required by 20.106.07, Control Rod Drift.  Examinee identifies RPS did not actuate.
* 5.	[ODE-10] If one or both divisions of RPS fail to actuate after Mode Switch in Shutdown, examinee depresses RPS Manual Scram Pushbuttons and monitors for proper operation of RPS.	* 5.	Manual Scram Pushbuttons are depressed.
<b>CUE: End JPM when RPS has been actuated using Manual Scram pushbuttons, and all rods are fully inserted.</b>			

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* Critical Step

JOB PERFORMANCE MEASURE

JPM Title Respond to Multiple Control Rod Drifts and RPS Failure	No.: JP-OP-802-2104-212 Revision: 4 Page 6
---	--

**Evaluator Notes:**

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

**Generic Notes and Cues:**

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

Controllers have an Auto light that is GREEN when selected and AMBER (YELLOW) when Manual is selected. When in Manual, the open and closed pushbuttons control the parameter to be changed by adjusting position or speed. When the deviation meter is nulled, then the process can be shifted to Auto to allow the desired setpoint to control the process.

**System Specific Notes and Cues:**

None

**Task Performance and Cues:**

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

**Critical Steps:**

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Respond to Multiple Control Rod Drifts and RPS Failure	No.: JP-OP-802-2104-212 Revision: 4 Page 7
---	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Respond to Multiple Control Rod Drifts and RPS Failure	No.: JP-OP-802-2104-212 Revision: 4 Page 8
---	--

**Simulator Setup**

**IC#:**

IC-19 (or any full power IC)

**Malfunctions:**

Number	Title	Value	Delay	Ramp	Step
C11MF0109	Control Rod 10-15 Drift In	ACTIVE	0	0	1
C11MF0067	Control Rod 06-27 Drift In* <b>See NOTE 1</b>	ACTIVE	10	0	2
C11MF0283	Control Rod 18-27 Drift In* <b>See NOTE 1</b>	ACTIVE	13	0	2
C11MF0661	Control Rod 34-39 Drift In* <b>See NOTE 1</b>	ACTIVE	16	0	2
C11MF0859	Control Rod 42-51 Drift In* <b>See NOTE 1</b>	ACTIVE	19	0	2
C11MF1039	Control Rod 54-27 Drift In* <b>See NOTE 1</b>	ACTIVE	22	0	2
C11MF0109	Control Rod 10-15 Drift In	CLEAR	0	0	3

**Remote Functions:**

Number	Title	Value	Delay	Ramp	Step
N/A					

**Override Functions:**

Number	Title	Value	Delay	Ramp	Step
P603_A048_4	Reactor Mode Run Handle Pos	1	0	0	1

\* NOTE 1 - Conditional on P603\_A071\_1 EQ 1 (Rod Drift Reset Switch in RESET)

**Special Instructions:**

1. Initialize the simulator to the desired IC and place in **RUN**.
2. Open and execute Lesson **JP2104-212**.Isn, or load the malfunctions/overrides as listed above.
3. Trigger the first control rod drift when cued by examiner.
4. Trigger "Disarm CR 10-15" when cued by examiner.

**Cue Sheet (JP-OP-802-2104-212)**

**Initial Conditions:**

- You are the P603 Operator.
- Plant conditions are as you see them.

**Initiating Cue(s):**

- Respond to conditions in accordance with plant procedures.
- Another operator will address plant alarms **not** associated with this task.

**JOB PERFORMANCE MEASURE**

Job Position SRO / RO	No. JP-OP-315-0166-404	Revision 0
JPM Title Perform Div 2 SGTS Filter and Secondary Containment Isolation Damper Operability Test	Duration 15 minutes	Page 1

Examinee: \_\_\_\_\_ SRO / RO

Evaluator: \_\_\_\_\_

JPM Type:                    **Normal** / Alternate Path / Time Critical                    Start Time \_\_\_\_\_

Evaluation Method:        **Perform** / Walkthrough / Discuss                                    Stop Time \_\_\_\_\_

Location:                     Plant / **Simulator** / Classroom    Total Time: \_\_\_\_\_

<b>PERFORMANCE EVALUATION SUMMARY</b>											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
1.				11.							
* 2.				12.							
3.				13.							
* 4.				14.							
* 5.				15.							
* 6.				16.							
* 7.				*17.							
* 8.				18.							
9.											
10.											

<b>OPERATOR FUNDAMENTALS OBSERVATION</b>				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
<b>Operator Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>	<b>Comment Number</b>
<b>Monitoring</b>				
<b>Control</b>				
<b>Conservatism</b>				
<b>Teamwork</b>				
<b>Knowledge</b>				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Perform Div 2 SGTS Filter and Secondary Containment Isolation Damper Operability Test	No.: JP-OP-315-0166-404 Revision 0 Page 2
---	---

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

## JOB PERFORMANCE MEASURE

JPM Title Perform Div 2 SGTS Filter and Secondary Containment Isolation Damper Operability Test	No.: JP-OP-315-0166-404 Revision 0 Page 3
---	---

### JPM Information

**System:**

T4600 - Standby Gas Treatment System

**Task:**

77039 – Perform Div 2 SGTS Filter & SC Isolation Damper Operability Test

**References:** Required (R) / Available (A)

24.404.04, "Division 2 SGTS Filter And Secondary Containment Isolation Damper Operability Test" (R)  
23.404, "Standby Gas Treatment System" (R)

**Tools and Equipment Required:**

Marked up copy of 24.404.04 to step 5.2.  
Stopwatch

**Initial Conditions:**

- You are the Third NSO.
- RBHVAC is operating normally, CCHVAC is in the NORMAL Mode, and Div 1 & 2 SGTS are in standby.
- Maintenance is complete on the T4100-F010 Damper (solenoid was replaced).
- The CRS and CRNSO have released partial surveillance 24.404.04.
- The surveillance is scheduled on the POD, to be performed on your shift.
- SPF Form is filled out, approved, and correct.
- The surveillance is complete up to Section 5.2.
- A pre-job brief has been conducted with all participants.
- The RB Rounds operator is on the AB 5<sup>th</sup> Floor, standing by for your direction.

**Initiating Cue(s):**

The CRS directs you to perform 24.404.04, Division 2 SGTS Filter And Secondary Containment Isolation Damper Operability Test, Section 5.2. (**T4100-F010 ONLY**)

**Terminating Cue(s):**

Div 1 SGTS is operating and RB D/P is -0.125 to -0.5 inches wc

**Task Standard:**

Perform Division 2 SGTS Filter And Secondary Containment Isolation Damper Operability Test in accordance with 24.404.04.

JOB PERFORMANCE MEASURE

JPM Title Perform Div 2 SGTS Filter and Secondary Containment Isolation Damper Operability Test	No.: JP-OP-315-0166-404 Revision 0 Page 4
---	---

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function/Category:**

SF9 - Radioactivity Release

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** 288000 – Plant Ventilation Systems  
**K/A STATEMENT:**  
A3 - Ability to monitor automatic operations of the PLANT VENTILATION SYSTEMS including:  
    A3.01 Isolation / Initiation Signals..... 3.8 / 3.8  
**K/A SYSTEM:** 290001 – Secondary Containment  
**K/A STATEMENT:**  
A4 - Ability to manually operate and/or monitor in the control room:  
    A4.01 Reactor Building D/P ..... 3.3 / 3.4  
    A4.12 Surveillance Testing ..... 2.8 / 3.2

**Maintenance Rule Safety Classification:**

T4600-06

**Maintenance Rule Risk Significant? (Yes or No)**

Yes

JOB PERFORMANCE MEASURE

JPM Title Perform Div 2 SGTS Filter and Secondary Containment Isolation Damper Operability Test	No.: JP-OP-315-0166-404 Revision 0 Page 5
---	---

PERFORMANCE EVALUATION

Start Time \_\_\_\_\_

ELEMENT		STANDARD	
<b>CUE: Inform the examinee that all communications will be directed to you and you will provide the necessary information and response. Provide Examinee with CUE SHEET and the marked up copy of 24.404.04.</b>			
<b>CUE: Report as RB Rounds that SGTS Totalizer Meter indicates 451 hours.</b>			
1.	[5.2.1] Record initial indication on T46-R400B, Div 2 SGTS Elapsed Time Totalizer (T46-P404, AB5-G14).	1.	Directs RB Rounds to obtain SGTS Totalizer Meter Reading.
*2.	[5.2.2] Place collar of Division 2 Manual Isolation TRIP pushbutton in ARMED and verify Annunciator 8D29, DIV II REAC BLDG ISO PB ARMED, alarms.	*2.	Places Div 2 Manual Isolation TRIP pushbutton collar in ARMED. Verifies 8D29, DIV II REAC BLDG ISO PB ARMED, alarms.
3.	[5.2.3] Make the following announcement over the Hi-Com:  "Attention all personnel, Division 2 SGTS is now in operation. No use of solvents or painting is permitted in the Reactor Building while SGTS is running."	3.	Makes Hi-Com announcement and Crew Update.
<b>NOTE: RBHVAC will trip, and Div 2 SGTS will auto start, and CCHVAC will shift to Recirculation Mode.</b>			
*4.	[5.2.4] Depress Division 2 Manual Isolation TRIP pushbutton, measure stroke time of T4100-F010 to nearest 1/10th second, then record stroke time and verify acceptance criteria met.	*4.	Depresses Division 2 Manual Isolation TRIP pushbutton.  Measures and records the stroke time for T4100-F010 damper.  Verifies the damper stroke time meets the acceptance criteria.
*5.	[5.2.5] Record indication on T46-R800B, Div 2 SGTS Exh Gas Flow Recorder, and start time.	*5.	Records flow on Div 2 SGTS Exh Gas Flow Recorder.  Records start time.
*6.	[5.2.6] Place all RBHVAC Supply and Exhaust Fan CMC switches in OFF/RESET.	*6.	Places all RBHVAC Supply and Exhaust Fan CMC switches in OFF/RESET.
*7.	[5.2.7] Place collar of Division 2 Manual Isolation TRIP pushbutton in DISARMED and verify Annunciator 8D29, DIV II REAC BLDG ISO PB ARMED, clears.	*7.	Places Div 2 Manual Isolation TRIP pushbutton collar in DISARMED, and verifies 8D29, DIV II REAC BLDG ISO PB ARMED, clears.
*8.	[5.2.8] Depress Division 2 Manual Isolation RESET pushbutton, and verify Division 2 Reactor Building Isolate RESET light is ON.	*8.	Depresses Div 2 Manual Isolation RESET pushbutton, and verifies Div 2 Reactor Building Isolate RESET light is ON.

JOB PERFORMANCE MEASURE

JPM Title Perform Div 2 SGTS Filter and Secondary Containment Isolation Damper Operability Test	No.: JP-OP-315-0166-404 Revision 0 Page 6
---	---

ELEMENT	STANDARD
<b>NOTE: Steps for placing RBHVAC in the shutdown lineup are in 23.426. All equipment should be in the required condition except the Supply and Exhaust Fan switches.</b>	
9. [8.1.2.1] Shutdown selected Exhaust Fan.	9. Places an RBHVAC Exhaust Fan CMC switch in OFF/RESET.
10. [8.1.2.2] Verify paired supply fan trips, exhaust dampers close, and supply fan dampers close.	10. Verifies paired supply fan tripped, exhaust dampers closed, and supply fan dampers closed.
11. [8.1.2.3] Place switch for paired supply fan in OFF/RESET.	11. Places switch for paired supply fan in OFF/RESET.
12. [8.1.2.1] Shutdown (other) selected Exhaust Fan.	12. Places the remaining RBHVAC Exhaust Fan CMC switch in OFF/RESET.
13. [8.1.2.2] Verify paired supply fan trips, exhaust dampers close, and supply fan dampers close.	13. Verifies paired supply fan tripped, exhaust dampers closed, and supply fan dampers closed.
14. [8.1.2.3] Place switch for paired supply fan in OFF/RESET.	14. Places switch for paired supply fan in OFF/RESET.
15. [8.1.2.5] Verify T4100-F029, RBHVAC Intake Air Damper, closes when Reactor Building Supply and Exhaust Fans have been shutdown.	15. Verifies T4100-F029, RBHVAC Intake Air Damper, closes when Reactor Building Supply and Exhaust Fans have been shutdown.
16. [8.1.2.6] When Reactor Building Supply and Exhaust Fans have been shutdown, verify the following valves close: <ul style="list-style-type: none"> <li>• T4100-F010, RBHVAC Sply Otbd Iso Damper</li> <li>• T4100-F011, RBHVAC Sply Inbd Iso Damper</li> <li>• T4100-F009, RBHVAC Exh Inbd Iso Damper</li> <li>• T4100-F008, RBHVAC Exh Otbd Iso Damper</li> </ul>	16. When Reactor Building Supply and Exhaust Fans have been shutdown, verifies the following valves close: <ul style="list-style-type: none"> <li>• T4100-F010, RBHVAC Sply Otbd Iso Damper</li> <li>• T4100-F011, RBHVAC Sply Inbd Iso Damper</li> <li>• T4100-F009, RBHVAC Exh Inbd Iso Damper</li> <li>• T4100-F008, RBHVAC Exh Otbd Iso Damper</li> </ul>
*17. [8.1.2.7] Place switches for the following in OFF/RESET: <ul style="list-style-type: none"> <li>• T4100-C015, RB Sample Sink Bstr Exh Fan</li> <li>• T4100-C016, RB CA Equip Room Bstr Exh Fan</li> </ul>	*17. Places switches for the following in OFF/RESET: <ul style="list-style-type: none"> <li>• T4100-C015, RB Sample Sink Bstr Exh Fan</li> <li>• T4100-C016, RB CA Equip Room Bstr Exh Fan</li> </ul>
18. [8.1.2.8] Depress Reactor Building Exhaust Fan Trip Alarm Reset pushbutton, and turn pushbutton collar to OFF to defeat Reactor Building Fifth Floor Loss of Ventilation Alarm (RB5-A15).	18. Directs RB Rounds to depress Reactor Building Exhaust Fan Trip Alarm Reset pushbutton, and turn pushbutton collar to OFF to defeat Reactor Building Fifth Floor Loss of Ventilation Alarm (RB5-A15).
<b>CUE: Terminate JPM when Div 2 SGTS is operating, and RB HVAC is shut down.</b>	

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_ \* Critical Step

## JOB PERFORMANCE MEASURE

JPM Title Perform Div 2 SGTS Filter and Secondary Containment Isolation Damper Operability Test	No.: JP-OP-315-0166-404 Revision 0 Page 7
---	---

### Evaluator Notes:

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

### Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

### System Specific Notes and Cues:

None

### Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

### Critical Steps:

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Perform Div 2 SGTS Filter and Secondary Containment Isolation Damper Operability Test	No.: JP-OP-315-0166-404 Revision 0 Page 8
---	---

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Perform Div 2 SGTS Filter and Secondary Containment Isolation Damper Operability Test	No.: JP-OP-315-0166-404 Revision 0 Page 9
---	---

**Simulator Setup**

**IC#:**

IC-20 or any full power IC.

**Malfunctions:**

Number	Title	Value	Delay	Ramp
None				

**Remote Functions:**

Number	Title	Value	Delay	Ramp
None				

**Override Functions:**

Number	Title	Value	Delay	Ramp
None				

**Special Instructions:**

1. Initialize to the desired IC, and place the simulator in **RUN**.

**Cue Sheet: (JP-OP-315-0166-404)**

**Initial Conditions:**

- You are the Third NSO.
- RBHVAC is operating normally, CCHVAC is in the NORMAL Mode, and Div 1 & 2 SGTS are in standby.
- Maintenance is complete on the T4100-F010 Damper (solenoid was replaced).
- The CRS and CRNSO have released partial surveillance 24.404.04 (T4100-F010 PMT stroke time) for you to perform.
- The surveillance is scheduled on the POD, to be performed on your shift.
- The SPF Form is filled out, approved, and is correct.
- The surveillance is complete up to Section 5.2.
- A pre-job brief has been conducted with all participants.
- The RB Rounds operator is on the AB 5<sup>th</sup> Floor, standing by for your direction.

**Initiating Cue(s):**

The CRS directs you to perform 24.404.04, Division 2 SGTS Filter And Secondary Containment Isolation Damper Operability Test, Section 5.2. **(T4100-F010 ONLY)**

**JOB PERFORMANCE MEASURE**

Job Position SRO	No. JP-OP-802-4101-419	Revision 4
JPM Title Perform a CRS Short Term Relief	Duration 20 minutes	Page 1

Examinee: \_\_\_\_\_ SRO

Evaluator: \_\_\_\_\_

JPM Type:                   **Normal** / Alternate Path / Time Critical                   Start Time \_\_\_\_\_

Evaluation Method:       **Perform** / Walkthrough / Discuss                   Stop Time \_\_\_\_\_

Location:                   Plant / **Simulator** / Classroom                   Total Time: \_\_\_\_\_

<b>PERFORMANCE EVALUATION SUMMARY</b>											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
* 1.											
* 2.											
* 3.											
4.											
* 5.											
* 6.											
* 7.											

<b>OPERATOR FUNDAMENTALS OBSERVATION</b>				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Perform a CRS Short Term Relief	No.: JP-OP-802-4101-419 Revision: 4 Page 2
--	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Perform a CRS Short Term Relief	No.: JP-OP-802-4101-419 Revision: 4 Page 3
--	--

**JPM Information**

**System:**

N/A

**Task:**

76128 - Provide Short Term Relief

**References:** Required (R) / Available (A)

- MOP07, Shift Turnover (R)
- MOP01003, CRS Shift Relief Checklist (R)

**Tools and Equipment Required:**

Unit Log for previous 24 hours  
Urgent Required Reading Book (in simulator)  
LCO book (in simulator)

**Initial Conditions:**

- You are an extra SRO assigned to the shift.
- You attended the shift turnover meeting this morning.
- Plant conditions are stable and as you see them.
- Your Qualifications have been verified.

**Initiating Cue(s):**

- The SM directs you to provide a Short Term Relief with the CRS.
- All prerequisites are complete.

**Terminating Cue(s):**

Short Term Relief has been completed in accordance with MOP07.

**Task Standard:**

Conduct a CRS Short Term Relief in the Control Room in accordance with MOP07.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

N/A

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** Generic  
**K/A STATEMENT:**  
2.1.3 Knowledge of shift or short-term relief turnover practices. (CFR 41.10/45.13)..... 3.7 / 3.9

**Maintenance Rule Safety Classification:**

N/A

**Maintenance Rule Risk Significant? (Yes or No)**

N/A

JOB PERFORMANCE MEASURE

JPM Title Perform a CRS Short Term Relief	No.: JP-OP-802-4101-419 Revision: 4 Page 4
--	--

PERFORMANCE EVALUATION

Start Time \_\_\_\_\_

ELEMENT	STANDARD
<b>CUE: Provide examinee with Cue Sheet. If asked, provide the examinee with the CRS Shift Relief Checklist (attached).</b>	
<b>NOTE: Examiner is to perform as the CRS being relieved.</b>	
<b>CUE: When asked, provide the examinee with the Unit Log for the past 24 hours (attached).</b>	
* 1. Review Unit Log and abnormal events that have occurred in the last 24 hours.	* 1. Reviews Unit Log, and initials MOP01003.
<b>CUE: A few hours ago power was raised from 82% to 100%. Power had been reduced to perform Turbine Valve testing. The Reactor Building Rounds NO is monitoring and adjusting Recirc MG Set oil temperatures as necessary. HPCI was tagged out to perform corrective maintenance on the Aux Oil Pump, and HPCI has been restored to operable status.</b>	
* 2. Review General Plant Status by discussing operating condition, special limitations, bands and ranges.	* 2. Reviews General Plant Status with CRS by discussing operating condition, special limitations, bands and ranges, and initials MOP01003.
<b>CUE: If asked, there are no outstanding LCOs. (CORA not available on the computer. Use LCO Logbook)</b>	
* 3. Review LCOs.	* 3. Reviews LCO log book or discusses with CRS, and initials MOP01003.
4. Read Urgent Required Reading.	4. Verifies no Urgent Required Reading present (red binder).
<b>CUE: Alarm 1D34 is in due to a faulty conductivity cell E11-N001A. There has been a CARD written to address the problem. Conductivity is currently normal. (If asked, inform the candidate that a continuous sample point is in service. Alarm 4D78 is in due to a broken level switch N30-N095. There has been a CARD written to address the problem. The tank level is currently normal, and the Turbine Building Rounds NO is checking the level twice per shift.</b>	
<b>CUE: SM acknowledges report of the problem with HPCI, and directs the examinee to complete the turnover. The concern with HPCI will be addressed when turnover is complete.</b>	
* 5. Walk down COPs, and discuss any off-normal condition, status of ESF equipment, reasons for lit annunciators, and IPCS alarms.	* 5. Walks down COPs, and discusses any off-normal condition, status of ESF equipment, reasons for lit annunciators, and IPCS alarms, and initials MOP01003. <ul style="list-style-type: none"> <li>• Asks reasons for alarms 1D34 &amp; 4D78.</li> <li>• Determines HPCI Aux Oil Pump CMC is improperly positioned and informs SM/CRS.</li> </ul>

JOB PERFORMANCE MEASURE

JPM Title Perform a CRS Short Term Relief	No.: JP-OP-802-4101-419 Revision: 4 Page 5
--	--

ELEMENT	STANDARD
<b>CUE: Currently, there are no “non-triggered” situation surveillances required.</b>	
* 6. Discuss “non-triggered” situational surveillance requirements.	* 6. Discusses “non-triggered” situational surveillance requirements, and initials MOP01003.
<b>CUE: End JPM when the items noted by an asterisk on the Shift Relief Checklist are completed.</b>	

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* **Critical Step**

## JOB PERFORMANCE MEASURE

JPM Title Perform a CRS Short Term Relief	No.: JP-OP-802-4101-419 Revision: 4 Page 6
--	--

### Evaluator Notes:

This JPM should be started at the CRS Desk in the Simulator.

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

### Generic Notes and Cues:

None

### System Specific Notes and Cues:

None

### Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

### Critical Steps:

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Perform a CRS Short Term Relief	No.: JP-OP-802-4101-419 Revision: 4 Page 7
--	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Perform a CRS Short Term Relief	No.: JP-OP-802-4101-419 Revision: 4 Page 8
--	--

**Simulator Setup**

**IC#:**

IC-20

**Malfunctions:**

Number	Title	Value	Delay	Ramp
C97MF0048	01D034 RHR HX Water Conductivity High	1	0	0
C97MF0709	04D078 Seal Oil Reservoir Tank Level Low	1	0	0

**Remote Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Override Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Special Instructions:**

1. Initialize the simulator and place in RUN.
2. Open and execute lesson JP4101-419.Isn, or insert the malfunctions listed above.
3. Place E4101-C005, HPCI Turbine Aux Oil Pump, CMC switch in OFF RESET.
4. Acknowledge all alarms, and ensure plant conditions are stable.
5. Ensure the following items are available:
  - CRS shift Relief Checklist - MOP01003
  - Previous 24 hours unit log (attached to JPM)
  - **Required reading books**
  - **LCO book**
  - **Urgent Required**

**Cue Sheet: (JP-OP-802-4101-419)****Initial Conditions:**

- You are an extra SRO assigned to the shift.
- You attended the shift turnover meeting this morning.
- Plant conditions are stable and as you see them.
- Your Qualifications have been verified.

**Initiating Cue(s):**

- The SM directs you to provide a Short Term Relief with the CRS.
- All prerequisites are complete.

**TRAINING USE ONLY**  
**Fermi 2 Control Room Log**

<b>Date</b>	<b>Entry</b>	<b>User</b>
Yesterday 07:02	G. Neco relieved R. Valor as CRNSO, T. Sword relieved R. Kitchen as P603, P. Crabbe relieved A. Nightlight as CRS, M. L. Hopwick relieved J. Konners as STA Mode: 1 Reactor Power: 82 % 2807MWt Recirc Speeds: A: 62 % B: 63 % Core Flow: 77 MLB/HR RPV Pressure: 1001 PSIG RPV Level: 197 IN Torus Temp: 79 DEGF Torus Level: -0.6 IN DW Temp: 129 DEGF DW Press: 0.4 PSIG Condenser Pressure: 1.07 PSIA Generator Output: 923 MWe	e52xxx
Yesterday 15:42	N3000 Added hydrogen to the generator IAW 23.122 section 11.0, Initial pressure 70 PSIG Final Pressure 75 PSIG	e51xxx
Yesterday 18:30	Rel - S.Floyd relieved J.Koch as Radwaste Operator Assigned. Also Fred Seever is U.I. for ROA	e50xxx
Yesterday 19:05	R. Valor relieved G. Neco as CRNSO, R. Kitchen relieved T. Sword as P603, A. Nightlight relieved P. Crabbe as CRS, J. Konners relieved M. L. Hopwick as STA Mode: 1 Reactor Power: 82 % 2808MWt Recirc Speeds: A: 62 % B: 63 % Core Flow: 77 MLB/HR RPV Pressure: 1002 PSIG RPV Level: 197 IN Torus Temp: 80 DEGF Torus Level: -0.6 IN DW Temp: 129 DEGF DW Press: 0.4 PSIG Condenser Pressure: 1.06 PSIA Generator Output: 924 MWe	e56xxx
Yesterday 19:20	Started P4100C011 CW RESERVOIR WEST MAKEUP PUMP in accordance with 23.131 section 6.8 - CW Reservoir Makeup Pump Operation	e56xxx
Yesterday 19:25	M. Adore relieved G. Almos as Shift Manager Shift assignments are in accordance with the shift assignment sheet.	e57xxx
Yesterday 20:32	N3033 Added water to Stator Water Head Tank IAW 23.120 section 6.4	e56xxx
Yesterday 21:43	Stopped P4100C010 CW RESERVOIR EAST MAKEUP PUMP in accordance with 23.131 section 6.8 - CW Reservoir Makeup Pump Operation	e56xxx
Yesterday 23:28	N3000 Added hydrogen to the generator IAW 23.122 section 11.0, Initial pressure 70 PSIG Final Pressure 75 PSIG	e58xxx
Today 01:42	Started a planned reactivity change from 82% to 100% reactor power using a combination of Flow and Rods for Rod Pattern Adjustment Initial Recirc Speeds: A 62.00 B 63.00 Initial Core Flow is 77	e59xxx
Today 02:32	Started P4100C010 CW RESERVOIR EAST MAKEUP PUMP in accordance with 23.131 section 6.8 - CW Reservoir Makeup Pump Operation	e58xxx
Today 04:39	N3000 Added hydrogen to the generator IAW 23.122 section 11.0, Initial pressure 71 PSIG Final Pressure 75 PSIG	e58xxx
Today 04:45	Verified reactor power at 95% is within 3% (of rated) of the value indicated in the Power vs. Steam Flow graph IAW 22.000.03	e59xxx
Today 05:08	Stopped P4100C011 CW RESERVOIR WEST MAKEUP PUMP in accordance with 23.131 section 6.8 - CW Reservoir Makeup Pump Operation	e58xxx
Today 05:38	Completed a planned reactivity change from 82% to 100% reactor power using Recirc Flow. Final Recirc Speeds: A 70.2 B 70.2 Final Core Flow is 84.8 Contacted CSS (Mitchell) and MOC (Scott).	e55xxx
Today 06:18	Completed licensed operator walkdown and returned HPCI Aux Oil Pump to service.	e59xxx
Today 06:20	E4101 - Exit LCO 09-0573 for HPCI Aux Oil Pump Inoperable.	e59xxx
Today 06:30	Rel - J. Koch relieved S. Floyd as Radwaste Operator Assigned.	e55xxx
Today 06:55	R. Valor relieved G. Neco as CRNSO, R. Kitchen relieved T. Sword as P603, A. Nightlight relieved P. Crabbe as CRS, J. Konners relieved M. L. Hopwick as STA Mode: 1 Reactor Power: 99.5% 3430 MWt Recirc Speeds: A: 70.25% B: 70.25% Core Flow: 84.8 MLB/HR RPV Pressure: 1030 PSIG RPV Level: 197 IN Torus Temp: 78.8 DEGF Torus Level: 0.12 IN DW Temp: 135.5 DEGF DW Press: 0.52 PSIG Condenser Pressure: 1.36 PSIA Generator Output: 1153 MWe	e56xxx

**JOB PERFORMANCE MEASURE**

Job Position SRO	No. JP-OP-802-4101-102	Revision 1
JPM Title Evaluate Degraded Power Sources	Duration 15 minutes	Page 1

Examinee: \_\_\_\_\_ SRO

Evaluator: \_\_\_\_\_

JPM Type:                    **Normal** / Alternate Path / Time Critical                    Start Time \_\_\_\_\_

Evaluation Method:        **Perform** / Walkthrough / Discuss                                    Stop Time \_\_\_\_\_

Location:                     Plant / Simulator / **Classroom**    Total Time: \_\_\_\_\_

PERFORMANCE EVALUATION SUMMARY											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
* 1.											
* 2.											
* 3.											
4.											
* 5.											
* 6.											

OPERATOR FUNDAMENTALS OBSERVATION				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

**JOB PERFORMANCE MEASURE**

JPM Title Evaluate Degraded Power Sources	No.: JP-OP-802-4101-102 Revision: 1 Page 2
--	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Evaluate Degraded Power Sources	No.: JP-OP-802-4101-102 Revision: 1 Page 3
--	--

**JPM Information**

**System:**

N/A

**Task:**

76034 - Implement Technical Specification/Technical Requirements Manual actions

**References:** Required (R) / Available (A)

Tech Specs 3.8.1, AC Sources - Operating (R)

**Tools and Equipment Required:**

None

**Initial Conditions:**

- You are the CRS.
- Ten (10) minutes ago, ITC was performing troubleshooting activities when 345kV breakers BM & DF opened on fault. All attempts to reclose the breakers have failed.
- All other 345kV / 120kV breakers are in the normal position.
- No other plant equipment is out of service.

**Initiating Cue(s):**

The SM directs you to evaluate this malfunction for potential Tech Spec impact, and document accordingly.

**Terminating Cue(s):**

Required actions listed under Tech Spec 3.8.1, Condition D, have been identified, and the LCO documented using MOP05003.

**Task Standard:**

Required actions of Tech Spec 3.8.1, Condition D, have been identified, and the LCO Sheet is completed correctly per MOP05003.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

N/A

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** GENERIC  
**K/A STATEMENT:**  
2.2.36 Ability to analyze the effect of maintenance activities, such as degraded power sources, on the status of limiting conditions for operations. (CFR 41.10 / 43.2 / 45.13) ..... 3.1 / 4.2

**Maintenance Rule Safety Classification:**

N/A

**Maintenance Rule Risk Significant? (Yes or No)**

N/A

JOB PERFORMANCE MEASURE

JPM Title Evaluate Degraded Power Sources	No.: JP-OP-802-4101-102 Revision: 1 Page 4
--	--

**PERFORMANCE EVALUATION**

Start Time \_\_\_\_\_

ELEMENT	STANDARD
<b>CUE: Provide examinee with Cue Sheet.</b>	
* 1. Review initial conditions to determine which Tech Spec LCO is impacted.	* 1. Determines that, with the BM & DF breakers open, <b>an offsite circuit must be declared inoperable</b> (loss of main generator could lead to loss of offsite circuit).
* 2. Review Tech Spec LCO 3.8.1 to determine which Condition(s) apply to the malfunction.	* 2. Determines that <b>Condition D applies</b> to one offsite circuit inoperable.
* 3. Review LCO 3.8.1, Action D.1 to determine its applicability.	* 3. Determines that <b>SR 3.8.1</b> for operable offsite circuit must be completed.
4. Review LCO 3.8.1, Action D.2 to determine its applicability.	4. Determines that Action D.2 is <b>NOT</b> required.
* 5. Review LCO 3.8.1, Action D.3 to determine its applicability.	* 5. Determines that the offsite circuit must be restored to operable status within <b>72 hours</b> .
<b>CUE: If asked, the LCO Sheet cannot be generated electronically and must be documented on paper. Provide the examinee with a copy of MOP05003.</b>	
* 6. Document the operability determination.	* 6. Operability determination documented on LCO Sheet.
<b>CUE: End JPM when required actions listed under Tech Spec 3.8.1, Condition D, have been identified, and LCO is documented on MOP05003.</b>	

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* **Critical Step**

## JOB PERFORMANCE MEASURE

JPM Title  
Evaluate Degraded Power Sources

No.: JP-OP-802-4101-102  
Revision: 1  
Page 5

### Evaluator Notes:

This JPM may be started at the CRS desk in the simulator.

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

### Generic Notes and Cues:

None

### System Specific Notes and Cues:

None

### Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

### Critical Steps:

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Evaluate Degraded Power Sources	No.: JP-OP-802-4101-102 Revision: 1 Page 6
--	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Evaluate Degraded Power Sources	No.: JP-OP-802-4101-102 Revision: 1 Page 7
--	--

**Simulator Setup**

**IC#:**

N/A

**Malfunctions:**

Number	Title	Value	Delay	Ramp
N/A				

**Remote Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Override Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Special Instructions:**

N/A

**Cue Sheet: (JP-OP-802-4101-102)**

**Initial Conditions:**

- You are the CRS.
- Ten (10) minutes ago, ITC was performing troubleshooting activities when 345kV breakers BM & DF opened on fault. All attempts to reclose the breakers have failed.
- All other 345kV / 120kV breakers are in the normal position.
- No other plant equipment is out of service.

**Initiating Cue(s):**

The SM directs you to evaluate this malfunction for potential Tech Spec impact, and document accordingly.



JOB PERFORMANCE MEASURE

JPM Title Calculate Stay time and determine if dose extension is needed.	No.: JP-OP-802-4101-413 Revision: 3 Page 2
---	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Calculate Stay time and determine if dose extension is needed.	No.: JP-OP-802-4101-413 Revision: 3 Page 3
---	--

**JPM Information**

**System:**

N/A

**Task:**

73443 - SOER 01-1 Rec. 5 - Radiation protection training and retraining for plant personnel should include a review of selected industry events involving large, unplanned exposures and the responsibility of individuals for the prevention of such events.

**References:** Required (R) / Available (A)

MRP12, Authorization To Exceed Dose Control Thresholds (R)

**Tools and Equipment Required:**

Survey Map for N. RWCU Room

**Initial Conditions:**

- An NSO must enter the N. RWCU Pump Room to perform an investigation of G33-F013A, North RWCU Pump Discharge Isolation Valve.
- The estimated time necessary to perform the inspection is 6 minutes.
- The NSO's exposure for the year is 753 mrem TEDE.
- The situation is **NOT** an emergency, but there is no alternative to performing the inspection.

**Initiating Cue(s):**

Determine what requirements must be met, if any, to allow the NSO to perform this inspection.

**Terminating Cue(s):**

Candidate informs SM that dose extension must be obtained.

**Task Standard:**

Determination is made that authorization to exceed Fermi 2 Administrative Guidelines must be obtained in accordance with MRP 12.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

N/A

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** GENERICS  
**K/A STATEMENT:**  
2.3.4 Knowledge of Radiation exposure limits and contamination control including permissible levels in excess of those authorized.....2.5 / 3.1

**Maintenance Rule Safety Classification:**

N/A

**Maintenance Rule Risk Significant? (Yes or No)**

N/A

JOB PERFORMANCE MEASURE

JPM Title Calculate Stay time and determine if dose extension is needed.	No.: JP-OP-802-4101-413 Revision: 3 Page 4
---	--

**PERFORMANCE EVALUATION**

Start Time \_\_\_\_\_

ELEMENT		STANDARD	
<b>CUE: Provide candidate with Cue Sheet. If asked, provide candidate with Survey Map of N. RWCU Pump Room.</b>			
<b>CUE: If asked, the radiation level in the area of the valve to be inspected is 6 Rem/hr.</b>			
* 1.	Determine that RWP survey results are needed for estimation of radiation dose.	* 1.	Determines radiation level in the area of the valve is 6 Rem/hr.
* 2.	Calculate dose.	* 2.	Dose = 6/60 hr * 6 Rem/hr = 0.1 hr * 6000 mr/hr = 600 mr 600 mr + 753 mr = 1353 mr = 1.353 R (Fermi Admin Guideline = 1 REM/yr TEDE)
<b>CUE: As SM, acknowledge the report.</b>			
* 3.	Inform SM that dose will exceed Fermi 2 administrative guidelines, and a dose extension will be required.	* 3.	Informs SM that dose will exceed Fermi 2 administrative guidelines, and a dose extension is necessary.
<b>CUE: End JPM when SM has been informed that a dose extension is necessary.</b>			

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* **Critical Step**

## JOB PERFORMANCE MEASURE

JPM Title Calculate Stay time and determine if dose extension is needed.	No.: JP-OP-802-4101-413 Revision: 3 Page 5
---	--

### Evaluator Notes:

The Plant can be in any mode of operation to conduct this JPM.  
This JPM may be started at the CRS Desk in the Simulator.

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

### Generic Notes and Cues:

None

### System Specific Notes and Cues:

None

### Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

### Critical Steps:

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Calculate Stay time and determine if dose extension is needed.	No.: JP-OP-802-4101-413 Revision: 3 Page 6
---	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Calculate Stay time and determine if dose extension is needed.	No.: JP-OP-802-4101-413 Revision: 3 Page 7
---	--

**Simulator Setup**

**IC#:**

N/A

**Malfunctions:**

Number	Title	Value	Delay	Ramp
None				

**Remote Functions:**

Number	Title	Value	Delay	Ramp
None				

**Override Functions:**

Number	Title	Value	Delay	Ramp
None				

**Special Instructions:**

**Cue Sheet: (JP-OP-802-4101-413)**

**Initial Conditions:**

- An NSO must enter the N. RWCU Pump Room to perform an investigation of G33-F013A, North RWCU Pump Discharge Isolation Valve.
- The estimated time necessary to perform the inspection is 6 minutes.
- The NSO's exposure for the year is 753 mrem TEDE.
- The situation is **NOT** an emergency, but there is no alternative to performing the inspection.

**Initiating Cue(s):**

Determine what requirements must be met, if any, to allow the NSO to perform this inspection.

**JOB PERFORMANCE MEASURE**

Job Position SRO / RO	No. JP-OP-315-0043-005	Revision 2
JPM Title Recovery of RCIC following a Manual Trip	Duration 25 minutes	Page 1

Examinee: \_\_\_\_\_ SRO / RO

Evaluator: \_\_\_\_\_

JPM Type:                    **Normal** / Alternate Path / Time Critical                    Start Time \_\_\_\_\_  
 Evaluation Method:       **Perform** / Walkthrough / Discuss                    Stop Time \_\_\_\_\_  
 Location:                    Plant / **Simulator** / Classroom                    Total Time: \_\_\_\_\_

<b>PERFORMANCE EVALUATION SUMMARY</b>											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
* 1.				*11.							
2.				*12.							
* 3.				*13.							
4.				*14.							
5.				15.							
*6.				*16.							
*7.				*17.							
*8.											
9.											
10.											

<b>OPERATOR FUNDAMENTALS OBSERVATION</b>				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Recovery of RCIC following a Manual Trip	No.: JP-OP-315-0043-005 Revision: 2 Page 2
---	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Recovery of RCIC following a Manual Trip	No.: JP-OP-315-0043-005 Revision: 2 Page 3
---	--

**JPM Information**

**System:**

E5100 - Reactor Core Isolation Cooling System

**Task:**

63607 - Perform a recovery of RCIC following a trip

**References:** Required (R) / Available (A)

23.206, Reactor Core Isolation Cooling System

**Tools and Equipment Required:**

None

**Initial Conditions:**

- You are the Control Room NSO with the reactor shut down following a transient.
- The EOPs have been entered.
- RCIC, SBFW, and CRD pumps were injecting to control reactor water level.
- RCIC was subsequently shutdown using the manual trip pushbutton.
- N2103-F001 (SBFW injection valve) has just failed closed, and the pumps have been shut down.

**Initiating Cue(s):**

The CRS directs you to reset and manually restart RCIC per 23.206 section 7, and restore water level to 173"-214".

**Terminating Cue(s):**

RCIC is injecting into the RPV at approximately 650 gpm.

**Task Standard:**

RCIC has been restarted following a manual trip per 23.206, Reactor Core Isolation Cooling System.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

2-Reactor Water Inventory Control

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** 217000 - Reactor Core Isolation Cooling System

**K/A STATEMENT:**

- A4. Ability to operate and/or monitor in the control room:  
A4.02 Turbine trip throttle valve reset..... 3.9/3.9

**Maintenance Rule Safety Classification:**

E5100-01

**Maintenance Rule Risk Significant? (Yes or No)**

Yes

JOB PERFORMANCE MEASURE

JPM Title Recovery of RCIC following a Manual Trip	No.: JP-OP-315-0043-005 Revision: 2 Page 4
---	--

**PERFORMANCE EVALUATION**

Start Time \_\_\_\_\_

ELEMENT	STANDARD
<b>CUE: Provide the examinee with the cue sheet.</b>	
* 1. [7.1.2.1.a] Depress RCIC System Initiate Signal reset pushbutton and verify: <ul style="list-style-type: none"> <li>White SEALED IN light goes off</li> <li>Annunciator 1D24, RCIC SYSTEM ACTUATION, clears.</li> </ul>	* 1. Depresses RCIC System Initiate Signal reset pushbutton, and verifies SEALED IN light goes out and 1D24 clears.
2. [7.1.2.1.b] Close or verify closed E5150-F095, RCIC Turb Stm Inlet Byp Vlv.	2. Verifies E5150-F095 is closed.
* 3. [7.1.2.1.c] Close or verify closed the following valves: <ul style="list-style-type: none"> <li>E5150-F059, RCIC Turbine Trip Throttle Vlv</li> <li>E5150-F019, RCIC Min Flow Vlv</li> <li>E5150-F013, RCIC Disch to FW Inbd Iso Valve</li> <li>E5150-F045, RCIC Turb Steam Inlet Vlv</li> <li>E5150-F046, RCIC Oil Clr Clg Water Iso Vlv</li> </ul>	* 3. Closes E5150-F059. Verifies E5150-F019 is closed. Verifies E5150-F013 is closed. Closes E5150-F045. Closes E5150-F046.
4. [7.1.2.1.d] Open the following valves: <ul style="list-style-type: none"> <li>E5150-F025, RCIC Turb Stm Drn Pot Inbd Iso</li> <li>E5150-F026, RCIC Turb Stm Drn Pot Otbd Iso</li> <li>E5150-F005, RCIC Cond To RW Otbd Iso Vlv</li> </ul>	4. Verifies the following valves are open: <ul style="list-style-type: none"> <li>E5150-F025</li> <li>E5150-F026</li> <li>E5150-F005</li> </ul>
<b>NOTE: RPV Level is &gt;Level 2, and RCIC was tripped manually, so 7.1.2.2 &amp; 7.1.2.3 are NA.</b>	
5. [7.1.2.4.c] Place RCIC Turbine Trip Pushbutton collar in DISARMED.	5. Verifies RCIC Turbine Trip PB collar is in DISARMED.
* 6. [7.1.2.5.a] Verify RCIC System Initiation Signal has been reset (if possible).	* 6. RCIC System Initiation Signal has been reset.
* 7. [7.1.2.5.c] Close E5150-F059, RCIC Turbine Trip Throttle Vlv,	* 7. Verifies E5150-F059 is closed.
* 8. [7.1.2.5.d] Open E5150-F059, RCIC Turbine Trip Throttle Vlv,	* 8. Opens E5150-F059.
9. [7.1.2.5.e] Verify annunciator 1D94, RCIC Turbine Tripped is clear.	9. Verifies 1D94 is clear.
<b>CUE: NO reports that valve stem for E51-F059, RCIC Turbine Inlet Trip Throttle Vlv, is in OPEN.</b>	

JOB PERFORMANCE MEASURE

JPM Title Recovery of RCIC following a Manual Trip	No.: JP-OP-315-0043-005 Revision: 2 Page 5
---	--

ELEMENT	STANDARD
10. [7.1.2.5.f] Verify locally valve stem for E51-F059, RCIC Turbine Inlet Trip Throttle Vlv, is in OPEN.	10. Directs NO to locally verify valve stem for E51-F059, RCIC Turbine Inlet Trip Throttle Vlv, is in OPEN.
<b>CUE: If asked, the student may restart RCIC using section 5.4 or Enclosure B (Hard Card) with all prerequisites met or waived by CRS.</b>	
<b>NOTE: If Enclosure B is used, the Turbine Steam Drain Pot Valves will not be verified closed.</b>	
*11. [5.4.2.1] Start E5101-C004 RCIC Baro Cndr Vacuum Pump.	*11. Starts E5101-C004, RCIC Baro Cndr Vacuum Pump.
*12. [5.4.2.2] Open E5150-F046, RCIC Oil Clr Clg Water Iso Vlv.	*12. Opens E5150-F046.
<b>NOTE: Examinee should make Hi Com announcement and Crew Update "Starting RCIC"</b>	
*13. [5.4.2.3.a] Open E5150-F095, RCIC Turb Stm Inlet Byp Vlv.	*13. Opens E5150-F095.
*14. [5.4.2.3.b] After approximately 15 seconds, open E5150-F045, RCIC Turb Steam Inlet Vlv.	*14. After 15 seconds, opens E5150-F045.
15. [5.4.2.4] Verify the following valves close: <ul style="list-style-type: none"> <li>• E5150-F025, RCIC Turb Stm Drn Pot Inbd Iso</li> <li>• E5150-F026, RCIC Turb Stm Drn Pot Otbd Iso</li> </ul>	15. Verifies E5150-F025 and E5150-F026 close.
*16. [5.4.2.6] Open E5150-F013, RCIC Dish To FW Inbd Iso Valve	*16. Opens E5150-F013.
*17. [5.4.2.7] Adjust flow as necessary with E51-K615, RCIC Discharge Flow Controller.	*17. Adjusts flow with E51-K615 to maintain RPV Level.
<b>CUE: End JPM when RCIC is injecting with approximately 650 gpm with level increasing.</b>	

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* Critical Step

## JOB PERFORMANCE MEASURE

JPM Title Recovery of RCIC following a Manual Trip	No.: JP-OP-315-0043-005 Revision: 2 Page 6
---	--

### Evaluator Notes:

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

### Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Ex.: Pump start: "Switch has been rotated to the start position, red light is lit, green light is out, amperage initially pegs out high, and is now indicating  X  amps."

Pump stop: "Switch has been rotated to the stop position, green light is lit, red light is out, amperage indicates 0 amps."

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

Controllers have an Auto light that is GREEN when selected and AMBER (YELLOW) when Manual is selected. When in Manual, the open and closed pushbuttons control the parameter to be changed by adjusting position or speed. When the deviation meter is nulled, then the process can be shifted to Auto to allow the desired setpoint to control the process.

### System Specific Notes and Cues:

None

### Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

### Critical Steps:

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title  
Recovery of RCIC following a Manual Trip

No.: JP-OP-315-0043-005  
Revision: 2  
Page 7

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Recovery of RCIC following a Manual Trip	No.: JP-OP-315-0043-005 Revision: 2 Page 8
---	--

**Simulator Setup**

**IC#:** 20

**Malfunctions:**

<b>Number</b>	<b>Title</b>	<b>Value</b>	<b>Delay</b>	<b>Ramp</b>
N20MF0023	Heater Feed Pump Trip C	ACTIVE	0	0
N20MF0024	Heater Feed Pump Trip E	ACTIVE	0	0
N20MF0025	Heater Feed Pump Trip W	ACTIVE	0	0

**Remote Functions:**

<b>Number</b>	<b>Title</b>	<b>Value</b>	<b>Delay</b>	<b>Ramp</b>
---------------	--------------	--------------	--------------	-------------

**Override Functions:**

<b>Number</b>	<b>Title</b>	<b>Value</b>	<b>Delay</b>	<b>Ramp</b>
---------------	--------------	--------------	--------------	-------------

**Special Instructions:**

1. Initialize the simulator to the desired IC, and place in RUN.
2. Open and Execute lesson **JP0043-005**.Isn, or set the malfunctions listed above.
3. Place Mode Switch in Shutdown.
4. Dial down the RCIC flow controller to 0, and manually trip the RCIC turbine. Place the trip pushbutton collar in Disarmed.
5. Shut down HPCI when level has recovered to ~140 inches.
6. Verify RPV level about 160", then place the simulator in FREEZE.
7. When examiner is ready, place the simulator in RUN.

**Cue Sheet: (JP-OP-315-0043-005)**

**Initial Conditions:**

- You are the Control Room NSO with the reactor shut down following a transient.
- The EOPs have been entered.
- RCIC, SBFW, and CRD pumps were injecting to control reactor water level.
- RCIC was subsequently shutdown using the manual trip pushbutton.
- N2103-F001 (SBFW injection valve) has just failed closed, and the pumps have been shut down.

**Initiating Cue(s):**

The CRS directs you to reset and manually restart RCIC per 23.206 section 7, and restore water level to 173"-214".

**JOB PERFORMANCE MEASURE**

Job Position <b>SRO</b>	No. JP-OP-802-4101-443	Revision 0
Activate ECOS in accordance with EP-290	Duration 15 minutes	Page 1

Examinee: \_\_\_\_\_ SRO

Evaluator: \_\_\_\_\_

JPM Type:                   **Normal** / Alternate Path / Time Critical                   Start Time \_\_\_\_\_  
 Evaluation Method:       **Perform** / Walkthrough / Discuss                   Stop Time \_\_\_\_\_  
 Location:                   Plant / Simulator / **Classroom**                   Total Time: \_\_\_\_\_

<b>PERFORMANCE EVALUATION SUMMARY</b>											
Element	S	U	Comment	Element	S	U	Comment	Element	S	U	Comment
* 1.											
* 2.											
* 3.											
* 4.											
* 5.											
* 6.											
* 7.											
* 8.											

<b>OPERATOR FUNDAMENTALS OBSERVATION</b>				
Monitor operator fundamentals during the JPM set. Rate each area based on the criteria by placing a checkmark in the appropriate column. Indicate the comment number associated with the observation.				
Operator Fundamental	Meets all Expectations	Opportunity for Improvement	Does not meet Expectations	Comment Number
Monitoring				
Control				
Conservatism				
Teamwork				
Knowledge				

**OVERALL EVALUATOR COMMENTS:**

\_\_\_\_\_ **PASS**      \_\_\_\_\_ **FAIL**

Evaluator Signature / Date: \_\_\_\_\_ / \_\_\_\_\_

JOB PERFORMANCE MEASURE

JPM Title Activate ECOS in accordance with EP-290	No.: JP-OP-802-4101-443 Revision: 0 Page 2
--	--

**JPM Observation Criteria**

<b>Fundamental</b>	<b>Meets all Expectations</b>	<b>Opportunity for Improvement</b>	<b>Does not meet Expectations</b>
<b>Monitoring</b>	Equipment status monitored at proper frequency, using multiple means if available. Understood which indications were critical.	Some monitoring was performed but undue focus on task or lack of system knowledge prevented ideal monitoring.	Did not recognize key equipment status indicators, too much focus on single indications and ignored total system status.
<b>Control</b>	Task preview used to prepare for job. Aware of control bands and maintained them. Configuration control maintained.	Adequate control of system maintained throughout task but some improvements could be made such as better manual control or greater depth of knowledge for anticipating system response.	No anticipation of results of actions. Unaware or control bands or not able to maintain them. Lack of knowledge of how to control system parameters.
<b>Conservatism</b>	Low threshold for identification of problems. Questioning attitude. Uses "stop when unsure" if needed. Sensitive to nuclear safety.	Some opportunities existed to question before proceeding, High focus on task completion without consideration for other system affects.	Proceeds even when unsure with unanswered questions. High threshold for problem conditions.
<b>Teamwork</b>	Routinely communicates system status changes to the team. Communicates actions before taking them.	Communicated most status and actions. Some improvement would be warranted.	Routinely takes action without informing the team.
<b>Knowledge</b>	Able to anticipate system response based on solid system knowledge. Good working knowledge of generic fundamentals to predict and monitor system response.	Plant, system, or generic fundamental knowledge has some gaps.	Unable to predict system response, unsure of generic fundamentals concepts related to plant operation. Only relied on procedure for operating knowledge.

JOB PERFORMANCE MEASURE

JPM Title Activate ECOS in accordance with EP-290	No.: JP-OP-802-4101-443 Revision: 0 Page 3
--	--

**JPM Information**

**System:**

N/A

**Task:**

73999 - Activate the Emergency Call Out System (ECOS)

**References:** Required (R) / Available (A)

EP-290, Emergency Notifications (R)

**Tools and Equipment Required:**

Unplugged Telephone

**Initial Conditions:**

- You are the Work Control Supervisor.
- It is back shift on a Saturday night.
- A Site Area Emergency has been declared and you have reported to the Main Control Room as requested by the Shift Manager.
- Initial notifications to County, State, and Ontario Province have been completed.

**Initiating Cue(s):**

Activate ECOS using a phone in accordance with Enclosure E, of EP-290, Emergency Notifications.

**Terminating Cue(s):**

ECOS is activated.

**Task Standard:**

ECOS is activated using a phone in accordance with EP-290, Enclosure E.

**Licensed Operator Exam Information (required for NRC exams)**

**Safety Function:**

N/A

**K/A Reference:** (from NUREG 1123)

**K/A SYSTEM:** Generic  
**K/A STATEMENT:**  
2.4.43 – Knowledge of emergency communication systems and techniques. .... 3.2 / 3.8

**Maintenance Rule Safety Classification:**

No

**Maintenance Rule Risk Significant? (Yes or No)**

No

JOB PERFORMANCE MEASURE

JPM Title Activate ECOS in accordance with EP-290	No.: JP-OP-802-4101-443 Revision: 0 Page 4
--	--

PERFORMANCE EVALUATION

Start Time \_\_\_\_\_

ELEMENT	STANDARD
<b>NOTE: An unplugged telephone available for examinee's use will allow more effective simulation of ECOS activation by SM phone.</b>	
<b>CUE: Provide the examinee with the Cue Sheet. If necessary, provide the examinee with a current copy of EP-290.</b>	
* 1. [3.1.1] Have ready the applicable <i>Scenario ID Number</i> from Table 1-1 for the corresponding classification.	* 1. Determines correct <i>Scenario ID Number</i> from Table 1-1 is <b>3</b> .
* 2. [3.1.2] Call the Remote Scenario Activation phone number (800) 380-0407 or (615) 844-5611.	* 2. Dials [800] 380-0407 or [615] 986-3719.
<b>CUE: After the phone number has been dialed, state "Welcome, enter your User ID Number followed by the # sign."</b>	
* 3. [3.1.3] At the prompt for User ID, enter <b>65235</b> , then press #.	* 3. Enters <b>65235</b> , followed by #.
<b>CUE: After the User ID and # have been entered, state "Enter your Security PIN number, followed by the # sign."</b>	
<b>CUE: If asked, the Security PIN number is 12345.</b>	
* 4. [3.1.4] At the prompt for Security PIN, enter the confidential PIN number, then press #.	* 4. Enters <b>12345</b> , followed by #.
<b>CUE: After the Security PIN and # have been entered, state "Enter the Scenario ID Number followed by the # sign."</b>	
* 5. [3.1.5] At the prompt for Scenario ID, enter the associated Scenario ID from Table 1-1, and then press #.	* 5. Enters <b>3</b> , followed by #.
<b>NOTE: The system will go through a list of options from the program menu.</b>	
<b>CUE: After the Scenario ID and # have been entered, state "Listen to the following Options then press the appropriate number on the phone key pad: Press 1 - to listen to the current scenario message [pre-recorded messages designed for Fermi 2 ERO] - or - Press 2 - to re-record the scenario message. The system will give instructions on how to record and verify your message. - or - Press 3 - to start the scenario. When you hear the response, "The scenario is building", exit the program by pressing #. - or - Press 4 - to return to the main menu."</b>	
* 6. [3.1.6] Press the appropriate number on the phone key pad.	* 6. Presses <b>3</b> .
<b>CUE: After the number 3 has been entered, state "The Scenario is building."</b>	
* 7. [3.1.6] When the system reports that the scenario is building exit the program by pressing the # sign.	* 7. Presses #, and hangs up the phone.

JOB PERFORMANCE MEASURE

JPM Title Activate ECOS in accordance with EP-290	No.: JP-OP-802-4101-443 Revision: 0 Page 5
--	--

ELEMENT	STANDARD
<b>NOTE:</b> ECOS is programmed to immediately call [734] 586-5235 at the Shift Manager's desk for "emergency" or "test" activations.	
<b>CUE:</b> After the phone has been hung up, state <b>"The phone is ringing."</b> When the applicant answers the phone, states <b>"Enter the last 5 digits of your SAP Employee Number."</b>	
* 8. [4.2] Answer the call, and when prompted for the last five digits of your SAP Employee Number, enter <b>1111</b> , then press <b>#</b> .	* 8. Enters <b>1111</b> , followed by <b>#</b> .
<b>CUE:</b> After 1111 and # have been entered, state <b>"ECOS is activated."</b>	
<b>CUE:</b> End JPM when ECOS is activated.	

\_\_\_\_\_ SATISFACTORY

\_\_\_\_\_ UNSATISFACTORY

Stop Time \_\_\_\_\_

\* **Critical Step**

JOB PERFORMANCE MEASURE

JPM Title Activate ECOS in accordance with EP-290	No.: JP-OP-802-4101-443 Revision: 0 Page 6
--	--

**Evaluator Notes:**

**ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.**

**Generic Notes and Cues:**

None

**System Specific Notes and Cues:**

None

**Task Performance and Cues:**

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee.

**Critical Steps:**

Critical Tasks are identified by asterisk (\*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE

JPM Title Activate ECOS in accordance with EP-290	No.: JP-OP-802-4101-443 Revision: 0 Page 7
--	--

**FOLLOW-UP DOCUMENTATION QUESTIONS**

Reason for follow-up question(s):

---

---

Question:

---

---

---

---

---

Reference:

Response:

---

---

---

---

---

---

---

---

---

---

Question:

---

---

---

---

---

Reference

Response:

---

---

---

---

---

---

---

---

---

---

JOB PERFORMANCE MEASURE

JPM Title Activate ECOS in accordance with EP-290	No.: JP-OP-802-4101-443 Revision: 0 Page 8
--	--

**Simulator Setup**

**IC#:**

N/A

**Malfunctions:**

Number	Title	Value	Delay	Ramp
N/A				

**Remote Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Override Functions:**

Number	Title	Value	Delay	Ramp
N/A				

**Special Instructions:**

N/A

**Cue Sheet: (JP-OP-802-4101-443)**

**Initial Conditions:**

- You are the Work Control Supervisor.
- It is back shift on a Saturday night.
- A Site Area Emergency has been declared and you have reported to the Main Control Room as requested by the Shift Manager.
- Initial notifications to County, State, and Ontario Province have been completed.

**Initiating Cue(s):**

Activate ECOS using a phone in accordance with Enclosure E, of EP-290, Emergency Notifications.