

NRR-PMDAPEm Resource

From: Miller, Ed
Sent: Friday, December 27, 2013 2:11 PM
To: White, Brandi
Subject: FW: Farley Unit 1 Post Accident Monitoring Report

Brandi,
Could you add this to ADAMS and let me know the ML number. Thanks!

Ed

From: Thorp, John
Sent: Friday, December 20, 2013 11:17 AM
To: Miller, Ed
Cc: Stattel, Richard
Subject: RE: Farley Unit 1 Post Accident Monitoring Report

Thanks for the information Ed.

EICB has reviewed the information provided in the 30 day report from Joseph Farley station on the Unit 1 condensate storage tank level instrument. We understand the transmitter discussed in the report has been restored to operable status and we have no questions or concerns at this point.

John

John E. Thorp
Chief, Instrumentation & Controls Branch
Division of Engineering
Office of Nuclear Reactor Regulation
USNRC
301-415-8508

From: Miller, Ed
Sent: Friday, December 20, 2013 9:58 AM
To: Thorp, John
Subject: Farley Unit 1 Post Accident Monitoring Report

John,
The link below is for a TS required report submitted by Farley, Unit No. 1, for an inoperable Condensate Storage Tank level transmitter greater than 30 days. The licensee was able to restore operability prior to submission of the report and determined that the problem was a degraded cabling splice. Please let me know if you have any questions on the issue otherwise, I'll close out NRC staff activity on the matter. Thanks.

Ed Miller
415-2481

[View ADAMS P8 Properties ML13116A343](#)

[Open ADAMS P8 Document \(Joseph M. Farley, Unit 1 - Post Accident Monitoring Report.\)](#)

Hearing Identifier: NRR_PMDA
Email Number: 975

Mail Envelope Properties (9C2386A0C0BC584684916F7A0482B6CAF33C32F637)

Subject: FW: Farley Unit 1 Post Accident Monitoring Report
Sent Date: 12/27/2013 2:11:14 PM
Received Date: 12/27/2013 2:11:15 PM
From: Miller, Ed

Created By: Ed.Miller@nrc.gov

Recipients:
"White, Brandi" <Brandi.White@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	1915	12/27/2013 2:11:15 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: