



December 27, 2013

NRC 2013-0113  
10 CFR 50.55a

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Point Beach Nuclear Plant Unit 2  
Docket 50-301  
Renewed License No. DPR-27

10 CFR 50.55a Request  
Relief Request 2-RR-7  
Re-Categorization of Unit 2 Steam Generator Nozzle to Safe-End Welds

Pursuant to 10 CFR 50.55a(g)(6)(ii)(F)(2), NextEra Energy Point Beach, LLC (NextEra) requests that the Nuclear Regulatory Commission (NRC) allow the re-categorization of the four (4) steam generator nozzle dissimilar metal welds installed in Point Beach Nuclear Plant (PBNP) Unit 2.

Due to the June 21, 2011 rulemaking change to 10CFR50.55a [FR36232 Volume 76, Number 119], the primary Steam Generator (SG) nozzle to safe-end welds were required to have a baseline inspection performed in the first outage following August 22, 2011. The rulemaking required the use of American Society of Mechanical Engineers (ASME) Boiler & Pressure Vessel Code (BPVC) Code Case N-770-1 with conditions specified in 10CFR50.55a(g)(6)(ii)(F). NextEra is requesting the dissimilar metal weld categorization change to reflect the actual weld profile rather than the default A-2 and B assignment under the new rule.

NextEra requests approval of this request by December 31, 2014. The proposed alternative categorization for the Unit 2 SG nozzle dissimilar metal welds (inlet and outlet) will be a permanent change to the PBNP ISI Program for the duration of the extended license.

This letter contains no new Regulatory Commitments or revisions to existing Regulatory Commitments.

A047  
NRC

If you have questions or require additional information, please contact Mr. Michael Millen, Licensing Manager, at 920/755-7845.

In accordance with the provisions of 10 CFR 50.91, a copy of this submittal has been provided to the designated Wisconsin Official.

Very truly yours,

NextEra Energy Point Beach, LLC

A handwritten signature in black ink that reads "Larry Meyer". The signature is written in a cursive style with a large initial "L" and "M".

Larry Meyer  
Site Vice President

Enclosure

cc: Regional Administrator, Region III, USNRC  
Project Manager, Point Beach Nuclear Plant, USNRC  
Resident Inspector, Point Beach Nuclear Plant, USNRC  
PSCW  
Mr. Mike Verhagan, Department of Commerce, State of Wisconsin