



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

January 13, 2014

Mr. Matthew W. Sunseri  
President and Chief Executive Officer  
Wolf Creek Nuclear Operating Corporation  
Post Office Box 411  
Burlington, KS 66839

SUBJECT: WOLF CREEK GENERATING STATION – CORRECTION TO TECHNICAL SPECIFICATION PAGE ISSUED FOR AMENDMENT NO. 206, REVISE TECHNICAL SPECIFICATION 3.8.1, “AC SOURCES - OPERATING” (TAC NO. ME9603)

Dear Mr. Sunseri:

By letter dated December 2, 2013 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML13282A147), the U.S. Nuclear Regulatory Commission (NRC) issued Amendment No. 206 to Facility Operating License No. NPF-42 for the Wolf Creek Generating Station. The amendment increased the voltage limit for the emergency diesel generator full load rejection test specified by Technical Specification (TS) 3.8.1, “AC [Alternating Current] Sources - Operating,” Surveillance Requirement 3.8.1.10.

On December 31, 2013, your staff identified that the new TS page 3.8-9 issued with Amendment No. 206 did not include changes to the page issued with Amendment No. 204. Please find enclosed a replacement TS page 3.8-9 for Amendment No. 206. This correction does not change any of the NRC staff's conclusions in the safety evaluation associated with the amendment.

M. Sunseri

- 2 -

The remainder of the letter and the enclosure were correct. I apologize for any inconvenience due to the error. If you have any questions, please contact me at 301-415-2296 or via e-mail at [fred.lyon@nrc.gov](mailto:fred.lyon@nrc.gov).

Sincerely,

A handwritten signature in black ink that reads "CFlyon". The letters are cursive and somewhat stylized.

Carl F. Lyon, Project Manager  
Plant Licensing Branch IV-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-482

Enclosure:  
Revised TS page 3.8-9

cc w/encl: Distribution via Listserv

**ENCLOSURE**

**REVISED TECHNICAL SPECIFICATION PAGE 3.8-9 FOR  
AMENDMENT NO. 206 ISSUED DECEMBER 2, 2013**

**WOLF CREEK NUCLEAR OPERATING CORPORATION**

**WOLF CREEK GENERATING STATION**

**DOCKET NO. 50-482**

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.8.1.7	<p>-----NOTE----- All DG starts may be preceded by an engine prelube period. -----</p> <p>Verify each DG starts from standby condition and achieves:</p> <p>a. In <math>\leq 12</math> seconds, voltage <math>\geq 3950</math> V and frequency <math>\geq 59.4</math> Hz; and</p> <p>b. Steady state voltage <math>\geq 3950</math> V and <math>\leq 4320</math> V, and frequency <math>\geq 59.4</math> Hz and <math>\leq 60.6</math> Hz.</p>	184 days
SR 3.8.1.8	Not Used.	
SR 3.8.1.9	Not Used.	
SR 3.8.1.10	Verify each DG operating at a power factor $\leq 0.9$ and $\geq 0.8$ does not trip and voltage is maintained $\leq 4992$ V and frequency is maintained $\leq 65.4$ Hz during and following a load rejection of $\geq 5650$ kW and $\leq 6201$ kW.	18 months

(continued)

M. Sunseri

- 2 -

The remainder of the letter and the enclosure were correct. I apologize for any inconvenience due to the error. If you have any questions, please contact me at 301-415-2296 or via e-mail at [fred.lyon@nrc.gov](mailto:fred.lyon@nrc.gov).

Sincerely,

**/ RA /**

Carl F. Lyon, Project Manager  
Plant Licensing Branch IV-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-482

Enclosure:  
Revised TS page 3.8-9

cc w/encl: Distribution via Listserv

**DISTRIBUTION:**

PUBLIC  
LPLIV-1 Reading  
RidsAcrcsAcnw\_MailCTR Resource  
RidsNrrDorlLpl4-1 Resource  
RidsNrrLAJBurkhardt Resource  
RidsNrrPMWolfCreek Resource  
RidsRgn4MailCenter Resource

**ADAMS Accession No.: ML14006A218**

\*via email

OFFICE	NRR/DORL/LPL4-1/PM	NRR/DORL/LPL4-1/LA	NRR/DORL/LPL4-1/BC	NRR/DORL/LPL4-1/PM
NAME	FLyon	JBurkhardt*	MMarkley	FLyon
DATE	1/13/14	1/10/14	1/13/14	1/13/14

**OFFICIAL RECORD COPY**