

January 14, 2014

Mr. Patrick R. Simpson,
Manager-Licensing
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: EXEMPTION REQUEST FOR TRANSNUCLEAR, INC. TN-68 CASKS LOADED WITH FUEL BUNDLES WITH INCORRECT COOLING TIMES AT THE PEACH BOTTOM INDEPENDENT SPENT FUEL STORAGE INSTALLATION – ACKNOWLEDGEMENT OF WITHDRAWAL (TAC NO. L24749)

Dear Mr. Simpson:

By letter dated May 23, 2013 (ML13144A219), Exelon Generation Company, LLC (EGC) submitted an exemption request for the four Peach Bottom Power Station (PBAPS) Unit 3 fuel assemblies that were loaded into four TN - 68 casks (i.e., one assembly per cask) with cooling times less than the minimum cooling time specified in the Certificate of Compliance (CoC) No. 1027, Amendment No. 0, Appendix A, Technical Specification (TS) 2.1.1, Table 2.1.1-1, "Minimum Acceptable Cooling Time as a Function of Max. Burnup and Min. Initial Enrichment".

By letter dated January 06, 2014 (ML14006A355), EGC requested to withdraw the application from NRC review. The NRC acknowledges your request to withdraw the application. NRC staff activities on the review have ceased and the associated Technical Assignment Control number has been closed.

If you have any questions, please contact me at (301) 287-9202.

Sincerely,

/RA/

John-Chau Nguyen, Sr. Project Manager
Licensing Branch
Division of Spent Fuel Storage and Transportation
Office of Nuclear Material Safety
and Safeguards

Docket Nos.: 72-29, 50-277, 50-278, 72-1027
TAC No.: L24749

cc: See attached list

Mr. Patrick R. Simpson,
Manager-Licensing
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: EXEMPTION REQUEST FOR TRANSNUCLEAR, INC. TN-68 CASKS LOADED WITH FUEL BUNDLES WITH INCORRECT COOLING TIMES AT THE PEACH BOTTOM INDEPENDENT SPENT FUEL STORAGE INSTALLATION – ACKNOWLEDGEMENT OF WITHDRAWAL (TAC NO. L24749)

Dear Mr. Simpson:

By letter dated May 23, 2013 (ML13144A219), Exelon Generation Company, LLC (EGC) submitted an exemption request for the four Peach Bottom Power Station (PBAPS) Unit 3 fuel assemblies that were loaded into four TN - 68 casks (i.e., one assembly per cask) with cooling times less than the minimum cooling time specified in the Certificate of Compliance (CoC) No. 1027, Amendment No. 0, Appendix A, Technical Specification (TS) 2.1.1, Table 2.1.1-1, "Minimum Acceptable Cooling Time as a Function of Max. Burnup and Min. Initial Enrichment".

By letter dated January 06, 2014 (ML14006A355), EGC requested to withdraw the application from NRC review. The NRC acknowledges your request to withdraw the application. NRC staff activities on the review have ceased and the associated Technical Assignment Control number has been closed.

If you have any questions, please contact me at (301) 287-9202.

Sincerely,

/RA/

John-Chau Nguyen, Sr. Project Manager
Licensing Branch
Division of Spent Fuel Storage and Transportation
Office of Nuclear Material Safety
and Safeguards

Docket Nos.: 72-29, 50-277, 50-278, 72-1027

TAC No.: L24749

cc: See attached list

Close out TAC# L24749

Distribution:

SFST r/f MLombard SCoffin DMarcano AGendelman JDavis (SFST)
BDean/RI MFerdas/RI JNicholson/RI REnnis/NRR SHansell/RI RRolph/RI
RMcCullum/NEI JBobrowsky DForsyth CAraguas MRahimi

ADAMS: ML14015A010

File location:G:\SFST\Nguyen\Peach Bottom TN68\withdrawal of exemption request-acknowledgement letter.docx

DIVISION	SFST	SFST	SFST
NAME:	JCNguyen	WWheatley (via email)	BJDavis for MSampson
DATE:	01/13/2014	01/13/2014	1/14/14

OFFICIAL RECORD COPY

LETTER FOR PEACH BOTTOM EXEMPTION

Mr. Donis Shaw
Transnuclear, Inc.
7135 Minstrel Way
Columbia, MD 21045

Mr. John Schrage
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555