

# PUBLIC SUBMISSION

<b>As of:</b> January 29, 2014
<b>Received:</b> January 15, 2014
<b>Status:</b> Pending_Post
<b>Tracking No.</b> 1jy-89vu-nw1r
<b>Comments Due:</b> February 18, 2014
<b>Submission Type:</b> Web

**Docket:** NRC-2009-0096  
Material Control and Accounting of Special Nuclear Material

**Comment On:** NRC-2009-0096-0017  
Amendments to Material Control and Accounting Regulations

**Document:** NRC-2009-0096-DRAFT-0025  
Comment on FR Doc # 2013-25617

---

## Submitter Information

**Name:** Gary Kodman

---

## General Comment

Appendix A, Note #2

The regulatory easing that reduces accounting/protection by one category level for certain fuels if the radiation level exceeds 100 rads/hr is not justified nor supported by technical data. This in essence, allows the fuel to be considered as "self-protecting" and would not require greater levels of physical protection and accountability. This level should be sent at the LD50, which would be technically justified. I believe the LD50 is between 500 and 650 rads/hr at 1 meter.