

JAN 22 2014

Serial: BSEP 14-0010

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Subject: Brunswick Steam Electric Plant, Unit Nos. 1 and 2
Renewed Facility Operating License Nos. DPR-71 and DPR-62
Docket Nos. 50-325 and 50-324
Supplement to Request for License Amendments - Diesel Generator (DG)
Completion Time (CT) Extension for Technical Specification (TS) 3.8.1, "AC
Sources - Operating" (TAC No. ME8893 and ME8894)

References:

1. Letter from M. Annacone to the U.S. Nuclear Regulatory Commission, *Request for License Amendments - Diesel Generator (DG) Completion Time (CT) Extension for Technical Specification (TS) 3.8.1, "AC Sources - Operating,"* dated June 19, 2012. ADAMS Accession Number ML12173A112
2. Letter from A. Pope to the U. S. Nuclear Regulatory Commission, *Supplement to Request for License Amendments - Diesel Generator (DG) Completion Time (CT) Extension for Technical Specification (TS) 3.8.1, "AC Sources – Operating,"* dated May 14, 2013. ADAMS Accession Number ML13141A405

Ladies and Gentlemen:

On June 19, 2012 (i.e., Reference 1), Duke Energy Progress, Inc., requested a revision to the Technical Specifications (TS) for the Brunswick Steam Electric Plant (BSEP), Unit Nos. 1 and 2. The proposed revision extends the Completion Time (CT) of TS 3.8.1, Required Action D.4 for an inoperable diesel generator (DG) from 7 days to 14 days. A commensurate change was also proposed to extend the maximum Completion Time of TS 3.8.1, Required Actions C.3 and D.4.


In support of the proposed amendments, Duke Energy is installing a supplemental diesel generator (SUPP-DG). In a letter dated May 14, 2013 (i.e., Reference 2), Duke Energy requested that the implementation schedule for the proposed amendments be within 90 days of the supplemental diesel generator being available.

Based on discussions with the NRC, Duke Energy requests that implementation of the proposed amendments be prior to startup from the 2014 Unit 1 refueling outage (i.e., B120R1).

ADD
NRR

No regulatory commitments are contained in this submittal. Please refer any questions regarding this submittal to Mr. Lee Grzeck, Manager - Regulatory Affairs, at (910) 457-2487.

Sincerely,



Annette H. Pope
Manager – Organizational Effectiveness
Brunswick Steam Electric Plant

MAT/mat

cc:

U. S. Nuclear Regulatory Commission, Region II
ATTN: Mr. Victor M. McCree, Regional Administrator
245 Peachtree Center Ave, NE, Suite 1200
Atlanta, GA 30303-1257

U. S. Nuclear Regulatory Commission
ATTN: Ms. Farideh E. Saba (Mail Stop OWFN 8G9A) **(Electronic Copy Only)**
11555 Rockville Pike
Rockville, MD 20852-2738

U. S. Nuclear Regulatory Commission
ATTN: Ms. Michelle P. Catts, NRC Senior Resident Inspector
8470 River Road
Southport, NC 28461-8869

Chair - North Carolina Utilities Commission
P.O. Box 29510
Raleigh, NC 27626-0510

Mr. W. Lee Cox, III, Section Chief **(Electronic Copy Only)**
Radiation Protection Section
North Carolina Department of Health and Human Services
1645 Mail Service Center
Raleigh, NC 27699-1645
lee.cox@dhhs.nc.gov