

PMNorthAnna3COLPEmails Resource

From: Patel, Chandu
Sent: Monday, February 10, 2014 2:03 PM
To: 'na3raidommailbox@dom.com' (na3raidommailbox@dom.com)
Cc: PMNorthAnna3COLPEmails Resource; Carpentier, Marcia; Weisman, Robert; Clark, Theresa; Hsu, Kaihwa
Subject: RAI Letter 113, RAI 7414, Section 3.12 North Anna COLA
Attachments: RAI_7414.docx

By letter dated November 26, 2007, Dominion Virginia Power (Dominion) submitted a Combined License Application for North Anna, Unit 3, pursuant to Title 10 of the *Code of Regulations*, Part 52. The U.S. Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this COLA.

The NRC staff has identified that additional information is needed to continue portions of the review and a Request for Additional Information (RAI), is enclosed. To support the review schedule, Dominion is requested to respond within 30 days of the date of this request. If the RAI response involves changes to the application documentation, Dominion is requested to include the associated revised documentation with the response.

Sincerely,
Chandu Patel
Lead Project Manager for NA3 COLA

Hearing Identifier: NorthAnna3_Public_EX
Email Number: 1146

Mail Envelope Properties (8C658E9029C91D4D90C6960EF59FC0D60125F9CCD73C)

Subject: RAI Letter 113, RAI 7414, Section 3.12 North Anna COLA
Sent Date: 2/10/2014 2:03:04 PM
Received Date: 2/10/2014 2:03:12 PM
From: Patel, Chandu

Created By: Chandu.Patel@nrc.gov

Recipients:

"PMNorthAnna3COLPEmails Resource" <PMNorthAnna3COLPEmails.Resource@nrc.gov>
Tracking Status: None
"Carpentier, Marcia" <Marcia.Carpentier@nrc.gov>
Tracking Status: None
"Weisman, Robert" <Robert.Weisman@nrc.gov>
Tracking Status: None
"Clark, Theresa" <Theresa.Clark@nrc.gov>
Tracking Status: None
"Hsu, Kaihwa" <Kaihwa.Hsu@nrc.gov>
Tracking Status: None
"na3raidommailbox@dom.com' (na3raidommailbox@dom.com)" <na3raidommailbox@dom.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	823	2/10/2014 2:03:12 PM
RAI_7414.docx	29530	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information 113

Issue Date: 02/10/2014

Application Title: North Anna, Unit 3 - Docket Number 52-017

Operating Company: Dominion

Docket No. 52-017

Review Section: 03.12 - ASME Code Class 1, 2, and 3 Piping Systems and Piping Components and
Their Associated Supports

Application Section: 3.12

QUESTIONS

03.12-2

FSAR 3.12 states that information on seismic category I and II, and nonseismic piping analysis and their associated supports is presented in DCD Sections 3.7, 3.9, 3D, 3K, 5.2 and 5.4.

The staff noted that referencing DCD Sections indicates that the applicant's seismic analysis will consider the CSDRS only and does not have to address the site-specific seismic exceedances which are identified in NAPS FSAR Section 3.7. The staff is requesting the applicant to address this issue by either revising the reference or providing justification for neglecting the site specific seismic exceedances. Where appropriate, other sections that use seismic response spectra for input should be similarly updated.