



Global Nuclear Fuel

A Joint Venture of GE, Toshiba, & Hitachi

Global Nuclear Fuel

Scott P. Murray
Manager, Facility Licensing

3901 Castle Hayne Road
P.O. Box 780
Wilmington, NC 28402
USA

T (910) 819-5950
F (910) 362-5950
scott.murray@ge.com

SPM 14-009

February 25, 2014

Attn: Document Control Desk
Director, Office of Nuclear Material Safety and Safeguards
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Subject: Semi-Annual Effluent Monitoring Report


References: 1) NRC License SNM-1097, Docket 70-1113
2) NRC Regulation 10CFR70.59

Dear Sir or Madam:

With respect to activities authorized by NRC License SNM-1097, the Global Nuclear Fuel-Americas, L.L.C. (GNF-A) facility in Wilmington, North Carolina hereby submits the semi-annual effluent monitoring report required by 10CFR70.59 for the time period of July through December 2013.

If you have any questions regarding this matter, please contact me at (910) 819-5950.

Sincerely,



Scott Murray, Manager
Facility Licensing

Commitments: None

Attachment: 1) Semi-Annual Effluent Monitoring Report (July- December 2013)

cc: NRC Region II Administrator, Atlanta, GA
Manuel Crespo, USNRC, RII
Ty Naquin, USNRC, NMSS
Lee Cox, NCDHHS
Mark Poirier, ANI

SEMI-ANNUAL EFFLUENT REPORT

Global Nuclear Fuel - Americas, LLC
 Wilmington, North Carolina

July 2013 - December 2013

NRC License SNM 1097, Docket # 70-1113

Fiscal Weeks 27-52

I. GASEOUS EFFLUENT-PARTICULATE

NUCLIDES	QUANTITY (Ci)	CONCENTRATION (uCi/cc)	* APPENDIX B LIMIT (uCi/cc)	% of LIMIT	CEDE mrem	CDE (Lung) mrem
U234	6.42E-06	3.66E-15	5.00E-14	7.32%	1.83E-02	1.54E-01
U235	2.52E-07	1.44E-16	6.00E-14	0.24%	6.03E-04	5.02E-03
U236	7.21E-09	4.11E-18	6.00E-14	0.01%	1.73E-05	1.44E-04
U238	8.21E-07	4.68E-16	6.00E-14	0.78%	1.97E-03	1.64E-02
TOTAL	7.50E-06	---	---	---	0.0209	0.175

EXHAUST VOLUME = 1.75E+15 (cc)

II. LIQUID EFFLUENT

NUCLIDES	QUANTITY (Ci)	CONCENTRATION (uCi/cc)	* APPENDIX B LIMIT (uCi/cc)	% of LIMIT	CEDE (mrem)	CDE (Lung) (mrem)	CDE (Bone Surface) (mrem)
U234	1.02E-02	4.39E-08	3.E-07	14.62%	3.20E-06	2.02E-06	4.65E-05
U235	4.01E-04	1.72E-09	3.E-07	0.57%	1.79E-07	1.14E-07	2.60E-06
U236	1.15E-05	4.93E-11	3.E-07	0.02%	3.40E-09	2.17E-09	4.94E-08
U238	1.31E-03	5.61E-09	3.E-07	1.87%	3.70E-07	2.36E-07	5.37E-06
TOTAL U	1.19E-02	---	---	---	3.75E-06	2.37E-06	5.45E-05

TOTAL VOLUME OF LIQUID EFFLUENT = 2.33E+08 (litres)

III. ABNORMAL RELEASES

	Air	Water	Total
# Releases	0	0	0
Activity Released (Ci)	0	0	0

IV. SUMMARY

	** Max Release (uCi/cc)	CEDE, total (mrem)	CDE (Lung), total (mrem)
Value	4.39E-08	2.09E-02	1.75E-01
Limit	3.00E-07	25	25
% of Limit	14.62%	0.08%	0.70%

* Limit from 10 CFR 20 Appendix B, Table 2, Columns 1 & 2

** From nuclide with release that is the largest percentage of its release limit.

NOTES:

Air sampling is continuous. Water samples analyzed are representative, continuous composite samples of process effluent stream.

Reported effluent concentration values are representative of the effluent concentration at the point of release and do not consider effects of dilution from point of release to the plant site boundary.